PMSTPCOL PEmails

From: Muniz, Adrian
Sent: Wednesday, July 22, 2009 1:56 PM
To: jwcook@stpegs.com
Subject: Draft RAI 3136
Attachments: Draft RAI 3136.doc

James:

I have attached to this electronic communication a draft request for additional information (RAI) for Section 7.6 of the STP COLA. If you need a conference call to clarify the requested information, please contact me. If a conference call is not needed, please send me an email and I will continue the formal process of issuing the RAI to STPNOC.

Thanks,

Adrian Muñiz, USNRC
Chapter 7 PM

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1472

Mail Envelope Properties (Adrian.Muniz@nrc.gov20090722135600)

Subject: Draft RAI 3136
Sent Date: 7/22/2009 1:56:03 PM
Received Date: 7/22/2009 1:56:00 PM
From: Muniz, Adrian

Created By: Adrian.Muniz@nrc.gov

Recipients:
"jwcook@stpegs.com" <jwcook@stpegs.com>
Tracking Status: None

Post Office:

Files	**Size**	**Date & Time**
MESSAGE	430	7/22/2009 1:56:00 PM
Draft RAI 3136.doc	27642	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft Request for Additional Information No. 3136 Revision 02

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 07.06 - Interlock Systems Important to Safety
Application Section: 07.06

QUESTIONS for Instrumentation, Controls and Electrical Engineering 2 (ESBWR/ABWR Projects) (ICE2)

07.06-***

COLA FSAR Tier 1 Figure 2.2.5 shows oscillation power range monitor (OPRM) as part of average power range monitor (APRM). However Section 7.6.1.1.2.2 states that APRM is independent from OPRM. Clarify this inconsistency.