

## PMSTPCOL PEmails

---

**From:** Muniz, Adrian  
**Sent:** Wednesday, July 22, 2009 2:06 PM  
**To:** jwcook@stpegs.com  
**Subject:** Draft RAI 3155  
**Attachments:** Draft RAI 3155.doc

James:

I have attached to this electronic communication a draft request for additional information (RAI) for Section 7.7 of the STP COLA. If you need a conference call to clarify the requested information, please contact me. If a conference call is not needed, please send me an email and I will continue the formal process of issuing the RAI to STPNOC.

Thanks,

Adrian Muñiz, USNRC  
Chapter 7 PM

**Hearing Identifier:** SouthTexas34Public\_EX  
**Email Number:** 1476

**Mail Envelope Properties** (Adrian.Muniz@nrc.gov20090722140600)

**Subject:** Draft RAI 3155  
**Sent Date:** 7/22/2009 2:06:00 PM  
**Received Date:** 7/22/2009 2:06:00 PM  
**From:** Muniz, Adrian

**Created By:** Adrian.Muniz@nrc.gov

**Recipients:**  
"jwcook@stpegs.com" <jwcook@stpegs.com>  
Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	430	7/22/2009 2:06:00 PM
Draft RAI 3155.doc	27130	

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

Draft Request for Additional Information No. 3155 Revision 0

South Texas Project Units 3 and 4  
South Texas Project Nuclear Operating Co  
Docket No. 52-012 and 52-013  
SRP Section: 07.07 - Control Systems  
Application Section: Part 2 - FSAR Tier 2, Subsection 7.7.1.2(5)

QUESTIONS for Instrumentation, Controls and Electrical Engineering 2 (ESBWR/ABWR Projects)  
(ICE2)

07.07-\*\*\*

STD DEP 7.7-7, "RCIS Design Details," indicates changes to Item (5) in Subsection 7.7.1.2 of the ABWR DCD that describe Power Sources, but no changes to Item (5) are shown in the STP 3 & 4 FSAR Subsection 7.7.1.2(5) for Subsection 7.7.1.2(5) of the DCD. Clarify this discrepancy.