**Non-Proprietary Version** 

August 2009

© 2009 Mitsubishi Heavy Industries, Ltd.

All Rights Reserved

MUAP-09018NP (R0)

## **Revision History**

| Revision | Page | Description    |
|----------|------|----------------|
| 0        | All  | Original Issue |

#### © 2009

#### MITSUBISHI HEAVY INDUSTRIES, LTD.

All Rights Reserved

This document has been prepared by Mitsubishi Heavy Industries, Ltd. ("MHI") in connection with the U.S. Nuclear Regulatory Commission's ("NRC") licensing review of MHI's US-APWR nuclear power plant design. No right to disclose, use or copy any of the information in this document, other than by the NRC and its contractors in support of the licensing review of the US-APWR, is authorized without the express written permission of MHI.

This document contains technology information and intellectual property relating to the US-APWR, and it is delivered to the NRC on the express condition that it not be disclosed, copied or reproduced in whole or in part, or used for the benefit of anyone other than MHI without the express written permission of MHI, except as set forth in the previous paragraph.

This document is protected by the laws of Japan, U.S. copyright law, international treaties and conventions, and the applicable laws of any country where it is being used.

MITSUBISHI HEAVY INDUSTRIES, LTD. 16-5, Konan 2-chome, Minato-ku Tokyo 108-8215 Japan

MUAP-09018NP (R0)

#### **Abstract**

This report contains the methodology used by Mitsubishi Heavy Industries (MHI) to determine the typical fast neutron fluence in the reactor vessel, the uncertainty in the evaluation, and the results of fast neutron fluence for the US-APWR.

The methodology of neutron fluence evaluation for the US-APWR reactor vessel is based on the guidance provided in Regulatory Guide 1.190, "Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence".

## **Table of Contents**

| List of T | able  | es    |                                       | ii  |
|-----------|-------|-------|---------------------------------------|-----|
| List of F | igur  | es    |                                       | iii |
| List of A | Acror | nyms… |                                       | V   |
|           |       |       |                                       |     |
| 1.0 INT   | ROI   | DUCTI | ON                                    | . 1 |
| 2.0 N     | EUT   | RON 1 | TRANSPORT CALCULATION                 | . 2 |
| 2.        | .1    | NEUTI | RON TRANSPORT CALCULATION METHODS     | . 2 |
| 2.        | .2    | CROS  | S SECTION LIBRARY                     | . 3 |
| 2.        | .3    | GEOM  | IETRY MODELING                        | . 3 |
| 2.        | .4    | CORE  | NEUTRON SOURCE AND FISSION SPECTRA    | . 5 |
| 2.        | .5    | OTHE  | R CONDITIONS                          | . 6 |
| 2.        | .6    | UNCE  | RTAINTY AND BIAS                      | . 7 |
| 2.        | .7    | RESU  | LTS OF NEUTRON TRANSPORT CALCULATIONS | . 7 |
|           |       | 2.7.1 | HORIZONTAL CROSS SECTION              | . 7 |
|           |       | 2.7.2 | VERTICAL CROSS SECTION                | . 8 |
| 3.0 REF   | ERI   | ENCES | 5                                     | . 9 |
|           |       |       |                                       |     |
| APPEN     | DIX   | A ST  | UDY OF UNCERTAINTY AND BIASA          | -1  |

## **List of Tables**

| Table 1 | BUGLE96)  | 10          |
|---------|---|-------------|
| Table 2 | Selected general data and dimensions of US-APWR reactor               | 11          |
| Table 3 | Number Density of Each Structure Component                            | 12          |
| Table 4 | Fission Spectra of 47 Neutron Groups                                  | 15          |
| Table 5 | Core Neutron Source and Fission Spectra                               | 16          |
| Table 6 | Neutron Flux Inside RV  | 17          |
| Table 7 | Fast Neutron Fluence Inside RV and on Welded Lines                    | 17          |
|         |   |             |
| Table A | - 1 Analysis input condition for DORT calculations                    | <b>\-</b> 9 |
| Table A | - 2 Comparison to Measurement and Calculational BenchmarkA            | -10         |
| Table A | - 3 Input parameters evaluated in the analytical sensitivity studiesA | -11         |
| Table A | - 4 Evaluated analytic uncertainties(E>1MeV)A                         | -12         |

## **List of Figures**

| Figure 1 Horizontal cross section of US-APWR reactor   | 18   |
|--|------|
| Figure 2 Schematic sketch of the axial geometry  | 19   |
| Figure 3 Core Center Cross Section ((r, $\theta$ ) Geometry)   | 20   |
| Figure 4 Core Center Cross Section ((x, y) Geometry)   | 21   |
| Figure 5 Core Vertical Cross Section ((r, z) Geometry)   | 22   |
| Figure 6 Cycle-Averaged Relative Power Distribution for Fuel Assemblies at Core Horizontal Cross Section                             | 23   |
| Figure 7 Cycle-Averaged Relative Power Distribution for Fuel Assembly, in Core Vertical Direction                                    | 24   |
| Figure 8 Distribution of Neutron Flux in Azimuthal Direction at Inner Surface in RV ((r, $\theta$ ) Geometry)                        | 25   |
| Figure 9 Distribution of Neutron Flux in Azimuthal Direction at RV 1/4 Thickness((r, $\theta$ )Geometry)                             | 26   |
| Figure 10 Relative Axial Distribution of Fast Neutron Flux (E>1 MeV) at Inner Surface in RV (Normalized as Maximum Value Set at "1") | 27   |
| Figure A- 1 Core Center Cross Section ((r, $\theta$ ) Geometry) of H.B.Robinson-2  | A-13 |
| Figure A- 2 Core Vertical Cross Section ((r, z) Geometry) of H.B.Robinson-2  | A-14 |
| Figure A- 3 Cycle-Averaged Relative Power Distribution for Fuel Assemblies at Core Horizontal Cross Section of H.B.Robinson-2        | A-15 |
| Figure A- 4 Cycle-Averaged Relative Power Distribution for Fuel Assembly, in Core Vertical Direction of H.B.Robinson-2               | A-16 |

## List of Acronyms

The following list defines the acronyms used in this document.

DCD Design Control Document

EFPY Effective Full Power Years

ENDF Evaluated Nuclear Data File

EOL End-of-Life

LWR Light Water Reactor

MHI Mitsubishi Heavy Industries

ORNL Oak Ridge National Laboratory

RG Regulatory Guide
RV Reactor Vessel

SUS Steel Use Stainless

#### 1.0 INTRODUCTION

Regulatory Guide(RG) 1.190 "Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence" [1] provides the guidance for the application and qualification of a methodology for determining the neutron fluence experienced by materials in the beltline region of Light Water Reactor(LWR) reactor vessel(RV). The calculation methodology for RV neutron fluence of the US-APWR is according to RG1.190. The neutron fluence evaluation must include the evaluation of the maximum exposure at the inner surface in the RV, and also, the radial, axial, and azimuthal direction distribution in the RV. The evaluation of neutron fluence in the RV is carried out by the plant specific neutron transport calculation which is qualified using the benchmark experiment. In the evaluation of qualification, the measured date is used to assess the accuracy of transport calculation.

The purpose of this report is to describe the methodology used by Mitsubishi Heavy Industries (MHI) to determine the typical fast neutron fluence in the RV, the uncertainty in the evaluation, and the results of fast neutron fluence for US-APWR.

The typical neutron fluence in the RV is evaluated from the neutron transport calculation for LWR geometry, considering the uncertainty obtained from the measured value in benchmark problem.

The qualification of the neutron fluence evaluation for PWR geometry is carried out in the following two evaluations of uncertainty;

- 1) Comparison of calculations with surveillance capsule measurements from the H.B.Robinson power reactor benchmark experiment[2].
- 2) An analytical sensitivity study addressing the uncertainty resulting from the input parameters for neutron transport calculations used in the neutron fluence assessments.

In subsequent sections of this report, the methodology used by MHI to perform calculations of neutron fluence in RV for US-APWR, the uncertainties, and the results containing the uncertainty are described. The uncertainty and bias are shown in Appendix A.

#### 2.0 NEUTRON TRANSPORT CALCULATION

As noted in Section 1 of this report, the typical fast neutron fluence of the RV is evaluated as absolute neutron transport calculation for LWR, considering the uncertainty that is estimated using the measurements obtained from the RV materials in the benchmark problems.

In this section, the neutron transport evaluation methodologies are discussed; and then, the necessary data, the uncertainty, required in RG1.190, and neutron fluence considering the uncertainty are presented.

#### 2.1 NEUTRON TRANSPORT CALCULATION METHODS

The neutron fluence calculations are generally carried out using the two-dimensional discrete ordinates transport calculation method. The neutron transport calculations for US-APWR are accomplished using Discrete-Ordinates transport code DORT[3] and cross section library BUGLE-96[4] based on the Evaluated Nuclear Data File (ENDF/B-VI[5]). BUGLE-96 libraries provide a 67 group coupled neutron-gamma ray cross-section data set produced specifically for light water reactor application. In the DORT analysis, anisotropic scattering is treated with a P3 legendre expansion and the angular discretization is modeled with S8 angular quadrature.

Calculations are carried for  $(r, \theta), (r,z)$  and (x,y) geometry.

For analysis, the actual geometries and core neutron source distributions of US-APWR are modeled.

The core neutron source distributions is based on the cycle-averaged power distributions of the 24 months equilibrium core considering special distributions and numbers of neutrons generated per fission.

The fundamental calculation equation is as follows;

$$\Omega \cdot \nabla \phi(r, \Omega, E) + \Sigma t(r, E) \cdot \phi(r, \Omega, E)$$

$$= \iint \Sigma s(r : \Omega' \to \Omega, E' \to E) \phi(r, \Omega', E') d\Omega' dE' + Q(r, \Omega, E)$$

where

 $\phi(r,\Omega,E)$ 

:angular flux (number of neutrons at a position r passing per unit time through a plane perpendicular to  $\Omega$  per unit solid angle moving in the direction of a unit vector  $\Omega$ )

MUAP-09018NP (R0)

 $\Sigma t(r, E)$  : total macro cross sections

 $\Sigma s(r:\Omega'\to\Omega,E'\to E)$ :macro scattering cross sections

 $Q(r, \Omega, E)$  : number of neutrons generated at fuel portion

[

]

#### 2.2 CROSS SECTION LIBRARY

BUGLE96 is used as the cross section library. Developed by Oak Ridge National Laboratory (ORNL) in the USA on the basis of ENDF/B-VI, this library is an integrated cross section library consisting of neutron & gamma ray of 47 neutron groups and 20 gamma ray groups. Table 1 shows the energy group structure of these 47 neutron groups. [

]

#### 2.3 GEOMETRY MODELING

In US-APWR actual geometry, the model includes the core, reactor internals, RV and the primary shield. In developing an analytical model of the reactor geometry, the nominal design

MUAP-09018NP (R0)

| dimensions are normally used for geometry modeling. The coolant temperatures and coolant density in the reactor core and downcomer regions of the reactor are normally taken to be representative of full power operating conditions. [ |
|---|
|   |
| ] Selected general data and dimensions of US-APWR reactor are shown in Table 2. An octant of the horizontal cross-section of the reactor is shown in Figure 1, and axial geometry and dimensions are given in Figure 2.                 |
| The number density of each structure component is shown in Table 3.   |
| (1) Horizontal cross section  |
| [   |
|   |

| (2) Vertical cross section  |
|---|
| [   |
|   |
|   |
|   |
| ]   |
| 2.4 CORE NEUTRON SOURCE AND FISSION SPECTRA   |
| The cycle-averaged power distribution of the 24 months equilibrium core[6] is used for the assessment of the RV neutron exposure. [ |
|   |
|   |
|   |

The cycle-averaged relative power distribution is shown in Figure 6 and the relative axial power distribution is shown in Figure 7.

The power distributions are calculated by the NRC approved code ANC[7], as described in Subsection 4.3.3.1 of the US-APWR DCD. The ANC can properly model the effect of the Neutron Reflector.

[

]

]

The core neutron source and fission spectra are summarized in Table 5.

#### 2.5 OTHER CONDITIONS

Other conditions used for DORT calculation are shown as follows;

- Boundary condition

(x,y)geometry

Left, Bottom : reflection

Right, Top : vacuum

 $(r, \theta)$ geometry

Left, Top, Bottom: reflection

Right : vacuum

(r,z)geometry

Left : reflection

Right, Top, Bottom: vacuum

- point-wise inner iteration flux convergence criterion :0.001

#### 2.6 UNCERTAINTY AND BIAS

In connection with the evaluation methodology of neutron flux, the R.G.1.190 defines that the effect of uncertainty ( $\sigma$ ) and bias (B) shall be examined so as to correct the calculated value of neutron flux ( $\varphi_c$ ) in accordance with the uncertainty and bias as indicated below and to set neutron flux ( $\varphi$ ):

a)  $\sigma \leq 20\%$  :  $\varphi = (1+B) \varphi_c$ 

b) 20%< $\sigma$  <30% :  $\varphi$  =(1+B+( $\sigma$ -20)/100)  $\varphi_c$ 

c)  $\sigma \ge 30\%$  : evaluation methodology inappropriate, review required

The uncertainty and bias for the current evaluation methodology are as follows and the basis is described in Appendix A.

uncertainty ( $\sigma$ ) :20% or less

bias(B) : [ ]

Thus, the neutron flux and fluence inside the RV shall be evaluated considering the bias correction according to Item a) above to the neutron flux calculation results obtained by DORT calculation.

#### 2.7 RESULTS OF NEUTRON TRANSPORT CALCULATIONS

The following sections summarize the neutron flux and the maximum fast neutron fluence obtained on the basis of the methodology and calculation conditions in previous section 2.1 to 2.6, where uncertainty and bias are taken into account.

#### 2.7.1 HORIZONTAL CROSS SECTION

The neutron flux in the RV is calculated using  $(r, \theta)$  geometry.

MUAP-09018NP (R0)

The maximum value in the azimuthal distribution appears at a 45 degree direction closest to the fuel assemblies, while the minimum value in the azimuthal distribution appears at a 0 degree direction.

The azimuthal distribution of neutron flux at inner surface in the RV is indicated in Figure 8. Similarly, the azimuthal distributions of neutron flux at 1/4 thickness in the RV is shown in Figure 9.

The maximum neutron flux at inner surface and 1/4 thickness in the RV is shown in Table 6. The maximum fast neutron fluence (E>1 MeV) inside the RV at the time of 60EFPY is shown in Table 7.

The neutron flux on the core boundary (boundary between the core and neutron reflector) in the radial direction is obtained using the (x, y) geometry.

The maximum value at the core boundary appears at the 45 degree direction.

The maximum neutron flux on the core boundary (boundary between the core and neutron reflector) are shown in Table 6.

#### 2.7.2 VERTICAL CROSS SECTION

The axial distribution of neutron flux in the RV as well as neutron flux at the core center and on the core boundary (top and bottom side boundary) are calculated using (r, z) geometry.

The relative axial distribution (normalized as maximum value set at "1") of neutron flux at inner surface in the RV is shown in Figure.10.

The maximum neutron flux in the core center and the neutron flux at the core boundary on center axis (top and bottom side boundary) are shown in Table 6. The maximum fast neutron fluence (E>1 MeV) on welded lines on the RV inner surface at the time of 60EFPY are shown in Table 7.

#### 3.0 REFERENCES

| 1. | Regula | tory Guide | e 1.190, "C | alcula | tional and | Dosimetry N | lethods for De | eterminii | ng F | Pressure |
|----|--------|------------|-------------|--------|------------|-------------|----------------|-----------|------|----------|
|    | Vessel | Neutron    | Fluence",   | U.S.   | Nuclear    | Regulatory  | Commission     | Office    | of   | Nuclear  |
|    | Regula | torv Rese  | arch, Marc  | h 200  | 1.         |             |                |           |      |          |

- 2. I.Remec and F.B.K.Kam, "H. B. Robinson-2 Pressure Vessel Benchmark", NUREG/CR6453 (ORNL/TM-13204), February 1998.
- Oak Ridge National Laboratory, "DOORS 3.2: One-, Two- and Three Dimensional Discrete Ordinates Neutron/Photon Transport Code System", RSICC Computer Code Collection CCC-650.
- 4. Oak Ridge National Laboratory, "BUGLE-96: Coupled 47 Neutron, 20 Gamma-Ray Group Cross Section Library Derived from ENDF/B-VI for LWR Shielding and Pressure Vessel Dosimetry Applications", RSICC Data Library Collection DLC=185.
- 5. P. F. Rose, ENDF/B-VI Summary Documentation, BNL-NCS-1741 (ENDF-201), 4th Edition
- 6. "US-APWR Fuel System Design Evaluation," MUAP-07016-P, Appendix-A, February 2008
- 7. "Qualification of Nuclear Design Methodology using PARAGON/ANC," MUAP-07019-P, December 2007
- 8. [
- 9. H.Soodak, Reactor Handbook Second Edition, Vol. III Part A, "Physics", 1962

Table 1 Energy Group Structure of 47 Neutron Groups (Energy Group Structure of BUGLE96)

|              | Neutron      |              |
|--------------|--------------|--------------|
| Group Number | Upper Energy | Lower Energy |
| Group Number | (MeV)        | (MeV)        |
| 1            | 1.7332E+01   | 1.4191E+01   |
| 2            | 1.4191E+01   | 1.2214E+01   |
| 3            | 1.2214E+01   | 1.0000E+01   |
| 4            | 1.0000E+01   | 8.6071E+00   |
| 5            | 8.6071E+00   | 7.4082E+00   |
| 6            | 7.4082E+00   | 6.0653E+00   |
| 7            | 6.0653E+00   | 4.9659E+00   |
| 8            | 4.9659E+00   | 3.6788E+00   |
| 9            | 3.6788E+00   | 3.0119E+00   |
| 10           | 3.0119E+00   | 2.7253E+00   |
| 11           | 2.7253E+00   | 2.4660E+00   |
| 12           | 2.4660E+00   | 2.3653E+00   |
| 13           | 2.3653E+00   | 2.3457E+00   |
| 14           | 2.3457E+00   | 2.2313E+00   |
| 15           | 2.2313E+00   | 1.9205E+00   |
| 16           | 1.9205E+00   | 1.6530E+00   |
| 17           | 1.6530E+00   | 1.3534E+00   |
| 18           | 1.3534E+00   | 1.0026E+00   |
| 19           | 1.0026E+00   | 8.2085E-01   |
| 20           | 8.2085E-01   | 7.4274E-01   |
| 21           | 7.4274E-01   | 6.0810E-01   |
| 22           | 6.0810E-01   | 4.9787E-01   |
| 23           | 4.9787E-01   | 3.6883E-01   |
| 24           | 3.6883E-01   | 2.9721E-01   |
| 25           | 2.9721E-01   | 1.8316E-01   |
| 26           | 1.8316E-01   | 1.1109E-01   |
| 27           | 1.1109E-01   | 6.7379E-02   |
| 28           | 6.7379E-02   | 4.0868E-02   |
| 29           | 4.0868E-02   | 3.1828E-02   |
| 30           | 3.1828E-02   | 2.6058E-02   |
| 31           | 2.6058E-02   | 2.4176E-02   |
| 32           | 2.4176E-02   | 2.1875E-02   |
| 33           | 2.1875E-02   | 1.5034E-02   |
| 34           | 1.5034E-02   | 7.1017E-03   |
| 35           | 7.1017E-03   | 3.3546E-03   |
| 36           | 3.3546E-03   | 1.5846E-03   |
| 37           | 1.5846E-03   | 4.5400E-04   |
| 38           | 4.5400E-04   | 2.1445E-04   |
| 39           | 2.1445E-04   | 1.0130E-04   |
| 40           | 1.0130E-04   | 3.7266E-05   |
| 41           | 3.7266E-05   | 1.0677E-05   |
| 42           | 1.0677E-05   | 5.0435E-06   |
| 43           | 5.0435E-06   | 1.8554E-06   |
| 44           | 1.8554E-06   | 8.7643E-07   |
| 45           | 8.7643E-07   | 4.1399E-07   |
| 46           | 4.1399E-07   | 1.0000E-07   |
| 47           | 1.0000E-07   | 1.0000E-11   |

Table 2 Selected general data and dimensions of US-APWR reactor


| 0.5 cm  |  |
|---------|--|
|         |  |
|         |  |
| 26.5 cm |  |
| 27 cm   |  |
|         |  |
|         |  |
|         |  |
|         |  |

MUAP-09018NP (R0)

| Table 3 | Number Density of Each Structure Con | nponent |
|---------|--------------------------------------|---------|
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |
|         |                                      |         |

MUAP-09018NP (R0)

| Table 3 Number D | Density of Each Struc | cture Component (Contin | ued) |
|------------------|-----------------------|-------------------------|------|
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |
|                  |                       |                         |      |



| Table 4 Fission Spectra of 47 Neutron Groups |
|--|
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |
|  |

#### **Table 5 Core Neutron Source and Fission Spectra**

| Term                                       | Contents                                   |  |  |  |
|--|--|--|--|--|
| Core power                                 | 4451MWt                                    |  |  |  |
| Core pattern                               | 24 months equilibrium core load pattern[6] |  |  |  |
| Power distribution                         | See Figure 6 and 7                         |  |  |  |
| Axial peaking factor                       |  |  |  |  |
| (used (r, $\theta$ ), (x,y) geometry)      |  |  |  |  |
| Fission assignment rate                    |  |  |  |  |
| Number of neutrons produced per fission[9] |  |  |  |  |
| Energy released per fission                |  |  |  |  |
| Fission spectra of neutron                 | See Table 4                                |  |  |  |

Table 6 Neutron Flux Inside RV

(Unit: n/(cm2•s))

|  | E > 1MeV | 1MeV > E ><br>3.35keV | 3.35keV > E ><br>0.414eV | E < 0.414eV |  |
|--|----------|-----------------------|--------------------------|-------------|--|
| RV inner surface (maximum value: (r, θ)Geometry)           | 5.2E+9   | 1.1E+10               | 8.0E+9                   | 1.1E+10     |  |
| RV 1/4 thickness (maximum value) : $(r, \theta)$ Geometry) | 2.5E+9   | 1.0E+10               | 3.3E+9                   | 1.9E+8      |  |
| Core center (maximum value: r,z Geometry))                 | 1.0E+14  | 1.7E+14               | 1.2E+14                  | 3.8E+13     |  |
| Core outer boundary<br>(maximum value:<br>x,y Geometry)    | 4.6E+13  | 8.0E+13               | 5.7E+13                  | 1.7E+13     |  |
| Core top boundary<br>(on center axis:<br>r,z Geometry)     | 2.5E+13  | 3.9E+13               | 3.1E+13                  | 2.4E+13     |  |
| Core bottom boundary<br>(on center axis:<br>r,z Geometry)  | 2.7E+13  | 4.2E+13               | 3.3E+13                  | 2.9E+13     |  |

Table 7 Fast Neutron Fluence Inside RV and on Welded Lines

(Unit: n/cm2)

|  | Fast Neutron fluence<br>(E > 1MeV, 60EFPY) |  |
|--|--|--|
| RV inner surface (maximum value)                                   | 9.8E+18                                    |  |
| RV 1/4 thickness (maximum value)                                   | 4.7E+18                                    |  |
| Welded line (inner face) on bottom cylinder top (maximum value)    | 1.9E+18                                    |  |
| Welded line (inner face) on bottom cylinder bottom (maximum value) | 8.5E+18                                    |  |
| Welded line (inner face) on bottom end cover top (maximum value)   | < 1.0E+17 <sup>1)</sup>                    |  |

<sup>1)</sup> As the bottom end cover top is located more than 150 cm below the bottom cylinder bottom, it is evident from Fig.8 that neutron fluence is well below 1.0 E+17 (n/c m²).




Figure 2 Schematic sketch of the axial geometry




Figure 3 Core Center Cross Section ((r,  $\theta$ ) Geometry)





Figure 4 Core Center Cross Section ((x, y) Geometry)



|   | 1    | 2    | 3    | 4    | 5    | 6    | 7    | 8    | 9    |
|---|------|------|------|------|------|------|------|------|------|
| 1 | 0.70 | 0.85 | 1.08 | 1.02 | 1.22 | 1.08 | 1.10 | 1.20 | 0.58 |
| 2 | 0.85 | 0.91 | 0.95 | 1.28 | 1.07 | 1.27 | 1.27 | 1.19 | 0.59 |
| 3 | 1.08 | 0.95 | 1.29 | 1.27 | 1.05 | 1.33 | 1.08 | 1.08 | 0.55 |
| 4 | 1.02 | 1.28 | 1.27 | 1.05 | 1.28 | 1.26 | 0.99 | 1.10 | 0.52 |
| 5 | 1.22 | 1.07 | 1.05 | 1.28 | 1.30 | 0.99 | 1.20 | 1.06 | 0.41 |
| 6 | 1.08 | 1.27 | 1.33 | 1.26 | 0.99 | 0.90 | 1.02 | 0.60 |      |
| 7 | 1.10 | 1.28 | 1.08 | 0.99 | 1.20 | 1.02 | 0.92 | 0.39 |      |
| 8 | 1.20 | 1.19 | 1.08 | 1.10 | 1.06 | 0.60 | 0.39 |      |      |
| 9 | 0.58 | 0.59 | 0.55 | 0.52 | 0.41 |      |      |      |      |

Figure 6 Cycle-Averaged Relative Power Distribution for Fuel Assemblies at Core Horizontal Cross Section




Figure 7 Cycle-Averaged Relative Power Distribution for Fuel Assembly, in Core Vertical Direction




Figure 8 Distribution of Neutron Flux in Azimuthal Direction at Inner Surface in RV ((r,  $\theta$ ) Geometry)




Figure 9 Distribution of Neutron Flux in Azimuthal Direction at RV 1/4 Thickness((r,  $\theta$ )Geometry)




Figure 10 Relative Axial Distribution of Fast Neutron Flux (E>1 MeV) at Inner Surface in RV (Normalized as Maximum Value Set at "1")

#### APPENDIX A STUDY OF UNCERTAINTY AND BIAS

The benchmark analysis and the uncertainty analysis were done to qualify the MHI's methodology for Reactor Vessel (RV) Neutron Fluence calculation.

A.1 Comparisons measurements with calculational Benchmarks

#### A.1.1 Benchmark analysis

The benchmark analysis was done for the qualification of MHI methodology for RV neutron fluence calculations. The benchmark problem, analysed here, is H.B.Robinson-2 Pressure Vessel Benchmark (NUREG/CR-6453)[1].

The transport calculations were performed using the DORT computer code [2]. The calculation were done for  $(r, \theta)$  geometry and (r,z) geometry. These geometries were shown in Figure A-1 and Figure A-2, respectively. In the  $(r, \theta)$  geometry, the surveillance capsule was set in the geometry.

The BUGLE-96[3] cross section library based on ENDF/B-VI[4] is used in the calculations. [

1

The source distributions were made based on the power distribution averaged over the cycle-9 of H.B.Robinson. The cycle-averaged relative power distribution of each fuel assembly is shown in Figure A-3. [

]

The axial distribution was derived based on the axial power distribution averaged over the cycle-9 of H.B.Robinson. The relative axial power distribution is shown in Figure A-4.

]

The major calculational conditions are summarized in Table A-1.

## A.1.2 Results and discussion

The reaction rates calculated for the cycle average power distribution and core thermal power output of 2300MW, were given in Table A-2. In the table, the ratio (C/M) calculated to measured specific activities are also given.

[

## A.2 UNCERTAINTY ANALYSIS

An analytical sensitivity studies addressing the uncertainty resulting from the input parameters for neutron transport calculations used in the neutron fluence assessments were carried out for the parameters shown in Table A-3. The sensitivity studies are done for H.B.Robinson-2.

A.2.1.3 Vessel inner radius

[

A.2.1.4 Coolant temperature

]

```
A.2.2 Source Term
[
                                                                                        ]
A.2.2.1 Peripheral assembly source strength
[
                        ]
A.2.2.2 Axial power distribution
[
                                                                       ]
A.2.2.3 Peripheral assembly burn-up (U/Pu ratio)
[
                                                                                 ]
A.2.2.4 Spatial distribution of the source
[
```

```
]
A.2.3 Others
                                                                                      ]
A.2.3.1 Convergence criteria
[
                                                                                    ]
A.2.3.2 Transport cross section
[
                                ]
A.2.3.3 Fission spectra
[
                                                            ]
A.2.3.4 Angular discretization
[
                                       ]
```

A.2.4 Results of sensitivity studies

[

]

The uncertainty in MHI's methodology is less than 20%.

## APPENDIX A REFERENCES

| TENDIKIT TELETIOLO  |
|---|
| 1. I.Remec and F.B.K.Kam, "H. B. Robinson-2 Pressure Vessel Benchmark", NUREG/CR6453 (ORNL/TM-13204), February 1998.  |
| <ol> <li>Oak Ridge National Laboratory,"DOORS 3.2: One-, Two- and Three Dimensional<br/>Discrete Ordinates Neutron/Photon Transport Code System", RSICC Computer Code<br/>Collection CCC-650.</li> </ol>  |
| <ol> <li>Oak Ridge National Laboratory, "BUGLE-96: Coupled 47 Neutron, 20 Gamma-Ray Group<br/>Cross Section Library Derived from ENDF/B-VI for LWR Shielding and Pressure Vessel<br/>Dosimetry Applications", RSICC Data Library Collection DLC=185.</li> </ol> |
| 4. P. F. Rose, ENDF/B-VI Summary Documentation, BNL-NCS-1741 (ENDF-201), 4th Edition  |
| <ol> <li>[RSIC Computer Code Collection CCC-276, "DOT 3.5, Two Dimensional Discrete<br/>Ordinates Radiation Transport Code", 1977.]</li> </ol>  |
| 6. [  |
| 7. [  |
| 8. [  |

9. [

Table A-1 Analysis input condition for DORT calculations

| term   | contents  | information                             |  |  |
|--|---|---|--|--|
| Benchmark problem                              | NUREG/CR-6453   | H.B.Robinson-2                          |  |  |
| Computer code                                  | DORT  | DOORS-3.2[2]                            |  |  |
| Cross section library Activation cross section | BUGLE-96  | [ ]                                     |  |  |
| Material composition                           | Based on NUREG/CR-6453  | NUREG/CR-6453[1]                        |  |  |
| Pℓ, Sn   | [ ]   | -                                       |  |  |
| Geometry                                       | $(r, \theta)$ : Figure A-1 $(r, z)$ : Figure A-2  | NUREG/CR-6453[1]                        |  |  |
| Source distribution                            | Radial distribution : Figure A-3 Axial distribution : Figure A-4  | NUREG/CR-6453 Averaged over the cycle-9 |  |  |
| Fission rate                                   |   |   |  |  |
| Fission spectra                                | Table4 of section 2.0   |   |  |  |
| Neutron production rate                        |   |   |  |  |
| per fission                                    |   |   |  |  |
| Core thermal power                             | 2300MWt   | NUREG/CR-6453[1]                        |  |  |
| Boundary conditions                            | <ul><li>(r, θ) Left, Top, Bottom : reflection</li><li>Right : vacuum</li><li>(r, z) Left : reflection</li><li>Right, Top, Bottom : vacuum</li></ul> |   |  |  |
| Convergence criteria                           | ≤0.001 (≤0.1%)  |   |  |  |




Table A-3 Input parameters evaluated in the analytical sensitivity studies

| INPUT PARAMETERS       |                                     |                         |  |  |  |
|------------------------|-------------------------------------|-------------------------|--|--|--|
| <modeling></modeling>  | <source term=""/>                   | <others></others>       |  |  |  |
| $(r, \theta)$ modeling | Peripheral assembly source strength | Convergence criteria    |  |  |  |
| Internal dimension     | Axial power distribution            | Transport cross section |  |  |  |
| Vessel inner radius    | Peripheral assembly burnup          | Fission spectra         |  |  |  |
| Coolant temperature    | Spatial distribution of the source  | Angular discretization  |  |  |  |

Table A- 4 Evaluated analytic uncertainties (E>1MeV)

|             |                                     | σ (%)                              | <i>σ</i> (%)           |
|-------------|-------------------------------------|------------------------------------|------------------------|
|             |                                     | in-vessel<br>dosimeter<br>location | Inner Surface<br>of RV |
|             | (r, 	heta)modeling                  |                                    |                        |
| modeling    | Internal dimension                  |                                    |                        |
|             | Vessel inner radius                 |                                    |                        |
|             | Coolant temperature                 |                                    |                        |
|             | Peripheral assembly source strength |                                    |                        |
| Source term | Axial power distribution            |                                    |                        |
|             | Peripheral assembly burnup          |                                    |                        |
|             | Spatial distribution of the source  |                                    |                        |
|             | Convergence criteria                |                                    |                        |
| others      | Transport cross section             |                                    |                        |
|             | Fission spectra                     |                                    |                        |
|             | Angular discretization              |                                    |                        |
| TOTAL       | $=\sqrt{\sum \sigma^2}$             |                                    |                        |




Figure A- 1 Core Center Cross Section ((r,  $\theta$ ) Geometry) of H.B.Robinson-2




Figure A- 2 Core Vertical Cross Section ((r, z) Geometry) of H.B.Robinson-2

|    | Н    | G    | F    | Е    | D    | С    | В    | A    |
|----|------|------|------|------|------|------|------|------|
| 8  | 1.01 | 1.17 | 1.02 | 1.26 | 1.01 | 0.95 | 1.10 | 0.44 |
| 9  | 1.17 | 1.03 | 1.14 | 0.99 | 1.18 | 1.03 | 1.02 | 0.33 |
| 10 | 1.02 | 1.14 | 1.02 | 1.11 | 1.05 | 1.21 | 0.94 |      |
| 11 | 1.27 | 1.01 | 1.11 | 1.01 | 1.16 | 1.12 | 0.72 |      |
| 12 | 1.05 | 1.22 | 1.06 | 1.15 | 1.19 | 0.82 |      | •    |
| 13 | 0.98 | 1.06 | 1.23 | 1.12 | 0.81 |      | •    |      |
| 14 | 1.13 | 1.05 | 0.96 | 0.73 |      | •    |      |      |
| 15 | 0.44 | 0.33 |      |      | •    |      |      |      |

Figure A- 3 Cycle-Averaged Relative Power Distribution for Fuel Assemblies at Core Horizontal Cross Section of H.B.Robinson-2




Figure A- 4 Cycle-Averaged Relative Power Distribution for Fuel Assembly, in Core Vertical Direction of H.B.Robinson-2