



**INDIANA
MICHIGAN
POWER**

**Indiana Michigan
Power Company**
Nuclear Generation Group
One Cook Place
Bridgman, MI 49106
aep.com

August 5, 2009

AEP-NRC-2009-59
10 CFR 50.90

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

SUBJECT: Donald C. Cook Nuclear Plant Unit 2
Docket No. 50-316
Withdrawal of License Amendment Request for One-Time Extension of Technical
Specification Completion Times

Reference: Letter from L. J. Weber, Indiana Michigan Power Company, to U. S. Nuclear
Regulatory Commission Document Control Desk, "License Amendment Request for
One-Time Extension of Technical Specification Completion Times for Inoperable
Train of Reactor Trip System and Engineered Safety Features Actuation System,"
dated July 17, 2009.

Dear Sir or Madam:

The referenced letter transmitted a request by Indiana Michigan Power Company (I&M) to amend the Appendix A Technical Specifications (TS) to Facility Operating License DPR-74 for Donald C. Cook Nuclear Plant Unit 2. The requested amendment would have modified the TS to allow a one-time extension of the Completion Times to restore an inoperable train of the Reactor Trip System and an inoperable train of the Engineered Safety Features Actuation System to an operable status. The proposed extension was requested as a contingency for replacement of the Multiplexer Test Switch in Train A of the Unit 2 Solid State Protection System with the unit in Mode 1. Subsequent to submittal of the proposed amendment, the Multiplexer Test Switch was replaced during an unscheduled Unit 2 outage. I&M is therefore withdrawing the proposed amendment as it is no longer needed.

There are no new or modified regulatory commitments in this letter. Should you have any questions, please contact Mr. James M. Petro, Jr., Regulatory Affairs Manager, at (269) 466-2489.

Sincerely,

Lawrence J. Weber
Site Vice President

JRW/jen

AD001
NAR

c: T. A. Beltz, NRC Washington DC
J. T. King, MPSC
S. M. Krawec, Ft. Wayne AEP
MDEQ – WHMD/RPS
NRC Resident Inspector
M. A. Satorius, NRC Region III