



Note 1: Sampling Activity Monitoring System (KLK) components are located in the Nuclear Auxiliary Building. Components shown are not actually located directly outside the plant stack.

Note 2: Access Building is located between Safeguards Building 3 & 4. This drawing shows the Access Building adjacent to the Nuclear Auxiliary Building for component routing purposes.

Note 3: This drawing is for general system layout purposes only (with exception of notes 1 & 2). This drawing is intended to show major components of HVAC systems only.

Note 4: This drawing only incorporates the major buildings of the NI. Simpler auxiliary NI buildings, such as the Diesel Generator Building, the Essential Service Water Pump Building, and the Circulating Water Pump Building are not shown

R Radiation Detector

**FOR INFORMATION ONLY**

FIGURE B-1 HVAC Systems of the US EPR Nuclear Island