



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
612 EAST LAMAR BLVD, SUITE 400
ARLINGTON, TEXAS 76011-4125

August 20, 2009

Randall K. Edington, Executive
Vice President, Nuclear/CNO
Mail Station 7602
Arizona Public Service Company
P.O. Box 52034
Phoenix, AZ 85072-2034

SUBJECT: PALO VERDE NUCLEAR GENERATING STATION, Unit 2 – NOTIFICATION OF INSPECTION (NRC INSPECTION REPORT 05000529/2009005) AND REQUEST FOR INFORMATION

Dear Mr. Edington:

From October 13 – 21, 2009, reactor inspectors from the U. S. Nuclear Regulatory Commission's (NRC) Region IV office will perform the baseline inservice inspection at Palo Verde Nuclear Generating Station, Unit 2, using NRC Inspection Procedure 71111.08, "Inservice Inspection Activities," and TI 2515/172, "Reactor Coolant System Dissimilar Metal Butt Welds." Experience has shown that this inspection is a resource intensive inspection both for the NRC inspectors and your staff. In order to minimize the impact to your onsite resources and to ensure a productive inspection, we have enclosed a request for documents needed for this inspection. These documents have been divided into two groups. The first group (Section A of the enclosure) identified information to be provided prior to the inspection to ensure that the inspectors are adequately prepared. The second group (Section B of the enclosure) identifies the information the inspectors will need upon arrival at the site. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the onsite portions of the inspection.

We have discussed the schedule for these inspection activities with your staff and understand that our regulatory contact for this inspection will be Mr. Del Elkinton of your licensing organization. Our inspection dates are subject to change based on your updated schedule of outage activities. If there are any questions about this inspection or the material requested, please contact the lead inspector Breck Henderson at (817) 276-6569 (breck.henderson@nrc.gov) or Matthew Young at (817) 276-6545 (matt.young@nrc.gov).

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Thomas Farnholtz, Chief
Engineering Branch 1
Division of Reactor Safety

Docket: 50-529
License: NPF-51

Enclosure:
Inservice Inspection Document Request
Mr. Steve Olea
Arizona Corporation Commission
1200 W. Washington Street
Phoenix, AZ 85007

Mr. Douglas Kent Porter
Senior Counsel
Southern California Edison Company
Law Department, Generation Resources
P.O. Box 800
Rosemead, CA 91770

Chairman
Maricopa County Board of Supervisors
301 W. Jefferson, 10th Floor
Phoenix, AZ 85003

Mr. Aubrey V. Godwin, Director
Arizona Radiation Regulatory Agency
4814 South 40 Street
Phoenix, AZ 85040

Mr. Scott Bauer, Director
Regulatory Affairs
Palo Verde Nuclear Generating Station
Mail Station 7636
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. Dwight C. Mims
Vice President
Regulatory Affairs and Plant Improvement
Palo Verde Nuclear Generating Station
Mail Station 7605
P.O. Box 52034
Phoenix, AZ 85072-2034

Mr. Jeffrey T. Weikert
Assistant General Counsel
El Paso Electric Company
Mail Location 167
123 W. Mills
El Paso, TX 79901

Mr. Eric Tharp
Los Angeles Department of Water & Power
Southern California Public Power Authority
P.O. Box 51111, Room 1255-C
Los Angeles, CA 90051-0100

Mr. James Ray
Public Service Company of New Mexico
2401 Aztec NE, MS Z110
Albuquerque, NM 87107-4224

Mr. Geoffrey M. Cook
Southern California Edison Company
5000 Pacific Coast Hwy. Bldg. D21
San Clemente, CA 92672

Mr. Robert Henry
Salt River Project
6504 East Thomas Road
Scottsdale, AZ 85251

Mr. Brian Almon
Public Utility Commission
William B. Travis Building
P.O. Box 13326
Austin, TX 78701-3326

Environmental Program Manager
City of Phoenix
Office of Environmental Programs
200 West Washington Street
Phoenix, AZ 85003

Mr. John C. Taylor
Director, Nuclear Generation
El Paso Electric Company
340 East Palm Lane, Suite 310
Phoenix, AZ 85004

Chief, Technological Hazards
Branch
FEMA Region IX
1111 Broadway, Suite 1200
Oakland, CA 94607-4052

Electronic distribution by RIV:
 Regional Administrator (Elmo.Collins@nrc.gov)
 Deputy Regional Administrator (Chuck.Casto@nrc.gov)
 DRP Director (Dwight.Chamberlain@nrc.gov)
 DRP Deputy Director (Anton.Vegel@nrc.gov)
 DRS Director (Roy.Caniano@nrc.gov)
 DRS Deputy Director (Troy.Pruett@nrc.gov)
 Senior Resident Inspector (Ryan.Treadway@nrc.gov)
 Resident Inspector (Michelle.Catts@nrc.gov)
 Resident Inspector (Joseph.Bashore@nrc.gov)
 Branch Chief, DRP/D (Michael.Hay@nrc.gov)
 PV Site Secretary (vacant)
 Senior Project Engineer, DRP/D (Don.Allen@nrc.gov)
 Public Affairs Officer (Victor.Dricks@nrc.gov)
 Team Leader, DRP/TSS (Chuck.Paulk@nrc.gov)
 RITS Coordinator (Marisa.Herrera@nrc.gov)
 Regional Counsel (Karla.Fuller@nrc.gov)
 Congressional Affairs Officer (Jenny.Weil@nrc.gov)
 OEmail Resource
 DRS STA (Dale.Powers@nrc.gov)
 OEDO RIV Coordinator (Leigh.Trocine@nrc.gov)
 ROReports

SUNSI Review Completed: _____ ADAMS: Yes No Initials: _____
 Publicly Available Non-Publicly Available Sensitive Non-Sensitive

ML

RI:EB1	RI:EB1			C:EB1
B. Henderson	M. Young			T. Farnholtz
/RA/	/RA/			/RA/
8/20/09	8/20/09			8/20/09

OFFICIAL RECORD COPY T=Telephone E=E-mail F=Fax

INSERVICE INSPECTION DOCUMENT REQUEST

Inspection Dates: October 13-21, 2009

Inspection Procedures: IP 71111.08 "Inservice Inspection (ISI) Activities"
TI 2515/172 "Reactor Coolant System Dissimilar Metal Butt Welds"

Inspectors: Breck Henderson, Reactor Inspector (Lead Inspector - ISI)
Matthew Young, Reactor Inspector

A. Information Requested for the In-Office Preparation Week

The following information should be sent to the Region IV office in hard copy or electronic format (ims.certrec.com preferred), in care of Breck Henderson, by October 1, 2009, to facilitate the selection of specific items that will be reviewed during the onsite inspection week. The inspector will select specific items from the information requested below and then request from your staff additional documents needed during the onsite inspection week (Section B of this enclosure). We ask that the specific items selected from the lists be available and ready for review on the first day of inspection. *Please provide requested documentation electronically if possible. If requested documents are large and only hard copy formats are available, please inform the inspector(s), and provide subject documentation during the first day of the onsite inspection. If you have any questions regarding this information request, please call the inspector as soon as possible.

A.1 ISI/Welding Programs and Schedule Information

- a) A detailed schedule (including preliminary dates) of:
- i) Nondestructive examinations (NDEs) planned for Class 1 & 2 systems and containment, performed as part of your ASME Section XI, Risk Informed (if applicable), and augmented ISI programs during the upcoming outage.

Provide a status summary of the NDE inspection activities vs. the required inspection period percentages for this Interval by category per ASME Section XI, IWX-2400 (Do not provide separately if other documentation requested contains this information)
 - ii) Examinations planned for Alloy 82/182/600 components that are not included in the Section XI scope. (If applicable)
 - iii) Examinations planned as part of your Boric Acid Corrosion Control Program (Mode 3 walkdowns, bolted connection walkdowns, etc.)

- iv) Welding activities that are scheduled to be completed during the upcoming outage (ASME Class 1, 2, or 3 structures, systems, or components (SSCs)).
- b) A copy of ASME Section XI Code Relief Requests and associated NRC Safety Evaluations applicable to the examinations identified above.
- c) A list of NDE reports (ultrasonic, radiography, magnetic particle, dye penetrate, Visual VT-1, VT-2, and VT-3), which have identified relevant conditions on Code Class 1 & 2 systems since the beginning of the last refueling outage. This should include the previous Section XI pressure test(s) conducted during start up and any evaluations associated with the results of the pressure tests. Also, include in the list the NDE reports with relevant conditions in the RPVH penetration nozzles which have been accepted for continued service. The list of NDE reports should include a brief description of the SSC where the relevant condition was identified.
- d) A list with a brief description (e.g., system, material, pipe size, weld number, and NDE performed) of the welds in Code Class 1 and 2 systems which have been fabricated due to component repair/replacement activities since the beginning of the last refueling outage, or are planned to be fabricated this refueling outage.
- e) If reactor vessel weld examinations required by the ASME Code are scheduled to occur during the upcoming outage, provide a detailed description of the welds to be examined and the extent of the planned examination. Please also provide reference numbers for applicable procedures that will be used to conduct these examinations.
- f) Copy of any 10 CFR Part 21 reports applicable to your SSCs within the scope of Section XI of the ASME Code that have been identified since the beginning of the last refueling outage.
- g) A list of any temporary non-code repairs in service (e.g., pinhole leaks).
- h) Please provide copies of the most recent self assessments for the ISI, Welding, and Alloy 600 Programs.

A.2 Boric Acid Corrosion Control Program (BACCP)

- a) Copy of the procedures that govern the scope, equipment and implementation of the inspections required to identify boric acid leakage and the procedures for boric acid leakage/corrosion evaluation.
- b) Please provide a list of leaks (including code class of the components) that have been identified since the last refueling outage and associated corrective action documentation. If during the last cycle, the unit was shutdown, please provide documentation of containment walkdown inspections performed as part of the BACCP.

- c) Please provide a copy of the most recent self-assessment performed for the BACCP.

A.3 Steam Generator Tube (SGT) Inspections

- a) A detailed schedule of:
 - i) SGT inspection, data analyses, and repair activities for the upcoming outage. (If applicable)
 - ii) SG secondary side inspection activities for the upcoming outage. (If applicable)
- b) Please provide a copy of your SG ISI Inspection Program and Plan. Please include a copy of the Operational Assessment from last outage and a copy of the following documents as they become available:
 - i) Degradation Assessment
 - ii) Condition Monitoring Assessment
- c) If you are planning on modifying your Technical Specifications such that they are consistent with TSTF-449, please provide copies of your correspondence with the NRC regarding deviations from the STS.
- d) Copy of SG history documentation given to vendors performing eddy current (ET) testing of the SGs during the upcoming outage.
- e) Copy of SG Eddy Current Data Analyst Guidelines and Site Validated Eddy Current Technique Specification Sheets (ETSS). Additionally, please provide a copy of EPRI Appendix H ETSS Qualification Records.
- f) Identify and quantify any SGT leakage experienced during the previous operating cycle. Also provide documentation identifying which SG was leaking and corrective actions completed or planned for this condition (If applicable).
- g) Provide past history of the condition and issues pertaining to the secondary side of the steam generators (including items such as loose parts, fouling, top of tube sheet condition, crud removal amounts, etc.)
- h) Please provide copies of your most recent self assessments of the SG monitoring, loose parts monitoring, and secondary side water chemistry control programs.
- i) Please also indicate where the primary, secondary, and resolution analyses are scheduled to take place.
- j) Please provide a summary of the scope of the SGT examinations, including examination methods such as Bobbin, Rotating Pancake, or Plus Point, and the

percentage of tubes to be examined. **Do not provide these documents separately if already included in other information requested.*

A.4 Materials Reliability (MRP-139) Program Activities

- a) A list of, with verification, that the baseline inspections of all applicable Dissimilar Metal Butt Welds (DMBW) have been completed by December 31, 2008.
- b) Verification that baseline inspection of hot leg and cold leg temperature DMBWs have been included in the inspection program and that the schedules for the baseline inspections are consistent with the baseline schedules in MRP-139.
- c) A list and schedule (examination dates) of all DMBW examinations planned for the upcoming refueling outage. If none are scheduled, then data from previous examinations should be available for review.
- d) A list and schedule for any welding to be performed on DMBWs in the upcoming outage. If no welding will be performed, then records of previous welding on DMBWs and postweld NDE documentation.
- e) A list and schedule of any stress improvement (SI) activities planned for the upcoming refueling outage. If none are scheduled then have qualification reports for any SIs previously performed.
- f) Documentation and description of how the baseline and inservice inspection specifications in MRP-139 are satisfied at your facility.
- g) A list of weld locations controlled by MRP-139 which includes the MRP-139 weld category, pre-mitigation volumetric examination date, type of mitigation or stress improvement, post mitigation volumetric examination date, and plans for future MRP-139 required examinations.

A.5 Additional information related to all ISI activities

- a) A list with a brief description of ISI, BACCP, and SGT inspection related issues (e.g., condition reports) entered into your corrective action program since the beginning of the last refueling outage (for Unit 2). For example, a list based upon data base searches using key words related to piping or SG tube degradation such as: ISI, ASME Code, Section XI, NDE, cracks, wear, thinning, leakage, rust, corrosion, boric acid, or errors in piping/SGT examinations.
- b) Please provide names and phone numbers for the following program leads:
 - ISI contacts (Examination, planning)
 - Containment Exams
 - RPVH Exams
 - Snubbers and Supports
 - Repair and Replacement Program Manager

Licensing Contact
Site Welding Engineer
Boric Acid Corrosion Control Program
SG Inspection Activities (site lead and vendor contact)

B. Information to be provided onsite to the inspector(s) at the entrance meeting (October 13, 2009):

B.1 ISI / Welding Programs and Schedule Information

- a) Updated schedules for ISI/NDE activities, including SGT inspections, planned welding activities, and schedule showing contingency repair plans, if available.
- b) For ASME Code Class 1 and 2 welds selected by the inspector from the lists provided from section A of this enclosure, please provide copies of the following documentation for each subject weld:
 - i) Weld data sheet (traveler)
 - ii) Weld configuration and system location
 - iii) Applicable Code Edition and Addenda for weldment
 - iv) Applicable Code Edition and Addenda for welding procedures
 - v) Applicable weld procedures (WPS) used to fabricate the welds
 - vi) Copies of procedure qualification records (PQRs) supporting the WPS from B.1.b.v
 - vii) Copies of mechanical test reports identified in the PQRs above
 - viii) Copies of the nonconformance reports for the selected welds (If applicable)
 - ix) Radiographs of the selected welds and access to equipment to allow viewing radiographs (If RT was performed)
 - x) Copies of the preservice examination records for the selected welds
 - xi) Copies of welder performance qualifications records applicable to the selected welds, including documentation that welder maintained proficiency in the applicable welding processes specified in the WPS (at least six months prior to the date of subject work)
 - xii) Copies of NDE personnel qualifications (VT, PT, UT, RT), as applicable
- c) For the ISI related corrective action issues selected by the inspector(s) from section A of this enclosure, provide a copy of the corrective actions and supporting documentation.
- d) For the NDE reports with relevant conditions on Code Class 1 & 2 systems selected by the inspector from Section A above, provide a copy of the examination records, examiner qualification records, and associated corrective action documents.
- e) A copy of (or ready access to) most current revision of the ISI Program Manual and Plan for the current interval.

- f) For the NDEs selected by the inspector from section A of this enclosure, provide copy of the NDE procedures used to perform the examinations (including calibration and flaw characterization/sizing procedures). For ultrasonic examination procedures qualified in accordance with ASME Code, Section XI, Appendix VIII, provide documentation supporting the procedure qualification (e.g., the EPRI performance demonstration qualification summary sheets). Also, include qualification documentation of the specific equipment to be used (e.g., ultrasonic unit, cables, and transducers including serial numbers) and NDE personnel qualification records.

B.2 Boric Acid Corrosion Control Program (BACCP)

- a) Please provide boric acid walkdown inspection results, an updated list of boric acid leaks identified so far this outage, associated corrective action documentation, and overall status of planned boric acid inspections.
- b) Please provide any engineering evaluations completed for boric acid leaks identified since the end of the last refueling outage. Please include a status of corrective actions to repair and/or clean these boric acid leaks. Please identify specifically which known leaks, if any, have remained in service or will remain in service as active leaks.

B.3 Steam Generator Tube (SGT) Inspections

- a) Copies of the Examination Technique Specification Sheets (ETSS) and associated justification for any revisions.
- b) Copy of the guidance to be followed if a loose part or foreign material is identified in the SGs.
- c) Please provide a copy of the ET procedures used to perform the SGT inspections (specifically calibration and flaw characterization/sizing procedures, etc.). Also include documentation for the specific equipment to be used.
- d) Please provide copies of your responses to NRC and industry operating experience communications such as Generic Letters, Information Notices, etc. (as applicable to SGT inspections) **Do not provide these documents separately if already included in other information requested such as the degradation assessment.*
- e) List of corrective action documents generated by the vendor and/or site with respect to SG inspection activities.

B.4 Codes and Standards

- a) Ready access to (i.e., copies provided to the inspector(s) for use during the inspection at the onsite inspection location, or room number and location where available):
 - i) Applicable Editions of the ASME Code (Sections V, IX and XI) for the inservice inspection program and the repair/replacement program.
 - ii) EPRI and industry standards referenced in the procedures used to perform the SGT eddy current examination.

Inspector Contact Information:

Breck Henderson
Reactor Inspector
817-276-6569

Breck.Henderson@nrc.gov

Matthew Young
Reactor Inspector
817-276-6545

matt.young@nrc.gov

Mailing Address:
US NRC Region IV
Attn: Breck Henderson
612 E. Lamar Blvd, Suite 400
Arlington, TX 76011