


SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-315	6.0-7.0	Poorly Graded SAND, with silt, tan			
CBR (Soaked):	18.9	Soaking Time:	4 Days		
Surcharge:	50 PSF	Swell:			
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	109.2	Before Soaking:	11.6		
After Soaking:	109.1	After Soaking:	12.3		
Max. Dry Density:	114.9	Optimum Moisture:	11.4		



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/27/2006
Boring No.:	Depth (ft):	Sample Description:			
TP-B-335	5.0-6.0	Silty SAND, brown			
CBR (Unsoaked):	36.2	Soaking Time:	N/A		
Surcharge:	50 PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	124.0	Before Soaking:	7.6		
After Soaking:	N/A	After Soaking:	N/A		
Max. Dry Density:	130.5	Optimum Moisture:	7.6		



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/27/2006
Boring No.	Depth (ft)	Sample Description				
TP-B-335	5.0-6.0	Silty SAND, brown				
CBR (Soaked):	18.0	Soaking Time:	4 Days			
Surcharge:	50 PSF	Swell:	0.0%			
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	124.0	Before Soaking:	7.6			
After Soaking:	123.8	After Soaking:	9.0			
Max. Dry Density:	130.5	Optimum Moisture:	7.6			



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/25/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-407	4.5-5.5	Well Graded SAND, with silt, trace gravel, dark			
CBR (Unsoaked):	14.8	Soaking Time:	N/A		
Surcharge:	50 PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	113.1	Before Soaking:	8.7		
After Soaking:	N/A	After Soaking:	N/A		
Max. Dry Density:	119.1	Optimum Moisture:	8.6		



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/25/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-407	4.5-5.5	Well Graded SAND, with silt, trace gravel, dark			
CBR (Soaked):	17.0	Soaking Time:	4 Days		
Surcharge:	50 PSF	Swell:			
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	113.1	Before Soaking:	8.7		
After Soaking:	113.0	After Soaking:	11.9		
Max. Dry Density:	119.1	Optimum Moisture:	8.6		



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/25/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-415	3.0-4.0	Poorly Graded SAND, trace silt, light brown			
CBR (Unsoaked):	11.1	Soaking Time:	N/A		
Surcharge:	50 PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	111.1	Before Soaking:	9.7		
After Soaking:	N/A	After Soaking:	N/A		
Max. Dry Density:	116.7	Optimum Moisture:	9.8		



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/25/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-415	3.0-4.0	Poorly Graded SAND, trace silt, light brown			
CBR (Soaked):	4.7	Soaking Time:	4 Days		
Surcharge:	50 PSF	Swell:			
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	111.1	Before Soaking:	9.7		
After Soaking:	111.0	After Soaking:	13.0		
Max. Dry Density:	116.7	Optimum Moisture:	9.8		



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/27/2006
Boring No.:	Depth (ft):	Sample Description:				
TP-B-434	2.0-3.0	Sandy LEAN CLAY, dark brown				
CBR (Unsoaked):	9.3	Soaking Time:	N/A			
Surcharge:	50 PSF	Swell:	N/A			
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	120.6	Before Soaking:	10.1			
After Soaking:	N/A	After Soaking:	N/A			
Max. Dry Density:	127.1	Optimum Moisture:	10.1			



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/27/2006
Boring No.	Depth (ft)	Sample Description				
TP-B-434	2.0-3.0	Sandy LEAN CLAY, dark brown				
CBR (Soaked):	3.2	Soaking Time:	4 Days			
Surcharge:	10 PSF	Swell:	0.0%			
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	120.6	Before Soaking:	10.1			
After Soaking:	120.5	After Soaking:	13.3			
Max. Dry Density:	127.1	Optimum Moisture:	10.1			



UNSOAKED CBR




CALIFORNIA BEARING RATIO ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/25/2006
Boring No.	Depth (ft)	Sample Description				
B-435	7.0-8.0	Poorly Graded SAND, with silt, trace gravel, light brown				
CBR (Unsoaked):	26.8	Soaking Time:	N/A			
Surcharge:	50 PSF	Swell:	N/A			
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	118.2	Before Soaking:	8.9			
After Soaking:	N/A	After Soaking:	N/A			
Max. Dry Density:	123.9	Optimum Moisture:	8.9			



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/25/2006
Boring No.	Depth (ft)	Sample Description			
B-435	7.0-8.0	Poorly Graded SAND, with silt, trace gravel, light brown			
CBR (Soaked):	33.7	Soaking Time:	4 Days		
Surcharge:	50 PSF	Swell:	0.0%		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	118.2	Before Soaking:	8.9		
After Soaking:	118.1	After Soaking:	12.0		
Max. Dry Density:	123.9	Optimum Moisture:	8.9		



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description			
B-435	9.0-10.0	Clayey SAND, brown			
CBR (Soaked):	34.4	Soaking Time:	N/A		
Surcharge:	50 PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	124.4	Before Soaking:	6.9		
After Soaking:	N/A	After Soaking:	N/A		
Max. Dry Density:	130.2	Optimum Moisture:	7.3		



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description			
B-435	9.0-10.0	Clayey SAND, brown			
CBR (Unsoaked):	41.8	Soaking Time:	4 Days		
Surcharge:	50 PSF	Swell:	0.0%		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	124.4	Before Soaking:	6.9		
After Soaking:	124.2	After Soaking:	7.9		
Max. Dry Density:	130.2	Optimum Moisture:	7.3		



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-717	7.0-8.0	Poorly Graded SAND, with silt, trace gravel, light brown			
CBR (Unsoaked):	17.2	Soaking Time:	N/A		
Surcharge:	50 PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	117.8	Before Soaking:	10.0		
After Soaking:	N/A	After Soaking:	N/A		
Max. Dry Density:	123.8	Optimum Moisture:	10.2		



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description				
TP-B-717	7.0-8.0	Poorly Graded SAND, with silt, trace gravel, light brown				
CBR (Soaked):	23.1	Soaking Time:	4 Days			
Surcharge:	50 PSF	Swell:	0.0%			
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	117.8	Before Soaking:	10.0			
After Soaking:	117.7	After Soaking:	10.5			
Max. Dry Density:	123.8	Optimum Moisture:	10.2			



UNSOAKED CBR




CALIFORNIA BEARING RATIO ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description				
TP-B-719	7.0-8.0	Silty SAND, gray				
CBR (Unsoaked):	41.3		Soaking Time:	N/A		
Surcharge:	50	PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	113.5		Before Soaking:	10.1		
After Soaking:	N/A		After Soaking:	N/A		
Max. Dry Density:	119.6		Optimum Moisture:	10.0		



SOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland	Contract No.:	06120048.00	Date:	9/26/2006
Boring No.	Depth (ft)	Sample Description			
TP-B-719	7.0-8.0	Silty SAND, gray			
CBR (Soaked):	29.0	Soaking Time:	4 Days		
Surcharge:	50 PSF	Swell:	0.1%		
DRY DENSITY, PCF		MOISTURE CONTENT, %			
Before Soaking:	113.5	Before Soaking:	10.1		
After Soaking:	113.2	After Soaking:	10.8		
Max. Dry Density:	119.6	Optimum Moisture:	10.0		



UNSOAKED CBR




CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/27/2006
Boring No.	Depth (ft)	Sample Description				
TP-B-758	7.5-8.5	Silty SAND, trace gravel, light brown				
CBR (Unsoaked):	11.3		Soaking Time:	N/A		
Surcharge:	50	PSF	Swell:	N/A		
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	121.2		Before Soaking:	8.9		
After Soaking:	N/A		After Soaking:	N/A		
Max. Dry Density:	127.3		Optimum Moisture:	8.9		



SOAKED CBR



CALIFORNIA BEARING RATIO

ASTM D-1883

Project:	Constellation Energy Group COLA Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland		Contract No.:	06120048.00	Date:	9/27/2006
Boring No.	Depth (ft)	Sample Description				
TP-B-758	7.5-8.5	Silty SAND, trace gravel, light brown				
CBR (Soaked):	4.4	Soaking Time:	4 Days			
Surcharge:	50 PSF	Swell:	0.2%			
DRY DENSITY, PCF		MOISTURE CONTENT, %				
Before Soaking:	121.2	Before Soaking:	8.9			
After Soaking:	120.9	After Soaking:	11.1			
Max. Dry Density:	127.3	Optimum Moisture:	8.9			

