

**REPORT**  
**Reconciliation of EPRI and RCTS Results**  
**Calvert Cliffs Nuclear Power Plant Unit 3**

**Prepared for:**

**UniStar Nuclear Development, LLC**

**Prepared by:**

**Bechtel Power Corporation**



25237-000-30R-GEK-00001-000

**December 14, 2007**

Confidential © Bechtel Power Corporation 2007. This item contains confidential information proprietary to Bechtel Power Corporation that is not to be used, disclosed, or reproduced in any format by any non-Bechtel party without Bechtel's prior written permission. Notwithstanding the above, Constellation Generating Group, LLC. has the right to use the information contained in the document pursuant to Purchase Order 500117,

Revision 1, dated 4/11/06, between Bechtel Power Corporation and Constellation Generating Group, LLC. All rights reserved.



**TABLE OF CONTENTS**

<u>Section</u>	<u>Page</u>
<b>TABLE OF CONTENTS</b> .....	3
<b>LIST OF FIGURES</b> .....	5
<b>1 PURPOSE</b> .....	6
<b>2 BACKGROUND</b> .....	6
<b>3 EPRI CURVES</b> .....	6
<b>4 RCTS TEST RESULTS</b> .....	6
<b>5 EVALUATION OF RCTS TEST RESULTS</b> .....	7
<b>6 STRAIN-DEPENDENT PROPERTIES FOR SOILS BELOW 400 FEET</b> .....	8
<p>It is important to note that the calculated maximum strains based on the initially adopted EPRI curves for soils below 400 feet are in the 10<sup>-3</sup>% to 10<sup>-2</sup>% range for the 1E-4 and 1E-5 rock input motions, respectively, as shown in Figure 22. At these strain levels, the difference between the EPRI-based and RCTS-based curves are minor to insignificant, as evident in Figure 21.....</p>	
<b>7 CONCLUSIONS</b> .....	9
<b>8 CONFIRMATORY ANALYSIS</b> .....	9
<b>9 REFERENCES</b> .....	9



LIST OF TABLES

<u>Number</u>	<u>Page</u>
Table 1. Summary of RCTS Samples and Index Properties.....	10
Table 2. Summary Shear Modulus and Damping Ratios from Initially Adopted EPRI Curves.....	11
Table 3. Summary of RCTS Laboratory Test Results (Appendix A Tests).....	11
Table 4. Summary of RCTS Laboratory Test Results (Appendix B Tests).....	12
Table 5. Summary of RCTS Laboratory Test Results (Appendix I Tests).....	13
Table 6. Summary of RCTS Laboratory Test Results (Appendix C Tests).....	14
Table 7. Summary of RCTS Laboratory Test Results (Appendix J Tests).....	15
Table 8. Summary of RCTS Laboratory Test Results (Appendix D Tests).....	16
Table 9. Summary of RCTS Laboratory Test Results (Appendix K Tests).....	17
Table 10. Summary of RCTS Laboratory Test Results (Appendix M Tests).....	18
Table 11. Summary of RCTS Laboratory Test Results (Appendix E Tests).....	19
Table 12. Summary of RCTS Laboratory Test Results (Appendix L Tests).....	20
Table 13. Summary of RCTS Laboratory Test Results (Appendix G Tests).....	21
Table 14. Summary of RCTS Laboratory Test Results (Appendix F Tests).....	22
Table 15. Summary of RCTS Laboratory Test Results (Appendix H Tests).....	23
Table 16. Summary Average Shear Modulus and Damping Ratios Values from RCTS Results.....	25
Table 17. Final Shear Modulus and Damping Ratios for the CCNPP Unit 3 Soils.....	25



## LIST OF FIGURES

<u>Number</u>	<u>Page</u>
Figure 1. RCTS Test Locations .....	27
Figure 2. Shear Modulus and Damping Ratios from Initially Adopted EPRI Curves .....	28
Figure 3. RCTS Test Results: Stratum I-Terrace Sand (Appendix A Tests).....	29
Figure 4. RCTS Test Results: Stratum IIa-Chesapeake Clay/Silt (Appendix B Tests) .....	30
Figure 5. RCTS Test Results: Stratum IIa-Chesapeake Clay/Silt (Appendix I Tests).....	31
Figure 6. RCTS Test Results: Stratum IIb-Chesapeake Cemented Sand (Appendix C Tests).....	32
Figure 7. RCTS Test Results: Stratum IIb-Chesapeake Cemented Sand (Appendix J Tests) .....	33
Figure 8. RCTS Test Results: Stratum IIb-Chesapeake Cemented Sand (Appendix D Tests).....	34
Figure 9. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix K Tests).....	35
Figure 10. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix M Tests).....	36
Figure 11. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix E Tests).....	37
Figure 12. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix L Tests) .....	38
Figure 13. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix G Tests) .....	39
Figure 14. RCTS Test Results: Stratum III-Nanjemoy Sand (Appendix F Tests) .....	40
Figure 15. RCTS Test Results: Stratum III-Nanjemoy Sand (Appendix H Tests).....	41
Figure 16. Difference Between RCTS and EPRI Curves: $G/G_{max}$ and Damping .....	42
Figure 17. Difference Between RCTS and EPRI Curves: $G/G_{max}$ and Damping at $1E-2\pm\%$ Strain .....	43
Figure 18. Combined RCTS Test Results .....	44
Figure 19. Average Shear Modulus and Damping Ratio Curves from RCTS Test Results .....	45
Figure 20. Comparison of Average RCTS Test Results and Initially Adopted EPRI Curves .....	46
Figure 21. Selection of Shear Modulus and Damping Ratios for Soils Deeper than 400 Feet.....	47
Figure 22. Calculated Maximum Strains Based on Initially Adopted EPRI Curves.....	47
Figure 23. Final Shear Modulus and Damping Ratios for the CCNPP Unit 3 Soils .....	49
Figure 24. Comparison of Amplification Factors at $1E-4$ LF for the CCNPP Unit 3 Soils .....	49
Figure 25. Comparison of Amplification Factors at $1E-4$ HF for the CCNPP Unit 3 Soils.....	50



## **1 PURPOSE**

The purpose of this report is to 1) present and compare the soil strain-dependent EPRI curves with the site-specific Resonant Column Torsional Shear (RCTS) test results, 2) adopt final shear modulus and damping curves for the project, and 3) evaluate the soil amplification using both the EPRI-based and RCTS-based data.

This work was performed for Constellation Generating Group, LLC, per Purchase Order No. 500117, Rev. 1, dated April 11, 2006.

## **2 BACKGROUND**

As part of the initial development of the soil dynamic properties for the Calvert Cliffs Nuclear Power Plant (CCNPP) Unit 3 project, EPRI shear modulus and damping curves were adopted. Use of EPRI curves was due to the absence of RCTS test results for the site soils at the time. The adopted EPRI curves and the basis for their selection are addressed in Reference 1.

As part of the subsurface investigation, RCTS tests were commissioned for the site soils and the results of these tests are now available. A total of 13 samples were identified for RCTS testing with 7 additional samples placed in reserve as backup, if needed to replace any of the original 13 samples. Thirteen RCTS tests, along with the necessary index tests, were performed. All of the RCTS results were reviewed and were found acceptable by Dr. Kenneth Stokoe of the University of Texas at Austin. The RCTS test results are presented in Reference 2.

Selection and quantity of RCTS tests were based on the site stratigraphy, the thickness of various soil strata, their position with respect to the Category I structures, and sample availability. The locations of RCTS samples, and other relevant information, are shown on a typical site stratigraphic profile in Figure 1. A summary of the RCTS samples and their index properties is shown in Table 1.

## **3 EPRI CURVES**

Since the RCTS test results will be compared with the EPRI curves that were initially adopted, the EPRI curves are presented herein for ease of comparison. Selection of EPRI curves is addressed in Reference 1. The EPRI curves and numerical values are reproduced and shown in this report as Figure 2 and Table 2.

## **4 RCTS TEST RESULTS**

RCTS tests were performed on soils from the upper 400 feet of the site. More than one sample was tested in most of the soil strata. Samples were tested at depths ranging from about 15 to 400 feet below the existing ground surface (the ground surface at the time of the geotechnical investigation). All samples tested were obtained from tube samples, except for one sample (sample identified by the laboratory as "Appendix No. H" in Table 1), which was obtained from reconstituting jar samples. The quantity of samples tested from each stratum, and their locations, are shown in Figure 1, indicating the following number of samples tested from each stratum:

- Stratum I-Terrace Sand: 1 sample
- Stratum IIa-Chesapeake Clay/Silt: 2 samples
- Stratum IIb-Chesapeake Cemented Sand: 3 samples
- Stratum IIc-Chesapeake Clay/Silt: 5 samples
- Stratum III-Nanjemoy Sand: 2 samples



## Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3

- Soils below Stratum III: 0 (zero) samples, given that the soil borings during the geotechnical investigation did not penetrate these soils

The RCTS test results for individual samples are summarized and presented in Figures 3 through 15, with the corresponding numerical values given in Tables 3 through 15. Other complimentary information is also presented on the respective figures for ready comparison, namely:

- Selected EPRI Curve: shear modulus and damping ratios from the initially adopted EPRI curves
- Randomized EPRI Curve: the randomized minimum and maximum values of shear modulus and damping ratios, as well as the mean values  $\pm 1\sigma$  (sigma)
- RCTS Test Results: RCTS results at the mean in-situ stress ( $\sigma_0$ ) and at 4 times the mean in-situ stress
- Relationship from RCTS Results: curves representing the  $G/G_{\max}$  and damping ratios from the RCTS tests for comparison with EPRI and randomized curves

A “key” is shown on each figure, identifying the above information.

The curves fitted to the RCTS data are based on test results at confining stresses representing the in-situ stress for the test sample. In general, the results indicate that the RCTS curves offer higher shear modulus and lower damping ratios than those represented by the initially adopted EPRI curves. This is discussed below in more detail.

### 5 EVALUATION OF RCTS TEST RESULTS

As noted above, the RCTS test results indicate higher shear modulus ratio and lower damping ratio than the initially adopted EPRI curves. The relative differences in both shear modulus ratio and damping ratio between RCTS and the initially adopted EPRI curves was calculated at different strain levels and are shown in Figure 16. The results indicate from zero to over 200% difference in  $G/G_{\max}$  values over a shear strain range from 1E-4% to 1%. Similarly, the results indicate about  $\pm 60\%$  difference in damping ratio values over a shear strain range from 1E-4% to 1%. These differences in both the  $G/G_{\max}$  and damping ratios are over extreme strain values (from 1E-4 to 1%), a strain range unlikely to be experienced by the site soils. It should be noted that results of seismic analyses using the initially adopted EPRI curves indicated that the mean (of maximum) strain values were mostly in the 1E-2% range (Reference 3). These strain values, for each soil stratum, are shown on the respective curves for that stratum in Figure 17.

Figure 17 indicates that at a strain level of about 1E-2 $\pm$ %, the difference between the initially adopted EPRI and the actual RCTS  $G/G_{\max}$  values is much more limited than the previously noted 200%, actually ranging from about 1 to 11%, or average of about 6% for the noted strain level. This difference is not considered significant, given the natural variation in soils and the expected variation in RCTS test results. It is also noted that in the randomization of the  $G/G_{\max}$  values at a strain level of 1E-2%, the minimum and maximum values (with respect to the mean) are allowed to vary by as much as  $\pm 7\%$ , and sometimes by as much as  $\pm 8\%$ . The observed average value of 6% noted above is within the acceptable 7-8% range for randomization.

Similarly, from Figure 17, at a strain level of 1E-2 $\pm$ %, the difference between the initially adopted EPRI and the actual RCTS damping ratio values range from about -50% to +15%, or average of about 33%. Again, this difference is not considered significant, given the natural variation in soils and the expected variation in RCTS test results. It is also noted that in the randomization of the damping ratio values at a strain level of 1E-2%, the minimum and maximum values (with respect to the mean)



are allowed to vary from about -50% to +100%, or average of about 75%. The observed average value of 33% noted above is well within the acceptable -50% to +100% range for randomization.

Finally, the results of all 13 RCTS tests are combined, in terms of shear modulus and damping ratios, and are presented in Figure 18. Three distinct groups are noted in the  $G/G_{max}$  curves for the site soils. Given the relative similarity in responses among various groups of tests, and particularly in light of small variations at low strain levels (approximately  $1E-2\%$ ), it is possible to provide an average curve for each of the three distinct groups. A similar approach is followed for the damping curves shown in Figure 18. The average curves for the three distinct groups, for both shear modulus and damping ratios, are presented in Figure 19. The numerical values for these average curves are given in Table 16. These represent the strain-dependent properties for soils in the upper approximately 400 feet at the CCNPP Unit 3 site. For comparison purposes, these curves are shown along with the initially adopted EPRI curves in Figure 20.

## 6 STRAIN-DEPENDENT PROPERTIES FOR SOILS BELOW 400 FEET

As noted earlier, RCTS tests were performed on soils collected from the upper 400 feet of the site. RCTS tests were not performed on soils below 400 feet, for the boring depths were limited to about 400 feet, and therefore, soils samples were not available for testing. These deeper soils, in descending order, are the Marlboro Clay, Aquia/Brightseat Sand, Patapsco Sand, and the Patuxent/Arundel Clay.

To assess their utilization, EPRI curves initially adopted for these soils were compared with the set of curves derived from the RCTS results for the upper soils, as shown in Figure 21. The results indicate the following relative to the RCTS-based curves

- Marlboro Clay and Patuxent/Arundel Clay Curves: the EPRI curves are identical and fall nearly half-way between the RCTS-based curves for the Stratum I Sand (Curve 3) and Strata II and III soils (Curve 2) in their  $G/G_{max}$  relationship and closer to Curve 3 in their damping relationship. Based on the available RCTS results, it is inconceivable for these soils at such great depths (and expected high strength) to behave as “softly” as Stratum I Sand (Curve 3) which is at relatively shallow depths and primarily non-plastic. Therefore, as a minimum, the Marlboro and Patuxent/Arundel clays are expected to behave closer to that represented by Curve 2. On this basis, Curve 2 is a reasonable representation for these soils and is used for the dynamic characterization of Marlboro Clay and Patuxent/Arundel Clay.
- Aquia/Brightseat Sand and Patapsco Sand: the EPRI curves are nearly identical and follow Curve 2 closely in their  $G/G_{max}$  and damping relationship. Based on the RCTS results, and given their depths, these soils are expected to behave somewhere in the region represented by Curves 1 and 2, and possibly closer to Curve 1. Given that a number of the RCTS tests on sandy soils banded closely and were represented by Curve 2, the deeper sandy soils of the Aquia/Brightseat and Patapsco are expected to produce relationships that are mimicked by Curve 2, as a minimum. On this basis, Curve 2 is a reasonable representation for these soils and is used for the dynamic characterization of Aquia/Brightseat Sand and Patapsco Sand.

It is important to note that the calculated maximum strains based on the initially adopted EPRI curves for soils below 400 feet are in the  $10^{-3}\%$  to  $10^{-2}\%$  range for the  $1E-4$  and  $1E-5$  rock input motions, respectively, as shown in Figure 22. At these strain levels, the difference between the EPRI-based and RCTS-based curves are minor to insignificant, as evident in Figure 21.





## 7 CONCLUSIONS

A total of 13 RCTS tests were performed on soils from the CCNPP Unit 3 site. Final shear modulus ratio and damping ratio curves for all the soils at the CCNPP Unit 3 site are summarized in Figure 23, with the numerical values given in Table 17.

A comparison of the RCTS results with the initially adopted EPRI curves indicate that the difference between these curves at a mean strain level of about 1E-2% (the approximate mean strain level calculated in the soils from the initial seismic evaluation based on EPRI curves) is well within ranges considered acceptable for the randomization of these curves. This suggests that a new seismic analysis using the RCTS results would not significantly change the outcome of the initial seismic analysis that was based on the EPRI curves. This is particularly supported by the shape of the RCTS test curves that indicate consistently higher shear modulus and lower damping than the initially adopted EPRI curves, since such stiffer dynamic response should result in strains somewhat lower than (or at least similar to) the initially observed value of 1E-2±%, a level at which the RCTS and EPRI curves converge even closer with practically insignificant differences.

## 8 CONFIRMATORY ANALYSIS

To assess the above observations, an analysis was performed, comparing the sensitivity in soil amplification for both the EPRI-based and RCTS-based curves. The work consisted of separately running a soil column analysis using the EPRI-based curves (Figure 2) and the RCTS-based curves (Figure 23), without randomization. The shear wave velocity profile and material parameters were per Reference 1. Amplifications, in terms of spectral ratio of response motion to input motion, at outcrop depths of 0 (zero) and 41 feet for both high frequency (HF) and low frequency (LF)  $10^{-4}$  rock input motions, were obtained. The results are documented in Reference 4, and reported herein as Figures 24 and 25.

The results support the observations made earlier. They indicate that the differences in amplification factors are very small, especially at the LF input. At the HF input, small differences are evident; however, the RCTS-based results indicate reduced amplification, which should result in reduced spectral acceleration than from the EPRI-based curves. Accordingly, based on results of this analysis, it is concluded that the EPRI-based and site-specific RCTS-based curves arrive at very similar soil amplification, and therefore, the response motion (GMRS) presented in Reference 3 is sufficient for the CCNPP Unit 3 design.

## 9 REFERENCES

1. Calvert Cliffs Unit 3, Combined License Application, Rev. 0, Part 2, FSAR, Vol. 4, Section 2.5.4, "Stability of Subsurface Materials and Foundations" NRC Accession No. ML072000175, dated 7/13/2007.
2. Schnabel Engineering North, LLC (2007), Geotechnical Subsurface Investigation Data Report, Addendum No. 3 (RCTS Test Results), Rev. 02, CGG Combined Operating License Application (COLA) Project, Calvert Cliffs Nuclear Power Plant (CCNPP), Calvert County, Maryland.
3. Calvert Cliffs Unit 3, Combined License Application, Rev. 0, Part 2, FSAR, Vol. 3, Section 2.5.2, "Vibratory Ground Motion" NRC Accession No. ML072000172, dated 7/13/2007.
4. Risk Engineering, Inc. (2007), Calvert Cliffs Sensitivity of Site Response to RCTS vs. EPRI Soil Curves, 0620-ACR-038.



**Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3**

Table 1. Summary of RCTS Samples and Index Properties

Appendix No.	Sample	Sample No.	Sample Top Depth (ft)	Sample Bottom Depth (ft)	Sample Type	Index Testing					
						Lab Class	UW (lb/ft <sup>3</sup> )	MC (%)	SG	LL	PI
A	B-437	6	13.5	15.5	UD	SP-SM	124.1	7.2	2.66	NP	NP
B	B-301	10	33.5	35.5	UD	CH	117.5	31.1	2.74	59	42
C	B-305	17	39.5	41.5	UD	SC	117.2	34.7	2.71	72	50
D	B-404	14	52	53.6	UD	SP-SM	117.6	27.7	2.66	NP	NP
E	B-401	31	138.5	140.5	UD	CH	104.1	44.1	2.63	80	49
F	B-401	67	348.5	350.5	UD	SM	116.4	35.6	2.78	52	13
G	B-401	48	228.5	229.6	UD	MH	98.2	58.6	2.48	139	51
H	B-301	76	368.5	370	jar	SM	116.4	34.4	2.86	40	4
	B-301	77	378.5	379.5	jar						
	B-301	78	383.5	384.4	jar						
	B-301	79	388.5	390	jar						
	B-301	81	398.5	400	jar						
	B-401	68	358.5	359.4	jar						
I	B-306	17	68	70	UD	CH	115.8	30.7	2.73	62	38
J	B-409	15	35	36.1	UD	SP-SM	124.8	23.3	2.66	NP	NP
K	B-404	22	83.5	85.1	UD	SM	115.4	32.2	2.63	53	25
L	B-401	42	198.5	200.3	UD	SM	101.2	48.8	2.52	82	27
M	B-409	39	95	96.6	UD	SM	109.3	33.1	2.64	61	19

**Key:**

Appendix No. Sample designation assigned by the laboratory for tracking purposes  
 UD Shelby tube sample  
 Jar Glass jar sample  
 Lab Class Laboratory classification of soils  
 UW Total unit weight  
 MC Moisture content  
 SG Specific gravity  
 LL Liquid limit  
 PI Plasticity index



Table 2. Summary Shear Modulus and Damping Ratios from Initially Adopted EPRI Curves

Depth 0-25 ft. (Terrace Sand)			Depth 25-40 ft. (Chesapeake Clay/Silt)			Depth 40-100 ft. (Ches. Cemented Sand)			Depth 100-285 ft. (Ches. Clay/Silt)			Depth 285-355 ft. (Nanjemoy Cemented Clay/Silt)		
Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear
Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1	1.4	1.E-04	1	1.5	1.E-04	1	1	1.E-04	1	2	1.E-04	1	1.5
3.E-04	1	1.5	3.E-04	1	1.5	3.E-04	1	1	3.E-04	1	2	3.E-04	1	1.5
1.E-03	0.98	1.8	1.E-03	1	1.6	1.E-03	1	1.2	1.E-03	1	2	1.E-03	1	1.6
3.E-03	0.914	2.8	3.E-03	0.97	2.05	3.E-03	0.97	1.64	3.E-03	0.995	2.13	3.E-03	0.97	2.05
1.E-02	0.75	5	1.E-02	0.878	3.21	1.E-02	0.87	2.8	1.E-02	0.955	2.75	1.E-02	0.878	3.21
3.E-02	0.509	9.3	3.E-02	0.685	5.77	3.E-02	0.68	5.49	3.E-02	0.832	4.38	3.E-02	0.685	5.77
1.E-01	0.27	15.3	1.E-01	0.413	10.64	1.E-01	0.43	10.2	1.E-01	0.59	8	1.E-01	0.413	10.64
3.E-01	0.116	21.9	3.E-01	0.208	16.22	3.E-01	0.22	16.5	3.E-01	0.34	13.16	3.E-01	0.208	16.22
1.E+00	0.04	27	6.E-01	0.115	18.65	1.E+00	0.09	22.9	6.E-01	0.22	16.15	6.E-01	0.115	18.65
3.E+00	0.02	30	1.E+00	0.075	19	3.E+00	0.05	27	1.E+00	0.15	17.56	1.E+00	0.075	19

Depth 355-456 ft. (Nanjemoy Sand)			Depth 456-471 ft. (Marlboro Clay)			Depth 471-631 ft. (Aquilar/Brightseat Sand)			Depth 631-1,731 ft. (Patapsco Sand)			Depth 1,731-2,531 ft. (Patuxent/Arundel Clay)		
Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear	Cyclic Shear		Cyclic Shear
Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)	Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1	0.7	1.E-04	1	1.5	1.E-04	1	0.6	1.E-04	1	0.55	1.E-04	1	1.5
3.E-04	1	0.8	3.E-04	1	1.5	3.E-04	1	0.6	3.E-04	1	0.55	3.E-04	1	1.5
1.E-03	1	0.8	1.E-03	1	1.6	1.E-03	1	0.6	1.E-03	1	0.55	1.E-03	1	1.6
3.E-03	0.988	1.12	3.E-03	0.97	2.05	3.E-03	0.99	0.81	3.E-03	1	0.77	3.E-03	0.97	2.05
1.E-02	0.93	1.8	1.E-02	0.878	3.21	1.E-02	0.95	1.2	1.E-02	0.96	1.15	1.E-02	0.878	3.21
3.E-02	0.791	3.53	3.E-02	0.685	5.77	3.E-02	0.852	2.5	3.E-02	0.88	2.1	3.E-02	0.685	5.77
1.E-01	0.57	7.1	1.E-01	0.413	10.64	1.E-01	0.65	5.3	1.E-01	0.71	4.2	1.E-01	0.413	10.64
3.E-01	0.321	12.78	3.E-01	0.208	16.22	3.E-01	0.41	10.27	3.E-01	0.47	8.45	3.E-01	0.208	16.22
1.E+00	0.15	19.3	6.E-01	0.115	18.65	1.E+00	0.2	16.7	1.E+00	0.265	14.5	6.E-01	0.115	18.65
3.E+00	0.09	23	1.E+00	0.075	19	3.E+00	0.1	20.1	3.E+00	0.16	17.4	1.E+00	0.075	19



Table 3. Summary of RCTS Laboratory Test Results (Appendix A Tests)

Resonant Column		Isotropic Confining Stress, $\sigma'_c = 8.6$ psi					
		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
6.00E-05	1.00	1.28	3.38E-04	1.00	1.59	3.26E-04	1.00
1.42E-04	1.00	1.36	8.87E-04	1.00	1.50	8.83E-04	1.00
3.49E-04	0.98	1.72	1.81E-03	1.00	1.67	1.82E-03	0.97
8.14E-04	0.96	2.13	3.54E-03	0.94	2.18	3.57E-03	0.91
1.91E-03	0.90	2.55	4.76E-03	0.91	2.51	4.78E-03	0.89
4.48E-03	0.80	3.05	1.07E-02	0.81	3.45	1.07E-02	0.79
1.05E-02	0.67	4.07	2.69E-02	0.65	7.89	2.60E-02	0.65
2.56E-02	0.53	5.74	---	---	---	---	---
6.21E-02	0.42	7.65	---	---	---	---	---
1.47E-01	0.33	10.43	---	---	---	---	---

Resonant Column		Isotropic Confining Stress, $\sigma'_c = 34.4$ psi					
		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
2.30E-05	1.00	1.04	8.41E-04	0.97	1.20	8.53E-04	0.95
5.60E-05	1.00	1.03	1.67E-03	0.94	1.13	1.67E-03	0.94
1.39E-04	0.99	1.21	3.47E-03	0.90	1.16	3.48E-03	0.90
3.27E-04	0.98	1.38	7.34E-03	0.85	2.00	7.33E-03	0.85
8.17E-04	0.96	1.78	---	---	---	---	---
1.94E-03	0.92	1.99	---	---	---	---	---
4.68E-03	0.84	2.33	---	---	---	---	---
1.13E-02	0.73	3.05	---	---	---	---	---
2.62E-02	0.61	3.87	---	---	---	---	---
4.20E-02	0.53	4.35	---	---	---	---	---

Test ID: Appendix A  
 Boring: B-437  
 Sample No.: UD6  
 Layer: Stratum I - Terrace Sand  
 Sample Depth = 14.9 ft  
 USCS Classification = SP-SM  
 Sample Description: poorly graded SAND with silt  
 Moisture Content = 3.0%  
 Total Unit Weight = 124.1 pcf  
 Specific Gravity = 2.66  
 LL = NP, PL = NP, PI = NP  
 Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{mean} = 8.6$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index  
 NP = Non-Plastic



Table 4. Summary of RCTS Laboratory Test Results (Appendix B Tests)

		Isotropic Confining Stress, $\sigma_0 = 12$ psi						
		Resonant Column			Torsional Shear (1 <sup>st</sup> Cycle)			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
9.80E-05	1.00	1.87	3.09E-04	1.00	1.90	3.13E-04	1.00	1.69
2.01E-04	1.00	1.86	6.03E-04	1.00	1.94	6.05E-04	1.00	2.14
4.96E-04	1.00	1.98	9.31E-04	1.00	2.09	9.60E-04	1.00	2.23
1.33E-03	0.99	2.17	1.89E-03	1.00	2.46	1.89E-03	1.00	2.34
3.18E-03	0.99	2.48	3.88E-03	0.99	2.93	3.92E-03	0.99	2.75
7.88E-03	0.95	3.11	9.62E-03	0.87	3.61	9.60E-03	0.88	3.48
1.85E-02	0.86	3.90	2.18E-02	0.77	4.92	2.23E-02	0.76	5.07
4.53E-02	0.71	5.86	6.48E-02	0.55	8.05	6.67E-02	0.55	8.00
1.20E-01	0.53	8.96	---	---	---	---	---	---

		Isotropic Confining Stress, $\sigma_0 = 48.1$ psi						
		Resonant Column			Torsional Shear (1 <sup>st</sup> Cycle)			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
1.30E-04	1.00	1.24	3.03E-04	1.00	1.58	3.16E-04	1.00	1.70
2.19E-04	1.00	1.24	8.78E-04	1.00	1.13	8.78E-04	1.00	1.47
3.95E-04	1.00	1.24	1.74E-03	1.00	1.48	1.75E-03	1.00	1.18
7.64E-04	1.00	1.24	3.54E-03	1.00	1.69	3.54E-03	1.00	1.91
1.50E-03	1.00	1.41	9.67E-03	0.92	2.69	9.65E-03	0.93	2.61
2.91E-03	0.99	1.56	2.14E-02	0.83	3.63	2.17E-02	0.83	3.67
5.67E-03	0.98	2.05	5.55E-02	0.64	6.04	5.72E-02	0.63	6.16
2.14E-02	0.93	2.87	---	---	---	---	---	---
3.97E-02	0.85	3.49	---	---	---	---	---	---
7.56E-02	0.74	4.18	---	---	---	---	---	---
1.58E-01	0.60	5.65	---	---	---	---	---	---
3.79E-01	0.46	7.73	---	---	---	---	---	---
8.81E-01	0.33	10.75	---	---	---	---	---	---

Test ID: Appendix B  
 Boring: B-301  
 Sample No.: UD10  
 Layer: Stratum Ila - Ches. Clay/Silt  
 Sample Depth = 35.4 ft  
 USCS Classification = CH  
 Sample Description: fat CLAY with sand  
 Moisture Content = 30.1%  
 Total Unit Weight = 117.5 pcf  
 Specific Gravity = 2.74  
 LL = 55, PL = 17, PI = 42  
 Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{\text{mean}} = 12$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index



Table 5. Summary of RCTS Laboratory Test Results (Appendix I Tests)

Resonant Column		Isotropic Confining Stress, $\sigma'_o = 23.6$ psi			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
2.35E-04	1.00	1.63	5.75E-04	1.00	1.03
4.26E-04	1.00	1.61	9.77E-04	1.00	1.03
8.80E-04	1.00	1.62	1.98E-03	1.00	1.17
1.79E-03	1.00	1.62	4.02E-03	1.00	1.63
3.53E-03	1.00	1.63	---	---	---
6.81E-03	0.98	1.68	---	---	---
1.27E-02	0.96	1.80	---	---	---
2.31E-02	0.91	1.95	---	---	---
4.19E-02	0.83	2.06	---	---	---
7.93E-02	0.71	2.66	---	---	---
1.69E-01	0.56	4.01	---	---	---
2.78E-01	0.49	6.48	---	---	---

Resonant Column		Isotropic Confining Stress, $\sigma'_o = 94.3$ psi			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
1.40E-04	1.00	1.28	1.00E-03	1.00	1.25
2.73E-04	1.00	1.27	1.98E-03	1.00	1.08
5.56E-04	1.00	1.29	4.02E-03	1.00	1.16
1.11E-03	1.00	1.29	1.00E-02	0.95	1.66
2.21E-03	1.00	1.29	---	---	---
4.40E-03	1.00	1.29	---	---	---
8.58E-03	1.00	1.33	---	---	---
1.63E-02	0.98	1.41	---	---	---
2.91E-02	0.94	1.53	---	---	---
5.04E-02	0.88	1.80	---	---	---
9.03E-02	0.78	2.59	---	---	---
1.75E-01	0.65	3.40	---	---	---
3.87E-01	0.50	5.18	---	---	---

Test ID: Appendix I  
 Boring: B-306  
 Sample No.: UD17  
 Layer: Stratum Ila - Ches. Clay/Silt  
 Sample Depth = 69.3 ft  
 USCS Classification = CH  
 Sample Description: fat CLAY, trace sand  
 Moisture Content = 31.2%  
 Total Unit Weight = 115.8 pcf  
 Specific Gravity = 2.73  
 LL = 62, PL = 24, PI = 38  
 Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{mean} = 23.6$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index



Table 6. Summary of RCTS Laboratory Test Results (Appendix C Tests)

Test ID: Appendix C		Isotropic Confining Stress, $\sigma_c = 20.7$ psi							
Resonant Column		Torsional Shear (1 <sup>st</sup> Cycle)		Torsional Shear (10 <sup>th</sup> Cycle)					
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
2.73E-04	1.00	5.00E-04	1.00	4.98E-04	1.00	1.51	4.98E-04	1.00	1.35
5.73E-04	1.00	9.81E-04	1.00	1.00E-03	1.00	1.34	1.00E-03	1.00	1.29
1.15E-03	1.00	1.99E-03	1.00	2.00E-03	1.00	1.61	2.00E-03	1.00	1.41
2.31E-03	1.00	4.09E-03	0.97	4.08E-03	0.98	1.53	4.08E-03	0.98	1.55
8.85E-03	0.98	9.66E-03	0.88	9.63E-03	0.89	2.26	9.63E-03	0.89	2.26
1.67E-02	0.94	2.14E-02	0.79	2.18E-02	0.79	3.60	2.18E-02	0.79	3.72
3.07E-02	0.88	5.52E-02	0.62	5.68E-02	0.60	5.65	5.68E-02	0.60	5.67
5.65E-02	0.80	---	---	---	---	---	---	---	---
1.10E-01	0.69	---	---	---	---	---	---	---	---
2.41E-01	0.54	---	---	---	---	---	---	---	---
6.32E-01	0.38	---	---	---	---	---	---	---	---

Resonant Column		Isotropic Confining Stress, $\sigma_c = 82.8$ psi							
Resonant Column		Torsional Shear (1 <sup>st</sup> Cycle)		Torsional Shear (10 <sup>th</sup> Cycle)					
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
6.65E-04	1.00	---	---	---	---	---	---	---	---
1.29E-03	1.00	---	---	---	---	---	---	---	---
2.44E-03	1.00	---	---	---	---	---	---	---	---
4.90E-03	0.99	---	---	---	---	---	---	---	---
9.52E-03	0.98	---	---	---	---	---	---	---	---
1.78E-02	0.95	---	---	---	---	---	---	---	---
3.19E-02	0.90	---	---	---	---	---	---	---	---
5.75E-02	0.82	---	---	---	---	---	---	---	---
1.05E-01	0.72	---	---	---	---	---	---	---	---
2.17E-01	0.57	---	---	---	---	---	---	---	---
5.90E-01	0.38	---	---	---	---	---	---	---	---

Sample Depth = 41 ft  
USCS Classification = SC  
Sample Description: clayey SAND with shells  
Moisture Content = 44.9%  
Total Unit Weight = 117.2 pcf  
Specific Gravity = 2.71  
LL = 72, PL = 22, PI = 50  
Estimated In-Situ  $K_0 = 0.5$   
Estimated In-Situ  $\sigma'_{mean} = 20.7$  psi

LL = Liquid Limit  
PL = Plastic Limit  
PI = Plasticity Index



Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3

Table 7. Summary of RCTS Laboratory Test Results (Appendix J Tests)

Isotropic Confining Stress, $\sigma'_0 = 11.8$ psi											
Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
1.33E-04	1.00	0.40	5.89E-04	1.00	0.41	5.81E-04	1.00	0.55	5.81E-04	1.00	0.55
2.67E-04	1.00	0.40	1.01E-03	1.00	0.42	1.01E-03	1.00	0.28	1.01E-03	1.00	0.28
5.23E-04	1.00	0.46	2.05E-03	1.00	0.68	2.07E-03	0.99	0.74	2.07E-03	0.99	0.74
1.05E-03	1.00	0.56	4.27E-03	0.96	1.01	4.31E-03	0.95	0.95	4.31E-03	0.95	0.95
1.93E-03	0.98	0.63	1.02E-02	0.86	1.97	1.02E-02	0.86	2.09	1.02E-02	0.86	2.09
3.50E-03	0.96	0.90	2.20E-02	0.80	3.08	2.21E-02	0.79	3.07	2.21E-02	0.79	3.07
6.25E-03	0.93	1.19	3.52E-02	0.75	4.21	3.51E-02	0.75	4.26	3.51E-02	0.75	4.26
1.06E-02	0.89	1.67	---	---	---	---	---	---	---	---	---
1.75E-02	0.83	2.16	---	---	---	---	---	---	---	---	---
2.86E-02	0.76	2.76	---	---	---	---	---	---	---	---	---
4.77E-02	0.68	3.60	---	---	---	---	---	---	---	---	---
8.01E-02	0.60	5.22	---	---	---	---	---	---	---	---	---

Isotropic Confining Stress, $\sigma'_0 = 47.2$ psi											
Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
6.40E-05	1.00	0.37	5.76E-04	1.00	0.33	5.80E-04	1.00	0.40	5.80E-04	1.00	0.40
1.28E-04	1.00	0.40	1.01E-03	1.00	0.27	1.03E-03	1.00	0.28	1.03E-03	1.00	0.28
2.53E-04	1.00	0.40	2.07E-03	0.98	0.26	2.07E-03	0.99	0.51	2.07E-03	0.99	0.51
4.97E-04	1.00	0.47	4.23E-03	0.96	0.89	4.26E-03	0.96	0.93	4.26E-03	0.96	0.93
1.01E-03	1.00	0.49	1.01E-02	0.92	1.29	1.01E-02	0.93	1.30	1.01E-02	0.93	1.30
1.92E-03	0.99	0.57	1.55E-02	0.90	1.61	1.55E-02	0.91	1.64	1.55E-02	0.91	1.64
3.50E-03	0.97	0.71	---	---	---	---	---	---	---	---	---
6.17E-03	0.95	1.01	---	---	---	---	---	---	---	---	---
1.10E-02	0.92	1.32	---	---	---	---	---	---	---	---	---
1.76E-02	0.89	1.69	---	---	---	---	---	---	---	---	---
2.86E-02	0.84	1.99	---	---	---	---	---	---	---	---	---
4.54E-02	0.78	2.44	---	---	---	---	---	---	---	---	---
7.25E-02	0.69	3.28	---	---	---	---	---	---	---	---	---
9.65E-02	0.64	4.46	---	---	---	---	---	---	---	---	---
1.17E-01	0.61	5.28	---	---	---	---	---	---	---	---	---

Test ID: Appendix J  
 Boring: B-409  
 Sample No.: UD15  
 Layer: Stratum Iib - Ches. Cem. Sand  
 Sample Depth = 36.1 ft  
 USCS Classification = SP-SM  
 Sample Description: poorly graded SAND with silt  
 Moisture Content = 21.5%  
 Total Unit Weight = 124.8 pcf  
 Specific Gravity = 2.66  
 LL = NP, PL = NP, PI = NP  
 Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{mean} = 11.8$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index  
 NP = Non-Plastic





Table 8. Summary of RCTS Laboratory Test Results (Appendix D Tests)

Resonant Column		Isotropic Confining Stress, $\sigma'_c = 21.9$ psi			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
3.41E-04	1.00	0.93	3.32E-04	1.00	1.05
6.94E-04	1.00	0.94	5.81E-04	1.00	1.28
1.37E-03	1.00	0.96	1.01E-03	1.00	0.77
2.63E-03	1.00	0.93	1.98E-03	1.00	1.07
4.94E-03	0.97	1.04	4.10E-03	1.00	1.59
9.13E-03	0.94	1.26	9.55E-03	0.92	2.23
1.67E-02	0.89	1.72	2.04E-02	0.86	3.52
3.06E-02	0.83	2.39	5.09E-02	0.69	6.25
5.61E-02	0.76	3.09	---	---	---
9.74E-02	0.67	4.35	---	---	---
1.73E-01	0.56	5.28	---	---	---
3.48E-01	0.44	6.48	---	---	---
5.34E-01	0.38	7.68	---	---	---

Resonant Column		Isotropic Confining Stress, $\sigma'_c = 87.6$ psi			
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
2.57E-04	1.00	0.74	9.36E-04	1.00	0.79
5.10E-04	1.00	0.66	1.93E-03	1.00	0.90
1.05E-03	1.00	0.78	3.80E-03	1.00	0.77
3.91E-03	0.98	0.71	9.97E-03	0.95	1.25
7.29E-03	0.96	0.81	2.08E-02	0.92	1.95
1.33E-02	0.93	0.89	3.88E-02	0.86	3.10
2.35E-02	0.90	1.17	---	---	---
4.13E-02	0.84	1.72	---	---	---
7.11E-02	0.76	2.32	---	---	---
1.21E-01	0.67	2.90	---	---	---
2.11E-01	0.57	3.65	---	---	---
3.67E-01	0.48	4.84	---	---	---

Test ID: Appendix D  
 Boring: B-404  
 Sample No.: UD14  
 Layer: Stratum IIb - Ches. Cem. Sand

Sample Depth = 53.2 ft  
 USCS Classification = SP-SM  
 Sample Description: poorly graded SAND with silt  
 Moisture Content = 28.3%  
 Total Unit Weight = 117.6 pcf  
 Specific Gravity = 2.66  
 LL = NP, PL = NP, PI = NP

Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{mean} = 21.9$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index  
 NP = Non-Plastic



**Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3**

**Table 9. Summary of RCTS Laboratory Test Results (Appendix K Tests)**

Test ID: Appendix K		Isotropic Confining Stress, $\sigma_0 = 30.3$ psi											
Boring: B-404		Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
Sample No.: UD22		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
Layer: Stratum IIC - Ches. Clay/Silt (sandy portion)		2.78E-04	1.00	1.27	3.37E-04	1.00	0.63	3.27E-04	1.00	0.79	6.49E-04	1.00	0.74
Sample Depth = 84 ft		5.04E-04	1.00	1.29	6.51E-04	1.00	0.72	6.49E-04	1.00	0.74	1.02E-03	1.00	0.80
USCS Classification = SM		9.88E-04	1.00	1.28	1.03E-03	1.00	0.85	1.02E-03	1.00	0.93	2.07E-03	1.00	1.45
Sample Description: Silty SAND		1.94E-03	1.00	1.31	2.07E-03	1.00	1.34	4.31E-03	0.95	2.26	1.03E-02	0.86	3.35
Moisture Content = 32.2%		3.71E-03	0.99	1.41	4.29E-03	0.97	2.28	1.03E-02	0.78	3.30	2.32E-02	0.77	4.55
Total Unit Weight = 115.4 pcf		7.17E-03	0.96	1.61	1.03E-02	0.87	3.30	5.43E-02	0.66	4.56	5.43E-02	0.66	4.55
Specific Gravity = 2.63		1.36E-02	0.91	1.94	2.29E-02	0.78	3.30	5.43E-02	0.66	4.56	5.43E-02	0.66	4.55
LL = 53, PL = 28, PI = 25		2.51E-02	0.85	2.43	5.38E-02	0.67	5.38	5.43E-02	0.66	4.56	5.43E-02	0.66	4.55
Estimated In-Situ $K_0 = 0.5$		4.66E-02	0.77	3.20	5.38E-02	0.67	5.38	5.43E-02	0.66	4.56	5.43E-02	0.66	4.55
Estimated In-Situ $\sigma'_{mean} = 30.3$ psi		9.07E-02	0.67	4.47	5.38E-02	0.67	5.38	5.43E-02	0.66	4.56	5.43E-02	0.66	4.55
		1.82E-01	0.57	5.38	5.38E-02	0.67	5.38	5.43E-02	0.66	4.56	5.43E-02	0.66	4.55
		Isotropic Confining Stress, $\sigma_0 = 121.1$ psi											
		Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
		1.14E-04	1.00	0.99	3.60E-04	1.00	0.52	3.67E-04	1.00	0.67	7.19E-04	1.00	0.60
		2.28E-04	1.00	0.99	7.24E-04	1.00	0.62	7.19E-04	1.00	0.60	1.02E-03	1.00	0.69
		4.52E-04	1.00	0.99	1.02E-03	1.00	0.63	1.02E-03	1.00	0.68	2.02E-03	1.00	1.06
		9.31E-04	1.00	0.99	2.00E-03	1.00	0.74	2.02E-03	1.00	1.06	4.05E-03	1.00	1.65
		3.64E-03	0.99	1.03	4.06E-03	0.94	1.65	1.03E-02	0.89	1.94	1.03E-02	0.95	2.14
		6.95E-03	0.97	1.22	1.03E-02	0.89	3.18	2.21E-02	0.89	3.18	2.21E-02	0.89	3.11
		1.28E-02	0.95	1.32	2.19E-02	0.82	3.18	4.26E-02	0.82	3.18	4.26E-02	0.82	3.11
		2.32E-02	0.90	1.62	4.25E-02	0.82	3.18	4.26E-02	0.82	3.18	4.26E-02	0.82	3.11
		4.14E-02	0.84	1.92	4.25E-02	0.82	3.18	4.26E-02	0.82	3.18	4.26E-02	0.82	3.11
		7.51E-02	0.77	2.64	4.25E-02	0.82	3.18	4.26E-02	0.82	3.18	4.26E-02	0.82	3.11
		1.39E-01	0.67	3.56	4.25E-02	0.82	3.18	4.26E-02	0.82	3.18	4.26E-02	0.82	3.11
		2.61E-01	0.57	5.24	4.25E-02	0.82	3.18	4.26E-02	0.82	3.18	4.26E-02	0.82	3.11

LL = Liquid Limit  
PL = Plastic Limit  
PI = Plasticity Index  
NP = Non-Plastic



Table 10. Summary of RCTS Laboratory Test Results (Appendix M Tests)

Test ID: Appendix M Boring: B-409 Sample No.: UD39 Layer: Stratum IIC - Ches. Clay/Silt (sandy portion)	Isotropic Confining Stress, $\sigma_0 = 28$ psi											
	Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	
Sample Depth = 96.1 ft	3.20E-04	1.00	1.19	--	1.77E-04	1.00	0.65	1.77E-04	1.00	0.65		
USCS Classification = SM	6.58E-04	1.00	1.19	--	3.39E-04	1.00	0.38	3.39E-04	1.00	0.38		
Sample Description: Silty SAND	1.30E-03	1.00	1.19	--	6.40E-04	1.00	0.48	6.40E-04	1.00	0.48		
Moisture Content = 33.1%	2.55E-03	1.00	1.18	--	1.02E-03	1.00	0.79	1.02E-03	1.00	0.79		
Total Unit Weight = 109.3 pcf	4.90E-03	1.00	1.23	--	2.06E-03	1.00	0.97	2.06E-03	1.00	0.97		
Specific Gravity = 2.64	9.32E-03	0.96	1.31	--	4.24E-03	1.00	1.13	4.24E-03	1.00	1.13		
LL = 61, PL = 42, PI = 19	1.72E-02	0.93	1.53	--	1.02E-02	0.95	2.01	1.02E-02	0.95	2.01		
Estimated In-Situ $K_0 = 0.5$	3.15E-02	0.87	2.11	--	---	---	---	---	---	---		
Estimated In-Situ $\sigma'_{mean} = 28$ psi	5.79E-02	0.79	2.68	--	---	---	---	---	---	---		
	1.09E-01	0.69	3.78	--	---	---	---	---	---	---		

Test ID: Appendix M Boring: B-409 Sample No.: UD39 Layer: Stratum IIC - Ches. Clay/Silt (sandy portion)	Isotropic Confining Stress, $\sigma_0 = 119.1$ psi											
	Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	
Sample Depth = 96.1 ft	1.59E-04	1.00	1.00	3.56E-04	1.00	0.53	3.56E-04	1.00	0.48			
USCS Classification = SM	3.09E-04	1.00	1.04	7.33E-04	1.00	0.62	7.33E-04	1.00	0.68			
Sample Description: Silty SAND	6.30E-04	1.00	1.04	1.01E-03	1.00	0.60	1.01E-03	1.00	0.66			
Moisture Content = 33.1%	1.25E-03	1.00	1.08	2.02E-03	1.00	0.66	2.03E-03	1.00	0.66			
Total Unit Weight = 109.3 pcf	2.47E-03	1.00	1.09	4.11E-03	0.98	0.85	4.10E-03	0.99	0.88			
Specific Gravity = 2.64	4.81E-03	0.99	1.09	8.42E-03	0.96	1.15	8.44E-03	0.96	1.12			
LL = 61, PL = 42, PI = 19	9.15E-03	0.97	1.14	---	---	---	---	---	---			
Estimated In-Situ $K_0 = 0.5$	1.69E-02	0.95	1.19	---	---	---	---	---	---			
Estimated In-Situ $\sigma'_{mean} = 28$ psi	3.06E-02	0.90	1.34	---	---	---	---	---	---			
	5.48E-02	0.84	1.85	---	---	---	---	---	---			
	9.97E-02	0.76	2.57	---	---	---	---	---	---			
	1.85E-01	0.67	3.72	---	---	---	---	---	---			
	3.50E-01	0.57	5.61	---	---	---	---	---	---			
	4.95E-01	0.52	6.55	---	---	---	---	---	---			

LL = Liquid Limit  
PL = Plastic Limit  
PI = Plasticity Index  
NP = Non-Plastic



Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3

Table 11. Summary of RCTS Laboratory Test Results (Appendix E Tests)

Test ID: Appendix E		Isotropic Confining Stress, $\sigma_0 = 46.6$ psi											
Boring: B-401		Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
Sample No.: UD31		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
Layer: Stratum Ilc - Ches. Clay/Silt		3.93E-04	1.00	1.24	5.40E-04	0.98	0.71	5.77E-04	1.00	0.80	1.12E-03	1.00	0.97
6.95E-04	1.00	1.21	1.09E-03	0.99	1.05	1.00	1.01	2.14E-03	1.00	0.89	4.37E-03	1.00	0.88
2.15E-03	1.00	1.31	4.33E-03	0.99	1.04	1.00	1.04	4.37E-03	1.00	0.88	4.37E-03	1.00	0.88
4.16E-03	1.00	1.35	---	---	---	---	---	---	---	---	---	---	---
9.87E-03	1.00	1.64	---	---	---	---	---	---	---	---	---	---	---
2.04E-02	0.98	1.91	---	---	---	---	---	---	---	---	---	---	---
3.91E-02	0.91	2.31	---	---	---	---	---	---	---	---	---	---	---
7.42E-02	0.82	2.99	---	---	---	---	---	---	---	---	---	---	---
1.54E-01	0.70	4.32	---	---	---	---	---	---	---	---	---	---	---
3.07E-01	0.58	5.67	---	---	---	---	---	---	---	---	---	---	---
4.91E-01	0.50	7.02	---	---	---	---	---	---	---	---	---	---	---

Test ID: Appendix E		Isotropic Confining Stress, $\sigma_0 = 186.3$ psi											
Boring: B-401		Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
Sample No.: UD31		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
Layer: Stratum Ilc - Ches. Clay/Silt		5.11E-04	1.00	1.17	3.38E-03	0.99	1.23	3.35E-03	1.00	1.30	6.74E-03	0.99	1.58
1.06E-03	1.00	1.18	6.72E-03	1.00	1.26	1.00	1.26	6.74E-03	0.99	1.58	1.01E-02	1.00	1.62
2.12E-03	1.00	1.16	1.01E-02	1.00	1.55	1.00	1.55	1.01E-02	1.00	1.62	2.17E-02	0.95	1.83
4.21E-03	1.00	1.16	2.16E-02	0.95	1.89	0.95	1.89	2.16E-02	0.95	1.83	---	---	---
8.30E-03	0.99	1.36	---	---	---	---	---	---	---	---	---	---	---
1.59E-02	0.97	1.55	---	---	---	---	---	---	---	---	---	---	---
2.90E-02	0.94	1.82	---	---	---	---	---	---	---	---	---	---	---
5.14E-02	0.89	2.25	---	---	---	---	---	---	---	---	---	---	---
9.11E-02	0.82	2.79	---	---	---	---	---	---	---	---	---	---	---
1.69E-01	0.73	3.43	---	---	---	---	---	---	---	---	---	---	---
3.45E-01	0.60	5.02	---	---	---	---	---	---	---	---	---	---	---
6.57E-01	0.49	6.25	---	---	---	---	---	---	---	---	---	---	---

Sample Depth = 140 ft  
USCS Classification = CH  
Sample Description: sandy fat CLAY  
Moisture Content = 41.1%  
Total Unit Weight = 104.7 pcf  
Specific Gravity = 2.63  
LL = 80, PL = 31, PI = 49  
Estimated In-Situ  $K_0 = 0.5$   
Estimated In-Situ  $\sigma_{\text{mean}} = 46.6$  psi

LL = Liquid Limit  
PL = Plastic Limit  
PI = Plasticity Index



Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3

Table 12. Summary of RCTS Laboratory Test Results (Appendix L Tests)

Peak Shear Strain (%)	Isotropic Confining Stress, $\sigma_o = 62.5$ psi							
	Resonant Column		Torsional Shear (1 <sup>st</sup> Cycle)		Torsional Shear (10 <sup>th</sup> Cycle)			
	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
2.56E-04	1.00	0.89	7.34E-04	1.00	0.77	7.31E-04	1.00	0.69
5.08E-04	1.00	0.89	1.03E-03	1.00	0.84	1.04E-03	1.00	0.80
1.09E-03	1.00	0.89	2.08E-03	1.00	0.84	2.08E-03	1.00	0.80
2.13E-03	1.00	0.89	4.19E-03	1.00	0.81	4.19E-03	1.00	0.85
4.16E-03	1.00	0.91	1.04E-02	1.00	1.09	1.03E-02	1.00	1.27
8.12E-03	0.99	0.93	---	---	---	---	---	---
1.53E-02	0.98	1.08	---	---	---	---	---	---
2.79E-02	0.94	1.15	---	---	---	---	---	---
5.01E-02	0.89	1.35	---	---	---	---	---	---
9.01E-02	0.81	1.86	---	---	---	---	---	---
1.66E-01	0.72	2.80	---	---	---	---	---	---
3.22E-01	0.61	3.97	---	---	---	---	---	---

Peak Shear Strain (%)	Isotropic Confining Stress, $\sigma_o = 250$ psi							
	Resonant Column		Torsional Shear (1 <sup>st</sup> Cycle)		Torsional Shear (10 <sup>th</sup> Cycle)			
	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
1.11E-04	1.00	0.78	3.67E-04	1.00	0.61	3.70E-04	1.00	0.54
2.25E-04	1.00	0.75	7.19E-04	1.00	0.64	7.20E-04	1.00	0.75
4.48E-04	1.00	0.76	1.03E-03	1.00	0.80	1.04E-03	1.00	0.78
9.23E-04	1.00	0.75	2.06E-03	1.00	0.77	2.06E-03	1.00	0.75
1.84E-03	1.00	0.74	4.16E-03	1.00	0.77	4.13E-03	1.00	0.68
3.63E-03	1.00	0.74	---	---	---	---	---	---
7.11E-03	0.99	0.79	---	---	---	---	---	---
1.36E-02	0.98	0.83	---	---	---	---	---	---
2.50E-02	0.96	0.91	---	---	---	---	---	---
4.82E-02	0.91	1.17	---	---	---	---	---	---
8.54E-02	0.85	1.54	---	---	---	---	---	---
1.52E-01	0.77	2.22	---	---	---	---	---	---
2.90E-01	0.66	3.50	---	---	---	---	---	---
4.21E-01	0.59	4.44	---	---	---	---	---	---

Test ID: Appendix L  
 Boring: B-401  
 Sample No.: UD42  
 Layer: Stratum IIc - Ches. Clay/Silt  
 Sample Depth = 200.3 ft  
 USCS Classification = SM  
 Sample Description: silty SAND  
 Moisture Content = 48.8%  
 Total Unit Weight = 101.2 pcf  
 Specific Gravity = 2.52  
 LL = 82, PL = 55, PI = 27  
 Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{mean} = 62.5$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index



**Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3**

**Table 13. Summary of RCTS Laboratory Test Results (Appendix G Tests)**

		Isotropic Confining Stress, $\sigma_o = 70.3$ psi												
		Resonant Column					Torsional Shear (1 <sup>st</sup> Cycle)					Torsional Shear (10 <sup>th</sup> Cycle)		
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
1.88E-04	1.00	0.98	1.03E-03	1.00	0.74	1.00E-03	1.00	0.74	1.00E-03	1.00	0.66	1.00E-03	1.00	0.66
3.83E-04	1.00	0.98	2.02E-03	1.00	0.67	2.04E-03	1.00	0.67	2.04E-03	1.00	0.65	2.04E-03	1.00	0.65
8.18E-04	1.00	0.95	4.11E-03	1.00	0.66	4.09E-03	1.00	0.66	4.09E-03	1.00	0.65	4.09E-03	1.00	0.65
1.62E-03	1.00	0.92	1.06E-02	0.96	1.04	1.07E-02	0.95	1.04	1.07E-02	0.95	1.02	1.07E-02	0.90	1.02
3.22E-03	1.00	0.92	2.25E-02	0.91	1.73	2.27E-02	0.90	1.73	2.27E-02	0.90	1.52	2.27E-02	0.90	1.52
6.24E-03	1.00	0.94	5.01E-02	0.82	2.70	5.05E-02	0.81	2.70	5.05E-02	0.81	2.66	5.05E-02	0.81	2.66
1.20E-02	0.98	0.96	---	---	---	---	---	---	---	---	---	---	---	---
2.19E-02	0.96	1.12	---	---	---	---	---	---	---	---	---	---	---	---
3.86E-02	0.92	1.31	---	---	---	---	---	---	---	---	---	---	---	---
6.82E-02	0.86	1.73	---	---	---	---	---	---	---	---	---	---	---	---
1.24E-01	0.77	2.32	---	---	---	---	---	---	---	---	---	---	---	---
2.34E-01	0.67	3.22	---	---	---	---	---	---	---	---	---	---	---	---
4.69E-01	0.55	5.08	---	---	---	---	---	---	---	---	---	---	---	---

		Isotropic Confining Stress, $\sigma_o = 281.3$ psi												
		Resonant Column					Torsional Shear (1 <sup>st</sup> Cycle)					Torsional Shear (10 <sup>th</sup> Cycle)		
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
1.31E-04	1.00	0.83	---	---	---	---	---	---	9.41E-04	1.00	0.62	1.85E-03	1.00	0.79
2.63E-04	1.00	0.83	---	---	---	---	---	---	3.76E-03	1.00	0.71	3.76E-03	1.00	0.71
5.21E-04	1.00	0.83	---	---	---	---	---	---	1.02E-02	0.99	1.03	1.02E-02	0.99	1.03
1.08E-03	1.00	0.83	3.72E-03	1.00	0.66	1.02E-02	0.99	0.97	2.10E-02	0.97	1.20	2.10E-02	0.97	1.20
2.15E-03	1.00	0.80	2.09E-02	0.96	1.22	2.09E-02	0.96	1.22	4.14E-02	0.93	1.76	4.14E-02	0.93	1.76
4.26E-03	1.00	0.81	4.14E-02	0.92	1.77	---	---	---	---	---	---	---	---	---
8.33E-03	0.99	0.82	---	---	---	---	---	---	---	---	---	---	---	---
1.59E-02	0.99	0.82	---	---	---	---	---	---	---	---	---	---	---	---
2.94E-02	0.97	0.96	---	---	---	---	---	---	---	---	---	---	---	---
5.27E-02	0.92	1.10	---	---	---	---	---	---	---	---	---	---	---	---
9.31E-02	0.86	1.41	---	---	---	---	---	---	---	---	---	---	---	---
1.67E-01	0.78	2.03	---	---	---	---	---	---	---	---	---	---	---	---
3.15E-01	0.68	3.09	---	---	---	---	---	---	---	---	---	---	---	---
6.23E-01	0.55	4.70	---	---	---	---	---	---	---	---	---	---	---	---

Test ID: Appendix G  
 Boring: B-401  
 Sample No.: UD48  
 Layer: Stratum IIC - Ches. Clay/Silt  
 Sample Depth = 229 ft  
 USCS Classification = MH  
 Sample Description: elastic SILT with sand  
 Moisture Content = 65.2%  
 Total Unit Weight = 98.2 pcf  
 Specific Gravity = 2.48  
 LL = 139, PL = 88, PI = 51  
 Estimated In-Situ  $K_0 = 0.5$   
 Estimated In-Situ  $\sigma'_{mean} = 70.3$  psi

LL = Liquid Limit  
 PL = Plastic Limit  
 PI = Plasticity Index



Table 14. Summary of RCTS Laboratory Test Results (Appendix F Tests)

Test ID: Appendix F		Isotropic Confining Stress, $\sigma_0 = 113.9$ psi											
Boring: B-401		Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
Sample No.: UD67		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
Layer: Stratum III - Nanjemoy Sand		4.00E-05	1.00	2.98	6.31E-04	1.00	0.79	6.36E-04	1.00	0.98	6.36E-04	1.00	0.98
Sample Depth = 349 ft		8.00E-05	1.00	3.01	1.07E-03	1.00	0.52	1.06E-03	1.00	1.00	1.06E-03	1.00	1.00
USCS Classification =SM		1.58E-04	1.00	3.07	2.15E-03	1.00	0.82	2.19E-03	1.00	0.72	2.19E-03	1.00	0.72
Sample Description: silty SAND		3.15E-04	1.00	3.11	4.34E-03	0.99	1.20	4.34E-03	0.98	0.75	4.34E-03	0.98	0.75
Moisture Content = 53.6%		6.52E-04	1.00	3.27	1.05E-02	0.93	1.83	1.04E-02	0.94	1.80	1.04E-02	0.94	1.80
Total Unit Weight = 116.4 pcf		1.31E-03	0.99	3.38	2.22E-02	0.88	2.49	2.24E-02	0.87	2.50	2.24E-02	0.87	2.50
Specific Gravity = 2.78		2.59E-03	0.99	3.60	3.92E-02	0.81	3.31	3.91E-02	0.81	3.24	3.91E-02	0.81	3.24
LL = 52, PL = 39, PI = 13		5.09E-03	0.97	3.81	---	---	---	---	---	---	---	---	---
Estimated In-Situ $K_0 = 0.5$		9.84E-03	0.94	4.03	---	---	---	---	---	---	---	---	---
Estimated In-Situ $\sigma'_{\text{mean}} = 113.9$ psi		1.87E-02	0.89	4.55	---	---	---	---	---	---	---	---	---
LL = Liquid Limit		3.59E-02	0.81	5.01	---	---	---	---	---	---	---	---	---
PL = Plastic Limit		7.02E-02	0.71	5.99	---	---	---	---	---	---	---	---	---
PI = Plasticity Index		1.42E-01	0.60	7.70	---	---	---	---	---	---	---	---	---
		Isotropic Confining Stress, $\sigma_0 = 455.6$ psi											
		Resonant Column				Torsional Shear (1 <sup>st</sup> Cycle)				Torsional Shear (10 <sup>th</sup> Cycle)			
		Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)
Measurements for 455.6 psi tests were likely adversely affected by high straining during tests at 113.9 psi, therefore, discarded.		---	---	---	---	---	---	---	---	---	---	---	---



Table 15. Summary of RCTS Laboratory Test Results (Appendix H Tests)

	Isotropic Confining Stresses, $\sigma_3 = 120.4$ psi									
	Resonant Column			Torsional Shear (1 <sup>st</sup> Cycle)			Torsional Shear (10 <sup>th</sup> Cycle)			
	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	
Test ID: Appendix H	1.08E-04	1.00	2.78	4.95E-04	1.00	1.42	4.97E-04	0.99	1.16	
Borings: B-301 & B-401	2.15E-04	1.00	2.78	9.93E-04	1.00	1.37	9.72E-04	1.00	0.94	
Sample No.: Composite	4.28E-04	1.00	2.88	1.98E-03	1.00	1.11	1.95E-03	0.99	1.05	
Layer: Stratum III - Nanjemoy Sand	8.78E-04	1.00	2.94	3.99E-03	0.99	1.59	4.03E-03	0.96	1.69	
Sample Depth = 359-385 ft	1.75E-03	0.99	2.96	1.01E-02	0.93	2.16	1.01E-02	0.91	2.04	
USCS Classification = SM	3.45E-03	0.97	3.33	2.17E-02	0.87	3.03	2.19E-02	0.84	2.99	
Sample Description: silty SAND	6.70E-03	0.94	3.96	---	---	---	---	---	---	
Moisture Content = 19.2%	1.17E-02	0.89	4.47	---	---	---	---	---	---	
Total Unit Weight = 116.4 pcf	2.51E-02	0.78	5.74	---	---	---	---	---	---	
Specific Gravity = 2.86	5.10E-02	0.65	6.86	---	---	---	---	---	---	
LL = 40, PL = 36, PI = 4	1.04E-01	0.55	8.19	---	---	---	---	---	---	
Estimated In-Situ $K_0 = 0.5$										
Estimated In-Situ $\sigma'_{\text{mean}} = 120.4$ psi										
LL = Liquid Limit										
PL = Plastic Limit										
PI = Plasticity Index										
Isotropic Confining Stresses, $\sigma_3 = 455.0$ psi										
Resonant Column			Torsional Shear (1 <sup>st</sup> Cycle)			Torsional Shear (10 <sup>th</sup> Cycle)				
Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)	Peak Shear Strain (%)	Shear Modulus (G/G <sub>max</sub> )	Damping Ratio (%)		
---	---	---	---	---	---	---	---	---	---	

Measurements for 455.0 psi tests were likely adversely affected by high straining during tests at 120.4 psi, therefore, discarded.





**Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3**

Table 16. Summary Average Shear Modulus and Damping Ratios Values from RCTS Results

<b>Stratum I-Terrace Sand (Depth 0-25 ft)</b>		
Cyclic Shear		
Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1	1.4
3.E-04	1	1.5
1.E-03	0.98	1.8
3.E-03	0.915	2.3
1.E-02	0.76	3.8
3.E-02	0.56	6.5
1.E-01	0.34	10.5
3.E-01	0.2	14.8
1.E+00	0.1	

<b>Stratum IIc-Chesapeake Clay/Silt (Depth 135-285 ft)</b>		
Cyclic Shear		
Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1.0	1.1
3.E-04	1.0	1.1
1.E-03	1.0	1.1
3.E-03	1.0	1.13
1.E-02	0.99	1.2
3.E-02	0.94	1.5
1.E-01	0.80	2.4
3.E-01	0.63	4.1
6.E-01	0.50	5.8
1.E+00	0.40	7.4

<b>Strata IIa, IIb, and III (Chesapeake &amp; Nanjemoy Soils)</b>		
Cyclic Shear		
Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1.0	1.3
3.E-04	1.0	1.3
1.E-03	1.0	1.4
3.E-03	0.99	1.6
1.E-02	0.94	2.2
3.E-02	0.82	3.2
1.E-01	0.62	5.4
3.E-01	0.42	8.4
6.E-01	0.31	10.6
1.E+00	0.25	12.6



**Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3**

Table 17. Final Shear Modulus and Damping Ratios for the CCNPP Unit 3 Soils

<b>Stratum I-Terrace Sand (Depth 0-25 ft, El. +85 to +60 ft)</b>		
Cyclic Shear		
Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1	1.4
3.E-04	1	1.5
1.E-03	0.98	1.8
3.E-03	0.915	2.3
1.E-02	0.76	3.8
3.E-02	0.56	6.5
1.E-01	0.34	10.5
3.E-01	0.2	14.8
1.E+00	0.1	

<b>Stratum IIc-Chesapeake Clay/Silt (Depth 135-285 ft, El. -50 to -200 ft)</b>		
Cyclic Shear		
Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1.0	1.1
3.E-04	1.0	1.1
1.E-03	1.0	1.1
3.E-03	1.0	1.13
1.E-02	0.99	1.2
3.E-02	0.94	1.5
1.E-01	0.80	2.4
3.E-01	0.63	4.1
6.E-01	0.50	5.8
1.E+00	0.40	7.4


<b>All Other Natural Soils</b>		
Cyclic Shear		
Strain (%)	G/G <sub>max</sub>	D (%)
1.E-04	1.0	1.3
3.E-04	1.0	1.3
1.E-03	1.0	1.4
3.E-03	0.99	1.6
1.E-02	0.94	2.2
3.E-02	0.82	3.2
1.E-01	0.62	5.4
3.E-01	0.42	8.4
6.E-01	0.31	10.6
1.E+00	0.25	12.6

Note: Depth=0 ft (El. 85 ft) is finished grade.



Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3

Figure 1. RCTS Test Locations



LEGEND:



- RCTS SAMPLE

FIGURE 1:  
RCTS TEST LOCATIONS  
CCNPP UNIT 3



# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 2. Shear Modulus and Damping Ratios from Initially Adopted EPRI Curves





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 3. RCTS Test Results: Stratum I-Terrace Sand (Appendix A Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 4. RCTS Test Results: Stratum Ila-Chesapeake Clay/Silt (Appendix B Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 5. RCTS Test Results: Stratum IIa-Chesapeake Clay/Silt (Appendix I Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3

Figure 6. RCTS Test Results: Stratum IIb-Chesapeake Cemented Sand (Appendix C Tests)









# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 7. RCTS Test Results: Stratum IIb-Chesapeake Cemented Sand (Appendix J Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 8. RCTS Test Results: Stratum IIb-Chesapeake Cemented Sand (Appendix D Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 9. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix K Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 10. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix M Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 11. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix E Tests)





**Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3**



Figure 12. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix L Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 13. RCTS Test Results: Stratum IIc-Chesapeake Clay/Silt (Appendix G Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3

Figure 14. RCTS Test Results: Stratum III-Nanjemoy Sand (Appendix F Tests)









# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 15. RCTS Test Results: Stratum III-Nanjemoy Sand (Appendix H Tests)





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 16. Difference Between RCTS and EPRI Curves:  $G/G_{max}$  and Damping





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 17. Difference Between RCTS and EPRI Curves:  $G/G_{max}$  and Damping at  $1E-2 \pm \%$  Strain





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3



Figure 18. Combined RCTS Test Results





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 19. Average Shear Modulus and Damping Ratio Curves from RCTS Test Results





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 20. Comparison of Average RCTS Test Results and Initially Adopted EPRI Curves





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 21. Selection of Shear Modulus and Damping Ratios for Soils Deeper than 400 Feet





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3

Figure 22. Calculated Maximum Strains Based on Initially Adopted EPRI Curves





Note: Strains shown are maximum, not effective, values.





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3


Figure 23. Final Shear Modulus and Damping Ratios for the CCNPP Unit 3 Soils





# Reconciliation of EPRI and RCTS Results Calvert Cliffs Nuclear Power Plant Unit 3

Figure 24. Comparison of Amplification Factors at 1E-4 LF for the CCNPP Unit 3 Soils





Reconciliation of EPRI and RCTS Results  
Calvert Cliffs Nuclear Power Plant Unit 3

Figure 25. Comparison of Amplification Factors at 1E-4 HF for the CCNPP Unit 3 Soils

