

PMSTPCOL PEmails

From: Muniz, Adrian
Sent: Friday, August 14, 2009 9:55 AM
To: jwcook@stpegs.com
Cc: STPCOL
Subject: Draft RAI 2636
Attachments: Draft RAI 2636.doc

James:

I have attached to this electronic communication a draft request for additional information (RAI) for Section 7.9S of the STP COLA. If you need a conference call to clarify the requested information, please contact me. If a conference call is not needed, please send me an email and I will continue the formal process of issuing the RAI to STPNOC.

Thanks,

Adrian Muñiz, USNRC
Chapter 7 PM

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1631

Mail Envelope Properties (3DF2506A7257014AAC5857E5E852DEAC075AEB2E12)

Subject: Draft RAI 2636
Sent Date: 8/14/2009 9:55:09 AM
Received Date: 8/14/2009 9:55:11 AM
From: Muniz, Adrian

Created By: Adrian.Muniz@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"jwcook@stpegs.com" <jwcook@stpegs.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	431	8/14/2009 9:55:11 AM
Draft RAI 2636.doc	27642	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft Request for Additional Information No. 2636 Revision 02

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 07.09 - Data Communication Systems
Application Section: 7.9S

QUESTIONS for Instrumentation, Controls and Electrical Engineering 2 (ESBWR/ABWR Projects)
(ICE2)

07.09-***

COLA FSAR Tier 1 Section 2.7.5 states that data cannot be transmitted from the non-safety-related side to safety-related equipment. However, COLA FSAR Tier 2 Section 7.9S.2.2 allows the manual data transmission from the non-safety related PICS to the safety-related NMS. Provide sufficient information on how the manual operation does not adversely impact the safety-related NMS.