

PMSTPCOL PEmails

From: Tai, Tom
Sent: Monday, August 17, 2009 1:51 PM
To: Agles, James
Cc: STPCOL; Mookhoek, William
Subject: STP Draft RAI 3085 for Chapter 10.2.3
Attachments: RAI 3085 10.02.03-xx.doc

Jim,

Attached for your use is an advanced copy of RAI 3085 for Chapter 10.2.3. Please let me know if you need a conference call on or before August 24. The RAI will be formally issued to STP if I do not receive any response by then.

Regards

Tom Tai
DNRL/NRO
(301) 415-8484
Tom.Tai@NRC.GOV

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1637

Mail Envelope Properties (C56E360E9D804F4B95BC673F886381E71FBDEDE9B1)

Subject: STP Draft RAI 3085 for Chapter 10.2.3
Sent Date: 8/17/2009 1:51:24 PM
Received Date: 8/17/2009 1:51:26 PM
From: Tai, Tom

Created By: Tom.Tai@nrc.gov

Recipients:

"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Mookhoek, William" <wemookhoek@STPEGS.COM>
Tracking Status: None
"Agles, James" <jaagles@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	330	8/17/2009 1:51:26 PM
RAI 3085 10.02.03-xx.doc		28666

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 3085 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 10.02.03 - Turbine Rotor Integrity
Application Section: 10.2

QUESTIONS for Component Integrity, Performance, and Testing Branch 2 (ESBWR/ABWR Projects)
(CIB2)

10.02.03-***

Please modify FSAR Section 10.2.5.1 and Commitment 10.2-1 to state that the as-built material property data will be provided in the FSAR update after procurement and prior to initial fuel load.