



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
612 EAST LAMAR BLVD, SUITE 400
ARLINGTON, TEXAS 76011-4125

August 24, 2009

Mr. John T. Conway
Senior Vice President-Energy Supply
& Chief Nuclear Officer
Pacific Gas and Electric Company
P.O. Box 3
Mail Code 104/6/601
Avila Beach, California 93424

SUBJECT: ERRATA TO NRC INSPECTION REPORT 050-00133/09-002

Dear Mr. Conway:

Please insert the enclosed Page 10 from the Report Details section into NRC Inspection Report 050-00133/09-002, ML092230614, dated August 11, 2009. The enclosed page was inadvertently omitted during report copying.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's document system (ADAMS), accessible from the NRC's Web site at <http://www.nrc.gov/reading-rm/adams.html>.

Should you have any questions concerning this letter, please contact Mr. Robert Evans, Senior Health Physicist, at (817) 860-8234 or the undersigned at (817) 860-8197.

Sincerely,

A handwritten signature in black ink, appearing to read "Jack E. Whitten".

for Jack E. Whitten, Chief
Nuclear Materials Safety Branch B

Docket No.: 050-00133
License No.: DPR-7

Enclosure:
Page 10 to NRC Inspection Report 050-00133/09-002

cc w/enclosure:
James Becker, Site Vice President
and Station Director
Pacific Gas and Electric Company
Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

Jennifer L. Post, Esq.
PG&E
P.O. Box 7442
San Francisco, CA 94120

Paul Roller, Director and Plant Manager
Humboldt Bay Power Plant, PG&E
1000 King Salmon Avenue
Eureka, CA 95505

Chairman
Humboldt County Board of Supervisors
County Courthouse
825 Fifth Street
Eureka, CA 95501

Law Office of Linda J. Brown, Esq.
300 Drake's Landing Road, Suite 172
Greenbrae, CA 94904

Regional Radiation Representative
U. S. Environmental Protection Agency
Region IX Office
75 Hawthorne Street
San Francisco, CA 94105

Dr. Richard Ferguson, Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, CA 95814

Dr. James F. Davis, State Geologist
Department of Conservation
Division of Mines & Geology
801 K Street MS 12-30
Sacramento, CA 95814-3531

Director, Radiologic Health Branch
State Department of Health Services
P.O. Box 997414 (MS 7610)
Sacramento, CA 95899-7414

Director
Energy Facilities Siting Division
Energy Resources Conservation &
Development Commission
1516 9th Street
Sacramento, CA 95814

Gretchen Dumas, Esq.
Public Utilities Commission
of the State of California
5066 State Building
San Francisco, CA 94102

Redwood Alliance
P.O. Box 293
Arcata, CA 95521

James D. Boyd, Commissioner
California Energy Commission
1516 Ninth Street (MS 34)
Sacramento, CA 95814

air monitors that monitor for alpha contamination in addition to beta-gamma contamination. Further, the licensee plans to install an alpha detecting monitor in the plant ventilation stack. This monitor was expected to be installed during September 2009, prior to start of decommissioning work involving alpha contamination.

4.3 Conclusions

The licensee implemented an occupational exposure program that effectively monitored the internal and external doses to radiation. No individual exceeded the regulatory limit for total effective dose equivalent exposures during calendar year 2008. During 2009, the licensee began implementing a program for control of worker exposures to alpha particulate contamination. This program supports the concept of ALARA and should help control worker exposures to licensed material.

5 Radioactive Waste Treatment, and Effluent and Environmental Monitoring

5.1 Inspection Scope

The inspector reviewed the licensee's program to control, monitor, and quantify releases of radioactive materials to the environment in liquid, gaseous, and particulate forms.

5.2 Observations and Findings

The inspector reviewed the Annual Radioactive Effluent Release Report for 2008 dated March 26, 2009, and the Annual Radiological Environmental Monitoring Report for 2008 dated April 30, 2009. The inspector compared the results presented in these reports to the requirements provided in site procedures and the Offsite Dose Calculation Manual. In summary, all required samples had been collected, and no sample result exceeded a licensed or regulatory limit. No adverse trends were apparent. The inspector identified several report errors, and the licensee agreed to update the reports during the next routine submittals.

The inspector compared the effluent and environmental monitoring results to the public dose limits specified in 10 CFR 20.1301. In summary, the records indicate that the public dose limits were not exceeded. The licensee's results suggest a maximum public dose of less than one millirem for 2008 with an annual regulatory limit of 100 millirems.

5.3 Conclusions

The effluent and environment monitoring programs were in compliance with license requirements. All required samples had been collected, no sample result exceeded applicable limits, and no adverse trends were identified. Annual doses to the public were well below the regulatory limit.

6 Solid Radioactive Waste Management and Transportation of Radioactive Materials (86750)

6.1 Inspection Scope

The inspector reviewed the licensee's plans for characterizing and shipping the radioactive wastes that will be generated during decommissioning.

bcc w/enclosure:

- A. Howell, D:DNMS
- C. Cain, DD:DNMS
- J. Whitten, C:DNMS/NMSB-B
- S. Williams, OEDO RIV Coordinator
- J. Weil, Congressional Affairs Officer
- J. Hickman, FSME/DWMEP/DURLD/RDB
- R. Evans, NMSB-B
- Fee Coordinator, DRMA

DRAFT: S:\DNMS\NMSB-B\RJE\HB 050-00133/09-002 errata.doc

FINAL: R:_DNMS_HB\2009\HB 050-00133-09/002 errata.doc

ML0xxxxxxx

ADAMS	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	<input checked="" type="checkbox"/> SUNSI Rev Complete	Reviewer Initials:	RJE
Publicly Avail.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Sensitive Value:		
RIV:DNMS:NMSB-B	C:NMSB-B			
RJEvans	JEWhitten			
<i>RJEvans</i>	<i>RJE for J. Whitten</i>			
08/19/09	08/19/09 8/24/09			

OFFICIAL RECORD COPY T=Telephone E=E-mail F=Fax

ADAM
 Template _____