

NRCREP Resource

6/02/09
74 FR 2644D

From: Miroslav Trubelja [mtrubelja@structint.com]
Sent: Wednesday, August 12, 2009 4:48 PM
To: NRCREP Resource
Subject: Response from "Comment on NRC Documents"

15

RECEIVED

AUG 13 PM 1:05

RULES AND DIRECTIVES
PART 1
2009

Below is the result of your feedback form. It was submitted by

Miroslav Trubelja (mtrubelja@structint.com) on Wednesday, August 12, 2009 at 16:48:06

Document_Title: DG-1193 ASME Code Cases Not Approved for USE
(ML090900461) 06/2009

Comments: As identified in the FRN there were several lessons learned from USNRC approved pilot plant application as well as a number of follow-on applications. Four units to date have been approved which include both BWR and PWRs. These lessons learned consisted of the items listed below which can easily be incorporated in Reg. Guide 1.147 thereby allowing plants to use this code case in the short term. Acceptance of N716 into Reg. Guide 1.147, with the comments below, will not only result in a substantial reduction in worker exposure and radwaste, but will also reduced unnecessary NRC staff burden, as compared to waiting until the code case is revised by ASME and subjected to review by NRC during subsequent revision of Reg. Guide 1.147, which at times can take multiple numbers of years to be issued.

Technical Changes

Section 2.0 General Requirements and in particular Section 2(a)(5) should include the following requirement "any piping segment whose contribution to large early release frequency is greater than 1E-07 be classified as high safety significant"

Section 4.0 Inservice Inspection Requirements and in particular Section 4(c), the following sentence should be added: If this cannot be accomplished due to a limited number of available welds between the first isolation valve and the RPV, then 25% of the available piping welds between the RPV and the first isolation valve shall be selected, not to exceed ten percent of the RCPB.

Table 1, Footnote 10 should be revised to read as follows: To be conducted during a system pressure test or a pressure test specific to that element or segment, in accordance with Examination Categories B-P, C-H or D-B as applicable.

organization: Structural Integrity Associates, Inc.

address1: 5215 Hellyer Avenue

address2: Suite 210

city: San Jose

state: CA

zip: 95138

country: USA

phone: (408) 978-8200

SONSI Review Complete
Template = ADH-013

F-RDS = ADH-03
Add = m. Byssie (mumbi)
W. Marie (WEN)
