

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261
August 24, 2009

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 09-266A
NAPS/JHL R2
Docket No. 50-338
License No. NPF-4

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
NORTH ANNA POWER STATION UNIT 1
WITHDRAWAL OF RELIEF REQUEST NDE-004
FOR THE FOURTH INTERVAL ISI PROGRAM

In a letter dated October 17, 2008 (Serial No. 08-0595), Dominion submitted the North Anna Power Station Unit 1 inservice inspection (ISI) program for the fourth inservice inspection (ISI) interval applicable to Class 1, 2 and 3 components and component supports. The ISI Plan described the programmatic aspects of the ISI examinations of components and component supports. Included with the program were requests for alternatives or relief from the specific code requirements in accordance with 10 CFR 50.55a(a)(3)(i) and/or (ii) or 10 CFR 50.55a(g)(5)(iii).

In an April 8, 2009 phone call, the NRC staff requested additional information to complete their review of Relief Request NDE-004. NDE-004 requested relief to allow Service Water System through-wall leaks to be repaired during the next scheduled Service Water header outage. Scheduling the repair was not to exceed 18 months, and not limited by the schedule for the next refueling outage. Dominion letter dated May 4, 2009 (Serial No. 09-266) provided Revision 1 to Relief Request NDE-004, which included the additional information. In an August 4, 2009 phone call, the NRC staff expressed a modified position regarding the application of a blanket relief request to address Service Water System through-wall leaks for the fourth interval. The staff now indicated that relief for the repair of Service Water System through-wall leaks will be evaluated by the NRC on a case by case basis. Therefore, Dominion is withdrawing Revision 1 to Relief Request NDE-004 at this time.

If you have any questions or require additional information, please contact Mr. Thomas Shaub at (804) 273-2763.

Sincerely,



Leslie N. Hartz
Vice President – Nuclear Support Services

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region II
Regional Administrator
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

Mr. J. E. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center
4201 Dominion Blvd.
Suite 300
Glen Allen, Virginia 23060

NRC Senior Resident Inspector
North Anna Power Station

Dr. V. Sreenivas
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 8 G9A
11555 Rockville Pike
Rockville, Maryland 20852

Ms. K. R. Cotton
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
Mail Stop 16 E15
11555 Rockville Pike
Rockville, Maryland 20852