

**“NRC Containment Audit –  
Hydrodynamic Loads – Pool Swell  
STP 3&4 COLA”**

**August 2009**

---

Westinghouse Electric Company LLC  
P.O. Box 355  
Pittsburgh, PA 15230-0355

©2009 Westinghouse Electric Company LLC  
All Rights Reserved

---

Westinghouse Non-Proprietary Class 3

---

# **NRC Containment Audit Hydrodynamic Loads – Pool Swell STP 3&4 COLA**

**Tom George  
Hirohide Oikawa**

**Numerical Applications, Inc.  
Toshiba**

**August 18, 2009**

Westinghouse Electric Company  
P.O. Box 355  
Pittsburgh, PA 15230-0355

©2009 Westinghouse Electric Company LLC  
All Rights Reserved



# Introduction

---

## Agenda

- Introduction
- Attendees
- Desired Outcomes
- GOTHIC vs. DCD Model - Comparison
- Pool Swell Test Data
- Comparison with Test Data and DCD Results
- ABWR Analysis and Sensitivity Studies
- Pool Swell Load Application
- Topical Report
- Response to Informal Questions



# Introduction

---

## STP Team Attendees

- |                   |              |
|-------------------|--------------|
| • Scott Head      | STPNOC       |
| • Jim Tomkins     | STPNOC       |
| • Aaron Heinrich  | STPNOC       |
| • Brad Maurer     | Westinghouse |
| • Nirmal Jain     | Westinghouse |
| • Rick Ofstun     | Westinghouse |
| • Jason Douglass  | Westinghouse |
| • Tom George      | NAI          |
| • Hirohide Oikawa | Toshiba      |
| • Koichi Kondo    | TANE         |





# Introduction

---

## Desired Outcomes

- Provide better understanding of related test (PSTF)
- Provide an update of comparisons with tests and DCD, and ABWR analysis
- Address the items raised by NRC at July 7 P/T Audit
  - Drawing showing equipment in wetwell airspace
  - Methodology for calculating equipment loads
  - Uncertainty in pool swell results
  - Table comparing Input differences for P/T and Pool Swell
- Provide information on the load application procedure and the scope content of the pool swell topical report
- Receive feedback from NRC




# Analysis Approach

---

- Develop GOTHIC modeling approach for conservative estimates of
  - Maximum swell height
  - Maximum pool velocity
  - Peak gas space pressure during swell
  - Peak bubble pressure during swell
- Results comparison with
  - PSTF 1/3 Scale Test
  - ABWR DCD
  - NEDO-33372
- Results for ABWR design
- Application of Pool Swell Results for Structural Loads Analysis



# ABWR Containment




August 18, 2009

Westinghouse Non-Proprietary Class 3



Westinghouse

# ABWR Wetwell Geometry



August 18, 2009


Westinghouse Non-Proprietary Class 3



Westinghouse



# Approach Comparison



August 18, 2009

# Approach Comparison

	<b>DCD</b>	<b>ABWR/GOTHIC</b>
<b>Initial water in vertical and horizontal vent pipes</b>	Ignored	Included. Vent clearing modeled.
<b>Vent location</b>	Gas injected at elevation of top of top vent	Gas injected at actual elevation of top vent
<b>Vent area</b>	Sequential addition of vents	All vents located at the top vent
<b>Injection Pressure</b>	Drywell pressure transient	Drywell pressure transient



# Approach Comparison

---

	DCD	ABWR/GOTHIC
Injection Composition	100% N <sub>2</sub> – perfect gas	100% N <sub>2</sub> – perfect gas
Injection Temperature	T <sub>Drywell</sub> from isentropic compression	GOTHIC calculated DW temperature transient
Vent Path Pressure Loss	Friction	Ignored
Vent Choking	Unclear	Included



# Approach Comparison

---

	<b>DCD</b>	<b>ABWR/GOTHIC</b>
<b>Gas Temperature in Bubble</b>	Drywell temperature	Near pool temperature
<b>Pool swell drag</b>	Ignored	Ignored
<b>Gas Temperature above Pool – Maximum Swell</b>	Polytropic compression - $PV^k = \text{const}$ ( $k=1.2$ )	Near isothermal compression
<b>Gas Temperature above Pool – Maximum Pressure</b>	Isentropic compression - $PV^k = \text{const}$ ( $k=1.4$ )	Near isentropic compression







# Approach Comparison

---

	DCD	ABWR/GOTHIC
Pool swell region	80% of wetwell	80% of wetwell (a,c)
Rising water slug	Constant thickness	
Conservative multiplier on maximum swell velocity	1.1	1.1



# GOTHIC Pool Surface Detection





August 18, 2009

Westinghouse Non-Proprietary Class 3



Westinghouse

# Pool Surface Velocity



$$Z = a_0 + a_1 t + a_2 t^2 + a_3 t^3$$

$$u = \frac{dZ}{dt}$$

August 18, 2009

Westinghouse Non-Proprietary Class 3



NRC Containment Audit for STP 3&4 COLA

## **Pool Swell Test Data**

August 18, 2009

- Pressure suppression test facility (PSTF) description
- Test matrix
- Test case used for GOTHIC benchmark



## ■ Pressure suppression test facility (PSTF)

- Confirmatory test by GE (San Jose, CA)
- Simulates Mark-III containment with horizontal vent configuration
- LOCA related hydrodynamic loads (pool swell, CO and chugging)

## ■ Configuration

- 1/135 (vol.) of BWR/6 Mark-III containment
- Test section scale : Full, 1/3, 1/9 (area)


## ■ Test results

- Drywell and wetwell pressurization
- Vent clearing
- Pool swell
- Condensation oscillation
- Chugging

# Pressure Suppression Test Facility (PSTF)

Class 1


## Pool Swell Test Facility



# Pressure Suppression Test Facility (PSTF)

Class 1

## Wetwell Geometries





# PSTF (Instrumentation)

---

Class 1

# PSTF Scaling

Class 1

	Mk-III	Full Scale (Run 5700)	1/3 (Run 5800)	1/9 (Run 6000)
Boiler	1	1 / 132	1 / 132	1 / 132
Break Area	1	1 / 130	1 / 130	1 / 130
DW Volume	1	1 / 128	1 / 128	1 / 128
Vent Area	1	1 / 45	1 / 135	1 / 138
Pool Area	1	1 / 46	1 / 134	1 / 135
WW Volume	1	1 / 112	1 / 112	1 / 112

# PSTF Test Matrix

Class 1

Scale	Test Series	Test Cases	Venturi Size (in)	Blowdown	Vent Row	Submergence (ft @CL)	Objectives
Full	5701	21	2' 1/8" ~ 3' 5/8"	Sat. Steam	1	2 ~ 15.5	Vent Clearing Demonstration Drywell Pressure
	5702	17	2' 1/8" ~ 3' 5/8"	Sat. Steam	2	1.93 ~ 11.97	Vent Clearing
	5703	3	2' 1/2" ~ 3' 5/8"	Sat. Steam	3	6.77 ~ 11.05	Vent Clearing
	5705	4	1 ~ 4' 1/4"	Air	2	6 ~ 8	Pool Swell (Scoping)
	5706	7	4' 1/4"	Air	2	6 ~ 10	Pool Swell Impact Load
	5707	22	2' 1/8" ~ 3	Sat. Steam	3	7.5	Chugging
1/3	5801	19	2' 1/8" ~ 3	Sat. Steam	3	5 ~ 10	Demonstration Pool Swell Roof dP
	5802	3	2' 1/8" ~ 3	Sat. Steam	3	6	Pool Swell
	5803	2	2' 1/8" ~ 3	Sat. Liquid	3	5 ~ 7.5	Demonstration Liquid Blowdown
	5804	5	2' 1/8" ~ 3	Sat. Steam	3	5	Roof dP (repeat)
	5805	52	1 ~ 3	Sat. Steam	3	5 ~ 10	Pool Swell (Impact)
	5806	12	2' 1/2" ~ 4' 1/4"	Air	3	5 ~ 7.5	Pool Swell
	5807	20	1 ~ 3	Sat. Steam and Liquid	3	7.5	Steam Condensation
1/9	6002	14	2' 1/8" ~ 3	Steam	9	5 ~ 10	Pool Swell (Multi Vent)
	6003	12	2' 1/2"	Steam	9	7.5	Steam Condensation (Multi Vent)

- Series 5800 (1/3 area scale) is “best balanced”
  - Consistent scale (RPV / DW / vent / WW)
  - Smaller configuration (1/9 scale) behaves more 1D like
- Runs 5806 provide representative pool swell data
  - Large steam line break
  - (Pool width / submergence) ratio is close to ABWR
- Data availability
  - Various measurements (swell velocity, slug thickness etc.)
  - 3D information (bubble and pool surface shape)
- NRC adopted 5800 series for pool swell evaluation basis

# Bubble and Pool Surface Shape

---

Class 1

# Pool Swell Level and Velocity

---

Class 1

25

## ■ PSTF test outline

- The only test of pool swell in horizontal vent configuration
- Test facility configuration and test matrix were summarized

## ■ Test case selected for GOTHIC benchmark

- 1/3 scale series (pool swell runs)
- Scaling balance (vol.-area scale, pool aspect ratio)
- Data availability

# Comparison with Test Data and DCD Results

- PSTF (Pressure Suppression Test Facility)
  - 1/3 Scale Test
- DCD





# PSTF Comparison

---

- Test Run 5806
  - 1/3 Scale
  - 3 Vents
  - Compressed Air Injection
  - Primary Objective – Pool Swell
  - 5.0 – 7.5 feet top vent submergence
    - Selected Case – 5.0 feet submergence
- 1/3 Scale tests have closest overall scaling to prototypic conditions
  - Pool and vent aspect ratios better matched in full scale tests.




# GOTHIC Results for PSTF 5806-1

## Pool Swell

---

(a,b,c)



August 18, 2009

Westinghouse Non-Proprietary Class 3



Westinghouse

# GOTHIC Results for PSTF 5806-1

## Pool Surface Velocity

---

(a,b,c)



# GOTHIC Results for PSTF 5806-1

## Slug Thickness

---



# GOTHIC Results for PSTF 5806-1

---

- GOTHIC modeling approach bounds surface elevation transient and surface velocity transient.
- Model allows some thinning of rising slug but less than indicated by test.
- Due to open gas space, 80% pool area has minimal impact on results.
- Vent Clearing Time
  - Measured 0.8 seconds
  - Simulation 0.7 seconds



# DCD Comparison

---


- Specified drywell pressure transient from FWLB in DCD.
- GOTHIC modeling approach is same as for PSTF comparison except that gas space is a closed volume.



# DCD Comparison

## GOTHIC Results for DCD Conditions

---



August 18, 2009

Westinghouse Non-Proprietary Class 3




Westinghouse

# DCD Comparison

## GOTHIC Results for DCD Conditions

---



August 18, 2009

Westinghouse Non-Proprietary Class 3



Westinghouse



# Comparison of Results

---

	<b>DCD</b>	<b>ABWR/ GOTHIC 80% Pool</b>
<b>Max Swell Height (m)</b>	7.0	7.4
<b>Max Slug Velocity (m/s) with 1.1 multiplier</b>	6.0	7.0
<b>Max Gas Space Pressure (kPag)</b>	108	106
<b>Max Bubble Pressure (kPag)</b>	133	141



# GOTHIC Results for DCD Comparison

---

- GOTHIC modeling approach bounds DCD results for peak swell elevation, peak surface velocity and peak bubble pressure.
- Gas space peak pressure is slightly lower.
  - Uncertainty in DCD peak pressure definition.
  - Small heat and mass transfer at pool surface.



# ABWR Design Case

---

- Applied drywell pressure transient is the upper envelope curve for all MSLB and FWLB transients considered for peak short term containment pressure and temperature.
- MSLB gives faster pressure rise in the drywell and is therefore bounding for pool swell analysis.
- Drywell pressure response includes vent inertia
  - Increases very short term drywell pressure rise rate and peak for MSLB cases.




- [illegible]



- August 18, 2009
- Westinghouse

# Design Case Drywell Pressure




August 18, 2009

Westinghouse Non-Proprietary Class 3



# Design Case Pool Swell

---



August 18, 2009

Westinghouse Non-Proprietary Class 3




Westinghouse



# Design Case Pool Surface Velocity

---



August 18, 2009

Westinghouse Non-Proprietary Class 3



Westinghouse

# Design Case Froth Level


---

- Assumed maximum froth level extends to 3.3 m above the maximum pool swell height.
- Consistent with NUREG-0978 for Mark III
- ABWR froth height is expected to be less.
  - Back pressure on the pool slug results in lower water inertia when the bubble breaks through the surface.
  - Reduced water momentum will result in lower froth height.
  - Higher gas space pressure results in reduced gas expansion and reduced water carry-up.





# Design Case Bubble and Gas Space Pressure



- Peaks registered just before or at breakthrough

# Design Case Results

---

	<b>DCD</b>	<b>NEDO 33372</b>	<b>Westinghouse ABWR</b>
<b>Max Swell Height (m)</b>	7.0	8.3	8.8
<b>Max Slug Velocity (m/s) with 1.1 multiplier</b>	6.0	6.0	10.9
<b>Max Gas Space Pressure (kPag)</b>	108	154	146
<b>Max Bubble Pressure (kPag)</b>	133	185	195



# GOTHIC Results for ABWR Design

---

- GOTHIC modeling approach bounds NEDO-33372 results for peak swell elevation, peak surface velocity and peak bubble pressure.
- Gas space peak pressure is slightly lower.
  - Uncertainty in DCD peak pressure definition.
  - Small heat and mass transfer at pool surface.



# Sensitivity Studies


---

- Variations on Design Case
  - Vent loss factor
  - Pool area factor
  - Vent inertia length
  - Gas space thermal behavior





# Sensitivity to Vent Loss Factor





August 18, 2009

Westinghouse Non-Proprietary Class 3




Westinghouse



# Sensitivity to Pool Area Factor



# Sensitivity to Vent Inertia Length



# Sensitivity to Gas Space Thermal Behavior





# Sensitivity Conclusions

---

- Relative response to selected sensitivity parameters is as expected.
- Results are most sensitivity to pool area factor.
- Small sensitivity to inertia length.
- Overall modeling approach is considered conservative.



# Conservatisms in Modeling Approach

---

- High estimate of drywell pressure transient
  - High vent losses
  - Vent inertia effects included
  - Maximum pool level
- Vent losses ignored in pool swell calculations
- Isothermal gas space minimizes back pressure on rising slug
- Minimum initial slug thickness
- Nitrogen injection
  - 20-30% higher peak swell velocity compared to tests with steam blowdown in the drywell



# Summary

---

- GOTHIC modeling approach bounds peak swell height, peak surface velocity and peak bubble pressure from
  - PSTF Test 5806-1
  - DCD
  - NEDO 33372
- GOTHIC results for peak gas space pressure are close to DCD and NEDO 33372 values
- Significant conservatisms are built into the GOTHIC modeling approach.



NRC Containment Audit for STP 3&4 COLA

## **Pool Swell Load Application**

August 18, 2009

## ■ Pool swell load application methodology

- Wetwell (WW) boundary
- Structures in WW airspace (NUREG-0487 / 0978)
- Submerged structures

## ■ Information of relevant equipment location (typ.)

# Pool Boundary Load


Class 1

## ■ Methodology

The pressure loads calculated by GOTHIC are applied to pressure boundary.

- Wetwell air space boundary
- Suppression pool boundary

Bubble pressure +  
Hydrostatic head



# Structures in WW

---

Class 1

# Structures in WW (SRVDL)

---

Class 1




## ■ Methodology

The methodology is the same as that used for DCD.

- Impact load (for small structure): NUREG-0487

$$P(t) = P_{\max} (1 - \cos(2\pi t / T)) / 2$$

$$P_{\max} = 2I_P / T, \quad I_P = (M_H / A) V / g_C$$





# Load on Structure in WW (cont.)

Class 1

- Drag load: the sum of standard and acceleration drags

$$P_d = 1/2 C_D \rho (V^2/g_c) + V_A \rho (\dot{V}/g_c)$$

- Treatment of froth region: NUREG-0978



## ■ Methodology

The methodology is based on the analytical model for LOCA charging bubble-induced load (Dr. Moody, NEDE-21471, 1977).

- Spherical, adiabatic ideal gas bubble dynamics equations with the flow field being described by a point source

$$R \ddot{R} + 3/2 \dot{R}^2 = g_c (P_{\text{bubble}} - P_{\infty}) / \rho$$

- The total drag is the sum of standard and acceleration drags
- The boundaries (including the free surface) are incorporated by using the method of images.

# Submerged Structures

---

Class 1

- Pool swell load application adopts existing and accepted methodology
  - Described in NUREGs and their references
  - GOTHIC results (P, V, H) are used in formulation
  
- Specific design calculation will be performed in detail design stage

# Contents of Topical Report (Preliminary)

---

- 1.Introduction and Background
  - 2.Purpose
  - 3.Pool Swell Phenomena and Related Hydrodynamic Loads
  - 4.GOTHIC Capabilities for Pool Swell Phenomena
  - 5.GOTHIC Model Description for ABWR Pool Swell
  - 6.Comparison of GOTHIC Methodology with the ABWR DCD Methodology
  - 7.Comparison of GOTHIC Results with the ABWR DCD Results
  - 8.PSTF Comparison
  - 9.Results for ABWR
  - 10.Sensitivity Studies
  - 11.Application of Pool Swell Results for Structural Loads Analysis
  - 12.Conclusions
  - 13.References
- Appendix A – Key GOTHIC ABWR Suppression Pool Model Input Parameters
- Appendix B – Comparison of GOTHIC Pool Swell Methodology with PSTF Test Data
- Appendix C – Drywell Pressure Transient for DCD Benchmark
- Appendix D – Drywell Pressure and Temperature Transients for Design Analysis
- Appendix E – Sensitivity Studies



# Response to Questions

---

- Scale drawings of equipment in wetwell air space
  - Discussed in presentation on design analysis
- Discussion of approach for calculating pool swell induced loads on equipment
  - Discussed in presentation on design analysis
- Effects of uncertainties in calculation of pool swell level surge
  - Discussed in presentation on design analysis
- Comparison of input differences for Short Term P/T, Long Term P/T, and Pool Swell Analyses
- Vent clearing times



# Model Input Comparison

Modeling Element	Short Term PT	Short Term for PS Input	Long Term PT (a,c)





# Vent Clearing Times

Test or Analysis	Vent Clearing Time (seconds) (a,b,c)



---

# Questions?

August 18, 2009

Westinghouse Non-Proprietary Class 3



Westinghouse