



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

September 11, 2009

LICENSEE: Florida Power & Light

FACILITY: Turkey Point Nuclear Generating Units 3 and 4

SUBJECT: SUMMARY OF AUGUST 6, 2009, CONFERENCE CALL WITH FLORIDA POWER & LIGHT, ON GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY RECIRCULATION DURING DESIGN BASIS ACCIDENTS AT PRESSURIZED-WATER REACTOR," RESPONSES (TAC NOS. MC4725 AND MC4726)

On August 6, 2009, a Category 1 public conference call was held between the U.S. Nuclear Regulatory Commission (NRC) and Florida Power & Light Company (the licensee). The purpose of the call was to discuss the responses to NRC requests for additional information (RAIs) for Generic Letter (GL) 2004-02, "Potential Impact of Debris Blockage on Emergency Recirculation during Design Basis Accidents at Pressurized-Water Reactors." A list of participants is enclosed.

The licensee summarized its Turkey Point Units 3 and 4 responses to NRC RAIs regarding GL 2004-02 (See the Agencywide Documents Access and Management System (ADAMS) Accession No. ML090920410 and ML090930452). The licensee clarified and explained in detail the tests and analyses performed to address the NRC RAIs, which are included in the responses.

The NRC staff queried the licensee about its responses to determine whether supplemental information is needed. The staff's questions focused on areas where there had been issues with previous GL 2004-02 responses and asked for clarification on the analyses that were performed for Turkey Point. Some example questions that the staff asked were to describe the break selection for debris transport, the area around the strainers and debris interceptors, and the amount of flow over the interceptors when more particulate is present on the debris bed.

The licensee plans to provide supplemental information to the questions needing further explanation than provided during the meeting. The supplemental information will be available in ADAMS when submitted by the licensee.

- 2 -

A member of the public was participating, but no Public Meeting Feedback form was received.

Please direct any inquiries to me at 301-415-2020 or Brenda.Mozafari@nrc.gov.

A handwritten signature in black ink that reads "Brenda Mozafari". The signature is written in a cursive, flowing style.

Brenda L. Mozafari, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

A member of the public was participating, but no Public Meeting Feedback form was received.

Please direct any inquiries to me at 301-415-2020 or Brenda.Mozafari@nrc.gov.

/RA/

Brenda L. Mozafari, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-250 and 50-251

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	RidsOgcRp Resource	EWong
Branch Reading	RidsRgn2MailCenter Resource	JLehning
RidsAcrsAcnw_MailCTR Resource	CTucci, NRR	SSmith
RidsNrrDorlLpl2-2 Resource	RTorres	CAshley
RidsNrrPMTurkeyPoint Resource	EGeiger	DDiaz-Toro, EDO Region 2
RidsNrrLABClayton Resource	PKlein	

ADAMS Accession No. ML092440479

OFFICE	DORL/LPL2-2/PE	DORL/LPL2-2/PM	DORL/LPL2-2/LA	DORL/LPL2-2/BC	DORL/LPL2-2/PM
NAME	BMozafari for JPaige	BMozafari	BClayton	EBrown for TBoyce	BMozafari (signature)
DATE	09/11/09	09/11/09	09/10/09	09/11/09	09/11/09

OFFICIAL RECORD COPY