

## PMBelCOL PEmails

---

**From:** Goetz, Sujata  
**Sent:** Wednesday, August 12, 2009 3:36 PM  
**To:** BelCol Resource; VogtleCOL Resource  
**Subject:** FW: BLN SER Chapter 5 confirmatory items  
**Attachments:** image001.gif

---

**From:** Eddie R Grant [mailto:Eddie.Grant@EXCELServices.com]

**Sent:** Thursday, August 06, 2009 8:00 AM

**To:** Goetz, Sujata

**Subject:** BLN SER Chapter 5 confirmatory items

Sue - As we discussed, in order to better prepare for our telecom discussion, below is draft language that we are preparing to include in the COL FSAR as revisions to address the two confirmatory items identified in the BLN SER in Chapter 5 .

### CI 5.2-1

#### **Associated VEGP COL Application Revisions:**

COLA Part 2, FSAR, Subsection 5.2.4.1, fifth paragraph, will be revised from:

The inservice inspection program is augmented for reactor vessel top head inspections by use of the ASME Code Case N-729-1, "Alternative Examination Requirements for Pressurized-Water Reactor (PWR) Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds," as modified by the NRC Staff position on the use of ASME Code Case N-729-1 shown in the proposed rulemaking dated April 5, 2007 (72 FR 16740).

To read:

The inservice inspection program is augmented for reactor vessel top head inspections by use of the ASME Code Case N-729-1, "Alternative Examination Requirements for Pressurized-Water Reactor (PWR) Vessel Upper Heads With Nozzles Having Pressure-Retaining Partial-Penetration Welds," as modified by the conditions specified in 10 CFR 50.55a(g)(6)(ii)(D).

### CI 5.3-1

#### **Associated VEGP COL Application Revisions:**

COLA Part 2, FSAR, Chapter 5, Subsection 5.3.2.6 (as revised by the supplement 2 response to BLN-RAI-LTR-002) will be revised from:

The type and quantity of test specimens exceed the minimum requirements of E185-82.

To read:

The type, quantity, and storage conditions (e.g., surveillance capsules backfilled with inert gas) of test specimens meet or exceed the minimum requirements of ASTM E185-82.

Thanks,

**Eddie R. Grant**

**NuStart - AP1000 Licensing**

**Hearing Identifier:** Bellefonte\_COL\_Public\_EX  
**Email Number:** 1657

**Mail Envelope Properties** (83F82891AF9D774FBBB39974B6CB134F948EF3BEB1)

**Subject:** FW: BLN SER Chapter 5 confirmatory items  
**Sent Date:** 8/12/2009 3:35:42 PM  
**Received Date:** 8/12/2009 3:35:44 PM  
**From:** Goetz, Sujata

**Created By:** Sujata.Goetz@nrc.gov

**Recipients:**  
"BelCol Resource" <BelCol.Resource@nrc.gov>  
Tracking Status: None  
"VogtleCOL Resource" <VogtleCOL.Resource@nrc.gov>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1937	8/12/2009 3:35:44 PM
image001.gif	595	

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

