



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

September 3, 2009

Mr. Charles G. Pardee  
President and Chief Nuclear Officer  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 – CORRECTION LETTER FOR  
LICENSE AMENDMENT NOS. 193 AND 180 RE: DELETE OBSOLETE  
LICENSE CONDITIONS AND REVISE TECHNICAL SPECIFICATIONS  
(TAC NOS. MD9616 AND MD9617)

Dear Mr. Pardee:

By letter dated August 27, 2009 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML092040273), the Nuclear Regulatory Commission (NRC) staff issued Amendment Nos. 193 and 180 to Facility Operating License Nos. NPF-11 and NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The amendments remove time, cycle, or modification-related items from the operating licenses and Technical Specifications in response to your application dated September 11, 2008 (ADAMS Accession No. ML082550530), as supplemented by letter dated August 11, 2009 (ADAMS Accession No. ML092240199).

Administrative errors were identified in the amendments. The amendments were incorrectly dated. They should be dated for August 28, 2009. It was also noted that the amendment numbers used were incorrect. The correct amendment numbers are 194 and 181 for LaSalle County Station, Units 1 and 2, respectively. Please replace the amendments dated August 27, 2009, with the enclosed amendments.

The incorrect information was editorial in nature. The corrections do not change the approval conveyed by the amendments, or the conclusions reached by the associated safety evaluation. We regret any inconvenience this may have caused you.

Sincerely,

A handwritten signature in cursive script that reads "Cameron S. Goodwin".

Cameron S. Goodwin, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:  
Amendments dated August 28, 2009

cc w/encl: Distribution via ListServ



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

August 28, 2009

Mr. Charles G. Pardee  
President and Chief Nuclear Officer  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2, ISSUANCE OF AMENDMENTS  
RE: DELETE OBSOLETE LICENSE CONDITIONS AND REVISE TECHNICAL  
SPECIFICATIONS (TAC NOS. MD9616 AND MD9617)

Dear Mr. Pardee:

The U.S. Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 194 to Facility Operating License No. NPF-11 and Amendment No. 181 to Facility Operating License No. NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The amendments are in response to your application dated September 11, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082550530), as supplemented by letter dated August 11, 2009 (ADAMS Accession No. ML092240199).

The amendments remove time, cycle, or modification-related items from the operating licenses and Technical Specifications (TS). Additionally, the amendment corrects a typographical error introduced into the TS from a previous amendment.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in cursive script that reads "Cameron S. Goodwin".

Cameron S. Goodwin, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosures:

1. Amendment No. 194 to NPF-11
2. Amendment No. 181 to NPF-18
3. Safety Evaluation

cc w/encls: Distribution via ListServ



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

EXELON GENERATION COMPANY, LLC

DOCKET NO. 50-373

LASALLE COUNTY STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 194  
License No. NPF-11


1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment filed by the Exelon Generation Company, LLC (the licensee), dated September 11, 2008, as supplemented by letter dated August 11, 2009, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-11 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 194, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "Stephen J. Campbell". The signature is written in a cursive style with a large, sweeping initial "S".

Stephen J. Campbell, Chief  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications and Facility Operating License

Date of Issuance: August 28, 2009



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

EXELON GENERATION COMPANY, LLC

DOCKET NO. 50-374

LASALLE COUNTY STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 181  
License No. NPF-18


1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment filed by the Exelon Generation Company, LLC (the licensee), dated September 11, 2008, as supplemented by letter dated August 11, 2009, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-18 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 181, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and shall be implemented within 30 days of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Stephen J. Campbell, Chief  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical  
Specifications and Facility Operating License

Date of Issuance: August 28, 2009

ATTACHMENT TO LICENSE AMENDMENT NOS. 194 AND 181

FACILITY OPERATING LICENSE NOS. NPF-11 AND NPF-18

DOCKET NOS. 50-373 AND 50-374

Replace the following pages of the Facility Operating Licenses and Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove

License NPF-11  
Pages 3 through 10  
Pages 11 through 17  
Attachment 1

License NPF-18  
Pages 3 through 9  
Pages 9a through 11  
Attachment 1  
Attachment 2

TSs

3.7.1-1  
3.7.1-2  
3.7.1-3  
3.7.2-1  
3.7.2-2  
3.7.2-3  
3.8.1-4  
3.8.1-6  
3.8.1-7  
3.8.1-8  
3.8.1-9  
3.8.1-10  
3.8.1-11  
3.8.1-12  
3.8.1-13  
3.8.1-14  
3.8.1-15  
3.8.1-16  
3.8.1-17  
3.8.1-18  
3.8.1-19  
5.6-3

Insert

License NPF-11  
Pages 3 through 10

License NPF-18  
Pages 3 through 9

TSs

3.7.1-1  
3.7.1-2  
-----  
3.7.2-1  
-----  
-----  
3.8.1-4  
3.8.1-6  
3.8.1-7  
3.8.1-8  
3.8.1-9  
3.8.1-10  
3.8.1-11  
3.8.1-12  
3.8.1-13  
3.8.1-14  
3.8.1-15  
3.8.1-16  
3.8.1-17  
3.8.1-18  
3.8.1-19  
5.6-3

Am. 146  
01/12/01

- (4) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components; and

Am. 146  
01/12/01

- (5) Exelon Generation Company, LLC, pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2.

C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

- (1) Maximum Power Level

The licensee is authorized to operate the facility at reactor core power levels not in excess of full power (3489 megawatts thermal).

- (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 194 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- (3) DELETED

- (4) DELETED

- (5) DELETED

- (6) DELETED

- (7) DELETED

(8) DELETED

(9) DELETED

(10) DELETED

(11) DELETED

(12) DELETED

(13) DELETED

(14) DELETED

(15) DELETED

(16) DELETED

Am. 10  
12/09/82

(17) DELETED

(18) DELETED

(19) DELETED

(20) DELETED

(21) DELETED

(22) DELETED

(23) DELETED

(24) DELETED

Am. 127  
06/10/98

(25) Fire Protection Program

The licensee shall implement and maintain all provisions of the approved Fire Protection Program as described in the Final Safety Analysis Report for LaSalle County Station, and as approved in NUREG-0519, "Safety Evaluation Report related to the operation of LaSalle County Station, Units 1 and 2," dated March 1981; Supplement 2 dated February 1982; Supplement 3 dated April 1982; Supplement 5 dated August 1983; Supplement 7 dated December 1983; Supplement 8 dated March 1984; and SERs for the following:

LaSalle Unit 1 License Amendment 1, dated June 18, 1982;  
LaSalle Unit 1 License Amendment 18, dated August 8, 1984;  
LaSalle Unit 1 License Amendment 23, dated May 22, 1985;  
LaSalle Unit 1 License Amendment 44, dated June 20, 1986;  
LaSalle Unit 1 License Amendment 127, dated June 10, 1998; and  
NRC Evaluation of the Consequences of Postulated Failures of 1 Hour Fire Rated Darmatt KM-1 Fire Barrier under Seismic Loading at LaSalle County Station, dated March 29, 1996.

The Licensee may make changes to the approved Fire Protection Program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

Am. 14  
5/05/83

(26) DELETED

Letter dated  
05/16/07

(27) Industrial Security (Section 13.6, SER, SSER #3)

Exelon Generation Company shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822), and the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans<sup>1</sup>, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "LaSalle County Station Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan, Revision 5," submitted by letter dated May 17, 2006.

---

<sup>1</sup> The Training and Qualification Plan and Safeguards Contingency Plan are Appendices to the Security Plan.

- (28) DELETED |
- (29) DELETED |
- (30) DELETED |
- (31) DELETED |
- (32) DELETED |
- (33) DELETED |
- Am. 103  
04/13/95 (34) DELETED |
- (35) DELETED |
- (36) DELETED |
- Am. 147  
03/30/01 (37) DELETED |
- Am. 146  
01/12/01 (38) Exelon Generation Company, LLC shall provide the Director of the Office of Nuclear Reactor Regulation a copy of any application, at the time it is filed, to transfer (excluding grants of security interests or liens) from Exelon Generation Company, LLC to its direct or indirect parent, or to any other affiliated company, facilities for the production, transmission, or distribution of electric energy having a depreciated book value exceeding ten percent (10%) of Exelon Generation Company, LLC's consolidated net utility plant, as recorded on Exelon Generation Company, LLC's books of account.
- Am. 146  
01/12/01 (39) Exelon Generation Company, LLC shall have decommissioning trust funds, for LaSalle Unit 1, in the following minimum amount, when LaSalle, Unit 1, is transferred to Exelon Generation Company, LLC:  
  
LaSalle, Unit 1 \$226,262,522

Am. 146  
01/12/01

(40) The decommissioning trust agreement for LaSalle, Unit 1, at the time the transfer of the unit to Exelon Generation Company (EGC), LLC is effected and thereafter, is subject to the following:

- (a) The decommissioning trust agreement must be in a form acceptable to the NRC.
- (b) With respect to the decommissioning trust fund, investments in the securities or other obligations of Exelon Corporation or affiliates thereof, or their successors or assigns are prohibited. Except for investments tied to market indexes or other non-nuclear sector mutual funds, investments in any entity owning one or more nuclear power plants are prohibited.

Am. 146  
01/12/01

(c) The decommissioning trust agreement for LaSalle, Unit 1, must provide that no disbursements or payments from the trust shall be made by the trustee unless the trustee has first given the Director of the Office of Nuclear Reactor Regulation, 30 days prior written notice of payment. The decommissioning trust agreement shall further contain a provision that no disbursements or payments from the trust shall be made if the trustee receives prior written notice of objection from the NRC.

(d) The decommissioning trust agreement must provide that the agreement can not be amended in any material respect without 30 days prior written notification to the Director of the Office of Nuclear Reactor Regulation.

(e) The appropriate section of the decommissioning trust agreement shall state that the trustee, investment advisor, or anyone else directing the investments made in the trust shall adhere to a "prudent investor" standard, as specified in 18 CFR 35.32(a)(3) of the Federal Energy Regulatory Commission's regulations.

Am. 146  
01/12/01

(41) Exelon Generation Company, LLC shall take all necessary steps to ensure that the decommissioning trust is maintained in accordance with the application for approval of the transfer of the LaSalle, Unit 1, license and the requirements of the Order approving the transfer, and consistent with the safety evaluation supporting the Order.

(42) DELETED

(43) DELETED

Letter dated  
08/09/07

(44) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
  - 1. Pre-defined coordination fire response strategy and guidance
  - 2. Assessment of mutual aid fire fighting assets
  - 3. Designated staging areas for equipment and materials
  - 4. Command and control
  - 5. Training of response personnel
  
- (b) Operations to mitigate fuel damage considering the following:
  - 1. Protection and use of personnel assets
  - 2. Communications
  - 3. Minimizing fire spread
  - 4. Procedures for implementing integrated fire response strategy
  - 5. Identification of readily-available pre-staged
  - 6. Training or integrated fire response strategy
  - 7. Spent fuel pool mitigation measures
  
- (c) Actions to minimize release to include consideration of:
  - 1. Water spray scrubbing
  - 2. Dose to onsite responders

Am. 186  
10/31/07

(45) Upon implementation of Amendment No. 186 adopting TSTF-448, Revision 3, the determination of control room envelope (CRE) unfiltered air inleakage as required by SR 3.7.4.5, in accordance with TS 5.5.15.c.(i), the assessment of CRE habitability as required by Specification 5.5.15.c.(ii), and the measurement of CRE pressure as required by Specification 5.5.15.d, shall be considered met. Following Implementation:

- (a) The first performance of SR 3.7.4.5, in accordance with Specification 5.5.15.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 3.0.2, as measured from 1998, the date of the most recent successful tracer gas test, as stated in the December 9, 2003 letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.

- (b) The first performance of the periodic assessment of CRE habitability, Specification 5.5.15.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 3.0.2, as measured from 1998, the date of the most recent successful tracer gas test, as stated in the December 9, 2003 letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.
- (c) The first performance of the periodic measurement of CRE pressure, Specification 5.5.15.d, shall be within 24 months, plus 6 months allowed by SR 3.0.2, as measured from the date of the most recent successful pressure measurement test, or within 6 months if not performed previously.

Am. 102  
03/16/95

D. The facility requires exemptions from certain requirements of 10 CFR Part 50, 10 CFR Part 70, and 10 CFR Part 73. These include:

- (a) Exemptions from certain requirements of Appendices G, H and J and 10 CFR Part 73 are described in the Safety Evaluation Report and Supplement No. 1, No. 2, No. 3 to the Safety Evaluation Report.
- (b) DELETED |
- (c) DELETED |
- (d) DELETED |
- (e) An exemption from the requirement of paragraph III.D of Appendix J to conduct the third Type A test of each ten-year service period when the plant is shutdown for the 10-year plant inservice inspections. Exemption (e) is described in the safety evaluation accompanying amendment No. 102 to this License.

Am. 112  
04/05/96

(f) An exemption was granted to remove the Main Steam Isolation Valves (MSIVs) from the acceptance criteria for the combined local leak rate test (Type B and C), as defined in the regulations of 10 CFR Part 50, Appendix J, Option B, Paragraph III.B. Exemption (f) is described in the safety evaluation accompanying Amendment No. 112 to this License.

These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. Therefore, these exemptions are hereby granted. The facility will operate, to the extent authorized herein, in conformity with the application, as amended, and the rules and regulations of the Commission (except as hereinafter exempted there from), and the provisions of the Act.

- E. This license is subject to the following additional condition for the protection of the environment:

Before engaging in additional construction or operational activities which may result in a significant adverse environmental impact that was not evaluated or that is significantly greater than that evaluated in the Final Environmental Statement and its Addendum, the licensee shall provide a written notification to the Director of the Office of Nuclear Reactor Regulation and receive written approval from that office before proceeding with such activities.

Am. 178  
06/14/06

- F. Deleted

- G. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.

Am. 4  
08/13/82

- H. This license is effective as of the date of issuance and shall expire April 17, 2022.

FOR THE NUCLEAR REGULATORY COMMISSION

Original Signed By

HAROLD R. DENTON, DIRECTOR  
OFFICE OF NUCLEAR REACTOR REGULATION

Attachment:

1. DELETED
2. Appendix A – Technical Specifications (NUREG-0861)
3. Appendix B – Environmental Protection Plan

Date of Issuance: April 17, 1982

Am. 34  
12/08/87

- (5) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of LaSalle County Station, Units 1 and 2.

C. The license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

Am. 125  
05/09/00

- (1) Maximum Power Level

The licensee is authorized to operate the facility at reactor core power levels not in excess of full power (3489 megawatts thermal). Items in Attachment 1 shall be completed as specified. Attachment 1 is hereby incorporated into this license.

- (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 18<sup>1</sup> and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

- (3) DELETED

- (4) DELETED

- (5) DELETED

- (6) DELETED

- (7) DELETED

- (8) DELETED

- (9) DELETED

(10) DELETED

(11) DELETED

(12) DELETED

(13) DELETED

(14) DELETED

Am. 112  
06/10/98

(15) Fire Protection Program

The licensee shall implement and maintain all provisions of the approved Fire Protection Program as described in the Final Safety Analysis Report for LaSalle County Station, and as approved in NUREG-0519, "Safety Evaluation Report related to the operation of LaSalle County Station, Units 1 and 2," dated March 1981; Supplement 2 dated February 1982; Supplement 3 dated April 1982; Supplement 5 dated August 1983; Supplement 7 dated December 1983; Supplement 8 dated March 1984; and SERs for the following:

LaSalle Unit 2 License Amendment 11, dated May 22, 1985;  
LaSalle Unit 2 License Amendment 14, dated October 2, 1985;  
LaSalle Unit 2 License Amendment 112, dated June 10, 1998; and  
NRC Evaluation of the Consequences of Postulated Failures of 1 Hour Fire Rated Darmatt KM-1 Fire Barrier under Seismic Loading at LaSalle County Station, dated March 29, 1996.

The Licensee may make changes to the approved Fire Protection Program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.

Letter dated  
05/16/07

(16) Industrial Security (Section 13.6, SER, SSER #3, SSER #5)

Exelon Generation Company shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification, and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822), and the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans<sup>1</sup>, which contain Safeguards Information protected under 10 CFR 73.21, is entitled: "LaSalle County Station Security Plan, Training and Qualification Plan, and Safeguards Contingency Plan, Revision 5," submitted by letter dated May 17, 2006.

(17) DELETED

(18) DELETED

(19) DELETED

(20) DELETED

Am. 133  
03/30/01

(21) Deleted.

Am. 132  
01/12/01

(22) EGC shall provide the Director of the Office of Nuclear Reactor Regulation a copy of any application, at the time it is filed, to transfer (excluding grants of security interests or liens) from EGC to its direct or indirect parent, or to any other affiliated company, facilities for the production, transmission, or distribution of electric energy having a depreciated book value exceeding ten percent (10%) of EGC's consolidated net utility plant, as recorded on EGC's books of account.

Am. 132  
01/12/01

(23) EGC shall have decommissioning trust funds for LaSalle, Unit 2, in the following minimum amount, when LaSalle, Unit 2, is transferred to EGC:

LaSalle, Unit 2	\$221,885,059
-----------------	---------------

<sup>1</sup> The Training and Qualification Plan and Safeguards Contingency Plan are Appendices to the Security Plan.

Am. 132  
01/12/01

(24) The decommissioning trust agreement for LaSalle, Unit 2, at the time the transfer of the unit to EGC is effected and thereafter, is subject to the following:

- (a) The decommissioning trust agreement must be in a form acceptable to the NRC.
- (b) With respect to the decommissioning trust fund, investments in the securities or other obligations of Exelon Corporation or affiliates thereof, or their successors or assigns are prohibited. Except for investments tied to market indexes or other non-nuclear sector mutual funds, investments in any entity owning one or more nuclear power plants are prohibited.
- (c) The decommissioning trust agreement for LaSalle, Unit 2, must provide that no disbursements or payments from the trust shall be made by the trustee unless the trustee has first given the Director of the Office of Nuclear Reactor Regulation, 30 days prior written notice of payment. The decommissioning trust agreement shall further contain a provision that no disbursements or payments from the trust shall be made if the trustee receives prior written notice of objection from the NRC.
- (d) The decommissioning trust agreement must provide that the agreement can not be amended in any material respect without 30 days prior written notification to the Director of the Office of Nuclear Reactor Regulation.
- (e) The appropriate section of the decommissioning trust agreement shall state that the trustee, investment advisor, or anyone else directing the investments made in the trust shall adhere to a "prudent investor" standard, as specified in 18 CFR 35.32(a)(3) of the Federal Energy Regulatory Commission's regulations.

Am. 132  
01/12/01

(25) EGC shall take all necessary steps to ensure that the decommissioning trust is maintained in accordance with the application for approval of the transfer of the LaSalle, Unit 2, license and the requirements of the Order approving the transfer, and consistent with the safety evaluation supporting the Order.

(26) DELETED

(27) DELETED

Letter dated  
08/09/07

(28) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:
  - 1. Pre-defined coordination fire response strategy and guidance
  - 2. Assessment of mutual aid fire fighting assets
  - 3. Designated staging areas for equipment and materials
  - 4. Command and control
  - 5. Training of response personnel
  
- (b) Operations to mitigate fuel damage considering the following:
  - 1. Protection and use of personnel assets
  - 2. Communications
  - 3. Minimizing fire spread
  - 4. Procedures for implementing integrated fire response strategy
  - 5. Identification of readily-available pre-staged
  - 6. Training or integrated fire response strategy
  - 7. Spent fuel pool mitigation measures
  
- (c) Actions to minimize release to include consideration of:
  - 1. Water spray scrubbing
  - 2. Dose to onsite responders

Am. 173  
10/31/07

(29) Upon implementation of Amendment No. 173 adopting TSTF-448, Revision 3, the determination of control room envelope (CRE) unfiltered air leakage as required by SR 3.7.4.5, in accordance with TS 5.5.15.c.(i), the assessment of CRE habitability as required by Specification 5.5.15.c.(ii), and the measurement of CRE pressure as required by Specification 5.5.15.d, shall be considered met. Following implementation:

- (a) The first performance of SR 3.7.4.5, in accordance with Specification 5.5.15.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 3.0.2, as measured from 1998, the date of the most recent successful tracer gas test, as stated in the December 9, 2003 letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.
  
- (b) The first performance of the periodic assessment of CRE habitability, Specification 5.5.15.c.(ii), shall be within 3 years, plus the 9-month allowance of SR 3.0.2, as measured from 1998, the date of the most recent successful tracer gas test, as stated in the December 9, 2003 letter response to Generic Letter 2003-01, or within the next 9 months if the time period since the most recent successful tracer gas test is greater than 3 years.

- (c) The first performance of the periodic measurement of CRE pressure, Specification 5.5.15.d, shall be within 24 months, plus the 6 months allowed by SR 3.0.2, as measured from the date of the most recent successful pressure measurement test, or within 6 months if not performed previously.

Am. 87  
03/16/95

D. The facility requires exemptions from certain requirements of 10 CFR Part 50, 10 CFR Part 70, and 10 CFR Part 73. These include:

- (a) Exemptions from certain requirements of Appendices G, H and J to 10 CFR Part 50, and to 10 CFR Part 73 are described in the Safety Evaluation Report and Supplement Numbers 1, 2, 3, and 5 to the Safety Evaluation Report.
- (b) DELETED
- (c) An exemption from the requirement of paragraph III.D of Appendix J to conduct the third Type A test of each ten-year service period when the plant is shutdown for the 10-year plant inservice inspections.

(d) DELETED

Am. 97  
04/05/96

- (e) An exemption was granted to remove the Main Steam Isolation Valves (MSIVs) from the acceptance criteria for the combined local leak rate test (Type B and C), as defined in the regulations of 10 CFR Part 50, Appendix J, Option B, Paragraph III.B. Exemption (e) is described in the safety evaluation accompanying Amendment No. 97 to this License.

These exemptions are authorized by law and will not endanger life or property or the common defense and security and are otherwise in the public interest. Therefore, these exemptions are hereby granted. The facility will operate, to the extent authorized herein, in conformity with the application, as amended, and the rules and regulations of the Commission (except as hereinafter exempted therefrom), and the provisions of the Act.

E. Before engaging in additional construction or operational activities which may result in a significant adverse environmental impact that was not evaluated or that is significantly greater than that evaluated in the Final Environmental Statement and its Addendum, the licensee shall provide a written notification to the Director of the Office of Nuclear Reactor Regulation and receive written approval from that office before proceeding with such activities.

Am. 164  
06/14/06

F. Deleted

Am. 164 G. Deleted  
06/14/06

- H. The licensee shall have and maintain financial protection of such type and in such amounts as the Commission shall require in accordance with Section 170 of the Atomic Energy Act of 1954, as amended, to cover public liability claims.
- I. This license is effective as of the date of issuance and shall expire at Midnight on December 16, 2023.

FOR THE NUCLEAR REGULATORY COMMISSION

Original signed by D.C. Eisenhut for

HAROLD R. DENTON, DIRECTOR  
OFFICE OF NUCLEAR REACTOR REGULATION

Attachment/Appendices:

1. DELETED
2. DELETED
3. Appendix A – Technical Specifications (NUREG-1013)
4. Appendix B – Environmental Protection Plan

Date of Issuance: December 16, 1983

3.7 PLANT SYSTEMS

3.7.1 Residual Heat Removal Service Water (RHRSW) System

LCO 3.7.1 Two RHRSW subsystems shall be OPERABLE.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>A. One RHRSW subsystem inoperable.</p>	<p>A.1 -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.4.9, "Residual Heat Removal (RHR) Shutdown Cooling System-Hot Shutdown," for RHR shutdown cooling subsystem made inoperable by RHRSW System. ----- Restore RHRSW subsystem to OPERABLE status.</p>	<p>7 days</p>

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3.	12 hours
C. Both RHRWS subsystems inoperable.	C.1 -----NOTE----- Enter applicable Conditions and Required Actions of LCO 3.4.9 for RHR shutdown cooling subsystems made inoperable by RHRWS System. -----  Restore one RHRWS subsystem to OPERABLE status.	8 hours
D. Required Action and associated Completion Time of Condition C not met.	D.1 Be in MODE 3.  <u>AND</u>  D.2 Be in MODE 4.	12 hours   36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.1.1 Verify each RHRWS manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	31 days

3.7 PLANT SYSTEMS

3.7.2 Diesel Generator Cooling Water (DGCW) System

LCO 3.7.2 The following DGCW subsystems shall be OPERABLE:

- a. Three DGCW subsystems; and
- b. The opposite unit Division 2 DGCW subsystem.

APPLICABILITY: MODES 1, 2, and 3.

ACTIONS

-----NOTE-----  
Separate Condition entry is allowed for each DGCW subsystem.  
-----

CONDITION	REQUIRED ACTION	COMPLETION TIME
A. One or more DGCW subsystems inoperable.	A.1 Declare supported component(s) inoperable.	Immediately

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
SR 3.7.2.1 Verify each DGCW subsystem manual, power operated, and automatic valve in the flow path, that is not locked, sealed, or otherwise secured in position, is in the correct position.	31 days
SR 3.7.2.2 Verify each DGCW pump starts automatically on each required actual or simulated initiation signal.	24 months

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>C. Required Division 3 DG inoperable.</p> <p><u>OR</u></p> <p>One required Division 1, 2, or 3 DG inoperable and the required opposite unit Division 2 DG inoperable.</p>	<p>C.1 Perform SR 3.8.1.1 for OPERABLE required offsite circuit(s).</p>	<p>1 hour</p> <p><u>AND</u></p>
	<p><u>AND</u></p>	<p>Once per 8 hours thereafter</p>
	<p>C.2 Declare required feature(s), supported by the inoperable DG(s), inoperable when the redundant required feature(s) are inoperable.</p>	<p>4 hours from discovery of Condition C concurrent with inoperability of redundant required feature(s)</p>
	<p><u>AND</u></p>	
	<p>C.3.1 Determine OPERABLE DG(s) are not inoperable due to common cause failure.</p>	<p>24 hours</p>
	<p><u>OR</u></p>	
<p>C.3.2 Perform SR 3.8.1.2 for OPERABLE DG(s).</p>	<p>24 hours</p>	
<p><u>AND</u></p>		
<p>C.4 Restore required DG(s) to OPERABLE status.</p>	<p>72 hours</p> <p><u>AND</u></p> <p>17 days from discovery of failure to meet LCO 3.8.1.a or b</p>	

(continued)

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>F. Two required Division 1, 2, or 3 DGs inoperable.</p> <p><u>OR</u></p> <p>Division 2 DG and the required opposite unit Division 2 DG inoperable.</p>	<p>F.1 Restore one required DG to OPERABLE status.</p>	<p>2 hours</p> <p><u>OR</u></p> <p>72 hours if Division 3 DG is inoperable</p>
<p>G. Required Action and associated Completion Time of Condition A, B, C, D, E, or F not met.</p>	<p>G.1 Be in MODE 3.</p>	<p>12 hours</p>
<p>H. Three or more required AC sources inoperable.</p>	<p>H.1 Enter LCO 3.0.3.</p>	<p>Immediately</p>

SURVEILLANCE REQUIREMENTS

- NOTES-----
1. SR 3.8.1.1 through SR 3.8.1.20 are applicable only to the given unit's AC electrical power sources.
  2. SR 3.8.1.21 is applicable to the required opposite unit's DG.
- 

SURVEILLANCE	FREQUENCY
SR 3.8.1.1     Verify correct breaker alignment and indicated power availability for each required offsite circuit.	7 days
SR 3.8.1.2     -----NOTES----- <ol style="list-style-type: none"> <li>1. All DG starts may be preceded by an engine prelube period and followed by a warmup period prior to loading.</li> <li>2. A modified DG start involving idling and gradual acceleration to synchronous speed may be used for this SR as recommended by the manufacturer. When modified start procedures are not used, the time, voltage, and frequency tolerances of SR 3.8.1.7 must be met.</li> <li>3. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> Verify each required DG starts from standby conditions and achieves steady state voltage $\geq 4010$ V and $\leq 4310$ V and frequency $\geq 58.8$ Hz and $\leq 61.2$ Hz.	31 days

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.8.1.3	<p>-----NOTES-----</p> <ol style="list-style-type: none"> <li>1. DG loadings may include gradual loading as recommended by the manufacturer.</li> <li>2. Momentary transients outside the load range do not invalidate this test.</li> <li>3. This Surveillance shall be conducted on only one DG at a time.</li> <li>4. This SR shall be preceded by, and immediately follow, without shutdown, a successful performance of SR 3.8.1.2 or SR 3.8.1.7.</li> <li>5. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> <p>Verify each required DG is synchronized and loaded and operates for <math>\geq 60</math> minutes at a load <math>\geq 2400</math> kW and <math>\leq 2600</math> kW.</p>	31 days
SR 3.8.1.4	Verify each required day tank contains $\geq 250$ gal of fuel oil for Divisions 1 and 2 and $\geq 550$ gal for Division 3.	31 days
SR 3.8.1.5	Check for and remove accumulated water from each required day tank.	31 days
SR 3.8.1.6	Verify each required fuel oil transfer system operates to automatically transfer fuel oil from storage tanks to the day tank.	92 days

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.7 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. All DG starts may be preceded by an engine prelube period.</li> <li>2. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> <p>Verify each required DG starts from standby condition and achieves:</p> <ol style="list-style-type: none"> <li>a. In <math>\leq 13</math> seconds, voltage <math>\geq 4010</math> V and frequency <math>\geq 58.8</math> Hz; and</li> <li>b. Steady state voltage <math>\geq 4010</math> V and <math>\leq 4310</math> V and frequency <math>\geq 58.8</math> Hz and <math>\leq 61.2</math> Hz.</li> </ol>	<p>184 days</p>
<p>SR 3.8.1.8 -----NOTE-----</p> <p>This Surveillance shall not normally be performed in MODE 1 or 2. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</p> <p>-----</p> <p>Verify manual transfer of unit power supply from the normal offsite circuit to the alternate offsite circuit.</p>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.9 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. This Surveillance shall not normally be performed in MODE 1 or 2. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</li> <li>2. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> <p>Verify each required DG rejects a load greater than or equal to its associated single largest post-accident load and following load rejection, the frequency is <math>\leq 66.7</math> Hz.</p>	<p>24 months</p>
<p>SR 3.8.1.10 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. This Surveillance shall not normally be performed in MODE 1 or 2. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</li> <li>2. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> <p>Verify each required DG does not trip and voltage is maintained <math>\leq 5000</math> V during and following a load rejection of a load <math>\geq 2600</math> kW.</p>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.11 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. All DG starts may be preceded by an engine prelube period.</li> <li>2. This Surveillance shall not normally be performed in MODE 1 or 2. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</li> </ol> <p>-----</p> <p>Verify on an actual or simulated loss of offsite power signal:</p> <ol style="list-style-type: none"> <li>a. De-energization of emergency buses;</li> <li>b. Load shedding from emergency buses for Divisions 1 and 2 only; and</li> <li>c. DG auto-starts from standby condition and:               <ol style="list-style-type: none"> <li>1. energizes permanently connected loads in <math>\leq 13</math> seconds,</li> <li>2. energizes auto-connected shutdown loads,</li> <li>3. maintains steady state voltage <math>\geq 4010</math> V and <math>\leq 4310</math> V,</li> <li>4. maintains steady state frequency <math>\geq 58.8</math> Hz and <math>\leq 61.2</math> Hz, and</li> <li>5. supplies permanently connected and auto-connected shutdown loads for <math>\geq 5</math> minutes.</li> </ol> </li> </ol>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.12 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. All DG starts may be preceded by an engine prelube period.</li> <li>2. This Surveillance shall not normally be performed in MODE 1 or 2. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</li> </ol> <p>-----</p> <p>Verify on an actual or simulated Emergency Core Cooling System (ECCS) initiation signal each required DG auto-starts from standby condition and:</p> <ol style="list-style-type: none"> <li>a. In <math>\leq 13</math> seconds after auto-start, achieves voltage <math>\geq 4010</math> V and frequency <math>\geq 58.8</math> Hz;</li> <li>b. Achieves steady state voltage <math>\geq 4010</math> V and <math>\leq 4310</math> V and frequency <math>\geq 58.8</math> Hz and <math>\leq 61.2</math> Hz; and</li> <li>c. Operates for <math>\geq 5</math> minutes.</li> </ol>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.13 -----NOTE-----            This Surveillance shall not normally be performed in MODE 1 or 2. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.            -----            Verify each required DG's automatic trips are bypassed on an actual or simulated ECCS initiation signal except:</p> <ul style="list-style-type: none"> <li>a. Engine overspeed; and</li> <li>b. Generator differential current.</li> </ul>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.14 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. Momentary transients outside the load and power factor ranges do not invalidate this test.</li> <li>2. This Surveillance shall not normally be performed in MODE 1 or 2 unless the other two DGs are OPERABLE. If either of the other two DGs becomes inoperable, this Surveillance shall be suspended. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</li> <li>3. If grid conditions do not permit, the power factor limit is not required to be met. Under this condition, the power factor shall be maintained as close to the limit as practicable.</li> <li>4. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> <p>Verify each required DG operating within the power factor limit operates for <math>\geq 24</math> hours:</p> <ol style="list-style-type: none"> <li>a. For <math>\geq 2</math> hours loaded <math>\geq 2860</math> kW; and</li> <li>b. For the remaining hours of the test loaded <math>\geq 2400</math> kW and <math>\leq 2600</math> kW.</li> </ol>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.15 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. This Surveillance shall be performed within 5 minutes of shutting down the DG after the DG has operated <math>\geq 2</math> hours loaded <math>\geq 2400</math> kW and <math>\leq 2600</math> kW.  Momentary transients outside of load range do not invalidate this test.</li> <li>2. All DG starts may be preceded by an engine prelube period.</li> <li>3. A single test of the common DG at the specified Frequency will satisfy the Surveillance for both units.</li> </ol> <p>-----</p> <p>Verify each required DG starts and achieves:</p> <ol style="list-style-type: none"> <li>a. In <math>\leq 13</math> seconds, voltage <math>\geq 4010</math> V and frequency <math>\geq 58.8</math> Hz; and</li> <li>b. Steady state voltage <math>\geq 4010</math> V and <math>\leq 4310</math> V and frequency <math>\geq 58.8</math> Hz and <math>\leq 61.2</math> Hz.</li> </ol>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.16 -----NOTE-----            This Surveillance shall not normally be performed in MODE 1 or 2. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.            -----            Verify each required DG:            a. Synchronizes with offsite power source while loaded with emergency loads upon a simulated restoration of offsite power;            b. Transfers loads to offsite power source; and            c. Returns to ready-to-load operation.</p>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.17 -----NOTE-----  This Surveillance shall not normally be performed in MODE 1 or 2. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.  -----  Verify, with a required DG operating in test mode and connected to its bus:</p> <ul style="list-style-type: none"> <li>a. For Division 1 and 2 DGs, an actual or simulated ECCS initiation signal overrides the test mode by returning DG to ready-to-load operation; and</li> <li>b. For Division 3 DG, an actual or simulated DG overcurrent trip signal automatically disconnects the offsite power source while the DG continues to supply normal loads.</li> </ul>	<p>24 months</p>
<p>SR 3.8.1.18 -----NOTE-----  This Surveillance shall not normally be performed in MODE 1 or 2. However, this Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.  -----  Verify interval between each sequenced load block, for Division 1 and 2 DGs only, is <math>\geq 90\%</math> of the design interval for each time delay relay.</p>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.19 -----NOTES-----</p> <ol style="list-style-type: none"> <li>1. All DG starts may be preceded by an engine prelube period.</li> <li>2. This Surveillance shall not normally be performed in MODE 1 or 2. However, portions of the Surveillance may be performed to reestablish OPERABILITY provided an assessment determines the safety of the plant is maintained or enhanced. Credit may be taken for unplanned events that satisfy this SR.</li> </ol> <p>-----</p> <p>Verify, on an actual or simulated loss of offsite power signal in conjunction with an actual or simulated ECCS initiation signal:</p> <ol style="list-style-type: none"> <li>a. De-energization of emergency buses;</li> <li>b. Load shedding from emergency buses for Divisions 1 and 2 only; and</li> <li>c. DG auto-starts from standby condition and:               <ol style="list-style-type: none"> <li>1. energizes permanently connected loads in <math>\leq 13</math> seconds,</li> <li>2. energizes auto-connected emergency loads including through time delay relays, where applicable,</li> <li>3. maintains steady state voltage <math>\geq 4010</math> V and <math>\leq 4310</math> V,</li> <li>4. maintains steady state frequency <math>\geq 58.8</math> Hz and <math>\leq 61.2</math> Hz, and</li> <li>5. supplies permanently connected and auto-connected emergency loads for <math>\geq 5</math> minutes.</li> </ol> </li> </ol>	<p>24 months</p>

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.8.1.20 -----NOTE-----            All DG starts may be preceded by an engine prelube period.            -----            Verify, when started simultaneously from standby condition, each required DG achieves, in <math>\leq 13</math> seconds, voltage <math>\geq 4010</math> V and frequency <math>\geq 58.8</math> Hz.</p>	<p>10 years</p>
<p>SR 3.8.1.21 -----NOTE-----            When the opposite unit is in MODE 4 or 5, or moving irradiated fuel assemblies in secondary containment, the following opposite unit SRs are not required to be performed: SR 3.8.1.3, SR 3.8.1.9 through SR 3.8.1.11, SR 3.8.1.14 through SR 3.8.1.16.            -----            For required opposite unit DG, the SRs of the opposite unit's Specification 3.8.1, except SR 3.8.1.12, SR 3.8.1.13, SR 3.8.1.17, SR 3.8.1.18, SR 3.8.1.19, and SR 3.8.1.20, are applicable.</p>	<p>In accordance with applicable SRs</p>

5.6 Reporting Requirements

---

5.6.5 CORE OPERATING LIMITS REPORT (COLR) (continued)

4. The Rod Block Monitor Upscale Instrumentation Setpoint for the Rod Block Monitor-Upscale Function Allowable Value for Specification 3.3.2.1.
5. The OPRM setpoints for the trip function for SR 3.3.1.3.3.
- b. The analytical methods used to determine the core operating limits shall be those previously reviewed and approved by the NRC, specifically those described in the following documents:
  1. ANF-524(P)(A), "ANF Critical Power Methodology for Boiling Water Reactors."
  2. ANF-913(P)(A), "COTRANSA 2: A Computer Program for Boiling Water Reactor Transient Analysis."
  3. ANF-CC-33(P)(A), "HUXY: A Generalized Multirod Heatup Code with 10 CFR 50, Appendix K Heatup Option."
  4. XN-NF-80-19(P)(A), "Advanced Nuclear Fuel Methodology for Boiling Water Reactors."
  5. XN-NF-85-67(P)(A), "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel."
  6. EMF-CC-074(P)(A), Volume 4 - "BWR Stability Analysis: Assessment of STAIF with input from MICROBURN-B2."
  7. XN-NF-81-58(P)(A), "RODEX2 Fuel Rod Thermal-Mechanical Response Evaluation Model."
  8. XN-NF-84-105(P)(A), "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis."

(continued)

---



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 194 TO FACILITY OPERATING LICENSE NO. NPF-11

AND AMENDMENT NO. 181 TO FACILITY OPERATING LICENSE NO. NPF-18

EXELON GENERATION COMPANY, LLC

LASALLE COUNTY STATION, UNITS 1 AND 2

DOCKET NOS. 50-373 AND 50-374

## 1.0 INTRODUCTION

By letter to the U.S. Nuclear Regulatory Commission (NRC) dated September 11, 2008, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082550530), as supplemented by letter dated August 11, 2009 (ADAMS Accession No. ML092240199), Exelon Generation Company, LLC (the licensee), requested, among other things, changes to the Technical Specifications (TS) for the LaSalle County Station (LaSalle), Units 1 and 2. The proposed TS changes would remove changes that were applicable in the following refueling outage: Unit 1 Refueling Outage 11, Unit 2 Refueling Outage 11 and Unit 1 Refueling Outage 12. The TS were approved and issued to the licensee in two letters dated February 23, 2006 (ADAMS Accession No. ML060270103) and November 20, 2006 (ADAMS Accession No. ML063250247).

### 1.1 Proposed License Amendment

The proposed TS changes would remove the TS that applied only during Unit 1 Refueling Outage 11, Unit 2 Refueling Outage 11 and Unit 1 Refueling Outage 12 in TS 3.7.1, "Residual Heat Removal (RHR) Service Water (RHRSW) System," TS 3.7.2, "Diesel Generator (DG) Cooling Water (DGCW) System" and TS 3.8.1, "AC Sources-Operating." Specifically, the proposed changes would remove the following notes, conditions, required actions and completion times as described below:

- Remove a condition note that states, "Not applicable to Unit 2 during replacement of the Division 1 CSCS isolation valves during Unit 1 Refueling 11 while Unit 1 is in Mode 4, 5, or defueled" from TS 3.7.1 Condition A.
- Remove TS 3.7.1 Condition B, Required Action B.1 and the associated completion time, "Restore RHRSW subsystem to OPERABLE status," associated with TS 3.7.1 in 10 days. Condition B is only applicable to Unit 2 during replacement of the Division 1 core standby cooling system (CSCS) isolation valves during Unit 1 Refueling 11 while Unit 1 is in Mode 4, 5, or defueled.
- Remove a condition note that states, "1. Not applicable to Division 1 during replacement of the Division 1 CSCS isolation valves during Unit 1 Refueling 11 while Unit 1 is in Mode

4, 5, or defueled. 2. Not applicable to Division 2 during replacement of the Division 2 CSCS isolation valves during Unit 2 Refueling 11 while Unit 2 is in Mode 4, 5, or defueled and during Unit 1 Refueling 12 while Unit 1 is in Mode 4, 5 or defueled” from TS 3.7.2 Condition A.

- Remove Condition B, Required Action B.1 and the associated completion time, a 6-day (for Division 2 CSCS valve maintenance) or 10-day (for Division 1 CSCS valve maintenance) completion time for TS 3.7.2 when one or more required DG cooling water subsystems(s) are inoperable. Condition B is only applicable for two specific times: (1) only applicable to Division 1 during replacement of the Division 1 CSCS isolation valves during Unit 1 Refueling 11 while Unit 1 is in Mode 4, 5, or defueled; (2) only applicable to Division 2 during replacement of the Division 2 CSCS isolation valves during Unit 2 Refueling 11 while Unit 2 is in Mode 4, 5, or defueled and during Unit 1 Refueling 12 while Unit 1 is in Mode 4, 5 or defueled.
- Remove TS 3.7.2 Condition C, “Required Action and the associated Completion Time of Condition B not met.”
- Remove a condition note that states, “1. Not applicable to Unit 1 during replacement of the Unit 2 Division 2 CSCS isolation valves during Unit 2 Refueling 11 while Unit 2 is in Mode 4, 5, or defueled. 2. Not applicable to Unit 2 during replacement of the Unit 1 Division 2 CSCS isolation valves during Unit 1 Refueling 12 while Unit 1 is in Mode 4, 5, or defueled” from TS 3.8.1 Condition C.
- Remove a condition note that states, “1. Not applicable to Unit 1 during replacement of the Unit 2 Division 2 CSCS isolation valves during Unit 2 Refueling 11 while Unit 2 is in Mode 4, 5, or defueled. 2. Not applicable to Unit 2 during replacement of the Unit 1 Division 2 CSCS isolation valves during Unit 1 Refueling 12 while Unit 1 is in Mode 4, 5, or defueled” from TS 3.8.1 Condition F.
- Remove Condition G, “Division 2 DG and the required opposite unit Division 2 DG inoperable” which is only applicable when, “1. Only applicable to Unit 1 during replacement of the Unit 2 Division 2 CSCS isolation valves during Unit 2 Refueling 11 while Unit 2 is in Mode 4, 5, or defueled. 2. Only applicable to Unit 2 during replacement of the Unit 1 Division 2 CSCS isolation valves during Unit 1 Refueling 12 while Unit 1 is in Mode 4, 5, or defueled” in TS 3.8.1.
- Remove TS 3.8.1 Condition I, “Required Action and associated Completion Time of Condition A, B, C, D, E, or F not met.”

These approved TS notes, conditions, required actions, and completion times were only used during Unit 1 Refueling Outage 11 (spring 2006), Unit 2 Refueling Outage 11 (spring 2007), and Unit 1 Refueling Outage 12 (spring 2008).

The proposed amendment also corrects an administrative error in TS section 5.6.5, “Core Operating Limits Report (COLR)”. TS Section 5.6.5 is being changed to align with the title used in the COLR.

## 2.0 REGULATORY EVALUATION

Section 50.36, "Technical Specifications," of Title 10 of the *Code of Federal Regulations* (10 CFR) establishes the regulatory requirements related to the content of TS. Pursuant to 10 CFR 50.36, TS include items in the following five specific categories related to station operation: (1) safety limits, limiting safety system settings, and limiting control settings; (2) limiting condition for operation; (3) surveillance requirements; (4) design features; and (5) administrative controls. The rule does not specify the particular requirements to be included in a plant's TS. As stated in 10 CFR 50.36(c)(2)(i), the "Limiting conditions for operation are the lowest functional capability or performance levels of equipment required for safe operation of the facility. When a limiting condition for operation of a nuclear reactor is not met, the licensee shall shut down the reactor or follow any remedial action permitted by the technical specifications."

TS changes can be grouped into four general categories as follows: administrative, relocated requirements, more restrictive requirements, and less restrictive requirements. These four general categories of changes to the TS requirements may be better understood as follows:

- Administrative Changes. Non-technical, administrative changes were intended to incorporate human-factors principles into the form and structure of the improved plant TS so that they would be easier to use for plant operations personnel. These changes are editorial in nature or involve the reorganization or reformatting of requirements without affecting technical content or operational requirements.
- Relocated requirements. Existing TS requirements which do not satisfy or fall within any of the four specified criteria may be relocated to appropriate licensee-controlled documents.
- More Restrictive Requirements. Licensee's can propose TS changes which include more restrictive requirements than are contained in the existing TS, which are either more conservative than corresponding requirements in the existing TS, or are additional restrictions which are contained in NUREG-1433 but are not contained in the existing TS.
- Less Restrictive Requirements. When requirements have been shown to provide little or no safety benefit, their removal from the TS may be appropriate. In most cases, relaxations in TS are the result of generic NRC actions, new NRC staff positions that have evolved from technological advancements and operating experience, or resolution of the Owners Groups' comments on the improved STS.

## 3.0 TECHNICAL EVALUATION

The proposed amendment removes time, cycle, or modification-related items from the TSs. The time, cycle, or modification-related items have been implemented or superseded, are no longer applicable, and no longer need to be maintained in the TS. Specifically, the proposed amendment removes conditional Notes related to TS associated with the Core Standby Cooling System (CSCS) valve replacement project. The refueling outages related to the extension of the Completion Times associated with the TS Sections 3.7.1, "Residual Heat Removal Service

Water (RHRSW) System,” 3.7.2, “Diesel Generator Cooling Water (DGCW) System,” and 3.8.1, “AC Sources Operating,” are complete and the added Conditions are no longer needed. Additionally, there is an administrative correction to TS Section 5.6.5, “Core Operating Limits Report.” The topical report XN-NF-524(P)(A), “ANF Critical Power Methodology for Boiling Water Reactors” referenced in TS 5.6.5 is being administratively changed to ANF-524(P)(A), “ANF Critical Power Methodology for Boiling Water Reactors.” LaSalle’s core operating limit report references topical report ANF-524(P)(A) Revision 2, “ANF Critical Power Methodology for Boiling Water Reactors” which was evaluated by the NRC and found to be acceptable on August 8, 1990 (ADAMS Accession No. ML9008130091). Finally, the proposed amendment will result in various editorial and formatting changes to the TS.

The TS notes, conditions, required actions and completion times were only used during Unit 1 Refueling Outage 11, Unit 2 Refueling Outage 11, and Unit 1 Refueling Outage 12 which were approved and issued to the licensee in the letters, referenced above in Section 1.0, are no longer applicable and can no longer be applied at LaSalle. The proposed amendment does not change any items in the safety limits, limiting safety system settings, limiting control settings; limiting conditions for operation; surveillance requirements; design features; or administrative controls in 10 CFR 50.36.

All changes proposed by Exelon Generation Company, LLC in this amendment request are administrative in nature, and propose removing one-time requirements that are no longer applicable. There are no physical changes to the facilities, nor any changes to the station operating procedures, limiting conditions for operation, or limiting safety system settings. The proposed amendment does not deviate from existing regulatory requirements and compliance with existing regulations is maintained. Therefore, with respect to compliance with current regulations, the NRC staff considers the proposed TS changes to be acceptable.

#### 4.0 STATE CONSULTATION

In accordance with the Commission’s regulations, the Illinois State official was notified of the proposed issuance of the amendments. The State official had no comments.

#### 5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). In addition, the amendment changes are administrative. Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(10). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

## 6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: K. Bucholtz

Date: August 28, 2009

Mr. Charles G. Pardee  
President and Chief Nuclear Officer  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

August 28, 2009

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2, ISSUANCE OF AMENDMENTS  
RE: DELETE OBSOLETE LICENSE CONDITIONS AND REVISE TECHNICAL  
SPECIFICATIONS (TAC NOS. MD9616 AND MD9617)

Dear Mr. Pardee:

The U.S. Nuclear Regulatory Commission (the Commission) has issued the enclosed Amendment No. 194 to Facility Operating License No. NPF-11 and Amendment No. 181 to Facility Operating License No. NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The amendments are in response to your application dated September 11, 2008 (Agencywide Document Management and Access System (ADAMS) Accession No. ML082550530), as supplemented by letter dated August 11, 2009 (ADAMS Accession No. ML092240199).

The amendments remove time, cycle, or modification-related items from the operating licenses and Technical Specifications (TS). Additionally, the amendment corrects a typographical error introduced into the TS from a previous amendment.

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly *Federal Register* notice.

Sincerely,

*/RA/*

Cameron S. Goodwin, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosures:

1. Amendment No. 194 to NPF-11
2. Amendment No. 181 to NPF-18
3. Safety Evaluation

cc w/encls: See next page

DISTRIBUTION:

PUBLIC	RidsNrrDorIDpr Resource	RidsNrrPMLaSalle Resource
RidsOgcRp Resource	RidsNrrDirsltsb Resource	RidsRgn3MailCenter Resource
RidsNrrDorLpl3-2 Resource	RidsNrrLATHarris Resource	LPL3-2 R/F
RidsAcrcAcnw_MailCTR Resource		

Amendment Accession No. ML092040273 NRR-058 \*Concurrence via memo dated

OFFICE	LPL3-2/PM	LPL3-2/LA	DIRS/ITSB	OGC(NLO)	LPL3-2/BC
NAME	CGoodwin	THarris	RElliott*	LSubin	SCampbell
DATE	8 /17/09	8 /13/09	6 / 16 /09	8 /21/09	8/28/09

OFFICIAL RECORD COPY

Mr. Charles G. Pardee  
President and Chief Nuclear Officer  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

September 3, 2009

**SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 – CORRECTION LETTER FOR  
LICENSE AMENDMENT NOS. 193 AND 180 RE: DELETE OBSOLETE  
LICENSE CONDITIONS AND REVISE TECHNICAL SPECIFICATIONS  
(TAC NOS. MD9616 AND MD9617)**

Dear Mr. Pardee:

By letter dated August 27, 2009 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML092040273), the Nuclear Regulatory Commission (NRC) staff issued Amendment Nos. 193 and 180 to Facility Operating License Nos. NPF-11 and NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The amendments remove time, cycle, or modification-related items from the operating licenses and Technical Specifications in response to your application dated September 11, 2008 (ADAMS Accession No. ML082550530), as supplemented by letter dated August 11, 2009 (ADAMS Accession No. ML092240199).

Administrative errors were identified in the amendments. The amendments were incorrectly dated. They should be dated for August 28, 2009. It was also noted that the amendment numbers used were incorrect. The correct amendment numbers are 194 and 181 for LaSalle County Station, Units 1 and 2, respectively. Please replace the amendments dated August 27, 2009, with the enclosed amendments.

The incorrect information was editorial in nature. The corrections do not change the approval conveyed by the amendments, or the conclusions reached by the associated safety evaluation. We regret any inconvenience this may have caused you.

Sincerely,

**/RA/**

Cameron S. Goodwin, Project Manager  
Plant Licensing Branch III-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:

Amendments dated August 28, 2009

cc w/encl: Distribution via ListServ

**DISTRIBUTION:**

PUBLIC LPL3-2 R/F RidsNrrPMLaSalle Resource  
RidsOgcRp Resource RidsNrrDirsltsb Resource  
RidsRgn3MailCenter Resource RidsNrrDorLpl3-2 Resource  
RidsNrrLATHarris Resource RidsNrrDorIDpr Resource  
RidsAcraAcnw\_MailCTR Resource

ADAMS Accession No. M092450404 NRR-106

OFFICE	LPL3-2/PM	LPL3-2/LA	LPL3-2/BC
NAME	CGoodwin	THarris	SCampbell
DATE	9/3/09	9/2/09	9/3/09

OFFICIAL RECORD COPY