

From: Vaidya, Bhalchandra
Sent: Tuesday, August 25, 2009 7:29 AM
To: 'Dorman, Eugene'; 'Pechacek, Joseph'
Cc: Salgado, Nancy; Pickett, Douglas; McHale, John; Tingen, Steve
Subject: ME1818 - Revised DRAFT RAI # 1 - Relief Request VRR-06

Based on the telephone discussions on August 24, 2009, between the NRC staff and the licensee staff, the revised RAI # 1 is provided below:

=====

=====

REVISED RAI #1
RELIEF REQUEST VRR-06
DOCKET NO. 50-333
TAC NO. ME1818

1. Request VRR-06 states that approximately one third of the main steam safety relief valve main assemblies (4, 4, and 3 main assemblies over a three-cycle period) will be sent to an offsite vendor and tested with steam pressure each refueling outage. Please describe how each main assembly will be tested with steam pressure.

=====

As committed to by the licensee during the telephone discussions, the supplemental submission providing the responses to all RAI Questions (two) are expected by September 4, 2009.

Please contact me, if you have any questions.

Bhalchandra K. Vaidya
Licensing Project Manager
NRC/NRR/DORL/LPL1-1
(301)-415-3308 (O)
bhalchandra.vaidya@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: ME1818 - Revised DRAFT RAI # 1 - Relief Request VRR-06
Sent Date: 08/25/2009 7:15:20 AM
Received Date: 08/25/2009 7:29:00 AM
From: Vaidya, Bhalchandra

Created By: Bhalchandra.Vaidya@nrc.gov

Recipients:
EDorman@entergy.com ('Dorman, Eugene')
Tracking Status: None
JPechac@entergy.com ('Pechacek, Joseph')

Tracking Status: None
Nancy.Salgado@nrc.gov (Salgado, Nancy)
Tracking Status: None
Douglas.Pickett@nrc.gov (Pickett, Douglas)
Tracking Status: None
John.McHale@nrc.gov (McHale, John)
Tracking Status: None
Steve.Tingen@nrc.gov (Tingen, Steve)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	14276	08/25/2009

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: