



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

October 13, 2009

Mr. Gene F. St. Pierre  
Site Vice President  
c/o Michael O'Keefe  
Seabrook Station  
NextEra Energy Seabrook, LLC  
P.O. Box 300  
Seabrook, NH 03874

**SUBJECT: SEABROOK STATION, UNIT NO. 1 - ISSUANCE OF AMENDMENT RE:  
CHANGES TO THE STEAM GENERATOR INSPECTION SCOPE AND  
REPAIR REQUIREMENTS (TAC NO. ME1386)**

Dear Mr. St. Pierre:

The Commission has issued the enclosed Amendment No. 123 to Facility Operating License No. NPF-86 for the Seabrook Station, Unit No. 1 (Seabrook). This amendment consists of changes to the Technical Specifications (TSs) in response to your application dated May 28, 2009, as supplemented by letters on September 16, 18, and 25, 2009. The letter dated September 18, 2009, revised the TSs as originally proposed in the application to be applicable only for Refueling Outage 13 and the next inspection cycle.

The amendment changes the inspection scope and repair requirements of TS Section 6.7.6.k, "Steam Generator (SG) Programs," and reporting requirements of TS Section 6.8.1.7, "Steam Generator Tube Inspection Report." The changes establish interim alternate repair criteria for portions of the SG tubes within the tubesheet.

G. St. Pierre

- 2 -

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly *Federal Register* notice.

Sincerely,



The signature is handwritten in black ink. It consists of the letters "D.E." followed by "Egan" and a small "for" written vertically below "Egan".

Dennis Egan, P.E.,  
Senior Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:

1. Amendment No. 123 to NPF-86
2. Safety Evaluation

cc w/encls: Distribution via Listserv



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

NEXTERA ENERGY SEABROOK, LLC, ET AL.\*

DOCKET NO. 50-443

SEABROOK STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123  
License No. NPF-86

1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment filed by NextEra Energy Seabrook, LLC, et al., (the licensee) dated May 28, 2009, as supplemented by letters on September 16, 18 and 25, 2009, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be imimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

---

\*NextEra Energy Seabrook, LLC is authorized to act as agent for the: Hudson Light & Power Department, Massachusetts Municipal Wholesale Electric Company, and Taunton Municipal Light Plant and has exclusive responsibility and control over the physical construction, operation and maintenance of the facility.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-86 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123, and the Environmental Protection Plan contained in Appendix B are incorporated into the Facility License No. NPF-86. NextEra Energy Seabrook, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days. The alternate inspection and repair criteria, approved in this amendment, are applicable to steam generator tube inspections performed during refueling outage 13 and any tube inspections performed prior to the next inspection required by TS 6.7.6.k.d.

FOR THE NUCLEAR REGULATORY COMMISSION



Harold K. Chernoff, Chief  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Attachment: Changes to the License and  
Technical Specifications

Date of Issuance: October 13, 2009

ATTACHMENT TO LICENSE AMENDMENT NO. 123

FACILITY OPERATING LICENSE NO. NPF-86

DOCKET NO. 50-443

Replace the following page of Facility Operating License No. NPF-86 with the attached revised page. The revised page is identified by amendment number and contains a marginal line indicating the area of change.

Remove  
3

Insert  
3

Replace the following pages of the Appendix A, Technical Specifications, with the attached revised pages as indicated. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove  
6-13  
6-14  
6-21

Insert  
6-13  
6-14  
6-21  
6-21a

- (4) NextEra Energy Seabrook, LLC, pursuant to the Act and 10 CFR 30, 40, and 70, to receive, possess, and use at any time any byproduct, source, and special nuclear material as sealed neutron sources for reactor startup, sealed sources for reactor instrumentation and radiation monitoring equipment calibration, and as fission detectors in amounts as required;
  - (5) NextEra Energy Seabrook, LLC, pursuant to the Act and 10 CFR 30, 40, and 70, to receive, possess, and use in amounts as required any byproduct, source, or special nuclear material without restriction to chemical or physical form, for sample analysis or instrument calibration or associated with radioactive apparatus or components;
  - (6) NextEra Energy Seabrook, LLC, pursuant to the Act and 10 CFR 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by the operation of the facility authorized herein; and
  - (7) **DELETED**
- C. This license shall be deemed to contain and is subject to the conditions specified in the Commission's regulations set forth in 10 CFR Chapter I and is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; is subject to the additional conditions specified or incorporated below:
- (1) **Maximum Power Level**

NextEra Energy Seabrook, LLC, is authorized to operate the facility at reactor core power levels not in excess of 3648 megawatts thermal (100% of rated power).
  - (2) **Technical Specifications**

The Technical Specifications contained in Appendix A, as revised through Amendment No. 123 \*, and the Environmental Protection Plan contained in Appendix B are incorporated into the Facility License No. NPF-86. NextEra Energy Seabrook, LLC shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.
  - (3) **License Transfer to FPL Energy Seabrook, LLC\*\***
    - a. On the closing date(s) of the transfer of any ownership interests in Seabrook Station covered by the Order approving the transfer, FPL Energy Seabrook, LLC\*\*, shall obtain from each respective transferring owner all of the accumulated decommissioning trust funds for the facility, and ensure the deposit of such funds and additional funds, if necessary, into a decommissioning trust or trusts for Seabrook Station established by FPL Energy Seabrook, LLC\*\*, such that the amount of such funds deposited meets or exceeds the amount required under 10 CFR 50.75 with respect to the interest in Seabrook Station FPL Energy Seabrook, LLC\*\*, acquires on such dates(s).

\* Implemented

\*\* On April 16, 2009, the name "FPL Energy Seabrook, LLC" was changed to "NextEra Energy Seabrook, LLC".

## **ADMINISTRATIVE CONTROLS**

---

### **PROCEDURES AND PROGRAMS**

#### **6.7.6 (Continued)**

The following alternate tube repair criteria shall be applied as an alternative to the 40% depth based criteria:

For refueling outage 13 and the subsequent inspection cycle, tubes with service-induced flaws located greater than 13.1 inches below the top of the tubesheet do not require plugging. Tubes with service-induced flaws located in the portion of the tube from the top of the tubesheet to 13.1 inches below the top of the tubesheet shall be plugged upon detection.

- d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet, and that may satisfy the applicable tube repair criteria. For refueling outage 13 and the subsequent inspection cycle, the portion of the tube below 13.1 inches from the top of the tubesheet is excluded from this requirement. The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. An assessment of degradation shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.
  1. Inspect 100% of the tubes in each SG during the first refueling outage following SG replacement.
  2. Inspect 100% of the tubes at sequential periods of 120, 90, and, thereafter, 60 effective full power months. The first sequential period shall be considered to begin after the first inservice inspection of the SGs. In addition, inspect 50% of the tubes by the refueling outage nearest the midpoint of the period and the remaining 50% by the refueling outage nearest the end of the period. No SG shall operate for more than 48 effective full power months or two refueling outages (whichever is less) without being inspected.

## ADMINISTRATIVE CONTROLS

---

### PROCEDURES AND PROGRAMS

#### 6.7.6 (Continued)

3. If crack indications are found in portions of the SG tube not excluded above, then the next inspection for each SG for the degradation mechanism that caused the crack indication shall not exceed 24 effective full power months or one refueling outage (whichever is less). If definitive information, such as from examination of a pulled tube, diagnostic non-destructive testing, or engineering evaluation indicates that a crack-like indication is not associated with a crack(s), then the indication need not be treated as a crack.

#### e. Provisions for monitoring operational primary to secondary leakage.

##### I. Control Room Envelope Habitability Program

A Control Room Envelope (CRE) Habitability Program shall be established and implemented to ensure that CRE habitability is maintained such that, with an OPERABLE Control Room Emergency Makeup Air and Filtration System (CREMAFS), CRE occupants can control the reactor safely under normal conditions and maintain it in a safe condition following a radiological event, hazardous chemical release, or a smoke challenge. The program shall ensure that adequate radiation protection is provided to permit access and occupancy of the CRE under design basis accident (DBA) conditions without personnel receiving radiation exposures in excess of 5 rem total effective dose equivalent (TEDE) for the duration of the accident. The program shall include the following elements:

- a. The definition of the CRE and the CRE boundary.
- b. Requirements for maintaining the CRE boundary in its design condition including configuration control and preventive maintenance.
- c. Requirements for (i) determining the unfiltered air in-leakage past the CRE boundary into the CRE in accordance with the testing methods and at the Frequencies specified in Sections C.1 and C.2 of Regulatory Guide 1.197, "Demonstrating Control Room Envelope Integrity at Nuclear Power Reactors," Revision 0, May 2003, and (ii) assessing CRE habitability at the Frequencies specified in Sections C.1 and C.2 of Regulatory Guide 1.197, Revision 0.

## **ADMINISTRATIVE CONTROLS**

---

6.8.1.6.c The core operating limits shall be determined so that all applicable limits (e.g., fuel thermal-mechanical limits, core thermal-hydraulic limits, ECCS limits, nuclear limits such as SHUTDOWN MARGIN, and transient and accident analysis limits) of the safety analysis are met. The CORE OPERATING LIMITS REPORT for each reload cycle, including any mid-cycle revisions or supplements thereto, shall be provided upon issuance, to the NRC Document Control Desk with copies to the Regional Administrator and the Resident Inspector.

### **STEAM GENERATOR TUBE INSPECTION REPORT**

- 6.8.1.7 A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with Specification 6.7.6.k, Steam Generator (SG) Program. The report shall include:
- a. The scope of inspections performed on each SG,
  - b. Active degradation mechanisms found,
  - c. Nondestructive examination techniques utilized for each degradation mechanism,
  - d. Location, orientation (if linear), and measured sizes (if available) of service induced indications,
  - e. Number of tubes plugged during the inspection outage for each active degradation mechanism,
  - f. Total number and percentage of tubes plugged to date,
  - g. The results of condition monitoring, including the results of tube pulls and in-situ testing,
  - h. The effective plugging percentage for all plugging in each SG.
  - i. For refueling outage 13 and the subsequent inspection cycle, the primary to secondary leakage rate observed in each SG (if it is not practical to assign the leakage to an individual SG, the entire primary to secondary leakage should be conservatively assumed to be from one SG) during the cycle preceding the inspection which is the subject of the report,
  - j. For refueling outage 13 and the subsequent inspection cycle, the calculated accident induced leakage rate from the portion of the tubes below 13.1 inches from the top of the tubesheet for the most limiting accident in the most limiting SG. In addition, if the calculated accident induced leakage rate from the most limiting accident is less than 2.50 times the maximum operational primary to secondary leakage rate, the report should describe how it was determined, and

## ADMINISTRATIVE CONTROLS

---

### 6.8.1.7 (Continued)

- k. For refueling outage 13, the results of monitoring for tube axial displacement (slippage). If slippage is discovered, the implications of the discovery and corrective action shall be provided.

### SPECIAL REPORTS

6.8.2 Special reports shall be submitted to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attn: Document Control Desk, with a copy to the NRC Regional Administrator within the time period specified for each report.

### **6.9 (THIS SPECIFICATION NUMBER IS NOT USED)**



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001**

**SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION**

**RELATED TO AMENDMENT NO. 123**

**TO FACILITY OPERATING LICENSE NO. NPF-86**

**SEABROOK STATION, UNIT NO. 1**

**DOCKET NO. 50-443**

**1.0 INTRODUCTION**

By letter dated May 28, 2009, NextEra Energy Seabrook, LLC (the licensee) submitted a license amendment request (LAR) to revise the technical specifications (TSs) of Seabrook Station, Unit No. 1 (Seabrook) (Reference 1). The request proposed changes to the inspection scope and repair requirements of TS Section 6.7.6.k, "Steam Generator (SG) Program," and to the reporting requirements of TS Section 6.8.1.7, "Steam Generator Tube Inspection Report." The proposed changes would establish permanent alternate repair criteria for portions of the SG tubes within the tubesheet. In response to an unresolved technical issue, the licensee submitted a letter dated September 18, 2009 (Reference 3), which revised the requested changes to the TSs proposed in the May 28, 2009, LAR to be one-time changes to TS 6.7.6.k and TS 6.8.1.7 rather than a permanent change. Specifically, the licensee's letter stated that the proposed changes related to SG tube inspection and repair would be applicable only "during refueling outage 13 and the subsequent operating cycles until the next scheduled inspection of the steam generator tubing." Throughout this safety evaluation and as shown in the TS changes proposed by the licensee, the time period for the one-time change is shown as "for refueling outage 13 and the subsequent inspection cycle." The term "inspection cycle" refers to the period between SG inspections required by Seabrook TS 6.7.6.k.d. As such, the proposed amendment would be applicable to SG tube inspections performed during refueling outage 13 (RFO 13) and any tube inspections performed prior to the next inspection required by TS 6.7.6.k.d.

The May 28, 2009, letter was supplemented by letters dated September 16, 18, and 25, 2009, (References 2, 3, and 4, respectively), which provided additional information that clarified the application, did not expand the scope of the application as originally noticed, and did not change the staff's original proposed no significant hazards consideration determination as published in the *Federal Register* on July 21, 2009 (74 FR 35891).

**2.0 BACKGROUND**

Seabrook Unit 1 has four Model F SGs that were designed and fabricated by Westinghouse. There are 5,626 Alloy 600 tubes in each SG, each with an outside diameter of 0.688 inches, and a nominal wall thickness of 0.040 inches. The thermally-treated tubes are hydraulically expanded for the full depth of the 21-inch tubesheet and are welded to the tubesheet at each tube end.

Until the fall of 2004, no instances of stress-corrosion cracking (SCC) affecting the tubesheet region of thermally treated Alloy 600 tubing had been reported at any nuclear power plants in the United States. In the fall of 2004, crack-like indications were found in tubes in the tubesheet region of Catawba Nuclear Station Unit 2 (Catawba), which has Westinghouse Model D5 SGs. Like Seabrook, the Catawba SGs use thermally treated Alloy 600 tubing that is hydraulically expanded against the tubesheet. The crack-like indications at Catawba were found in a tube overexpansion (OXP), in the tack expansion region, and near the tube-to-tubesheet (T/TS) weld. An OXP is created when the tube is expanded into a tubesheet bore hole that is not perfectly round. These out-of-round conditions were created during the tubesheet drilling process by conditions such as drill bit wandering or chip gouging. The tack expansion is an approximately 1-inch long expansion at each tube end. The purpose of the tack expansion is to facilitate performing the T/TS weld, which is made prior to the hydraulic expansion of the tube over the full tubesheet depth.

Since the initial findings at Catawba in the fall of 2004, other nuclear plants have found crack-like indications in tubes within the tubesheet as well. These plants include: Braidwood Station, Unit 2; Byron Station, Unit 2; Comanche Peak Steam Electric Station, Unit 2; Surry Power Station, Unit 2; Vogtle Electric Generating Plant (Vogtle), Unit 1; and Wolf Creek Generating Station. Most of the indications were found in the tack expansion region near the tube-end welds and were a mixture of axial and circumferential primary water SCC.

On February 21, 2006, Wolf Creek Nuclear Operating Corporation (WCNOC), the licensee for Wolf Creek Generating Station, submitted an LAR that would permanently limit the scope of inspections required for tubes within the tubesheet (Reference 5). The LAR was based on an analysis performed by Westinghouse Electric Company LLC (Westinghouse) that provided a technical basis for permanently limiting the scope of inspections required for tubes within the tubesheet. After three requests for additional information (RAIs) and several meetings with WCNOC, the Nuclear Regulatory Commission (NRC) staff informed WCNOC during a phone call on January 3, 2008, that it had not provided sufficient information to allow the NRC staff to approve the permanent LAR. WCNOC withdrew the LAR by letter dated February 14, 2008 (Reference 6). In a letter dated February 28, 2008 (Reference 7), the staff identified the specific issues that needed to be addressed to support any future request for a permanent amendment.

Southern Nuclear Operating Company (SNC), the licensee for Vogtle, had also submitted a permanent LAR (Reference 8) that used the same technical basis as the WCNOC LAR. Upon learning of the withdrawal of the WCNOC permanent LAR, SNC modified its permanent LAR by letter dated February 13, 2008 (Reference 9), with a one-cycle LAR that used a conservative interim alternate repair criteria (IARC) approach. The IARCs for Vogtle Unit 1 and Unit 2 were thus approved by the NRC on April 9, 2008 (Reference 10), and September 16, 2008 (Reference 11).

After SNC received approval of the IARC amendments, several licensees submitted and gained approval of one-cycle IARC amendments that used the more conservative approach. Seabrook currently has an approved one-cycle IARC amendment.

Subsequently, the licensees and their contractor, Westinghouse, worked with the NRC staff to address the issues posed in Reference 7. The NRC and industry held public meetings (References 12, 13, and 14) and phone calls to discuss resolution of these issues.

The permanent LAR submitted by Seabrook in May 2009 (Reference 1), resolved the issues identified by the staff in Reference 7, but the staff review raised additional technical issues. Subsequently, the licensee modified its LAR in a letter dated September 18, 2009, such that the proposed changes would only be applicable for one inspection cycle (Reference 3).

### 3.0 REGULATORY EVALUATION

The SG tubes are part of the reactor coolant pressure boundary (RCPB) and isolate fission products in the primary coolant from the secondary coolant. For the purposes of this safety evaluation, SG tube integrity means that the tubes are capable of performing this safety function in accordance with the plant design and licensing basis. The General Design Criteria (GDC) in Appendix A to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, state that the RCPB shall have "an extremely low probability of abnormal leakage...and of gross rupture" (GDC 14), "shall be designed with sufficient margin" (GDCs 15 and 31), shall be of "the highest quality standards practical" (GDC 30), and shall be designed to permit "periodic inspection and testing...to assess...structural and leaktight integrity" (GDC 32). The licensee discusses conformance with each of these GDCs for Seabrook in Section 3.1 of the Updated Final Safety Analysis Report (UFSAR) and does not identify deviations from these GDC for SG tube-related issues.

In 10 CFR 50.55a, it specifies that components which are part of the RCPB must meet the requirements for Class 1 components in Section III of the American Society of Mechanical Engineers *Boiler and Pressure Vessel Code* (ASME Code), except as provided in 10 CFR 50.55a(c)(2), (3), and (4). Section 50.55a further requires that throughout the service life of pressurized-water reactor (PWR) facilities (like Seabrook), ASME Code Class 1 components meet the Section XI requirements of the ASME Code to the extent practical, except for design and access provisions, and pre-service examination requirements. This requirement includes the inspection and repair criteria of Section XI of the ASME Code. The Section XI requirements pertaining to in-service inspection of SG tubing are augmented by additional requirements in the TS. The use of the proposed alternate repair criteria does not impact the integrity of the SG tubes and, therefore, the SG tubes still meet the description of conformance with the GDC in Appendix A to 10 CFR Part 50, provided in the Seabrook UFSAR and the requirements for Class 1 components in Section III of the ASME Code.

Analyses addressing the consequences of postulated design-basis accidents (DBAs), such as an SG tube rupture and a main steam line break (MSLB) are included in the plant's licensing basis. These analyses consider primary-to-secondary leakage that may occur during these events and must demonstrate that the offsite radiological consequences and control room operator doses do not exceed the applicable limits. The proposed changes do not affect the

accident analyses and consequences that the NRC has reviewed and approved for the postulated DBAs for SG tubes.

In 10 CFR 50.36, "Technical specifications," the requirements for administrative control provisions are established to assure operation of the facility in a safe manner. For Seabrook, the requirements for performing SG tube inspections and repair are in TS 6.7.6.k, while the requirements for reporting the SG tube inspections and repair are in TS 6.8.1.7.

SG tube integrity is maintained by meeting the performance criteria specified in TS 6.7.6.k.b for structural and leakage integrity, consistent with the plant design and licensing basis.

TS 6.7.6.k.a requires that a condition monitoring assessment be performed during each outage in which the SG tubes are inspected, to confirm that the performance criteria are being met.

TS 6.7.6.k.d includes provisions regarding the scope, frequency, and methods of SG tube inspections. These provisions require that the inspections be performed with the objective of detecting flaws of any type that may be present along the length of a tube, from the T/TS weld at the tube inlet to the T/TS weld at the tube outlet. The applicable tube repair criteria, specified in TS 6.7.6.k.c., are that tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40 percent of the nominal wall thickness shall be plugged, unless the tubes are permitted to remain in service through application of the alternate repair criteria provided in TS 6.7.6.k.c.

In License Amendment No. 112 the provisions for SG tube repair criteria, currently shown in TS 6.7.6.k.c., were modified with interim alternate repair criteria that were applicable during Seabrook Refueling Outage 11 (1R11) and the subsequent operating cycles. The interim alternate repair criteria excluded some indications of primary water SCC in the lowermost 4 inches of the tubesheet from application of the 40-percent, depth-based, tube-repair criterion. The proposed amendment eliminates inspection and repair of tubes more than 13.1 inches below the top of the tubesheet (TTS). Tubes with service-induced flaws located in the portion of the tube from the TTS to 13.1 inches below the TTS shall be plugged upon detection. The proposed amendment for these alternate inspection and repair criteria would be applicable to SG tube inspections performed during refueling outage (RFO) 13 and any tube inspections performed prior to the next inspection required by TS 6.7.6.k.d.

#### 4.0 TECHNICAL EVALUATION

##### 4.1 Proposed Changes to the TSs

TS 6.7.6.k.c. is being revised as follows (new text in **bold**):

- c. Provisions for SG tube repair criteria. Tubes found by inservice inspection to contain flaws with a depth equal to or exceeding 40% of the nominal tube wall thickness shall be plugged.

The following alternate tube repair criteria **shall** be applied as an alternative to the 40% depth based criteria:

**For refueling outage 13 and the subsequent inspection cycle, tubes with service-induced flaws located greater than 13.1 inches below the top of the tubesheet do not require plugging. Tubes with service-induced flaws located in the portion of the tube from the top of the tubesheet to 13.1 inches below the top of the tubesheet shall be plugged upon detection.**

TS 6.7.6.k.d. is being revised as follows (new text in **bold**):

- d. Provisions for SG tube inspections. Periodic SG tube inspections shall be performed. The number and portions of the tubes inspected and methods of inspection shall be performed with the objective of detecting flaws of any type (e.g., volumetric flaws, axial and circumferential cracks) that may be present along the length of the tube, from the tube-to-tubesheet weld at the tube inlet to the tube-to-tubesheet weld at the tube outlet, and that may satisfy the applicable tube repair criteria. **For refueling outage 13 and the subsequent inspection cycle, the portion of the tube below 13.1 inches from the top of the tubesheet is excluded from this requirement.** The tube-to-tubesheet weld is not part of the tube. In addition to meeting the requirements of d.1, d.2, and d.3 below, the inspection scope, inspection methods, and inspection intervals shall be such as to ensure that SG tube integrity is maintained until the next SG inspection. An assessment of degradation shall be performed to determine the type and location of flaws to which the tubes may be susceptible and, based on this assessment, to determine which inspection methods need to be employed and at what locations.
  1. [No change/Not shown]
  2. [No change/Not shown]
  3. **If crack indications are found in portions of the SG tube not excluded above, then the next inspection for each SG for the degradation mechanism that caused the crack indication shall not exceed 24 effective full power months or one refueling outage (whichever is less). If definitive information, such as from examination of a pulled tube, diagnostic nondestructive testing, or engineering evaluation indicates that a crack-like indication is not associated with a crack(s), then the indication need not be treated as a crack.**

TS 6.8.1.7 is being revised as follows (new text in **bold**):

A report shall be submitted within 180 days after the initial entry into MODE 4 following completion of an inspection performed in accordance with the Specification 6.7.6.k, Steam Generator (SG) Program. The report shall include:

- a. – h. [No change/Not shown]
- i. **For refueling outage 13 and the subsequent inspection cycle, the primary to secondary leakage rate observed in each SG (if it is not practical to assign the leakage to an individual SG, the entire primary to secondary leakage should be conservatively assumed to be from one SG) during the cycle preceding the inspection which is the subject of the report,**
- j. **For refueling outage 13 and the subsequent inspection cycle, the calculated accident induced leakage rate from the portion of the tubes below 13.1 inches from the top of the tubesheet for the most limiting accident in the most limiting SG. In addition, if the calculated accident induced leakage rate from the most limiting accident is less than 2.50 times the maximum operational primary to secondary leakage rate, the report should describe how it was determined, and**
- k. **For refueling outage 13, the results of monitoring for tube axial displacement (slippage). If slippage is discovered, the implications of the discovery and corrective action shall be provided.**

#### 4.2 Technical Evaluation

The T/TS joints are part of the pressure boundary between the primary and secondary systems. Each T/TS joint consists of the tube, which is hydraulically expanded against the bore of the tubesheet, the T/TS weld located at the tube end, and the tubesheet. The joints were designed in accordance with the ASME Code, Section III, as welded joints, not as friction joints. The T/TS welds were designed to transmit the tube end-cap pressure loads, during normal operating and DBA conditions, from the tubes to the tubesheet with no credit taken for the friction developed between the hydraulically-expanded tube and the tubesheet. In addition, the welds serve to make the joints leak-tight.

This design basis is a conservative representation of how the T/TS joints actually work, since it conservatively ignores the role of friction between the tube and tubesheet in reacting with the tube end-cap loads. The initial hydraulic expansion of the tubes against the tubesheet produces an “interference fit” between the tubes and the tubesheet; thus, producing a residual contact pressure between the tubes and tubesheet, which acts normally to the outer surface of the tubes and the inner surface of the tubesheet bore holes. Additional contact pressure between the tubes and tubesheet is induced by operational conditions, as will be discussed in detail

below. The amount of friction force that can be developed between the outer tube surface and the inner surface of the tubesheet bore is a direct function of the contact pressure between the tube and tubesheet times the applicable coefficient of friction.

To support the proposed TS changes, the licensee's contractor, Westinghouse, has defined a parameter called  $H^*$  to be that distance below the TTS over which sufficient frictional force, with acceptable safety margins, can be developed between each tube and the tubesheet under tube end-cap pressure loads associated with normal operating and DBA conditions to prevent significant slippage or pullout of the tube from the tubesheet, assuming the tube is fully severed at the  $H^*$  distance below the TTS. For Seabrook, the proposed  $H^*$  distance is 13.1 inches. Given that the frictional force developed in the T/TS joint over the  $H^*$  distance is sufficient to resist the tube end-cap pressure loads, it is the licensee's and Westinghouse's position that the length of tubing between the  $H^*$  distance and the T/TS weld is not needed to resist any portion of the tube end-cap pressure loads. Thus, the licensee is proposing to change the TS to not require inspection of the tubes below the  $H^*$  distance and to exclude tube flaws located below the  $H^*$  distance (including flaws in the T/TS weld) from the application of the TS tube repair criteria. Under these changes, the T/TS joint would now be treated as a friction joint extending from the TTS to a distance below the TTS equal to  $H^*$  for purposes of evaluating the structural and leakage integrity of the joint.

The regulatory standard by which the staff has evaluated the subject license amendment is that the amended TSs should continue to ensure that tube integrity will be maintained consistent with the current design basis, as defined in the UFSAR. This includes maintaining structural safety margins consistent with the structural performance criteria in TS 6.7.6.k.b.1 discussed in Section 4.2.1.1 below. In addition, this includes limiting the potential for accident-induced primary-to-secondary leakage to values that do not exceed the accident-induced leakage performance criteria in TS 6.7.6.k.b.2, which are consistent with values assumed in the UFSAR accident analyses. Maintaining tube integrity in this manner ensures that the amended TSs are in compliance with all applicable regulations. The staff's evaluation of joint structural integrity and accident-induced leakage integrity is discussed in Sections 4.2.1 and 4.2.2 of this safety evaluation, respectively.

#### 4.2.1 Joint Structural Integrity

##### 4.2.1.1 Acceptance Criteria

Westinghouse has conducted extensive analyses to establish the necessary  $H^*$  distance to resist pullout under normal operating and DBA conditions. The staff finds that pullout is the structural failure mode of interest since the tubes are radially constrained against axial fishmouth rupture by the presence of the tubesheet. The axial force which could produce pullout is derived from the pressure end-cap loads due to the primary-to-secondary pressure differentials associated with normal operating and DBA conditions. Westinghouse determined the needed  $H^*$  distance on the basis of maintaining a factor of three against pullout under normal operating conditions and a factor of 1.4 against pullout under DBA conditions. The staff

finds that these are the appropriate safety factors to apply to demonstrate structural integrity. These safety factors are consistent with the safety factors embodied in the structural integrity performance criteria in TS 6.7.6.k.b.1 and with the design basis including the stress limit criteria in the ASME Code, Section III.

#### 4.2.1.2 T/TS Interaction Model

The resistance to pullout is the axial friction force developed between the expanded tube and the tubesheet over the H\* distance. The friction force is a function of the radial contact pressure between the expanded tube and the tubesheet. Westinghouse used classical thick-shell equations to model the interaction effects between the tubes and tubesheet under various pressure and temperature conditions for purposes of calculating contact pressure (T/TS interaction model). For each tube, the tubesheet was modeled as an equivalent cylinder. The thickness of this equivalent cylinder was calculated to provide a stiffness equivalent to the actual tubesheet geometry in terms of the amount of tubesheet bore radial displacement that is associated with a given amount of radial pressure on the surface of the bore. Two-dimensional (2-D) finite element analyses of portions of the perforated tubesheet geometry were used to determine the thickness of the equivalent tubesheet cylinder that provided the necessary stiffness, as a function of tube location within the bundle. These analyses directly modeled a spectrum of possibilities concerning the pressure loads acting on nearby bore surfaces, instead of employing a beta factor adjustment as was done to support previous H\* amendment requests submitted prior to 2008. Based on its review, the staff concludes that the equivalent tubesheet cylinder thicknesses calculated by Westinghouse are conservative since they provide for lower bound stiffness estimates, leading to lower (conservative) estimates of contact pressure and resistance to pullout.

The shell model representing the tube was used to determine the relationship between the tube outer surface radial displacement and the applied axial end-cap load (due to the primary-to-secondary pressure differential), primary pressure acting on the tube inner surface, crevice pressure<sup>1</sup> acting on the tube outer surface, contact pressure between the tube and tubesheet bore, and tube thermal expansion. However, the equivalent shell model representing the tubesheet was used only to determine the relationship between the tubesheet bore surface radial displacement with the applied crevice pressure and contact pressure. Radial displacements of the tubesheet bore surfaces are also functions of the primary pressure acting on the primary face of the tubesheet and SG channel head, secondary pressure acting on the secondary face of the tubesheet and SG shell, and the temperature distribution throughout the entire lower SG assembly. These displacements are a function of tube location within the tube bundle and, also, a function of axial location within the tubesheet. To calculate these displacements, three-dimensional (3-D) finite element finite analyses were performed. The staff's evaluation of these finite element analyses is provided in Section 4.2.1.3, below. The

---

<sup>1</sup> Although the tubes are in tight contact with the tubesheet bore surfaces, surface roughness effects are conservatively assumed to create interstitial spaces, which are effectively crevices, between these surfaces. See Section 4.2.1.4 for more information.

tubesheet bore radial displacements from the 3-D finite element analyses were added to those from the tubesheet equivalent shell model to yield the total displacement of the tubesheet bore surface as a function of tube radial and axial location.

The reference T/TS interaction model (Reference 15) assumes as an initial condition that each tube is fully expanded against the tubesheet bore such that the outer tube surface is in contact with the inner surface of the tubesheet bore under room temperature, atmospheric pressure conditions, with zero residual contact pressure associated with the hydraulic expansion process. The staff finds the assumption of zero residual contact pressure in the reference analysis to be a very conservative assumption.

The thick-shell equations used in the T/TS interaction model allow calculation of the tube radial displacements and the tubesheet equivalent cylinder radial displacements for a given set of pressure and temperature conditions. Under normal operational and DBA pressures and temperatures, the tube outer surface undergoes a higher radial displacement than the tubesheet bore surface if interaction between the tube and tubesheet is ignored. Because T/TS interaction effects demand continuity of displacements (i.e., the radial displacement of the tube outer surface equal the radial displacement of the bore surface) at each axial location, contact pressure of sufficient magnitude to ensure equal radial displacements is developed between the two surfaces and can be directly solved for. The staff has reviewed the development of the T/TS interaction model and finds that it conservatively approximates the actual T/TS interaction effects and the resulting contact pressures.

The classical thick-shell equations used in the interaction model were developed for cylindrical shells whose geometry and applied loads are uniform along the cylindrical axis. As discussed above, radial deflections of the tubesheet bores are non-uniform from the top to the bottom of the tubesheet, due to the temperature and pressure loadings acting on the various components of the SG lower assembly. In addition, the crevice pressure may vary in the axial direction as discussed below. The interaction model essentially divides the T/TS joint into a series of horizontal slices, where each slice is assumed to behave independently of the slices above and below. The staff concludes this to be conservative since it adds radial flexibility to the T/TS joint leading to lower contact pressures and tube pullout resistance.

The resisting force to the applied end-cap load, which is developed over each incremental axial distance from the TTS, is the average contact pressure over that incremental distance times the tubesheet bore surface area (equal to the tube outer diameter surface area) over the incremental axial distance times the coefficient of friction. The staff reviewed the coefficient of friction used in the analysis and judges it to be a reasonable lower bound (conservative) estimate. The  $H^*$  distance for each tube was determined by integrating the incremental friction forces from the TTS to the distance below the TTS where the friction force integral equaled the applied end-cap load times the appropriate safety factor as discussed in Section 4.2.1.1.

In summary, the staff has evaluated the T/TS interaction model and finds it to be a reasonable and conservative approach for the calculation of  $H^*$  distances.

#### 4.2.1.3 3-D Finite Element Analysis

A 3-D finite element analysis of the lower SG assembly (consisting of the lower portion of the SG shell, the tubesheet, the channel head, and the divider plate separating the hot- and cold-leg inlet plenums inside the channel head) was performed to calculate the diameter changes of the tubesheet bore surfaces due to primary pressure acting on the primary face of the tubesheet and SG channel head, secondary pressure acting on the secondary face of the tubesheet and SG shell, and the temperature distribution throughout the entire lower SG assembly. These calculated diameter changes tended to be non-uniform around the circumference of the bore. The thick-shell equations used in the T/TS interaction model are axisymmetric. Thus, the non-uniform diameter change from the 3-D finite element analyses had to be adjusted to an equivalent uniform value before it could be used as input to the T/TS interaction analysis. A 2-D plane stress finite element model was used to define a relationship for determining a uniform diameter change that would produce the same change to average T/TS contact pressure as would the actual non-uniform diameter changes from the 3-D finite element analyses. In Reference 16, Westinghouse identified a difficulty in applying this relationship to Model D5 SGs. In reviewing the reasons for this difficulty, the staff developed questions relating to the conservatism of the relationship and whether the tubesheet bore displacement eccentricities are sufficiently limited such as to ensure that T/TS contact is maintained around the entire tube circumference. Responses to staff questions provided in Reference 2 did not provide sufficient information to allow the staff to reach a conclusion on the concerns relating to tubesheet bore displacement eccentricity. The licensee, therefore, modified its permanent amendment request on September 18, 2009 (Reference 3), to be an interim amendment request applicable only to RFO 13 and the subsequent inspection cycle. Section 4.2.4 provides the staff's evaluation of the interim H\* amendment request in light of the open issue relating to tubesheet bore displacement eccentricity. As described in Section 4.2.4, there is sufficient information to enable the staff to evaluate the proposed one-inspection-cycle change.

This 3-D finite element analysis replaces the 2-D axisymmetric finite element analyses used to support H\* amendment requests submitted prior to 2008. The staff finds that the 3-D analysis adequately addresses a concern cited by the staff in Reference 7 concerning the validity of the axisymmetric model to conservatively bound significant non-axisymmetric features of the actual tubesheets. These non-axisymmetric features include the solid (non-bored) portion of the tubesheet between the hot- and cold-leg sides, and the divider plate which acts to connect the solid part of the tubesheet to the channel head.

Some non-U.S. units have experienced cracks in the weld between the divider plate and the stub runner attachment on the bottom of the tubesheet. Should such cracks ultimately cause the divider plate to become disconnected from the tubesheet, tubesheet vertical and radial displacements under operational conditions could be significantly increased relative to those for an intact divider plate weld. Although the industry believes that there is little likelihood that cracks such as those seen abroad could cause a failure of the divider plate weld, the 3-D finite element analysis conservatively considered both the case of an intact divider plate weld and a

detached divider plate weld to ensure a conservative analysis. The case of a detached divider plate weld was found to produce the most limiting H\* values.

Separate 3-D finite element analyses were conducted for each loading condition considered (i.e., normal operating conditions, MSLB, feedwater line break (FLB)). The staff finds that this adequately addresses (corrects) a significant source of error in analyses used by applicants to support permanent H\* amendment requests submitted prior to 2008 and which were subsequently withdrawn or modified.

#### 4.2.1.4 Crevice Pressure Evaluation

As discussed in footnote 1, the H\* analyses postulate that interstitial spaces exist between the hydraulically-expanded tubes and tubesheet bore surfaces. These interstitial spaces are assumed to act as crevices between the tubes and the tubesheet bore surfaces. The staff finds that the assumption of crevices is conservative since the pressure inside the crevices acts to push against both the tube and the tubesheet bore surfaces, thus reducing contact pressure between the tubes and tubesheet.

For tubes which do not contain through-wall flaws within the thickness of the tubesheet, the pressure inside the crevice is assumed to be equal to the secondary system pressure. For tubes that contain through-wall flaws within the thickness of the tubesheet, a leak path is assumed to exist, from the primary coolant inside the tube, through the flaw, and up the crevice to the secondary system. Hydraulic tests were performed on several tube specimens that were hydraulically expanded against tubesheet collar specimens to evaluate the distribution of the crevice pressure from a location where through-wall holes had been drilled into the tubes to the top of the crevice location. The T/TS collar specimens were instrumented at several axial locations to permit direct measurement of the crevice pressures. Tests were run for both normal operating and MSLB pressure and temperature conditions.

The staff finds that the use of the drilled holes, rather than through-wall cracks, is conservative since it eliminates any pressure drop between the inside of the tube and the crevice at the hole location. This maximizes the pressure in the crevice at all elevations, thus reducing contact pressure between the tubes and tubesheet.

The crevice pressure data from these tests were used to develop a crevice pressure distribution as a function of normalized distance between the TTS and the H\* distance below the TTS where the tube is assumed to be severed. These distributions were used to determine the appropriate crevice pressure for each axial slice of the T/TS interaction model. Based on its review of the tests and test results, the staff finds the assumed crevice pressure distributions to be realistic and acceptable.

Because the crevice pressure distribution is assumed to extend from the H\* location, where crevice pressure is assumed to equal primary pressure, to the TTS, where crevice pressure equals secondary pressure, an initial assumption as to the H\* location must be made before

solving for  $H^*$  using the T/TS interaction model and 3-D finite element model. The resulting new  $H^*$  estimate becomes the initial estimate for the next  $H^*$  iteration.

#### 4.2.1.5 $H^*$ Calculation Process

The calculation of  $H^*$  in the reference analyses (Reference 15), consisted of the following steps for each loading case considered:

1. Perform initial  $H^*$  estimate using the interaction and 3-D finite element models, assuming nominal geometric and material properties, and assuming that the tube is severed at the bottom of the tubesheet for purposes of defining the pressure distribution over the length of the T/TS crevice.
2. Add 0.3-inch adjustment to the initial  $H^*$  estimate to account for uncertainty in the bottom of the tube expansion transition (BET) location relative to the TTS, based on an uncertainty analysis on the BET for Model F SGs conducted by Westinghouse.
3. For normal operating conditions only, add an additional adjustment to correct for the actual temperature distribution in the tubesheet compared to the linear distribution assumed in the finite element analysis. As discussed in Section 4.2.1.7, this step is conservative.
4. Steps 1 through 3 yield a so-called "mean" estimate of  $H^*$ , which is deterministically based. Step 4 involves a probabilistic analysis of the potential variability of  $H^*$ , relative to the mean estimate, associated with the potential variability of key input parameters for the  $H^*$  analyses. This leads to a "probabilistic" estimate of  $H^*$ , which includes the mean estimate.
5. Add a crevice pressure adjustment to the probabilistic estimate of  $H^*$  to account for the crevice pressure distribution which results from the tube being severed at the final  $H^*$  value, rather than at the bottom of the tubesheet. The value of this adjustment was determined iteratively.

The staff's evaluation of the probabilistic analysis is provided in Section 4.2.1.7 of this safety evaluation. Regarding step 2, the staff did not review the Westinghouse BET uncertainty analysis. Therefore, at the staff's request, the licensee has committed to a one-time inspection of the actual BET locations during the fall of 2009, to confirm that there are no significant deviations from the assumed BET value. Any such deviations will be entered into the corrective actions program for disposition. The staff finds this to be acceptable, since the BET inspections are a one-time action that is reviewable during routine NRC regional oversight activities. Any deviations are likely to be small (less than a few tenths of an inch) and not likely to impact the overall conservatism of the proposed  $H^*$  distance.

#### 4.2.1.6 Acceptance Standard - Probabilistic Analysis

The purpose of the probabilistic analysis is to develop a safe  $H^*$  distance that ensures, with a probability of 0.95, that the population of tubes will retain margins against pullout consistent with criteria evaluated in Section 4.2.1.1 of this safety evaluation, assuming all tubes to be completely severed at their  $H^*$  distance. The staff finds this probabilistic acceptance standard is consistent with what the staff has approved previously and is acceptable. For example, the upper voltage limit for the voltage-based tube repair criteria in NRC Generic Letter 95-05 (Reference 17) employs a consistent criterion. The staff also notes that use of the 0.95 probability criterion ensures that the probability of pullout of one or more tubes under normal operating conditions and conditional probability of pullout under accident conditions is well within tube rupture probabilities that have been considered in probabilistic risk assessments (References 18 and 19).

In terms of the confidence level that should be attached to the 0.95 probability acceptance standard, it is industry practice for SG tube integrity evaluations, as embodied in industry guidelines, to calculate such probabilities at a 50 percent confidence level. The Westinghouse recommended  $H^*$  value of 11.2 inches in Reference 15 for Model F SGs is based on probabilistic estimates performed at a 50 percent confidence value. However, as discussed in Section 4.2.1.7, the staff finds that the 13.1 inch  $H^*$  value proposed by the licensee conservatively bounds an  $H^*$  value based on probabilistic estimates performed at a 95 percent confidence value.

Another issue relating to the acceptance standard for the probabilistic analysis is determining what population of tubes needs to be analyzed. For accidents such as MSLB or FLB, the staff and licensee both find that the tube population in the faulted SG is of interest, since it is the only SG population that experiences a large increase in the primary-to-secondary pressure differential. However, normal operating conditions were found to be the most limiting in terms of meeting the tube pullout margins in Section 4.2.1.1. For normal operating conditions, tubes in all SGs at the plant are subject to the same pressures and temperatures. Although there is not a consensus between the staff and industry on which population needs to be considered in the probabilistic analysis for normal operating conditions, and although the Westinghouse recommended  $H^*$  value in Reference 15 is based on the population of just one SG, the staff finds that the 13.1 inch  $H^*$  value proposed by the licensee conservatively bounds an  $H^*$  value based on probabilistic estimates performed at a 95 percent confidence level for the entire tube population (i.e., for all SGs) at the plant, as discussed in Section 4.2.1.7 below.

#### 4.2.1.7 Probabilistic Analyses

Sensitivity studies were conducted and demonstrated that  $H^*$  was highly sensitive to the potential variability of the coefficients of thermal expansion (CTE) for the Alloy 600 tubing material and the SA-508 Class 2a tubesheet material. Given that no credit was taken in the reference  $H^*$  analyses (Reference 15) for residual contact pressure associated with the tube

hydraulic expansion process<sup>2</sup>, the sensitivity of  $H^*$  to other geometry and material input parameters was judged by Westinghouse to be inconsequential and were ignored, with the exception of Young's modulus of elasticity for the tube and tubesheet materials. Although the Young's modulus parameters were included in the reference  $H^*$  analyses sensitivity studies, these parameters were found to have a weak effect on the computed  $H^*$ . Based on its review of the analysis models and its engineering judgment, the staff concurs that the sensitivity studies adequately capture the input parameters which may significantly affect the value of  $H^*$ . This conclusion is based, in part, on no credit being taken for residual contact pressure during the reference  $H^*$  analyses.

These sensitivity studies were used to develop influence curves describing the change in  $H^*$ , relative to the mean  $H^*$  value estimate (see Section 4.2.1.5), as a function of the variability of each CTE parameter and Young's modulus parameter, relative to the mean values of CTE and Young's Modulus. Separate influence curves were developed for each of the four input parameters. The sensitivity studies showed that of the four input parameters, only the CTE parameters for the tube and tubesheet material had any interaction with one another. A combined set of influence curves containing this interaction effect were also created.

Two types of probabilistic analyses were performed independently. One was a simplified statistical approach utilizing a square root of the sum of the squares method and the other was a detailed Monte Carlo sampling approach. The staff's review relies primarily on the Monte Carlo analysis which provides the more realistic treatment of uncertainties.

The staff reviewed the implementation of probabilistic analyses in the reference analyses (References 15 and 16) and questioned whether the  $H^*$  influence curves had been conservatively treated. The staff concluded that the reference analyses were insufficient to support the amendment request. To address this concern, the licensee submitted new  $H^*$  analyses as documented in Reference 2 and referenced information in Reference 20 (although Reference 20 was submitted on the Vogtle docket, the reference is bounding for the SGs at Seabrook). These analyses made direct use of the  $H^*$  influence curves in a manner the staff finds to be acceptable. To show that the proposed  $H^*$  value in the subject LAR is conservative, the new analyses eliminated some of the conservatisms in the reference analyses as follows:

1. The reference analyses assumed that all tubes were located at the location in the tube bundle where the mean value estimate of  $H^*$  was at its maximum value. The new analyses divided the tubes by sector location within the tube bundle and all tubes were assumed to be at the location in their respective sectors where the mean value estimate of  $H^*$  was at its maximum value for that sector. The  $H^*$  influence curves discussed above, developed for the most limiting tube location in the tube bundle, were conservatively used for all sectors. The staff concludes the sector approach in the new analyses to result in a more realistic, but still conservative  $H^*$  estimate.

---

<sup>2</sup> Residual contact pressures are sensitive to variability of other input parameters.

2. The reference analyses add an incremental distance to  $H^*$  to account for the actual distribution of temperature in the tubesheet under normal operating conditions versus the linear distribution assumed in the reference finite element analyses (see step 3 in Section 4.2.1.5). The new analyses included new finite element analyses which considered the actual distribution of temperature under normal operating conditions. The new analyses confirmed the conservatism of the adjustment made in the reference analyses. The new finite element analyses, in conjunction with the sector analyses in item 1 above, result in an  $H^*$  value which is significantly less than the proposed 13.1 inch  $H^*$  based on a 0.95 probability/50 percent confidence, single SG basis. The staff concludes that direct modeling of the actual temperature distribution in the tubesheet provides a more realistic, but still conservative estimate of  $H^*$ , albeit on a 50 percent confidence, single SG basis. No  $H^*$  estimate was provided on a 0.95 probability/95 percent confidence, all SG basis for this specific case. However, the sensitivity of the calculated  $H^*$  when evaluated at a 95 percent versus 50 percent confidence level and when evaluated on an all SG versus single SG basis was determined for other cases. Based on its review of these sensitivities, the staff concludes that an  $H^*$  value for this case based on a 0.95 probability/95 percent confidence, all SG basis is less than the proposed  $H^*$  distance of 13.1 inches.
3. The reference analyses take no credit for residual contact pressure due to hydraulic expansion of the tubes against the respective tubesheet bores during SG manufacture. The new analyses include consideration of recently completed pullout tests and analyses. The licensee states that the tests confirm a significant level of residual contact pressure, and showed that within a small degree of slippage, the forces required to continue to move the tube by far exceeded the maximum pullout forces that could be generated under very conservative assumptions. The licensee finds that crediting this latest information, in conjunction with the sector analysis discussed in item 1 and the updated correction discussed in item 2 based on direct modeling of the temperature distribution in the tubesheet, leads to a further, significant reduction in the calculated  $H^*$  value relative to values calculated in items 1 and 2. This information, including the latest pullout test data, has not been reviewed in detail by the staff. However, the staff concludes that  $H^*$  estimates that include no credit for residual contact pressure (e.g., the estimates in items 1 and 2 above) are very conservative, as evidenced by the high pullout forces needed to overcome the residual contact pressure.

The new analyses, items 1, 2, and 3 above, also address a question posed by the staff in Reference 7 concerning the appropriate way to sample material properties for the tubesheet, whose properties are unknown but do not vary significantly for a given SG, in contrast to the tubes whose properties tend to vary much more randomly from tube to tube in a given SG. This issue was addressed by a staged sampling process where the tubesheet properties were sampled once and then held fixed, while the tube properties were sampled a number of times equal to the SG tube population. This process was repeated 10,000 times, and the maximum  $H^*$  value from each repetition was rank ordered. The final  $H^*$  value was selected from the rank ordering to reflect a 0.95 probability value at the desired level of confidence. The staff

concludes that this approach addresses the staff's question in a realistic fashion and is acceptable.

Based on items 1 and 2, and considering the significant conservatism associated with the assumption of zero residual contact pressure, the staff concludes that the proposed H\* distance of 13.1 inches for Seabrook Unit 1 ensures that all tubes will have acceptable pullout resistance for normal operating and DBAs, even with the conservative assumption that all tubes are severed at the H\* distance.

The licensee will monitor for tube slippage as part of the SG inspection program. Under the proposed license amendment, TS 6.8.1.7.k will require that the results of slippage monitoring be included as part of the 180-day report required by TS 6.8.1.7. TS 6.8.1.7.k will also require that should slippage be discovered, the implications of the discovery and corrective action shall be included in the report. The staff finds that slippage is not expected to occur for the reasons discussed previously. In the unexpected event it should occur, it will be important to understand why it occurred so that the need for corrective action can be evaluated. The staff concludes the licensee's plan to monitor for slippage and the accompanying reporting requirements are acceptable.

#### 4.2.1.8 Coefficient of Thermal Expansion

During operation, a large part of contact pressure in an SG T/TS joint is derived from the difference in the CTE between the tube and tubesheet. As discussed in Section 4.2.1.7, the calculated value of H\* is highly sensitive to the assumed values of these CTE parameters. However, CTE test data acquired by an NRC contractor, Argonne National Laboratory (ANL), suggested that CTE values may vary substantially from values listed in the ASME Code for design purposes. In Reference 7, the staff highlighted the need to develop a rigorous technical basis for the CTE values, and their potential variability, to be employed in future H\* analyses.

In response, Westinghouse had a subcontractor review the CTE data in question, determine the cause of the variance from the ASME Code CTE values, and provide a summary report (Reference 21). Analysis of the CTE data in question revealed that the CTE variation with temperature had been developed using a polynomial fit to the raw data, over the full temperature range from 75 °F to 1300 °F. The polynomial fit chosen resulted in mean CTE values that were significantly different from the ASME Code values from 75 °F to about 300 °F. When the raw data was reanalyzed using the locally weighted least squares regression method, the mean CTE values determined were in good agreement with the established ASME Code values.

Westinghouse also formed a panel of licensee experts to review the available CTE data in open literature, review the ANL provided CTE data, and perform an extensive CTE testing program on Alloy 600 and SA-508 steel material to supplement the existing data base. Two additional sets of CTE test data (different from those addressed in the previous paragraph) had CTE offsets at low temperature that were not expected. Review of the test data showed that the first

test, conducted in a vacuum, had proceeded to a maximum temperature of 700 °C, which changed the microstructure and the CTE of the steel during decreasing temperature conditions. As a result of the altered microstructure, the CTE test data generated in the second test, conducted in air, was also invalidated. As a result of the large "dead band" region and the altered microstructure, both data sets were excluded from the final CTE values obtained from the CTE testing program.

The test program included multiple material heats to analyze chemistry influence on CTE values and repeat tests on the same samples were performed to analyze for test apparatus influence. Because the tubes are strain-hardened when they are expanded into the tubesheet, strain-hardened samples were also measured to check for strain-hardening influence on CTE values.

The data from the test program were combined with the ANL data that were found by the licensee to be acceptable, and with the data obtained from the open literature search. A statistical analysis of the data uncertainties was performed by comparing deviations to the mean values obtained at the applicable temperatures. The correlation coefficients obtained indicated a good fit to a normal distribution, as expected. Finally, an evaluation of within-heat variability was performed due to increased data scatter at low temperatures. The within-heat variability assessment determined that the increase in data scatter was a testing accuracy limitation that was only present at low temperature. The CTE report is included as Appendix A to References 15 and 16.

The testing showed that the nominal ASME Code values for Alloy 600 and SA-508 steel were both conservative relative to the mean values from all the available data. Specifically, the CTE mean value for Alloy 600 was greater than the ASME Code value and the CTE mean value for SA-508 steel was smaller than the ASME Code value. Thus, the H\* analyses utilized the ASME Code values as mean values in the H\* analyses. The staff finds this to be conservative because it tends to lead to an over-prediction of the expansion of the tubesheet bore and an under-prediction of the expansion of the tube, thereby resulting in an increase in the calculated H\* distance. The statistical variances of the CTE parameters from the combined data base were utilized in the H\* probabilistic analysis.

Based on its review of Westinghouse CTE program, the staff concludes that the CTE values used in the H\* analyses are fully responsive to the concerns stated in Reference 7 and are acceptable.

#### 4.2.2 Accident-induced Leakage Considerations

Operational leakage integrity is assured by monitoring primary-to-secondary leakage relative to the applicable TS limiting condition for operation limits in TS 3.4.6, "Reactor Coolant System OPERATIONAL LEAKAGE." However, it must also be demonstrated that the proposed TS changes do not create the potential for leakage during DBA to exceed the accident leakage performance criteria in TS 6.7.6.k.b.2, including the leakage values assumed in the plant licensing basis accident analyses.

If a tube is assumed to contain a 100 percent through-wall flaw some distance into the tubesheet, a potential leak path between the primary and secondary systems is introduced between the hydraulically-expanded tubing and the tubesheet. The leakage path between the tube and tubesheet has been modeled by the licensee's contractor, Westinghouse, as a crevice consisting of a porous media. Using the Darcy model for flow through a porous media, the leak rate is proportional to differential pressure and inversely proportional to flow resistance. Flow resistance is a direct function of viscosity, loss coefficient, and crevice length.

Westinghouse performed leak tests of T/TS joint mockups to establish the loss coefficient as a function of contact pressure. A large amount of data scatter, however, precluded quantification of such a correlation. In the absence of such a correlation, Westinghouse has developed a leakage factor relationship between accident-induced leak rate and operational leakage rate, where the source of leakage is from flaws located at or below the H\* distance. Using the Darcy model, the leakage factor for a given type accident is the product of four quantities. The first quantity is ratio of the maximum primary-to-secondary pressure difference during the accident divided by that for normal operating conditions. The second quantity is the ratio of viscosity under normal operating primary-water temperature divided by viscosity under the accident condition primary-water temperature. The third quantity is the ratio of crevice length under normal operating conditions to crevice length under accident conditions. This ratio equals 1, provided it can be shown that positive contact pressure is maintained along the entire H\* distance for both conditions. The fourth quantity is the ratio of loss coefficient under normal operating conditions to loss coefficient under the accident condition. Although the absolute value of these loss coefficients is not known, Westinghouse has assumed that the loss coefficient is constant with contact pressure such that the ratio is equal to 1. The staff agrees that this is a conservative assumption, provided there is a positive contact pressure for both conditions along the entire H\* distance and provided that contact pressure increases at each axial location along the H\* distance when going from normal operating to accident conditions. Both assumptions were confirmed to be valid in the H\* analyses.

Leakage factors were calculated for DBAs exhibiting a significant increase in primary-to-secondary pressure differential, including MSLB, FLB, locked rotor, and control rod ejection. The design-basis FLB heat-up transient was found to exhibit the highest leakage factor, 2.50, meaning that it is the transient expected to result in the largest increase in leakage relative to normal operating conditions.

The licensee provided the following information in Reference 3 that describes how the leakage factor will be used to satisfy TS 6.7.6.k.a for condition monitoring and TS 6.7.6.k.b.2 regarding performance criteria for accident-induced leakage:

For the Condition Monitoring assessment, the component of operational leakage from the prior cycle from below the H\* distance will be multiplied by a factor of 2.50 and added to the total accident leakage from any other source and compared to the allowable accident induced leakage limit. For the Operational

Assessment, the difference between the allowable accident induced leakage and the accident induced leakage from sources other than the tubesheet expansion region will be divided by 2.50 and compared to the observed operational leakage. An administrative limit will be established to not exceed the calculated value.

The staff finds this methodology acceptable, since it provides further assurance, in addition to the licensee's operational leakage monitoring processes, that accident-induced SG tube leakage will not exceed values assumed in the licensing bases accident analyses. The staff finds that the leakage factor of 2.50 conservatively bounds the increase in leakage from locations below the H\* distance that may be induced by accident conditions relative to leakage from the same locations under normal operating conditions.

#### 4.2.3 Proposed Change to TS 6.8.1.7, "Steam Generator Tube Inspection Report"

The staff has reviewed the proposed new reporting requirements and finds that they, in conjunction with existing reporting requirements, are sufficient to allow the staff to monitor the condition of the SG tubing as part of its review of the 180-day inspection reports. Based on this conclusion, the staff finds that the proposed new reporting requirements are in accordance with 10 CFR 50.36 and are acceptable.

#### 4.2.4 Technical Bases for Interim H\* Amendment

The proposed H\* value is based on the conservative assumption that all tubes in all SGs are severed at the H\* location. This is a bounding, but necessary assumption for purposes of supporting a permanent H\* amendment because the tubes will not be inspected below the H\* distance for the remaining life of the SGs, which may range up to 30 years from now depending on the plant, and because the tubes are susceptible to SCC below the H\* distance. In addition, the proposed H\* distance conservatively takes no credit for residual contact pressure associated with the tube hydraulic expansion process.

As discussed in Section 4.2.1.3, the NRC staff does not have sufficient information to determine whether the tubesheet bore displacement eccentricity has been addressed in a conservative fashion. Thus, in spite of the significant conservatisms embodied in the proposed H\* distance, the staff is unable to conclude at this time that the proposed H\* distance is, on net, conservative from the standpoint of ensuring that all tubes will retain acceptable margins against pullout (i.e., structural integrity) and acceptable accident leakage integrity for the remaining lifetime of the SGs, assuming all tubes to be severed at the H\* location. However, the licensee is now requesting an interim amendment that is applicable only during Refueling Outage 13 and the subsequent operating cycles until the next scheduled inspection of the SG tubing rather than an amendment that is applicable to the remaining life of the plant. Seabrook TS 6.7.6.k.d.2 defines the maximum time allowed between inspections of each SG. This TS states that "[n]o SG shall operate for more than 48 effective full power months or two refueling outages (whichever is less) without being inspected." The staff finds that assuming all tubes will be severed at the H\*

distance over a period of 48 months to be unrealistic and that the proposed H\* distance is conservative for the next inspection cycle for the reasons cited below.

From a fleet-wide perspective (for all Westinghouse plants with tubes fabricated from thermally-treated Alloy 600), the staff has observed from operating experience that the extent of cracking is at an early stage in terms of the number of tubes affected by cracking below the H\* distance and the severity of cracks, compared to the idealized assumption that all tubes are severed at the H\* distance. Most of these cracks occur in the lower-most 1 inch of tubing, which is a region of relatively high residual stress associated with the 1-inch tack roll expansion in that region. Although the extent of cracking can be expected to increase with time, it is the staff's judgment based on experience that it will continue to be limited to a small percentage of tubes, mostly near the tube ends, over the next inspection cycle. The staff's observations are based on the review of SG tube inspection reports from throughout the PWR fleet. These reports are reviewed and the staff's conclusions are documented after each SG tube inspection.

Reference 22 provides a recent example of such a review by the staff.

In the fall of 2006, 50 percent of the population of hot-leg overexpansion and bulge indications were inspected at Seabrook, to a depth of 17 inches below the TTS and no degradation was found. Also, no crack-like indications were found during inspection of the expansion transition region (Reference 3). The staff finds that the extent and severity of cracking at Seabrook Unit 1 to be within the envelope of industry experience with similar units.

The staff concludes that there is sufficient conservatism embodied in the proposed H\* distances to ensure acceptable margins against tube pullout during Refueling Outage 13 and the subsequent inspection cycle for the reasons discussed above. The staff also concludes there is reasonable assurance, during the next inspection cycle, that any potential accident-induced leakage will not exceed the TS performance criteria for accident-induced leakage. This reflects current operating experience trends that cracking below the H\* distance is occurring predominantly in the tack roll region near the bottom of the tube. At this location, it is the staff's judgment that the total resistance to primary-to-secondary leakage will be dominated by the resistance of any "crevice" in the roll expansion region (due to very high T/TS contact pressures in this region), such that the leakage factors discussed in Section 4.2.2 will remain conservative even should there be a loss of T/TS contact near the TTS due to tubesheet bore eccentricity effects.

#### **4.3 Technical Evaluation Conclusions**

The staff finds that the proposed amendment request acceptably addresses all issues identified by the staff in Reference 7. However, the staff does not have sufficient information to determine whether the tubesheet bore displacement eccentricity has been addressed in a conservative fashion and, thus, the staff does not have an adequate basis to approve a permanent H\* amendment.

Notwithstanding any potential non-conservatism in the calculated H\* distance which may be associated with the eccentricity issue, the staff concludes that, given the current state of the tubes, there is sufficient conservatism embodied in the proposed H\* distances to ensure, for the period requested by the licensee, that tube structural and leakage integrity will be maintained with structural safety margins consistent with the design basis and with leakage integrity within assumptions employed in the licensing basis accident analyses. Based on this finding, the staff further concludes that the proposed amendment is acceptable.

Consistent with the changes approved in this amendment, the alternate inspection and repair criteria are applicable to SG tube inspections performed during Refueling Outage 13 and any tube inspections performed prior to the next inspection required by TS 6.7.6.k.d.

#### **5.0 STATE CONSULTATION**

In accordance with the Commission's regulations, the New Hampshire and Massachusetts State officials were notified of the proposed issuance of the amendment. The State officials provided no comments.

#### **6.0 ENVIRONMENTAL CONSIDERATION**

The amendment changes a requirement with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20. The NRC staff has determined that the amendment involves no significant increase in the amounts and no significant change in the types of any effluents that may be released offsite and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding (74 FR 35891). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

#### **7.0 CONCLUSION**

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner; (2) such activities will be conducted in compliance with the Commission's regulations; and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

## 8.0 REFERENCES

1. NextEra Energy Seabrook, LLC, Letter SBK-L-09118, "License Amendment Request 09-03 Revision to Technical Specification 6.7.6.k, "Steam Generator (SG) Program," for Permanent Alternate Repair Criteria (H\*), May 28, 2009, ADAMS Accession No. ML091530539. This letter also transmitted Reference 15.
2. NextEra Energy Seabrook, LLC, Letter SBK-L-09168, September 16, 2009, ADAMS Accession No. ML092650369, responding to Seabrook Requests for Additional Information and transmitting WEC letters LTR-SGMP-09-100-P (Proprietary) and LTR-SGMP-09-100-NP (Non-Proprietary) "Response to NRC Request for Additional Information on H\*; Model F and D5 Steam Generators," dated August 12, 2009, ADAMS Accession Nos. ML092370305 (Proprietary) and ML092370304 (Non-Proprietary) and WEC letter SGMP-09-109-P Attachment "Response to NRC Request for Additional Information on H\*; RAI #4; Model F and Model D5 Steam Generators," dated August 25, 2009, ADAMS Accession No. ML092450333.
3. NextEra Energy Seabrook, LLC, Letter SBK-L-09196, September 18, 2009, amending its H\* application to apply only to the next operating cycle, "License Amendment Request to Revise Technical Specification (TS) Sections 6.7.6.k, "Steam Generator (SG)Program" and TS 6.8.1., "Steam Generator Tube Inspection Report" for One-Time Alternate Repair Criteria". ADAMS Accession No. ML092720883.
4. NextEra Energy Seabrook, LLC, Letter SBK-L-09211, September 25, 2009, amending its H\* application to apply only to the next operating cycle, "Correction to Proposed Change in License Amendment Request to Revise Technical Specification (TS) Sections 6.7.6.k, "Steam Generator (SG)Program" and TS 6.8.1., "Steam Generator Tube Inspection Report" for One-Time Alternate Repair Criteria". ADAMS Accession No. ML092720463.
5. Wolf Creek Nuclear Operating Corporation, Letter ET-06-004, "Revision to Technical Specification 5.5.9, "Steam Generator Tube Surveillance Program,"" February 21, 2006, ADAMS Accession No. ML060600456.
6. Wolf Creek Nuclear Operating Corporation, letter ET-08-0010, "Withdrawal of License Amendment Request for a Permanent Alternate Repair Criteria in Technical Specification (TS) 5.5.9, "Steam Generator (SG) Program,"" February 14, 2008, ADAMS Accession No. ML080580201.
7. NRC letter to Wolf Creek Nuclear Operating Corporation, "Wolf Creek Generating Station – Withdrawal of License Amendment Request on Steam Generator Tube Inspections," February 28, 2008, ADAMS Accession No. ML080450185.
8. SNC letter NL-07-1710, Vogtle Electric Generating Plant Units 1 and 2 License Amendment Request to Technical Specification (TS) Sections TS 5.5.9, "Steam

Generator (SG) Program" and TS 5.6.10, "Steam Generator Tube Inspection Report," November 30, 2007, ADAMS Accession No. ML073380100.

9. SNC letter NL-08-0148, Vogtle Electric Generating Plant Units 1 and 2 License Amendment Request to Revise Technical Specification (TS) Sections TS 5.5.9, "Steam Generator (SG) Program" and TS 5.6.10, "Steam Generator Tube Inspection Report" for Interim Alternate Repair Criterion, February 13, 2008, ADAMS Accession No. ML080500223.
10. NRC letter to SNC, Vogtle Electric Generating Plant, Units 1 And 2, Issuance of Amendments Regarding Changes to Technical Specification (TS) Sections TS 5.5.9, "Steam Generator (SG) Program" and TS 5.6.10, "Steam Generator Tube Inspection Report," April 9, 2008, ADAMS Accession No. ML080950247.
11. NRC letter to SNC, Vogtle Electric Generating Plant, Units 1 and 2, Issuance of Amendments Regarding Steam Generator Tube Inspection Program, September 16, 2008, ADAMS Accession No. ML082530044.
12. NRC Meeting Minutes, "Summary of the October 29 and 30, 2008, Category 2 Public Meeting with the Nuclear Energy Institute (NEI) and Industry to Discuss Modeling Issues Pertaining to the Steam Generator Tube-to-Tubesheet Joints," ADAMS Accession No. ML083300422.
13. NRC Meeting Minutes, "Summary of the January 9, 2009, Category 2 Public Meeting with the U.S. Nuclear Industry Representatives to Discuss Steam Generator H\*/B\* Issues," ADAMS Accession No. ML090370945.
14. NRC Meeting Minutes, "Summary of the April 3, 2009, Category 2 Public Meeting with the U.S. Nuclear Industry Representatives to Discuss Steam Generator H\* Issues," April 30, 2009, ADAMS Accession No. ML091210437.
15. Westinghouse Electric Company report, WCAP-17071-P (Proprietary) and WCAP-17071-NP (Non- Proprietary), Rev. 0, "H\*: Alternate Repair Criteria for the Tubesheet Expansion Region in Steam Generators with Hydraulically Expanded Tubes (Model F)," April 2009; ADAMS Accession Nos. ML091530541 (Proprietary) and ML091530540 (Non-Proprietary).
16. Westinghouse Electric Company report, WCAP-17072-P (Proprietary) and WCAP-17072-NP (Non-Proprietary), Rev. 0, "H\*: Alternate Repair Criteria for the Tubesheet Expansion Region in Steam Generators with Hydraulically Expanded Tubes (Model D5)," May 2009, ADAMS Accession Nos. ML091670159 (Introduction through Section 6.2.2.2.2 - Proprietary), ML091670160 (Section 6.2.2.2.3 through Section 6.2.5.3 - Proprietary), ML091670161 (Section 6.2.6 through Appendix), and ML091670172 (Non- Proprietary).

17. NRC Generic Letter 95-05, "Voltage-Based Repair Criteria for Westinghouse Steam Generator Tubes Affected by Outside Diameter Stress Corrosion Cracking," August 3, 1995, ADAMS Accession No. ML031070113.
18. NUREG-0844, "NRC Integrated Program for the Resolution of Unresolved Safety Issues A-3, A-4, and A-5 Regarding Steam Generator Tube Integrity," September 1988.
19. NUREG-1570, "Risk Assessment of Severe Accident-Induced Steam Generator Tube Rupture," March 1998, ADAMS Accession No. ML070570094.
20. SNC letter NL-09-1317, August 28, 2009, transmitting WEC letter LTR-SGMP-09-104-P Attachment "White Paper on Probabilistic Assessment of H\*" dated August 13, 2009, ADAMS Accession Nos. ML092450030 (Proprietary) and ML092450029 (Non-Proprietary).
21. Nuclear Energy Institute letter dated July 7, 2009, ADAMS Accession No. ML082100086, transmitting Babcock and Wilcox Limited Canada letter 2008-06-PK-001, "Re-assessment of PMIC measurements for the determination of CTE of SA 508 steel," dated June 6, 2009, ADAMS Accession No. ML082100097.
22. NRC memorandum, "Review of Steam Generator Tube Inspection Report for fall 2006 – Seabrook Station, Unit No. 1," August 28, 2008, ADAMS Accession No. ML082280165.

Principal Contributors: E. Murphy, NRR  
A. Johnson, NRR

Date: October 13, 2009

A copy of our safety evaluation is also enclosed. Notice of Issuance will be included in the Commission's biweekly *Federal Register* notice.

Sincerely,  
*/RA by REnnis for/*

Dennis Egan, P.E.,  
 Senior Project Manager  
 Plant Licensing Branch I-2  
 Division of Operating Reactor Licensing  
 Office of Nuclear Reactor Regulation

Docket No. 50-443

**Enclosures:**

1. Amendment No. 123 to NPF-86
2. Safety Evaluation

cc w/encls: Distribution via Listserv

**DISTRIBUTION:**

PUBLIC	LPLI-2 R/F
RidsAcrsAcnw_MailCTR Resource	RidsNrrDorlDpr Resource
RidsNrrDorlLpl1-2 Resource	RidsRgn1MailCenter Resource
RidsNrrDirsltsb Resource	RidsNrrPMSeabrook Resource
RidsNrrLAABaxter Resource	RidsOgcRp Resource

**ADAMS Accession No.: ML092460184**

OFFICE	LPL1-2/PM	LPL1-2/LA	CSGB/BC	DIRS/ISTB	OGC (NLO w/comments)	LPL1-2/BC
NAME	DEgan REnnis for	ABaxter	MGavrilas	RElliott CSchulten for	LSubin	HChernoff
DATE	10/13/09	10/13/09	09/30/09	10/6/09	10/01/09	10/13/09

Official Record Copy