

REQUEST FOR ADDITIONAL INFORMATION 453-3397 REVISION 0

9/1/2009

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

SRP Section: 12.03-12.04 - Radiation Protection Design Features

Application Section: 12.3

QUESTIONS for Component Integrity, Performance, and Testing Branch 1 (AP1000/EPR Projects)
(CIB1)

12.03-12.04-32

Please address measures taken to limit the use of cobalt-bearing materials in the US-APWR structures, systems, and components exposed to reactor coolant and include any limitations in the US-APWR DCD, Tier 2, Section 12.3.