



**Qynergy Corporation**

3800 Osuna Road NE Suite 2  
Albuquerque, NM 87109-4401

Office: (505) 890-6887

Fax: (505) 792-8508

1 August 2007

John Yankovich  
United States Nuclear Regulatory Commission  
Materials Safety and Inspection Branch  
Division of Industrial and Medical Nuclear Safety  
Two White Flint North  
11545 Rockville Pike  
North Bethesda, MD 20852-2738

RE: Request for SS&DR for KRT-2000 Betavoltaic Power Cell

Dear Mr. Yankovich:

Qynergy Corporation requests a Sealed Source and Device Registration number for the KRT-2000 Betavoltaic Power Cell (also known as the QynCell™). Qynergy gives permission for the following documents to be reproduced and made available to the public.


- SS&DR Application
- Mechanical Drawing Package
- Instructions to Users
- KRT-2000 Label

Qynergy has included the following documents for information only and requests that they not be duplicated, distributed, or made available to the public. Due to the nature of the technical and manufacturing processes referenced within these documents, these items are regarded as "Qynergy Proprietary and Confidential".

- Prototype Test Report
- Addendum to Prototype Test Report
- KRT-2000 Design Report and Appendices 9.1, 9.2, 9.3, and 9.4
- Qynergy Quality Manual
- Radiation Profile Measurements

Your timely attention to this matter is greatly appreciated. If you have any questions, I can be reached at either (505) 314-1422 or [stephanie.jones@qynergy.com](mailto:stephanie.jones@qynergy.com). Thank you.

Sincerely,

  
Stephanie Jones

Quality Manager

Information in this record was deleted  
in accordance with the Freedom of Information  
Act, exemptions 4  
FOIA-2007-00804

b1

Attachments: SS&DR Application  
Mechanical Drawing Package  
Instructions to Users  
KRT-2000 Label  
Prototype Test Report  
Addendum to Prototype Test Report  
KRT-2000 Design Report  
KRT-2000 Design Report Appendix 9.1  
KRT-2000 Design Report Appendix 9.2  
KRT-2000 Design Report Appendix 9.3  
KRT-2000 Design Report Appendix 9.4  
Qynergy Quality Manual  
Radiation Profile Measurements,

Cc: Todd Bisio, President, Qynergy  
Christopher Eiting, Director of Engineering, Qynergy  
Viswanath Krishnamoorthy, Director of Technology and Quality Assurance, Qynergy

REGISTRY OF SEALED SOURCES AND DEVICES SAFETY EVALUATION	
Name and Complete Mailing Address of the Applicant: Qynergy Corporation 3800 Osuna Rd NE Ste 2 Albuquerque, NM 87109-4401 505-890-6887 505-792-8508 (FAX)	Name, Title, and Telephone Number of the Individual to Be Contacted if Additional Information or Clarification is Needed by the NRC: Stephanie Jones Quality Manager 505-314-1422
The Applicant is (check one): <input type="checkbox"/> Custom User <input type="checkbox"/> Manufacturer <input type="checkbox"/> Distributor <input checked="" type="checkbox"/> Manufacturer and Distributor	If the Applicant is Not the Manufacturer, Provide the Name and Complete Mailing Address of the Manufacturer: N/A
If the Applicant is a Custom User, Provide the Name and Complete Mailing Address of the Distributor: N/A	Provide the Name, Complete Mailing Address, and Function of Other Companies Involved: See page 2 for Details
Model Number: KRT-2000	Principal Use Code (see Appendix C): R (Gas)
Name Used by the Industry to Identify the Product (e.g., Radiography Exposure Device, Teletherapy Source, Calibration Source, etc.): Betavoltaic Power Cell: A device that captures electrons emitted by a decaying radioisotope for the purpose of producing usable electric power	For Use by: <input checked="" type="checkbox"/> Specific Licensees Only <input type="checkbox"/> General Licensees Only <input type="checkbox"/> Both Specific and General Licensees <input type="checkbox"/> Persons Exempt from Licensing
Leak-Test Frequency: <input checked="" type="checkbox"/> Periodic Leak-Testing is Not Required (Exempt from leak test due to <sup>85</sup> Kr gas form) <input type="checkbox"/> 6 Months <input type="checkbox"/> Attached is justification for a leak test frequency of greater than 6 months	Principal Section of the 10 CFR that Applies to the User (e.g., General Licensees under 10 CFR 31.5): Specific Licensees under 10 CFR 33.11 and General Licensees under 10 CFR 31.9 Radionuclides and Maximum Activities (including loading tolerance): <sup>85</sup> Kr 166.5 GBq + 20% (4.5 Ci + 20%)
<b>CERTIFICATION:</b>  THE APPLICANT UNDERSTANDS THAT ALL STATEMENTS AND REPRESENTATIONS MADE IN THIS APPLICATION ARE BINDING UPON THE APPLICANT.  THE APPLICANT AND ANY OFFICIAL EXECUTING THIS CERTIFICATION ON BEHALF OF THE APPLICANT, NAMED IN ITEM 2, CERTIFY THAT THIS APPLICATION IS PREPARED IN CONFORMITY WITH TITLE 10, CODE OF FEDERAL REGULATIONS, PARTS 30 AND 32 AND THAT ALL INFORMATION CONTAINED HEREIN IS TRUE AND CORRECT TO THE BEST OF THEIR KNOWLEDGE AND BELIEF.  WARNING: 18 U.S.C. SECTION 1001 ACT OF JUNE 25, 1948 62 STAT. 749 MAKES IT A CRIMINAL OFFENSE TO MAKE A WILLFULLY FALSE STATEMENT OR REPRESENTATION TO ANY DEPARTMENT OR AGENCY OF THE UNITED STATES AS TO ANY MATTER WITHIN ITS JURISDICTION.	
Certifying Officer – Typed Name and Title Christopher Eiting, PhD, PE, Director of Engineering	
Signature: <i>Christopher Eiting</i>	Date: 8/1/07

## **KRT-2000 Manufacturer's List**

### **Machining**

1. Team Specialty Products  
1400 Eubank Blvd SE  
Albuquerque, NM 87123  
Phone 505-291-0182 fax 505-271-8354

### **Joining**

1. California Brazing  
37955 Central Ct  
Newark, CA 94560  
Phone 510-790-2300 Fax 510-791-9300
2. EB Industries  
90 Carolyn Blvd.  
Farmingdale, NY 11735  
Phone 888-468-1991 Fax 631-752-7866

### **Testing**

1. Eckert & Ziegler Isotope Products  
24937 Avenue Tibbitts  
Valencia, CA 91355  
Phone (661) 309-1010
2. Technical Manufacturing Industries Inc.  
9901-B Southern S.E.  
Albuquerque, NM 87123  
phone (505)-293-6136 fax (505) 275-3657
3. Jona Manufacturing  
264 DP Rd.  
Los Alamos, NM 87544  
Phone (505) 662-4611

### **Isotope Loading**

1. Eckert & Ziegler Isotope Products  
24937 Avenue Tibbitts  
Valencia, CA 91355  
Phone (661) 309-1010



**Qynergy Corporation**  
3800 Osuna Rd NE Suite 2  
Albuquerque, NM 87109-4401  
Office: 505.890.6887  
Fax: 505.792.8508  
Web: [www.qynergy.com](http://www.qynergy.com)

## **1 CONDITIONS OF USE**

### **Intended Use**

The device is a prototype power cell that generates small amounts of power (microwatts) over a long time (years). The device will be used as a demonstration model for customers that have applications where small powers are needed for long periods of time. Customers will then provide specifications for new models that will be registered independently from the demonstration model.

### **Types of Users**

The power cells will be connected to the systems that they are intended to power. The installation will be performed by radiation certified technicians (overseen by radiation safety officers) in licensed facilities. The systems they will power are primarily detection and security systems manufactured by government contractors and used by the Department of Homeland Security and the Department of Defense.

### **Locations of Use**

This model will be tested within licensed facilities only, and will not be fielded. All radiation safety requirements will be followed including the establishment of shielded storage areas, radiation areas when in use, and ALARA practices for trained radiological workers as well as non-radiological workers in the facilities.

### **Occasions When Persons Will Be Near the Device and the Frequency of These Occasions**

Radiation certified workers will be the only users of this model and will be near the device during set up of a demonstration. Demonstration set ups will consist of attaching wires from the system requiring power to the wires exiting the sealed device. After the initial set up, there is no requirement that a worker be near the source. Radiation barriers can be established and appropriate security measures can be taken to allow long term demonstrations.

### **Normal Use Conditions**

This device is designed and manufactured for use as a power cell on demonstration systems housed in controlled factory settings. This device should not be subjected to conditions during use, handling, storage, and transport that exceed ISO/99/CX3344 as defined below:

- External pressure: 0 to 290 PSIA
- Working temperature: -60 and 200 Celsius
- Impact: 200 grams from 1 meter with hammer
- Vibration: 25-80 Hz for 90 minutes and up to 80-2000 Hz @ 20 g-force
- Puncture: 50 grams from 1 meter with nail
- Corrosive environment: Not to be used in a highly corrosive environment such as acids, sea water or salts.

This device has been evaluated based on these conditions and tested based on the following possible modes of failure under normal use conditions:

- Drop-from no more than a table height
- Impact-from a tool being dropped on the device during hook up
- Impact-from another package dropped onto the packaged device during transport
- Heat-from an overheated electronic part in the system the device is connected to
- Vibration-from small fans on the systems the device is connected to
- Vibration-from transport vehicles

The registered device will not come into contact with any corrosives during normal use. Also, the materials of construction are not detrimentally affected by the expected exposure to radiation either from internal or external sources during normal operation.

#### **Expected Working Life of the Source/Device (Years, Operations)**

The expected useful life of the KRT-2000 is 20 years. No regular maintenance is required. Actual working life is dependent on activity and power requirements for the end user. At the end of the working life of the device, the KRT-2000 will be returned to the manufacturer specified subcontractor for disposal. No devices will be returned to Qynergy.

## **2 CONSTRUCTION OF THE PRODUCT**

The KRT-2000 is a single wall, welded pressure vessel constructed of 316 stainless steel. It has a hermetic ceramic to metal feedthrough for electrical connection to the converters inside the device, and a brazed and crimped copper fill tube for the introduction of  $^{85}\text{Kr}$ . The steel structure provides both the seal as well as limited shielding for the  $^{85}\text{Kr}$ . Additional shielding may be required once installed as part of a larger system for demonstration. The package is leak tested prior to the introduction of  $^{85}\text{Kr}$ . The package is rated to handle pressures that far exceed the  $^{85}\text{Kr}$  loading pressure of 150 psi. Note:  $^{85}\text{Kr}$  is a beta and gamma emitter. All beta radiation is shielded by the steel case.

Within the pressure vessel, epoxied to the inside walls, are two PC boards upon which are soldered the semiconductor converters that generate the electrical power. 5%  $^{85}\text{Kr}$  gas and 95% Ar fill the remainder of the space. The crimped fill tube and electrical feedthrough are protected by a cap that is fastened into place. Two electrical leads exit the cap and provide the electrical power output.

See Attachment 1 Mechanical Drawing Package.

#### **Handling and Installation**

The device has a radiation signature and should be handled according to ALARA recommended practices. During transport, the KRT-2000 should be carried inside its shielded shipping container. Once it is ready for installation, the KRT-2000 should be handled with tongs to position it into its mounting brackets or clips. See Attachment 2 Instructions to Users for further details. Once in position, the wires can be attached to the system the KRT-2000 will be powering and additional shielding (lead or tungsten recommended) can be put into place.

#### **Materials**

See Attachment 1 Mechanical Drawing Package.

#### **Dissimilar Materials**

Mismatch in Coefficient of Thermal Expansion (CTE) between dissimilar materials will not be a concern in this design as the operational temperature range is small enough that the dimensional changes will not appreciably affect the integrity of the hermetic seal. The locations of the dissimilar materials are in the electric feedthrough and the fill tube. The feedthrough is rated for a temperature range of -268C to 450C. The CTE mismatch between the 316 SST and the Copper fill tube is very small.

The KRT-2000 is only designed for operation in an air environment, hence galvanic corrosion effects will be negligible.

### **3 LABELING**

All devices are labeled with the trefoil symbol on the large face of the device. The opposite large face of the device is labeled with the following:

QYNCELL

Caution: Radioactive Material

Kr-85

Serial Number

Part Number

Activity and Date of Assay

[www.qynergy.com](http://www.qynergy.com)

All labels are permanently etched into the outside surface of the device package. See Attachment 3 KRT-2000 Label for details.

### **4 PROTOTYPE TESTING**

The device has been tested according to standard procedures in ISO2919:1999 (ANSI/HPS N43.6-1997 Sealed Radioactive Sources – Classification equivalent). In

order to meet the demands of normal use conditions and possible failure modes under those normal use conditions, the device has been tested to the following classes:

Temperature:	Class X (Modified Class 3 with expanded temperature range of -60 to 200°C)
External Pressure:	Class 3
Impact:	Class 3
Vibration:	Class 4
Puncture:	Class 4

All prototypes were pressurized with He and leak tested according to ISO9978:1992 (ANSI/HPS N43.6-1997 Section A.2.2.5 equivalent). All devices passed classification ISO/99/CX3344.

## 5 RADIATION PROFILES

Radiation profiles for the KRT-2000 devices were both modeled and directly measured at contact, 5 cm, 30 cm, and 100 cm from all faces of the device. Direct measurements were completed for a 5.49 Ci loading (slightly higher than the 5.4 Ci maximum including tolerance). Maximum dose rates are present along the axis passing through the large faces of the KRT-2000. The theoretical model was validated using these direct measurements.

Distance (cm)	Total Dose Rate (mrem/hr)
0 (Contact)	3200
5	1220
30	109
100	11

Maximum Measured Dose Rates for 5.49 Ci KRT-2000

## 6 QUALITY ASSURANCE AND QUALITY CONTROL

The Qynergy Quality Manual details the quality control of these devices from raw materials to finished product. The program is designed to satisfy 10 CFR Part 50 (B). The program covers design and document control, purchasing, training, calibration records, device numbering, production, assay quality control, and confirming orders. The program also ensures that

1. The materials of construction and the final assembly meet the design specifications
2. The final product is leak tested.
3. A final radiation profile is performed.
4. A test is performed that verifies the KRT-2000 is operational and all safety components are operating properly.



5. A visual and mechanical inspection of critical safety components and components susceptible to failure under extreme conditions is performed.

In addition the program allows for the tracking of as-built specifications for each individual device including all version controlled documentation used in the manufacturing process.

All documents and activities related to the manufacturing of KRT-2000 cells are governed by the Qynergy Quality Manual.

## **7 INSTALLATION, SERVICING, AND INSTRUCTIONS TO USERS**

Installation, relocation, and radiation surveys may be performed by specific licensees. Maintenance, repair, source exchange, calibration, and training will be provided by the distributor. No leak testing is required following the initial leak test performed by the manufacturer due to the gas form of the  $^{85}\text{Kr}$ .

See Attachment 2, Instructions to Users

## Attachment 1

### Mechanical Drawing Package

8

7

6

5

4

3

2


1

D

C

B

A



ISO VIEW SHOWING LOADED QYNCELL

NOTES: UNLESS OTHERWISE SPECIFIED

1. ALL DIMENSIONS IN INCHES
2. DIMENSIONS AND TOLERANCING PER ASME Y14.5M-1994
3. ASSEMBLE PER KRT-2000 ASSEMBLY PROCEDURE
4. LASER ETCH OR EQUIVALENT, TRIFOIL ON SIDE SHOWN, FOLLOWING TEXT OTHER SIDE, CENTERED.

QYNCELL  
CAUTION - RADIOACTIVE MATERIAL  
KRYPTON-85

ACTIVITY \_\_\_\_\_  
DATE OF LOADING \_\_\_\_\_  
SERIAL NUMBER \_\_\_\_\_  
PART NO. KRT-2000 REV \_\_\_\_\_  
WWW.QYNERGY.COM



APPLY THREAD LOCKER PER LOCTITE SPECS

APPROXIMATE MASS: 100 GRAMS

REV		DESCRIPTION	DATE	APPROVED
A		UPDATED PART LIST, ADDED UNLOADED VIEW, UPDATED TITLE BLOCK	02/23/07	C. BTUNG

ITEM	QTY	PART NO.	DESCRIPTION	MATERIAL
18	A/R	HD Microsystems 8P1-2564	POLYIMIDE COATING	POLYIMIDE
17	A/R	MasterBond REP211DCHT	NON CONDUCTIVE EPOXY	EPOXY
16	A/R	Jaguar Ind. RJKY25-0	22 GA. WIRE -BLACK	COPPER/KYNAR
15	A/R	Jaguar Ind. RJKY25-1	22 GA. WIRE -RED	COPPER/KYNAR
14	1	Swagelok FES-LVCR-0.200	1/8" TUBE TO 1/4" VCR ADAPTER	304 SST
13	A/R	MasterBond Supreme H1 104	ELECTRICALLY CONDUCTIVE EPOXY	EPOXY
12	A/R	McMasterCarr 91458A28	LOCTITE 271 HIGH STRENGTH THREAD LOCKER	EPOXY
11	1	McMasterCarr 90828A18	PAN-HD 84-4 5/8" LG	SST
10	1	McMasterCarr 91400A080	PAN-HD 82-66 1/8" LG	SST
9	1	McMasterCarr 91131K002	RING TERMINAL	SST
8	A/R	Jaguar Ind. RJKY25-0	20 GA. WIRE	COPPER/KYNAR
7	A/R	Indium #121 and flux #3	SOLDER	TIN/SILVER
6	2	KRT-2200-1 REV A	PC BOARD ASSEMBLY	FR-4/GOLD
5	1	KRT-2100-1 REV A	LID ASSEMBLY	SST/COPPER/CERAMIC
4	1	KRT-2004-1 REV A	BOTTOM CAP	SST
3	1	KRT-2001-1	GASKET	KALREZ
2	1	KRT-2002-1 REV A	CAP	SST
1	1	KRT-2001-1 REV A	CASE	SST

KRT-2000 PART NO.		QYNCELL KR-85 QYNCELL MODEL KRT-2000 QYNCELL	
DESIGNER: _____ CHECKED: _____ APPROVED: _____		DATE: _____ DATE: _____ DATE: _____	

8

7

6

5

4

3

2

1

D

C

B

A



## **Attachment 2**

### **QYNCELL INSTALLATION-INSTRUCTIONS TO USERS**

Only authorized and properly trained personnel may open a package containing a QynCell. Please verify that the package is in good condition and that the QynCell is properly shielded in its shipping container.

Please note that the QynCell must be mounted in a location compatible with the "Conditions of Normal Use" and "Limitations and/or Other Considerations of Use" indicated on the registration certificate. No modifications may be made to the QynCell for use in the desired location. Compromising the integrity of the QynCell case could result in a release of radioactive material.

#### **Installation**


1. Establish a perimeter around the QynCell package before opening. The QynCell contains  $^{85}\text{Kr}$  and has a gamma radiation signature. Please see the accompanying documents for dose rates.
2. Open the package according to your shipping and receiving procedures for radioactive sources.
3. Verify dose rates and perimeter location once unpacked.
4. Use lead or other heavy metal shielding to reduce exposure during installation.
5. Do not remove the screw in the cap of the QynCell.
6. There are two wires leading from the top of the QynCell. Connect the black wire to ground and the red wire to the positive input of the system you are trying to run. Connection can be via soldering iron or screw terminals. Power is immediately available just like a battery.
7. If mounting is necessary, you must use exterior metal clips to hold in place. Clip into place so that the information label is visible. Do not puncture the QynCell in any way. Do not use tape as this will cover the labeling and can degrade from radiation. Do not weld or use any adhesives to keep the QynCell in place.
8. Finish placing shielding and perimeter barriers as needed for the location in which the QynCell has been installed.

#### **Troubleshooting/Service**

1. If the QynCell does not provide power, ensure wires are properly connected.
2. If the QynCell continues to fail to provide power, notify the manufacturer immediately. Do not attempt to repair.
3. When the QynCell stops providing adequate power, please return it to the manufacturer specified subcontractor and notify the manufacturer. Follow your shipping and receiving instructions for radioactive materials. Do not attempt to repair.

## Attachment 3

### KRT-2000 Label



Information Label View of KRT-2000



Trefoil View of KRT-2000

# Prototype Test Report

~~PROPRIETARY~~  
AND  
~~CONFIDENTIAL~~

Test Report No.	TR0173
Effective Date:	03 JUL 07
Control Date	03 JUL 07
Initials:	RAM
Page	1 of 27

SYNERGY PROPRIETARY  
DO NOT DISTRIBUTE

Page 1 of 27

### TEST PROTOCOL APPROVAL

Source Model No. 2000 QYNELL Drawing No. 3500000 Rev. A 3 (attached)

Target Sealed Source Classification:

☐ DOT: Capsule < 200 g; one dimension > 5 mm.

Tests to be performed:

☒ Temperature Class 3  
☒ Vibration Class 4

☒ Pressure Class 3  
☒ Puncture Class 4

☒ Impact Class 3  
☐ Bending Test N/A

☒ Inactive Capsule

☐ Active Capsule

Nuclide: \_\_\_\_\_

Activity: \_\_\_\_\_

LEAK TEST WILL BE BY HELIUM LEAK TEST CONDUCTED AT PTL.

### INITIAL TEST PROTOCOL APPROVAL

Originator (name): LLOYD L. FLOWERS

Test Engineer - Date: 15 MAY 07

Signing indicates agreement with the testing procedures described herein

Ana R. Ramirez Date: 15 MAY 07  
Director of Quality Operations /  
Regulatory Affairs Manager

[Signature] Date: 15 May 07  
Radiation Safety Officer / Sr. Health Physicist  
Alternate Radiation Safety Officer

### FINAL REPORT AND SUMMARY APPROVAL

Originator (name): LLOYD L. FLOWERS

Test Engineer - Date: 2 JUL 07

Signing indicates agreement with all of the documentation contained within this report.

Juda Jan Date: 3 Jul 07  
Director of Quality Operations /  
Regulatory Affairs Manager

Ana R. Ramirez Date: 3 Jul 07  
Radiation Safety Officer / Sr. Health Physicist  
Alternate Radiation Safety Officer



Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	2 of 27

**QYNERGY PROPRIETARY**

**DO NOT DISTRIBUTE**

**Temperature Test Class 3**

Capsule ID number: 0025 VERIFIED by initial: JA  
Capsule ID number: 0026 VERIFIED by initial: JA

*-60°C PER CUSTOMER'S REQUEST.*

**Low Temperature, -40°C (20 minutes)**

Fix thermocouple to capsule or capsule chamber to provide as accurate temperature readings of the capsule as possible. Using "dry ice", test is performed in an atmosphere of CO<sub>2</sub>. Source shall be cooled to the test temperature in less than 45 minutes., and held at ~~-40°C~~ *-60°C* (or lower) for a period of 20 minutes, then allowed to gradually re-warm to ambient temperature

Verify temperature during test using a type K thermocouple.

Set timer to 45 minutes. Start timer.

Set Timer1 for 45 minutes. Start timer. Start cooling source. Record temperature after 45 minutes -78.0°C.

Set Timer2 for 20 minutes. Start timer when the capsule or capsule chamber temperature reaches ~~-40°C~~ *-60°C*.

Allow the capsule/s to soak at ~~-40°C~~ *-60°C* for 20 minutes.

Record the temperature reading from the thermocouple, every 5 minutes during the test.

Start <del>-40°C</del> <i>-60°C</i> 20 minute soak	Temp (°C)	Initial
Temperature @ 5 minutes	-81.7	<u>JA</u>
Temperature @ 10 minutes	-85.3	<u>JA</u>
Temperature @ 15 minutes	-83.9	<u>JA</u>
Temperature @ 20 minutes	-81.5	<u>JA</u>

Allow source/sources to gradually re-warm to ambient temperature.

Test Conducted By: Hand J. Adams Date: 16 May 07  
*+200°C PER CUSTOMER'S REQUEST.*

**High Temperature Test, +180°C (1 hour)**

Verify temperature during test using a type K thermocouple. Fix thermocouple to capsule or capsule chamber to provide as accurate temperature readings of the capsule as possible. Place the capsule or capsule chamber in the furnace. Set the furnace temperature to ~~+180°C~~ *+200°C* with a ramp time not to exceed 10 min.

Set Timer1 for 10 minutes. Start timer. Start furnace. Record temperature after 10 minutes 207°C.

Set Timer2 for 60 minutes. Start timer when the capsule or capsule chamber temperature reaches ~~+180°C~~ *+200°C*.

Allow the capsule/s to soak at ~~+180°C~~ *+200°C* for 1 hour.

Record the temperature reading from the thermocouple, every 5 minutes.

\* *TEMPERATURE CHANGES PER CUSTOMER REQUEST. JA. 15 May 07*

Test Report No. <u>TR0173</u>
Effective Date: <u>03 JUL 07</u>
Control Date: <u>03 JUL 07</u>
Initials: <u>RM</u>
Page <u>3</u> of <u>27</u>

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

200°C 14.15 May 07 Page 3 of 27

Start +80°C 1 hr. soak	Temp (°C)	Initial
Temperature @ 5 minutes	212.5	11
Temperature @ 10 minutes	215.2	11
Temperature @ 15 minutes	205.8	11
Temperature @ 20 minutes	214.6	11
Temperature @ 25 minutes	211.7	11
Temperature @ 30 minutes	226.8	11
Temperature @ 35 minutes	231.9	11
Temperature @ 40 minutes	236.0	11
Temperature @ 45 minutes	231.5	11
Temperature @ 50 minutes	227.2	11
Temperature @ 55 minutes	222.3	11
Temperature @ 60 minutes	216.6	11

Test Conducted By: [Signature] Date: 16 May 07

Temperature testing is complete perform evaluation tests.

#### Equipment

Equipment	Manufacturer	Model No.	IPL ID or Serial Number	Calibration Date	Calibration Due Date
Furnace	Ney-Vulcan	3-550	DKW 0116111	Reference	N/A
Thermometer	Extech	422130	020508860	27 SEP 06	27 SEP 07
Timer	Control Co.	5000	221230127	13 OCT 06	13 OCT 07
500 ml quench tank	Polar Waste Co.	T1062	N/A	Reference	N/A

Test Report No. <u>TR0173</u>
Effective Date <u>03 JUL 07</u>
Control Date <u>03 JUL 07</u>
Initials <u>BM</u>
Page <u>4</u> of <u>27</u>

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 4 of 27

Post Test Evaluation For TEMPERATURE Test

Visual examination notes:

SOME DISCOLORATION WAS OBSERVED NEAR THE GASKET REGION.  
WIRES PROTRUDING FROM THE RYNCELLS MELTED AT THE POINT WHERE THEY  
MEET THE METAL. THIS OCCURRED WITH THE TWO CAPSULES, 0025 & 0026.  
NO OTHER CHANGE OR DAMAGE OBSERVED.

☒ Inactive test source – ~~no additional leak test required~~ 14.15 May 07 Helium Leak Test By PTL.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.1.3 Immersion test with a liquid scintillator.

The source is immersed for a minimum of 3 hours at room temperature in a liquid scintillation solution, which does not attack the source's outer surface material. The source is stored away from light to avoid photoluminescence. The sealed source is then removed and the activity of the liquid scintillation is measured.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.3.1. Wet wipe test.

Wipe all surfaces of the source with swab moistened with a liquid, which will not attack the source's outer surface material. The swab is then assayed.

Test	Capsule ID	Counts per minute detected	Net Activity (nCi)	Activity limit (nCi)	Test result	Initial & Date
				5		
				5		
N/A	Background		N/A	N/A	N/A	

Instrument Information:

Instrument Manufacturer:	
Instrument Model:	
Efficiency for selected nuclide:	
Calibration Date:	
Next Calibration Date	

Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	5 1 27

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 5 of 27

**External Pressure Test Class 3 & 4**

Capsule ID number: 0030 VERIFIED by initial: RM  
Capsule ID number: 0031 VERIFIED by initial: RM

**Low pressure**

Temperature: ambient

Test range: atmosphere to 25 kPa abs. = 7.4 "Hg"

Conduct the low-pressure test in air.

Place the source in the chamber and expose it to the test pressure for two periods of 5 minutes each. Use lab timer to time periods. Return the pressure to atmosphere between the periods.

Test Conducted By: David H. Flowers Date: 16 May 07

**High pressure**

Temperature: ambient

☒ Class 3 Test range: atmosphere to 2MPa = 276 psig

☐ Class 4 Test range: atmosphere to 7MPa = 1001 psig

Conduct the high-pressure test by a hydraulic method using water as the medium of contact. Place the source in the chamber and expose it to the test pressure for two periods of 5 minutes each. Use lab timer to time periods. Return the pressure to atmosphere between the periods.

Test Conducted By: David H. Flowers Date: 16 May 07

Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials:	RM
Page	6 of 27

~~QYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 6 of 27

**External Pressure testing is complete, perform visual and leak evaluation tests.**

### Equipment

**NOTE:** Record information on table as applicable.

Equipment	Manufacturer	Model No.	IPL ID or Serial Number	Calibration Date	Calibration Due Date
350 ml pressure vessel	Parr Instruments Co.	4760 series	N/A	N/A	N/A
0-2000 psi pressure gauge	Ashcroft	Dresser 35 1009SW0 2L 2000#/BR	PG-02-1	26 SEP 06	26 SEP 07
Vacuum pump				N/A	N/A
Pressure regulator 0-30" Hg	PRESSUREMENT	T3400/3V	9270-96	26 SEP 06	26 SEP 07
Jar	Nalgene	N/A	N/A	N/A	N/A
Timer	CONTROL CO.	5000	221230127	13 OCT 06	13 OCT 07

Test Report No.	TR0173
Effective Date:	03 JUL 07
Control Date:	03 JUL 07
Initials	RM
Page	7 of 27

~~QYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 7 of 27

Post Test Evaluation For EXTERNAL PRESSURE Test

Visual examination notes:

0030: NO CHANGE OR DAMAGE OBSERVED.

0031: NO CHANGE OR DAMAGE OBSERVED.

☒ Inactive test source -- ~~no additional leak test required.~~ 14.15 May 07 HELIUM LEAK TEST BY PTL.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.1.3 Immersion test with a liquid scintillator.

The source is immersed for a minimum of 3 hours at room temperature in a liquid scintillation solution, which does not attack the source's outer surface material. The source is stored away from light to avoid photoluminescence. The sealed source is then removed and the activity of the liquid scintillation is measured.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.3.1. Wet wipe test.

Wipe all surfaces of the source with swab moistened with a liquid, which will not attack the source's outer surface material. The swab is then assayed.

Test	Capsule ID	Counts per minute detected	Net Activity (nCi)	Activity limit (nCi)	Test result	Initial & Date
				5		
				5		
N/A	Background		N/A	N/A	N/A	

**Instrument Information:**

Instrument Manufacturer:	
Instrument Model:	
Efficiency for selected nuclide:	
Calibration Date:	
Next Calibration Date	

Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	8 of 27

~~QYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 8 of 27

### Impact Test Class 3

Capsule ID number: 0025 VERIFIED by initial: AA  
Capsule ID number: 0026 VERIFIED by initial: AA

A 200-gram hammer is dropped onto the capsule from 1 meter. A plumb guide tube is used to guide the hammer to the target capsule. The target capsule is placed on a steel billet. The hammer is guided with the intent to strike the capsule impacting the most vulnerable area.

1. Adjust the drop height, gap the distance between the anvil and bottom of the drop tube to no less than the height of the test capsule.
2. With the release pin inserted and using a magnetic grab tool, load the 200g hammer.
3. Position the capsule. Record the capsule orientation.
4. Install acrylic test shield for containment.
5. Pull release pin to drop the hammer.
6. Using forceps gently lift weight and remove source for evaluation.

Test Conducted By: David J. Harris Date: 17 May 07

**Impact test is complete; perform evaluation tests.**

### Equipment

**NOTE:** Record information on table as applicable.

Equipment	Manufacturer	Model No.	IPL ID or Serial Number	Calibration Date	Calibration Due Date
Impact Test Fixture Class 2 & 3	IPL	Custom	None	N/A	N/A
200g Hammer	IPL	Custom	IPL A6548-2-6	7 SEP 06	7 SEP 07

Impact Test Fixtures and hammers are designed to meet the requirements of ISO 2919, 7.4 Impact Test, 7.4.1 Apparatus, 7.4.1.1 Steel hammer, and 7.4.1.2 Steel anvil.

Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	9 of 27

**QYNERGY PROPRIETARY**  
**DO NOT DISTRIBUTE**

Page 9 of 27

Post Test Evaluation For IMPACT Test

Visual examination notes:

0025: MARKS WERE SEEN WHERE THE IMPACT WEIGHT STRUCK THE  
CAPSULE: NO OTHER CHANGE OR DAMAGE OBSERVED.

0026: NO CHANGE OR DAMAGE OBSERVED.

☒ Inactive test source – no additional leak test required 15 May 07. Helium Leak Test By PTL.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.1.3 Immersion test with a liquid scintillator.

The source is immersed for a minimum of 3 hours at room temperature in a liquid scintillation solution, which does not attack the source's outer surface material. The source is stored away from light to avoid photoluminescence. The sealed source is then removed and the activity of the liquid scintillation is measured.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.3.1. Wet wipe test.

Wipe all surfaces of the source with swab moistened with a liquid, which will not attack the source's outer surface material. The swab is then assayed.

Test	Capsule ID	Counts per minute detected	Net Activity (nCi)	Activity limit (nCi)	Test result	Initial & Date
				5		
				5		
N/A	Background		N/A	N/A	N/A	

**Instrument Information:**

Instrument Manufacturer:	
Instrument Model:	
Efficiency for selected nuclide:	
Calibration Date:	
Next Calibration Date	



Test Report No.	IR 0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	10 of 27

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 10 of 27

**Vibration Test Class 4**

Capsule ID number: 0028 Verified by initial: 18 (Capsule 1)  
Capsule ID number: 0029 Verified by initial: 18 (Capsule 2)

Fix the source securely to the platform. Each test consists of 3 complete test cycles of 30 minutes duration or longer sweeping the vibration frequency from 25 Hz to 80 Hz while maintaining 1.5 mm amplitude peak to peak and sweeping the vibration frequency from 80 Hz to 2000 Hz while maintaining 20 g acceleration. Conduct the test by sweeping through all frequencies in the range at a uniform rate, from minimum to maximum and return to minimum. Test is conducted in each axis of the source per ISO2919:1999, section 7.5.2. A maximum of three axes is tested. Conduct additional tests at each resonance frequency found for 30 minutes. Use a timer to verify timed test intervals.

Test Report No. TR0173  
Effective Date: 03 JUL 07  
Control Date: 03 JUL 07  
Initials RM

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 11 of 27

Capsule 1 Axis 1 25 Hz to 80 Hz to 25 Hz at 1.5 mm amplitude, 3 times, 30 minutes (0.110 OCT/MIN)

Sweep 1: Date: 16 May 07 Start Time: 13:45:11 End Time: 14:16:05 Duration: 30 MIN 54 SEC  
Sweep 2: Date: 16 May 07 Start Time: 14:16:10 End Time: 14:46:18 Duration: 30 MIN 8 SEC  
Sweep 3: Date: 16 May 07 Start Time: 14:46:23 End Time: 15:16:33 Duration: 30 MIN 10 SEC

Capsule 1 Axis 1 80 Hz to 2000 Hz to 80 Hz at 20g acceleration, 3 times, 30 minutes (0.29 OCT/MIN)

Sweep 1: Date: 18 JUN 07 Start Time: 08:20:45 End Time: 08:51:02 Duration: 30 MIN 17 SEC  
Sweep 2: Date: 18 JUN 07 Start Time: 08:51:11 End Time: 09:21:35 Duration: 30 MIN 24 SEC  
Sweep 3: Date: 18 JUN 07 Start Time: 09:21:42 End Time: 09:51:59 Duration: 30 MIN 17 SEC

Capsule 1 Axis 2 25 Hz to 80 Hz to 25 Hz at 1.5 mm amplitude, 3 times, 30 minutes

Sweep 1: Date: 17 May 07 Start Time: 08:16:05 End Time: 08:46:31 Duration: 30 MIN 26 SEC  
Sweep 2: Date: 17 May 07 Start Time: 08:46:41 End Time: 09:15:03 Duration: 30 MIN 22 SEC  
Sweep 3: Date: 17 May 07 Start Time: 09:15:11 End Time: 09:45:29 Duration: 30 MIN 18 SEC

Capsule 1 Axis 2 80 Hz to 2000 Hz to 80 Hz at 20g acceleration, 3 times, 30 minutes

Sweep 1: Date: 18 JUN 07 Start Time: 10:07:56 End Time: 10:38:18 Duration: 30 MIN 22 SEC  
Sweep 2: Date: 18 JUN 07 Start Time: 10:38:31 End Time: 11:08:53 Duration: 30 MIN 22 SEC  
Sweep 3: Date: 18 JUN 07 Start Time: 11:09:11 End Time: 11:39:40 Duration: 30 MIN 29 SEC

Capsule 1 Axis 3 25 Hz to 80 Hz to 25 Hz at 1.5 mm amplitude, 3 times, 30 minutes

Sweep 1: Date: 14 JUN 07 Start Time: 12:04:48 End Time: 12:05:11 Duration: 30 MIN 23 SEC  
Sweep 2: Date: 14 JUN 07 Start Time: 12:05:20 End Time: 12:35:46 Duration: 30 MIN 26 SEC  
Sweep 3: Date: 14 JUN 07 Start Time: 12:36:05 End Time: 13:06:27 Duration: 30 MIN 22 SEC

Capsule 1 Axis 3 80 Hz to 2000 Hz to 80 Hz at 20g acceleration, 3 times, 30 minutes

Sweep 1: Date: 20 JUN 07 Start Time: 11:52:11 End Time: 12:22:34 Duration: 30 MIN 23 SEC  
Sweep 2: Date: 20 JUN 07 Start Time: 12:22:51 End Time: 12:53:15 Duration: 30 MIN 24 SEC  
Sweep 3: Date: 20 JUN 07 Start Time: 12:53:25 End Time: 13:23:47 Duration: 30 MIN 22 SEC

**Capsule 2 Axis 1 25 Hz to 80 Hz to 25 Hz at 1.5 mm amplitude, 3 times, 30 minutes**

Sweep 1: Date: 17 May 07 Start Time: 09:46:10 End Time: 10:16:24 Duration: 30 MIN 14 SEC  
Sweep 2: Date: 17 May 07 Start Time: 10:16:31 End Time: 10:46:49 Duration: 30 MIN 18 SEC  
Sweep 3: Date: 17 May 07 Start Time: 10:46:53 End Time: 11:17:11 Duration: 30 MIN 18 SEC

**Capsule 2 Axis 1 80 Hz to 2000 Hz to 80 Hz at 20g acceleration, 3 times, 30 minutes**

Sweep 1: Date: 18 Jun 07 Start Time: 12:12:24 End Time: 12:42:45 Duration: 30 MIN 21 SEC  
Sweep 2: Date: 18 Jun 07 Start Time: 12:42:55 End Time: 13:13:11 Duration: 30 MIN 16 SEC  
Sweep 3: Date: 18 Jun 07 Start Time: 13:13:40 End Time: 13:43:59 Duration: 30 MIN 19 SEC

**Capsule 2 Axis 2 25 Hz to 80 Hz to 25 Hz at 1.5 mm amplitude, 3 times, 30 minutes**

Sweep 1: Date: 22 May 07 Start Time: 13:28:56 End Time: 13:59:14 Duration: 30 MIN 18 SEC  
Sweep 2: Date: 22 May 07 Start Time: 14:02:11 End Time: 14:32:29 Duration: 30 MIN 18 SEC  
Sweep 3: Date: 22 May 07 Start Time: 14:33:12 End Time: 15:03:29 Duration: 30 MIN 17 SEC

**Capsule 2 Axis 2 80 Hz to 2000 Hz to 80 Hz at 20g acceleration, 3 times, 30 minutes**

Sweep 1: Date: 18 Jun 07 Start Time: 14:44:23 End Time: 15:14:45 Duration: 30 MIN 22 SEC  
Sweep 2: Date: 18 Jun 07 Start Time: 15:16:53 End Time: 15:37:16 Duration: 30 MIN 23 SEC  
Sweep 3: Date: 18 Jun 07 Start Time: 15:37:25 End Time: 16:07:54 Duration: 30 MIN 29 SEC

**Capsule 2 Axis 3 25 Hz to 80 Hz to 25 Hz at 1.5 mm amplitude, 3 times, 30 minutes**

Sweep 1: Date: 14 Jun 07 Start Time: 13:44:25 End Time: 14:14:38 Duration: 30 MIN 18 SEC  
Sweep 2: Date: 14 Jun 07 Start Time: 14:14:45 End Time: 14:45:05 Duration: 30 MIN 20 SEC  
Sweep 3: Date: 14 Jun 07 Start Time: 14:45:11 End Time: 15:15:23 Duration: 30 MIN 12 SEC

**Capsule 2 Axis 3 80 Hz to 2000 Hz to 80 Hz at 20g acceleration, 3 times 30 minutes**

Sweep 1: Date: 20 Jun 07 Start Time: 14:02:11 End Time: 14:32:34 Duration: 30 MIN 23 SEC  
Sweep 2: Date: 20 Jun 07 Start Time: 14:32:40 End Time: 15:03:05 Duration: 30 MIN 25 SEC  
Sweep 3: Date: 20 Jun 07 Start Time: 15:03:11 End Time: 15:33:35 Duration: 30 MIN 24 SEC

Test Report No.	<u>TR0173</u>
Effective Date:	<u>03 JUL 07</u>
Control Date:	<u>03 JUL 07</u>
Initials	<u>RM</u>
Page	<u>13</u> of <u>27</u>

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~  
Page 13 of 27

<b>Test notes and deviations</b>	
Recorded By <u>LLOYD L. FLOWERS</u>	Date <u>2 JUL 07</u>
Reviewed and Approved <u>JANA JAN</u>	Date <u>3 JUL 07</u>
Noted resonance frequencies <u>NO RESONANCE FREQUENCIES DETECTED FOR CAPSULES</u> <u>0028 AND 0029.</u>	

Test Conducted By: [Signature] Date: 2 JUL 07

**Vibration testing is complete; perform visual and leak evaluation tests.**

**Equipment**

**NOTE:** Record information on table as applicable.

Equipment	Manufacturer	Model No.	IPL ID or Serial Number	Calibration Date	Calibration Due Date
Amplifier	MB Dynamics	SS250	007518	N/A	N/A
Shear Accelerometer	Kistler	<u>8636850</u> M05	<u>2 01607</u>	<u>15 SEP 05</u>	<u>15 SEP 07</u>
Shear Accelerometer	PCB	J353 B01	10422 or <u>10421</u> (As underlined)	<u>15 SEP 05</u>	<u>15 SEP 07</u>
Timer	Control Company	5000	221230127	<u>13 OCT 06</u>	<u>13 OCT 07</u>

\* For reference use only.

Test Report No.	TR0173
Effective Date:	03 JUL 07
Control Date:	03 JUL 07
Initials	RM
Page	14 of 27

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 14 of 27

Post Test Evaluation For VIBRATION Test

Visual examination notes:

NO CHANGE OR DAMAGE OBSERVED FOR BOTH CAPSULES THAT WERE  
TESTED FOR THE VIBRATION PARAMETERS, 0028 & 0029.

☒ Inactive test source - ~~no additional leak test required~~ 15 May 07 Helium Leak Test By PTL

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.1.3 Immersion test with a liquid scintillator.

The source is immersed for a minimum of 3 hours at room temperature in a liquid scintillation solution, which does not attack the source's outer surface material. The source is stored away from light to avoid photoluminescence. The sealed source is then removed and the activity of the liquid scintillation is measured.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.3.1. Wet wipe test.



Wipe all surfaces of the source with swab moistened with a liquid, which will not attack the source's outer surface material. The swab is then assayed.

Test	Capsule ID	Counts per minute detected	Net Activity (nCi)	Activity limit (nCi)	Test result	Initial & Date
				5		
				5		
N/A	Background		N/A	N/A	N/A	

**Instrument Information:**

Instrument Manufacturer:	
Instrument Model:	
Efficiency for selected nuclide:	
Calibration Date:	
Next Calibration Date	



# AXES USED IN VIBRATION TESTING



Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	15 of 07

4. PACKAGE AND IDENTIFY PART NUMBER THEREON
  3. SURFACE ROUGHNESS: 32  $\mu$ in RMS
  2. REMOVE BURRS AND BREAK EDGES 0.005 MAX
  1. MATERIAL:
- NOTES: UNLESS OTHERWISE SPECIFIED

P/N

 <b>Eckert &amp; Ziegler</b> Isotope Products Valencia, California 91355	UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCH-SIZES; METRIC UNITS (mm) ARE IN MILLIMETERS.	DRAWN THK	TITLE <b>QYNERGY CAPSULE</b>			
	TOLERANCES (UNLESS OTHERWISE SPECIFIED) X.XXX $\pm$ .002 INCH ANGULAR TOLERANCE OF 0°±30° X.XX $\pm$ .005 INCH FRACTIONAL DIMENSIONS $\pm$ 1/32" X.X $\pm$ .03 INCH REFERENCE DIMENSIONS (I) N/A X $\pm$ .1 INCH SURFACE ROUGHNESS (INCH MAX) ALL DIMENSIONS ARE FINISHED DIMENSIONS	ME/CHECKER LF	SERIES TITLE <b>DRAFT</b>			
THIRD ANGLE PROJECTION 	SCALE NONE	SIZE A	CAGE CODE 32993	DRAWING NO. Qynergy	REV 0	SHEET 1 OF 1

DO NOT DISSEMINATE

QYNERGY PROPRIETARY

Report No.	TR0173
Effective Date	03 JUL 07
Original Date	03 JUL 07
Revised	RM
Page	10 of 27

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

**Puncture Test Class 4**

Capsule ID number: 0025 VERIFIED by initial: ff  
Capsule ID number: 0026 VERIFIED by initial: ff

A 50-gram hammer/pin is dropped onto the capsule from 1 meter. A plumb guide tube is used to guide the hammer to the target capsule. The target capsule is placed on a steel billet. The hammer is guided with the intent to strike the capsule impacting the most vulnerable area.

1. Adjust the drop height, gap the distance between the anvil and bottom of the drop tube to no less than the height of the test capsule.
2. With the release pin inserted and using a magnetic grab tool, load the 50g hammer/pin.
3. Position the capsule. Record the capsule orientation.
4. Install acrylic test shield for containment.
5. Pull release pin to drop the hammer.
6. Using forceps gently lift weight and remove source for evaluation.

Test Conducted By: David J. Han Date: 17 May 07

**Puncture test is complete perform evaluation tests.**

Equipment	Manufacturer	Model No.	IPL ID or Serial Number	Calibration Date	Calibration Due Date
Puncture Test Fixture Class 4, 5 & 6	IPL	Custom	None	N/A	N/A
50g Hammer/pin	IPL	Custom	IPL A6550-3	7 SEP 06	7 SEP 07

Puncture Test Fixtures and hammer/pins are designed to meet the requirements of ISO 2919, 7.6 Puncture Test, 7.6.1 Apparatus, 7.6.1.1 Steel hammer, and 7.6.1.2 Hardened steel anvil.

Test Report No. <u>IR0173</u>
Effective Date <u>03 JUL 07</u>
Control Date <u>03 JUL 07</u>
Initials <u>RM</u>
Page <u>17</u> of <u>27</u>

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 17 of 27

Post Test Evaluation For PUNCTURE Test

Visual examination notes:

0025: A SMALL DENT WAS EVIDENT FOLLOWING THE PUNCTURE TEST.  
THE DENT WAS AT THE POINT OF PUNCTURE.  
NO OTHER CHANGE OR DAMAGE OBSERVED.

0026: SAME OBSERVATIONS AS ABOVE.  
UPON SHAKING BOTH CAPSULES, THERE WAS SOUND OF SOMETHING LOOSE  
WITHIN THE CAPSULE.

☒ Inactive test source – ~~no additional leak test required~~ 15 May 07 Helium Leak Test By PTL.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.1.3 Immersion test with a liquid scintillator.

The source is immersed for a minimum of 3 hours at room temperature in a liquid scintillation solution, which does not attack the source's outer surface material. The source is stored away from light to avoid photoluminescence. The sealed source is then removed and the activity of the liquid scintillation is measured.

☐ Leak test evaluation shall be by ISO 9978:1992(E) 5.3.1. Wet wipe test.

Wipe all surfaces of the source with swab moistened with a liquid, which will not attack the source's outer surface material. The swab is then assayed.

Test	Capsule ID	Counts per minute detected	Net Activity (nCi)	Activity limit (nCi)	Test result	Initial & Date
				5		
				5		
N/A	Background		N/A	N/A	N/A	

**Instrument Information:**

Instrument Manufacturer:	
Instrument Model:	
Efficiency for selected nuclide:	
Calibration Date:	
Next Calibration Date	



Test Report No.	TR0173
Effective Date:	03 JUL 07
Control Date:	03 JUL 07
Initials	RM
Page 18	of 27

~~QYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

Page 18 of 27

**Test notes and deviations**

Recorded By LLOYD L. FLOWERS Date 2 JUL 07  
Reviewed and Approved ANAR Ramirez Date 3 JUL 07

TEST SOURCES OF ACTUAL SIZE, FILLED WITH HELIUM GAS, WERE  
SUBJECTED TO VARIOUS TESTS.

THE TESTING PARAMETERS FOLLOWED WERE TEMPERATURE CLASS 3,  
PRESSURE CLASS 3, IMPACT CLASS 3, VIBRATION CLASS 4, AND  
PUNCTURE CLASS 4, IN ACCORDANCE WITH ISO 2919(1999).

THE TEMPERATURE TEST RANGE WAS FROM  $-60^{\circ}\text{C}$  (LOW TEMPERATURE) AND  
 $200^{\circ}\text{C}$  (HIGH TEMPERATURE). THERE WAS SOME DISCOLORATION NEAR THE  
GASKET REGION OF THE CELLS. WIRES PROTRUDING FROM THE CELLS  
MELTED AT THE POINT WHERE THEY MEET THE METAL.

THE IMPACT TEST LEFT THE MARK OF THE TEST WRIGHT ON THE CELLS.  
THE MARKS ON ONE CELL WAS BEARLY EVIDENT.

THE PUNCTURE TEST LEFT A SMALL DENT AT THE POINT OF IMPACT  
ON ONE CELL. SOME LOOSE MATERIAL WAS HEARD ON BOTH CAPSULES  
UPON SHAKING.

NO OTHER CHANGE OR DAMAGE WAS OBSERVED.

UPON COMPLETION OF THE TESTS CONDUCTED 16 MAY 07 THROUGH 29 JUN 07, THE  
CAPSULES WERE SUBMITTED TO PACIFIC TESTING LABORATORIES, INC. FOR  
HELIUM LEAK TESTING PER ISO 9978, 6.1. SEE ATTACHED PTL REPORT.

AS A RESULT OF THE TEST SOURCES PASSING ALL THE PHYSICAL TESTS TO WHICH  
THEY WERE SUBJECTED, IT IS RECOMMENDED THAT THE 4002-KRT2000  
CAPSULES BE CLASSIFIED AS ISO/99/C.33344.

8

7

6

5


4

3

2

1

REV	DESCRIPTION	DATE	APPROVED
1	UPDATED PART LIST AGAIN UNCLASSIFIED PARTS LIST	10/20/07	C. STAG



ISO VIEW SHOWING LOADED GYNCELL

NOTES: UNLESS OTHERWISE SPECIFIED

1. ALL DIMENSIONS IN INCHES
2. DIMENSIONS AND TOLERANCING PER ASME Y14.5M-2004
3. ASSEMBLE PER KRT-2000 ASSEMBLY PROCEDURE
4. LASER ETCH OR EQUIVALENT, TREFOL ON SIDE SHOWING FOLLOWING TEXT OTHER SIDE CENTERED

GYNCELL  
CAUTION - RADIOACTIVE MATERIAL  
KRYPTON-85  
ACTIVITY \_\_\_\_\_

DATE OF LOADING \_\_\_\_\_  
SERIAL NUMBER \_\_\_\_\_  
PART NO. KRT-2000 REV \_\_\_\_\_  
WWW.QYNERGY.COM




APPLY THREAD LOCKER PER LOCTITE SPECS

APPROXIMATE MASS: 100 GRAMS

Test Report No. TRO173  
Effective Date 03 JUL 07  
Date 05 JUL 07  
Page 19 of 27

ITEM	QTY	PART NO.	DESCRIPTION	MATERIAL
1	1	PC BOARD 1 REV 1	PC BOARD 1 REV 1	PC BOARD 1 REV 1
2	1	KRT-2000-1 REV 1	KRT-2000-1 REV 1	KRT-2000-1 REV 1
3	1	KRT-2000-2 REV 1	KRT-2000-2 REV 1	KRT-2000-2 REV 1
4	1	KRT-2000-3 REV 1	KRT-2000-3 REV 1	KRT-2000-3 REV 1
5	1	KRT-2000-4 REV 1	KRT-2000-4 REV 1	KRT-2000-4 REV 1
6	1	KRT-2000-5 REV 1	KRT-2000-5 REV 1	KRT-2000-5 REV 1
7	1	KRT-2000-6 REV 1	KRT-2000-6 REV 1	KRT-2000-6 REV 1
8	1	KRT-2000-7 REV 1	KRT-2000-7 REV 1	KRT-2000-7 REV 1
9	1	KRT-2000-8 REV 1	KRT-2000-8 REV 1	KRT-2000-8 REV 1
10	1	KRT-2000-9 REV 1	KRT-2000-9 REV 1	KRT-2000-9 REV 1
11	1	KRT-2000-10 REV 1	KRT-2000-10 REV 1	KRT-2000-10 REV 1
12	1	KRT-2000-11 REV 1	KRT-2000-11 REV 1	KRT-2000-11 REV 1
13	1	KRT-2000-12 REV 1	KRT-2000-12 REV 1	KRT-2000-12 REV 1
14	1	KRT-2000-13 REV 1	KRT-2000-13 REV 1	KRT-2000-13 REV 1
15	1	KRT-2000-14 REV 1	KRT-2000-14 REV 1	KRT-2000-14 REV 1
16	1	KRT-2000-15 REV 1	KRT-2000-15 REV 1	KRT-2000-15 REV 1
17	1	KRT-2000-16 REV 1	KRT-2000-16 REV 1	KRT-2000-16 REV 1
18	1	KRT-2000-17 REV 1	KRT-2000-17 REV 1	KRT-2000-17 REV 1
19	1	KRT-2000-18 REV 1	KRT-2000-18 REV 1	KRT-2000-18 REV 1
20	1	KRT-2000-19 REV 1	KRT-2000-19 REV 1	KRT-2000-19 REV 1
21	1	KRT-2000-20 REV 1	KRT-2000-20 REV 1	KRT-2000-20 REV 1
22	1	KRT-2000-21 REV 1	KRT-2000-21 REV 1	KRT-2000-21 REV 1
23	1	KRT-2000-22 REV 1	KRT-2000-22 REV 1	KRT-2000-22 REV 1
24	1	KRT-2000-23 REV 1	KRT-2000-23 REV 1	KRT-2000-23 REV 1
25	1	KRT-2000-24 REV 1	KRT-2000-24 REV 1	KRT-2000-24 REV 1
26	1	KRT-2000-25 REV 1	KRT-2000-25 REV 1	KRT-2000-25 REV 1
27	1	KRT-2000-26 REV 1	KRT-2000-26 REV 1	KRT-2000-26 REV 1
28	1	KRT-2000-27 REV 1	KRT-2000-27 REV 1	KRT-2000-27 REV 1
29	1	KRT-2000-28 REV 1	KRT-2000-28 REV 1	KRT-2000-28 REV 1
30	1	KRT-2000-29 REV 1	KRT-2000-29 REV 1	KRT-2000-29 REV 1
31	1	KRT-2000-30 REV 1	KRT-2000-30 REV 1	KRT-2000-30 REV 1
32	1	KRT-2000-31 REV 1	KRT-2000-31 REV 1	KRT-2000-31 REV 1
33	1	KRT-2000-32 REV 1	KRT-2000-32 REV 1	KRT-2000-32 REV 1
34	1	KRT-2000-33 REV 1	KRT-2000-33 REV 1	KRT-2000-33 REV 1
35	1	KRT-2000-34 REV 1	KRT-2000-34 REV 1	KRT-2000-34 REV 1
36	1	KRT-2000-35 REV 1	KRT-2000-35 REV 1	KRT-2000-35 REV 1
37	1	KRT-2000-36 REV 1	KRT-2000-36 REV 1	KRT-2000-36 REV 1
38	1	KRT-2000-37 REV 1	KRT-2000-37 REV 1	KRT-2000-37 REV 1
39	1	KRT-2000-38 REV 1	KRT-2000-38 REV 1	KRT-2000-38 REV 1
40	1	KRT-2000-39 REV 1	KRT-2000-39 REV 1	KRT-2000-39 REV 1
41	1	KRT-2000-40 REV 1	KRT-2000-40 REV 1	KRT-2000-40 REV 1
42	1	KRT-2000-41 REV 1	KRT-2000-41 REV 1	KRT-2000-41 REV 1
43	1	KRT-2000-42 REV 1	KRT-2000-42 REV 1	KRT-2000-42 REV 1
44	1	KRT-2000-43 REV 1	KRT-2000-43 REV 1	KRT-2000-43 REV 1
45	1	KRT-2000-44 REV 1	KRT-2000-44 REV 1	KRT-2000-44 REV 1
46	1	KRT-2000-45 REV 1	KRT-2000-45 REV 1	KRT-2000-45 REV 1
47	1	KRT-2000-46 REV 1	KRT-2000-46 REV 1	KRT-2000-46 REV 1
48	1	KRT-2000-47 REV 1	KRT-2000-47 REV 1	KRT-2000-47 REV 1
49	1	KRT-2000-48 REV 1	KRT-2000-48 REV 1	KRT-2000-48 REV 1
50	1	KRT-2000-49 REV 1	KRT-2000-49 REV 1	KRT-2000-49 REV 1
51	1	KRT-2000-50 REV 1	KRT-2000-50 REV 1	KRT-2000-50 REV 1
52	1	KRT-2000-51 REV 1	KRT-2000-51 REV 1	KRT-2000-51 REV 1
53	1	KRT-2000-52 REV 1	KRT-2000-52 REV 1	KRT-2000-52 REV 1
54	1	KRT-2000-53 REV 1	KRT-2000-53 REV 1	KRT-2000-53 REV 1
55	1	KRT-2000-54 REV 1	KRT-2000-54 REV 1	KRT-2000-54 REV 1
56	1	KRT-2000-55 REV 1	KRT-2000-55 REV 1	KRT-2000-55 REV 1
57	1	KRT-2000-56 REV 1	KRT-2000-56 REV 1	KRT-2000-56 REV 1
58	1	KRT-2000-57 REV 1	KRT-2000-57 REV 1	KRT-2000-57 REV 1
59	1	KRT-2000-58 REV 1	KRT-2000-58 REV 1	KRT-2000-58 REV 1
60	1	KRT-2000-59 REV 1	KRT-2000-59 REV 1	KRT-2000-59 REV 1
61	1	KRT-2000-60 REV 1	KRT-2000-60 REV 1	KRT-2000-60 REV 1
62	1	KRT-2000-61 REV 1	KRT-2000-61 REV 1	KRT-2000-61 REV 1
63	1	KRT-2000-62 REV 1	KRT-2000-62 REV 1	KRT-2000-62 REV 1
64	1	KRT-2000-63 REV 1	KRT-2000-63 REV 1	KRT-2000-63 REV 1
65	1	KRT-2000-64 REV 1	KRT-2000-64 REV 1	KRT-2000-64 REV 1
66	1	KRT-2000-65 REV 1	KRT-2000-65 REV 1	KRT-2000-65 REV 1
67	1	KRT-2000-66 REV 1	KRT-2000-66 REV 1	KRT-2000-66 REV 1
68	1	KRT-2000-67 REV 1	KRT-2000-67 REV 1	KRT-2000-67 REV 1
69	1	KRT-2000-68 REV 1	KRT-2000-68 REV 1	KRT-2000-68 REV 1
70	1	KRT-2000-69 REV 1	KRT-2000-69 REV 1	KRT-2000-69 REV 1
71	1	KRT-2000-70 REV 1	KRT-2000-70 REV 1	KRT-2000-70 REV 1
72	1	KRT-2000-71 REV 1	KRT-2000-71 REV 1	KRT-2000-71 REV 1
73	1	KRT-2000-72 REV 1	KRT-2000-72 REV 1	KRT-2000-72 REV 1
74	1	KRT-2000-73 REV 1	KRT-2000-73 REV 1	KRT-2000-73 REV 1
75	1	KRT-2000-74 REV 1	KRT-2000-74 REV 1	KRT-2000-74 REV 1
76	1	KRT-2000-75 REV 1	KRT-2000-75 REV 1	KRT-2000-75 REV 1
77	1	KRT-2000-76 REV 1	KRT-2000-76 REV 1	KRT-2000-76 REV 1
78	1	KRT-2000-77 REV 1	KRT-2000-77 REV 1	KRT-2000-77 REV 1
79	1	KRT-2000-78 REV 1	KRT-2000-78 REV 1	KRT-2000-78 REV 1
80	1	KRT-2000-79 REV 1	KRT-2000-79 REV 1	KRT-2000-79 REV 1
81	1	KRT-2000-80 REV 1	KRT-2000-80 REV 1	KRT-2000-80 REV 1
82	1	KRT-2000-81 REV 1	KRT-2000-81 REV 1	KRT-2000-81 REV 1
83	1	KRT-2000-82 REV 1	KRT-2000-82 REV 1	KRT-2000-82 REV 1
84	1	KRT-2000-83 REV 1	KRT-2000-83 REV 1	KRT-2000-83 REV 1
85	1	KRT-2000-84 REV 1	KRT-2000-84 REV 1	KRT-2000-84 REV 1
86	1	KRT-2000-85 REV 1	KRT-2000-85 REV 1	KRT-2000-85 REV 1
87	1	KRT-2000-86 REV 1	KRT-2000-86 REV 1	KRT-2000-86 REV 1
88	1	KRT-2000-87 REV 1	KRT-2000-87 REV 1	KRT-2000-87 REV 1
89	1	KRT-2000-88 REV 1	KRT-2000-88 REV 1	KRT-2000-88 REV 1
90	1	KRT-2000-89 REV 1	KRT-2000-89 REV 1	KRT-2000-89 REV 1
91	1	KRT-2000-90 REV 1	KRT-2000-90 REV 1	KRT-2000-90 REV 1
92	1	KRT-2000-91 REV 1	KRT-2000-91 REV 1	KRT-2000-91 REV 1
93	1	KRT-2000-92 REV 1	KRT-2000-92 REV 1	KRT-2000-92 REV 1
94	1	KRT-2000-93 REV 1	KRT-2000-93 REV 1	KRT-2000-93 REV 1
95	1	KRT-2000-94 REV 1	KRT-2000-94 REV 1	KRT-2000-94 REV 1
96	1	KRT-2000-95 REV 1	KRT-2000-95 REV 1	KRT-2000-95 REV 1
97	1	KRT-2000-96 REV 1	KRT-2000-96 REV 1	KRT-2000-96 REV 1
98	1	KRT-2000-97 REV 1	KRT-2000-97 REV 1	KRT-2000-97 REV 1
99	1	KRT-2000-98 REV 1	KRT-2000-98 REV 1	KRT-2000-98 REV 1
100	1	KRT-2000-99 REV 1	KRT-2000-99 REV 1	KRT-2000-99 REV 1
101	1	KRT-2000-100 REV 1	KRT-2000-100 REV 1	KRT-2000-100 REV 1

KRT-2000



Qynergy



GYNCELL  
KRT-2000 GYNCELL  
MODEL KRT-2000 GYNCELL

KRT-2000

KRT-2000

A D 1 of 2

QYNERGY PROPRIETARY  
DO NOT DISCLOSE



REV		DATE	BY
1	DESIGN	02/01/07	02/01/07
2	FOR THE USE OF THE USER TO VIEW, UNDERSTAND & USE	02/01/07	02/01/07

Serial No. TR0132  
 Date 02 JUL 07  
 Date 05 JUL 07  
 RM  
 Page 88 of 137

QYNCELL KR-88 QYNCELL MODEL KRT-2000 QYNCELL	
KRT-2000	A D 2 of 2

QYNCELL PROPRIETARY  
 DO NOT DISTRIBUTE

~~QYNERSY PROPRIETARY~~

~~DO NOT DISTRIBUTE~~

**PACIFIC TESTING LABORATORIES, INC.**

24950 Avenue Tibbitts, Valencia, CA 91355-3426, USA

TEL: (661) 257-1437  
FAX: (661) 257-2411

Test Report No. **PTL 070733**  
Effective Date **03 JUL 07**  
Control Date **03 JUL 07**  
Initials **RM**  
Page **21** of **27**

**TEST REPORT**

In Account With <b>ISOTOPE PRODUCTS LABORATORIES</b> 24937 Avenue Tibbitts Valencia, CA 91355  Attn: Lloyd Flowers	Date June 28, 2007	Page 1 of 7 Pages
	W.O. Number 34908	Specification None specified
	P.O.No. 30453	Received 06-21-2007

**IDENTIFICATION : Six (6) 'Capsules' were submitted by the customer for Helium Leak Testing in accordance Isotope Products purchase order number 30453. The 'Capsules' were identified as follows:**

**IDENTIFICATION**

**Qyncell Dummy Sealed Helium Source, P/N KRT-2000, Rev. A  
S/N's 0025, 0026, 0028, 0029, 0030, and 0031**

**SPECIFICATION : None specified.**

**REFERENCE : Purchase Order Number 30453.**

**TESTING : Helium Leak Test (Bell Jar).**

**SUMMARY : No leakage, in excess of  $1.0 \times 10^{-8}$  ATM cc/sec of helium, was detected on six (6) 'Capsules' identified within this report. The test results, reported herein, are submitted for customer evaluation.**

**Respectfully submitted,  
PACIFIC TESTING LABORATORIES, INC.**



**Michael Shin  
Laboratory Director**



**Donald W. Belanger  
Staff Engineer**

This report applies only to the sample(s) tested and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and Pacific Testing Laboratories, Inc., this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Pacific Testing Laboratories, Inc.

**TESTING ENGINEERING RESEARCH & DEVELOPMENT**

Test Report No	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Revised	RM
Page	22 of 27

~~SYNERGY PROPRIETARY~~

~~DO NOT DISTRIBUTE~~

Page No. : 2 of 7  
W/O No. : 34908

HELIUM LEAKAGE RATE TESTING

**INTRODUCTION** : Six (6) 'Capsules' were submitted by the customer for helium leak testing in accordance with Isotope Products purchase order number 30453.

**REQUIREMENT** : Isotope Products Laboratories purchase order number 30453:

'Helium leak rate shall not exceed  $1.0 \times 10^{-8}$  ATM cc/sec'

**CONDITIONING** : None, tested in an 'as received' condition.

**TEST METHOD** : The vacuum chamber background was measured and recorded prior to each of the six capsules being helium leak tested. The vacuum chamber was evacuated to the required test pressure of one atmosphere without the specimen. The helium leak rate was recorded every 5 seconds for a period of one minute. This data will be considered the background helium indication of the empty vacuum chamber.

The Capsules were individually placed into a vacuum chamber that was attached to a Helium Leak Detector and the chamber was evacuated to the required test pressure of one atmosphere. The helium leak rate test data was recorded every five seconds for a period of approximately one minute.

The specimen was subjected to the helium leak test as stated in this report using a Varian Leak Detector Model Number 960, I.D. Number EC0698. The leak detector was calibrated using a Veeco Calibrated Helium Leak, Model Number SC-4, Serial Number 19256, ID# EC0856, (calibrated 08/15/2006, calibration due 08/15/2007). The sensitivity of the instrument was such to detect a leak greater than or equal to  $2.0 \times 10^{-11}$  ATM cc/sec of helium, with an external pressure of one atmosphere.

The background helium indication of the empty vacuum chamber was subtracted from the recorded helium leak rate test data for each capsule tested as stated within this report. The test result at the end of the one minute test time was recorded as the 'net leak rate' for each capsule.

~~QYNERGY PROPRIETARY~~

~~DO NOT DISTRIBUTE~~

RESULTS

Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Initials	RM
Page	23 of 27

Page No. : 3 of 7

W/O No. : 34908

All of the capsules received were visually examined prior to testing.

Capsule S/N 0025 and 0026, when individually placed into the vacuum chamber, experienced a delay in the evacuation time required to reach proper test pressure of approximately 10 to 15 seconds. It was observed in the visual inspection that the material encapsulating the wire feed through on the capsules was different in color from the remaining four capsules received for testing. See photographs at the end of this report. This material could be experiencing outgassing when the vacuum pressure was applied. This outgassing increases the test pressure during the test which translates to a higher helium indication which may not necessarily be due to helium gas present. A helium leak was determined after the 60 second test time. The 'net leak rate' for each capsule is indicated on the following pages of this report.

Capsule S/N 0028, 0029, 0030 and 0031, when individually placed into the vacuum chamber, did achieve the required test pressure for testing. The 'net leak rate' for each capsule is indicated on the following pages of this report.

Test Report No.	TR0173
Effective Date	03 JUL 07
Control Date	03 JUL 07
Unit	RM
Page	24 of 27

Page No. : 4 of 7  
W/O No. : 34908

**QYNERGY PROPRIETARY**

**DO NOT DISTRIBUTE**

**RESULTS**

: continued:

**HELIUM LEAK RATE DATA**

SPECIMEN	Observed Helium Leak Rate
	Atm cc/sec
Qyncell Dummy Sealed Source Helium, S/N 0025	$8.0 \times 10^{-9}$
Qyncell Dummy Sealed Source Helium, S/N 0026	$7.8 \times 10^{-9}$
Qyncell Dummy Sealed Source Helium, S/N 0028	$< 1.0 \times 10^{-9}$
Qyncell Dummy Sealed Source Helium, S/N 0029	$< 1.0 \times 10^{-9}$
Qyncell Dummy Sealed Source Helium, S/N 0030	$< 1.0 \times 10^{-9}$
Qyncell Dummy Sealed Source Helium, S/N 0031	$< 1.0 \times 10^{-9}$

**SUMMARY**



: The test results, reported herein, are submitted for customer evaluation. See photographs of capsules on following pages. Helium leak rates reported are observed leak rates and does not necessarily conclude that no leaks are existing.

IR	Nr	TR0173
	Dat	03 JUL 07
	W/O	03 JUL 07
	RM	
	25	27



PHOTOGRAPHS

Capsule S/N 0025

~~DYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~



Capsule S/N 0026







Test Report No.	TR0173
Date	03 JUL 07
Time	03 JUL 07
RM	
Page	26 of 27



PHOTOGRAPHS

Capsule S/N 0028

~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~



Capsule S/N 0029





Report No.	TR0173
Date	03 JUL 07
Page	27
of	27

PHOTOGRAPHS



Capsule S/N 0030

~~SYNERGY PROPRIETARY~~

~~DO NOT DISTRIBUTE~~



Capsule S/N 0031



~~SYNERGY PROPRIETARY~~  
~~DO NOT DISTRIBUTE~~

## Eckert & Ziegler Isotope Products

### Addendum to Test Report TR0173

Capsule Test Date: 3 Jul 07  
Capsule Tested: KRT-2000  
Revision Date: 24 Jul 07

The changes to TR0173 are documented in the following summary:

1. The classification is changed from ISO/99/C33344 to ISO/99/CX3344. The change from 3 to X indicates that the temperature test was a special test. As noted in the test report (TR0173), the temperature range was from -60° C to 200°C instead of the temperature classification 3 with the temperature range of -40°C to 180°C. Pages 1 and 2 should read Temperature Class X.
2. The model number of the capsules is changed from 4002-KRT-2000 to KRT-2000. This change will affect page 18 of the test report.
3. The welding callout on the drawing needs to be indicated on the drawing. Page 2 of the drawing (KRT-2000 Rev. A) does not have the welding callout. The attached page 2 of the drawing will replace this page of the test report, page 20.

The above amendments are clerical and do not affect the test report. The addendum will be attached to test report TR0173.

*David F. Thomas*  
Test Engineer

25 Jul 07  
Date

*Frida Jan*  
Director of Quality Operations/  
Regulatory Affairs Manager

26 Jul 07  
Date

*Ana R. Ramirez*  
Radiation Safety Officer/Sr. Health Physicist/  
Alternate Radiation Safety Officer

26 Jul 07  
Date

Test Report No.	TR0173
Effective Date:	26 Jul 07
Control Date:	26 Jul 07
Initials:	MS
Page	1 of 1

8

7

6

5

4

3

2

1

REV		DESCRIPTION	REVISIONS	DATE	APPROVED
A		UPDATED PART LIST, ADDED UNLOADED VIEW, UPDATED TITLE BLOCK		02/23/07	C. BTM00



D

C

B


A

ISO VIEW OF UNLOADED QYNCELL



CUTAWAY ISO VIEW OF LOADED QYNCELL

UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES DECIMALS - 1/16" = .0625" FRACTIONS - 1/32" = .03125" ANGLES - 1/2" = 0.5"	
PART KRT-2000	
DESIGNED BY	DATE
DRWING	12/4/2006
CHKD BY	12/4/2006
APPROVED	12/4/2006



QYNCELL KR-85 QYNCELL MODEL KRT-2000 QYNCELL	
DATE	12/4/2006
REV	A
REV	D
REV	2
REV	0

QYNERGY CORPORATION  
 CONFIDENTIAL

QYNERGY PROPRIETARY  
 DO NOT DISSEMINATE

**FOIA-2009-0020A**

**PAGES 45-103**

**ARE BEING WITHHELD IN THEIR ENTIRETY**

**FOIA EXEMPTION 4**



~~PROPRIETARY AND CONFIDENTIAL~~

**Qynergy Corporation**  
3800 Osuna Rd NE Suite 2  
Albuquerque, NM 87109-4401  
Office: 505.890.6887  
Fax: 505.792.8508  
Web: www.qynergy.com

## Quality Manual

### Approval Log

	Name & Title	Phone & E-Mail	Signature & Date
Main Author:	Stephanie Jones, Quality Manager	505-314-1422 stephanie.jones@qynergy.com	<i>St Jones</i> 8/1/07
Approved:	Chris Eiting, Director of Engineering	505-314-1425 chris.eiting@qynergy.com	<i>Christopher Es</i> 8/1/07
Approved:	Viswanath Krishnamoorthy, Quality Director	505-314-1423 wish@qynergy.com	<i>Viswanath</i> 8/1/07

~~PROPRIETARY~~  
AND  
~~CONFIDENTIAL~~

## Revision Log

Revision	Date	Author(s)	Summary of Revisions/Comments
A	8/11/07	Stephanie Jones and Chris Eiting	Initial release

## Table of Contents

1	ORGANIZATION.....	- 4 -
2	PERSONNEL .....	- 4 -
2.1	Training .....	- 5 -
2.2	Qualified Users .....	- 5 -
2.3	Evaluations .....	- 5 -
2.4	Medical Records .....	- 5 -
3	EQUIPMENT .....	- 5 -
3.1	Equipment Log .....	- 5 -
3.2	Calibration .....	- 5 -
3.3	Special Equipment .....	- 6 -
4	DESIGN AND DOCUMENT CONTROL .....	- 6 -
4.1	Document Control .....	- 6 -
4.2	Top Level Assembly Drawing.....	- 6 -
4.3	Design Report .....	- 6 -
5	MATERIAL AND SERVICE PROCUREMENT .....	- 7 -
5.1	Supplier Selection.....	- 7 -
5.2	Procurement.....	- 7 -
5.3	Receipt Inspection .....	- 7 -
6	INVENTORY .....	- 8 -
7	PRODUCTION PROCEDURES AND PROCESSES .....	- 8 -
8	INSPECTION AND TESTING.....	- 8 -
8.1	Product Inspection .....	- 8 -
8.2	Process Inspection .....	- 9 -
9	NONCONFORMING MATERIALS .....	- 9 -
10	PACKAGING AND TRANSPORTATION .....	- 9 -
11	DEVIATIONS AND CUSTOMER COMPLAINTS .....	- 9 -
12	AUDITS.....	- 10 -
13	RECORDS AND DOCUMENTATION .....	- 10 -



## 1 ORGANIZATION

Qynergy Corporation is organized in the following manor:




Figure 1: Organizational chart.

The primary responsibilities of the principles are:

- President – steward of corporate mission and strategy; primary interface with Board of Directors; final budget authority
- Director of Engineering – directs engineering and production staff; final design and production authority
- Director of Technology, QA Director – directs internal research & development efforts; final Quality Program authority; authorized to halt production for quality issue
- Director of Business Development – directs business development and marketing efforts
- Controller – directs accounting and purchasing-related activities
- QA Manager – ensures QA Program is enforced; ensures safety regulations are followed; serves as NRC contact; authorized to halt production for quality issue

## 2 PERSONNEL

All employees of Qynergy must be qualified to perform their jobs and trained appropriately. Personnel files for every employee are maintained by the Controller and include: resumes (complete with education and work experience), training certificates, employee evaluations, and medical records (as appropriate).

## **2.1 Training**

On-the-job, task-specific training is accomplished as necessary. When an employee has been trained for a specific task, the QA Manager ensures that a Training Certificate is completed and filed in the employee's personnel file. Formal training, such as off-site software training, coursework, etc. is also documented in the same way.

## **2.2 Qualified Users**

Any employee who has been trained on a piece of equipment or to perform a specific task is known as a "Qualified User". The QA Manager maintains a master Qualified User List which is located in the directory "S:\Quality Assurance\Personnel Training Records".

## **2.3 Evaluations**

Employees are evaluated by their supervisors on an annual basis. Evaluations are based on observations of employee work habits and skills, as well as progress toward specific individually defined goals. All evaluations are documented and filed in the personnel files. Supervisors are responsible for ensuring proper documentation of employee evaluations.

## **2.4 Medical Records**

Qynergy does not currently keep any employee medical records on file. If, in the future, specific medical records are identified that may affect job performance, supervisors will be responsible for adding these documents to the personnel files.

# **3 EQUIPMENT**

All test and measurement equipment used for production or testing of Qynergy products is controlled, calibrated, and maintained. Each piece of equipment has a log file for recording maintenance and calibration activities.

## **3.1 Equipment Log**

A log file (stored in "S:\Quality Assurance\Equipment Logs") exists for every piece of equipment used for production or testing of Qynergy products. The file is updated after every maintenance and calibration event. The file includes: manufacturer, model and serial number, calibration procedures, calibration frequency, qualified calibration personnel, date calibrated, due date for calibration, procedures for and records of routine and unscheduled maintenance, nature of the maintenance performed, date maintenance was performed, date equipment is due for maintenance, and the frequency of the maintenance.

## **3.2 Calibration**

All equipment used for production or testing of Qynergy products that can be calibrated is on a yearly calibration schedule. All calibration standards are traceable to NIST or an equally valid national authority. The Calibration Reminder file in "S:\Quality Assurance\Equipment Logs" lists all equipment requiring calibration, along with due date, calibration date, and calibrator (company or individual). The file automatically

highlights equipment that is due for calibration within the next 30 days. Once calibration has occurred, the calibration certificate (if external calibration) is scanned and saved to the "S:\Quality Assurance\Calibration Certificates" directory and the equipment log is updated. All calibrated equipment is marked with a calibration sticker that contains the due date, calibration date, and calibrator (company or individual).

### **3.3 Special Equipment**

Pieces of equipment used for production or testing of Qynergy products that require special handling or storage procedures are marked as such. A label with the special procedures is affixed to the equipment or case.

## **4 DESIGN AND DOCUMENT CONTROL**

All aspects of the design and production of Qynergy products are documented. The QA Manager is responsible for ensuring that all documents contain all pertinent information and conform to all pertinent regulations and specifications.

### **4.1 Document Control**

All documents that are related to a Qynergy product are revision controlled. The latest version of every document is approved by the QA Manager and all affected department heads. An approval signature block and a modification summary are included at the beginning of every product-related document. Once a document version has been approved, the QA Manager converts it to PDF and releases it for use. Only the released versions (approved and converted to PDF) of documents are available for use; this ensures document revisions are not used until ready. Released versions of all product-related documents are kept in the "S:\Quality Assurance" in their appropriate folders. The Master Document List (also in "S:\Quality Assurance") contains all of the released documents titles, version numbers, dates of release, primary author, and whether the document is currently under revision. Any substantive change to a controlled document causes a revision; minor grammatical or spelling changes do not. The NRC Contact is responsible for notifying the NRC of any revisions pertinent to an NRC licensed device.

### **4.2 Top Level Assembly Drawing**

Every product has a unique part number which also serves as the name of the Top Level Assembly Drawing for the product. The Top Level Assembly Drawing includes drawings of the assembled product as well as references to all other documents associated with the product. The final Top Level Assembly Drawing for every product is located in the "S:\Quality Assurance\Design Records\Top Level Assembly Drawings" folder.

### **4.3 Design Report**

Every product has associated with it a Design Report which includes all information related to the design of the product. Product specifications, modeling and analysis results, rationale for critical design decisions, and test results are all included in this document. The final version of this document is located in "S:\Quality Assurance\Design Records".

## **5 MATERIAL AND SERVICE PROCUREMENT**

All materials and procedures used to produce Qynergy products meet specifications and pertinent regulations. Procurement of materials or services is controlled to ensure conformance with specifications.

### **5.1 Supplier Selection**

All suppliers of parts or services related to Qynergy products are chosen based on past history of providing identical or similar materials or services and the supplier's technical capability. The supplier's technical capability is determined by direct evaluation of the facility or by analysis of the quality of previously supplied materials or services. If the quality of the product cannot be determined through inspection or testing, the selection of a supplier is based on the results of an audit of the supplier's operations. The Qualified Suppliers List (in "S:\Quality Assurance\Supplier Records"), which is a controlled document maintained by the QA Manager, contains all of the suppliers qualified for providing materials or services related to Qynergy products. The document also contains the audit history of each supplier; supplier audits must occur at least every three (3) years.

### **5.2 Procurement**

Before procuring a material or service, Qynergy provides to the supplier a scope of work and technical requirements, identification of the documents that should accompany the material or service, identification of the documents that the supplier should keep on file, requirements for reporting and approving dispositions of nonconformance, and the signature of an authorized Purchasing Agent who reports to the Controller. In lieu of forwarding all the relevant information to the supplier each time an order is placed, Qynergy may initiate a written contract with a supplier which contains all the relevant information. Before ordering a material or service from a supplier under contract, the Purchasing Agent ensures the supplier has the most recent contract documentation. To procure a material or service, the requestor completes a Purchase Order Form (approved form in "S:\Quality Assurance\Forms") and receives approval from the appropriate signature authorities. The Purchasing Agent contacts the supplier and places the order.

### **5.3 Receipt Inspection**

All procured items are subject to some level of receipt inspection. The extent of the inspection depends on the item and supplier and is subject to the discretion of the QA Manager. All receipt inspections must, at a minimum, verify: quantity, part ID & size, conformance to specifications, and paperwork. New, non-audited suppliers will require 100% inspection, but items from audited suppliers with good past performance can be subject to sample inspections only. The inspection sampling rate increases if the quality of a material or service decreases. All components of an NRC licensed device that are not manufactured by an NRC licensee are subject to 100% inspection. Any nonconforming material or service is documented in the Supplier Nonconformance Log (in "S:\Quality Assurance\Supplier Records") and tagged by the QA Manager.

## **6 INVENTORY**

After procured items are received and inspected, they are taken to the controlled inventory area. Only items that have been through the receipt inspection process (which may be sample inspection, depending on the item) are taken to the inventory area. All items are labeled (either individually or as a group of like items) and segregated, and items requiring special handling are either labeled with the special handling instructions themselves or labeled "Special Handling Required". Instructions for items marked "Special Handling Required" are located in "S:\Quality Assurance\Production Records\Special Handling Instructions". Items which have a shelf life are marked with their expiration date and receipt date, and are used on a first-in/first-out basis. Any material identified as nonconforming during the inspection process is documented in the Supplier Nonconformance file (see Section 5.3), tagged, and placed in a separate nonconforming inventory area. Qynergy products which have been through final inspection and test are also kept in the controlled inventory area. Periodically, a physical inventory is performed by the QA Manager.

## **7 PRODUCTION PROCEDURES AND PROCESSES**

Qynergy has written procedures for all production processes. The procedures include the machinery and equipment to be used, required worker qualifications, equipment settings, and hold points for inspection and testing. Every product also has a corresponding traveler that is used for recording progress through the manufacturing process. All process documents associated with a Qynergy product are referenced in the Top Level Assembly Drawing (see Section 4.2) and the Traveler for a given product. All production processes are controlled documents, as described in Section 4, so the current released versions are PDF files located in "S:\Quality Assurance\Procedures".

## **8 INSPECTION AND TESTING**

Qynergy performs inspection and testing to ensure that all materials, devices, and production procedures conform to the appropriate specifications and regulations. All inspection points and their results are documented on the Traveler for each individual product. Travelers are hard copies. Once a Traveler is complete, it is considered a controlled document. It is scanned into a PDF format and stored in "S:\Quality Assurance\Production Records".

### **8.1 Product Inspection**

All in-process and final inspection and testing procedures (and appropriate hold points) for a given Qynergy product are described in the production process document. Acceptance criteria, receipt inspection criteria, inspection and test points, inspection sample size determination, final inspection procedures, and nonconformance provisions are all included in the production process document. The traveler is used to record inspection results, including the date and inspector. All inspections are performed by someone other than the person who accomplished the work being inspected. 100% of devices manufactured under an NRC license are subject to a final operational check and removal contamination test (gas loaded devices are exempt from contamination test). Items that pass all inspection points are labeled and taken to the controlled inventory area.

(see Section 6). Items that do not pass an inspection point are held for the QA Manager to disposition. Possible dispositions are: send on, rework, or pull for nonconformance. The QA Manager's disposition is also recorded on the traveler. If pulled for nonconformance, the product is tagged, recorded in the "Product Nonconformance Log" located in "S:\Quality Assurance\Production Records\Non-Conformance Records", and sent to the nonconforming inventory area.

## **8.2 Process Inspection**

Production processes are subject to periodic inspection. The file "Process Inspection Log", located in "S:\Quality Assurance\Internal Audit Records\Process Inspection Records", includes an inspection checklist for each production process and a record of all inspections (including date and inspector). Members of the production staff may perform inspections at any time, but the QA Manager inspects each process at least once per year. If a production process is found to be insufficient, the inspection results and their impact on previously manufactured products are evaluated by the QA Manager and other departments as appropriate. Corrective actions are taken as necessary, which may include customer notification or product recall.

## **9 NONCONFORMING MATERIALS**

Qynergy ensures that materials and devices that do not conform to specifications are not used in production or distributed. Nonconforming materials may be found through receipt inspection (see Section 5.3), in-process and final inspection and testing (see Section 8.1), and devices returned by customers (see Section 11). All nonconforming materials are segregated, placed into the nonconforming inventory area (see Section 6), and documented as appropriate (Supplier Nonconformance Log, Product Nonconformance Log, or Deviation Log). Periodically, the QA Manager disposes the items in the nonconforming inventory area. Items may be introduced back into production, reworked, sent back to the manufacturer, held for further analysis, or discarded at the discretion of the QA Manager.

## **10 PACKAGING AND TRANSPORTATION**

Packaging and shipping of all Qynergy products are completed according to the Packaging and Shipping Procedure located in "S:\Quality Assurance\Procedures". This procedure includes instructions for inspecting packages, evaluating shipping methods, and assigning transportation companies. This procedure also includes the Pre-Shipping Checklist which ensures items are packaged properly, all product related documentation is included or sent to the customer and all appropriate notifications for shipping have been completed. Completed checklists are stored in "S:\Quality Assurance\Shipping and Packaging Records".

## **11 DEVIATIONS AND CUSTOMER COMPLAINTS**

Qynergy applies rigorous inspection methods throughout the manufacturing process in order to ensure that customers receive quality products. For the rare case that a customer may have a problem with a product after it has passed its inspection points, Qynergy has a Deviation Documentation Procedure located in "S:\Quality Assurance\Procedures".

Customer complaints are logged into the Deviation Log as they are received. Each customer complaint record includes: name of complainant, nature and date of complaint, corrective action taken, cause of failure and model and serial number of device. Analysis is then performed to determine the cause of the deviation. The results are recorded in the Deviation Trend Analysis file. The Quality Manager then reviews the finding and initiates notification to customers and the NRC when appropriate. All notifications are recorded in the Deviation Notification Log. The Quality Manager also checks the Deviation Trend Analysis file at least annually for any trends that may indicate manufacturing issues. All customer complaint and deviation records are stored in "S:\Quality Assurance\Deviation (Customer) Records".

## **12 AUDITS**

In order to ensure policies and procedures are functional and being used as intended, Qynergy periodically performs an internal audit on our Quality Program according to the Internal Audit Procedure located in "S:\Quality Assurance\Procedures". The Internal Audit Procedure includes audit acceptance criteria, records and procedure checklists, and deficiencies and corrective actions checklists. Internal audits are performed by either the Quality Assurance Manager or the Quality Assurance Director. Both are independent observers of the processes and procedures being audited. Qynergy's Internal Audit Procedure also requires verification checklists for supplier audits. This ensures that supplier audits have been completed with the frequency required, and that they have been performed according to the Supplier Audit Procedure located in "S:\Quality Assurance\Procedures".

## **13 RECORDS AND DOCUMENTATION**

All records, procedures, checklists, logs, and other documentation related to Qynergy's Quality Assurance Program are kept electronically in "S:\Quality Assurance". Documents requiring signatures are also kept as a hard copy in the Quality Assurance Program Files with the Quality Assurance Manager. Any written procedures, forms, or drawings are created and revised according to the Document Creation and Revision Procedure located in "S:\Quality Assurance\Procedures".

**FOIA-2009-0020A**

**PAGES 114-117**

**ARE BEING WITHHELD IN THEIR ENTIRETY**

**FOIA EXEMPTION 4**