PMFermiCOLPEm Resource

From: Hale, Jerry
Sent: Thursday, September 03, 2009 10:13 AM
To: 'Norman K Peterson'; 'LaShawn G Green'
Cc: FermiCOL Resource
Subject: RAI 1747 Question

For next weeks conference call, the clarification question regarding DTE response to RAI 1747 is,

"Clarify that the Fermi-2 Loss of Service Water frequency (which is higher than the loss of service water frequency used in ESBWR PRA) is not going to be used for Fermi-3 and explain the reason."

Jerry Hale
Project Manager
U.S. Nuclear Regulatory Commission
Office of New Reactors
ESBWR/ABWR Branch 1
(301) 415-8148

Hearing Identifier: Fermi_COL_Public
Email Number: 500

Mail Envelope Properties (D841D501B2C4D244B75AB897F70C14949A64CEDCEF)

Subject: RAI 1747 Question
Sent Date: 9/3/2009 10:13:10 AM
Received Date: 9/3/2009 10:13:11 AM
From: Hale, Jerry

Created By: Jerry.Hale@nrc.gov

Recipients:
"FermiCOL Resource" <FermiCOL.Resource@nrc.gov>
Tracking Status: None
"'Norman K Peterson'" <petersonn@dteenergy.com>
Tracking Status: None
"'LaShawn G Green'" <greenl@dteenergy.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	452	9/3/2009 10:13:11 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: