

PMFermiCOLPEm Resource

From: Hale, Jerry
Sent: Monday, August 31, 2009 11:11 AM
To: LaShawn G Green
Cc: FermiCOL Resource
Subject: ANSI/ANS 2.6-1992 regarding snowpack

LaShawn,

In the call last Thursday, we promised to get you a reference from ANS 2.8. Here are the pertinent passages/sections that I believe address your questions regarding the RAI.

ANSI/ANS 2.6-1992

Section 5.3 "Snowpack and Snowmelt Flood"

This section discusses the condition of PMP on snowpack. In section 5.3.2, it goes on to suggest that a 100 year snow pack be applied to the PMP to determine the flooding condition. These sections are consistent with the alternatives discussed in Section 9.2.1.1 (Alternative III). More guidance on snow pack can be found in Appendix B of this guidance (page 52).

Jerry Hale
Project Manager
U.S. Nuclear Regulatory Commission
Office of New Reactors
ESBWR/ABWR Branch 1
(301) 415-8148

Hearing Identifier: Fermi_COL_Public
Email Number: 531

Mail Envelope Properties (D841D501B2C4D244B75AB897F70C14949A4D29C0E1)

Subject: ANSI/ANS 2.6-1992 regarding snowpack
Sent Date: 8/31/2009 11:10:43 AM
Received Date: 8/31/2009 11:10:44 AM
From: Hale, Jerry

Created By: Jerry.Hale@nrc.gov

Recipients:
"FermiCOL Resource" <FermiCOL.Resource@nrc.gov>
Tracking Status: None
"LaShawn G Green" <greenl@dteenergy.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	794	8/31/2009 11:10:44 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: