

PMSTPCOL NPEmails

From: Eudy, Michael
Sent: Wednesday, September 02, 2009 2:19 PM
To: Chappell, Coley
Cc: STPCOL
Subject: STP Chapter 1 draft RAI 3581
Attachments: RAI 3581.doc

Importance: High

Coley,

I could not find Bill's email, so please forward accordingly. Attached is a draft chapter 1 RAI. Please let me know if you need to discuss v.i.a. telecon. If I don't hear from STP by 9/9/09, I will issue this RAI on 9/10/09. Thanks.

Michael A. Eudy - Project Manager
U.S. Nuclear Regulatory Commission
NRO/DNRL/NGE1&2
301-415-3104

Hearing Identifier: SouthTexas34NonPublic_EX
Email Number: 1368

Mail Envelope Properties (3D27D29AB75BCD4BAE913B63CBFBEDFDE764A22EA)

Subject: STP Chapter 1 draft RAI 3581
Sent Date: 9/2/2009 2:18:47 PM
Received Date: 9/2/2009 2:18:51 PM
From: Eudy, Michael

Created By: Michael.Eudy@nrc.gov

Recipients:
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Chappell, Coley" <ccchappell@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	378	9/2/2009 2:18:51 PM
RAI 3581.doc	31738	

Options
Priority: High
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 3581 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 01 - Introduction and Interfaces
Application Section: 1.8 Conformance with Standard Review Plan and Applicability of Codes and Standards

QUESTIONS for ESBWR/ABWR Projects 2 (NGE2)

01-***

A number of Regulatory Guides (RGs) noted as applicable to the ABWR in Table 1.8-20 of the DCD/Tier 2 have been updated, but were not included in the FSAR respectively. In addition, these RGs were listed as the responsibility of the COL applicant to address. These RGs are as follows:

- RG 1.13, Rev. 3, 3/1997
- RG 1.20, Rev. 3, 3/2007
- RG 1.32, Rev. 3, 3/2004
- RG 1.52, Rev. 3, 6/2007
- RG 1.57, Rev. 1, 3/2007
- RG 1.101, Rev. 5, 6/2005
- RG 1.118, Rev. 3, 4/1995
- RG 1.124, Rev. 1, 2/2007
- RG 1.128, Rev. 2, 2/2007
- RG 1.129, Rev. 2, 2/2007
- RG 1.130, Rev. 2, 3/2007

With respect to addressing 10 CFR Part 52, Section 52.79(a)(41), the staff requests that the applicant reconcile these apparent inconsistencies accordingly.

01-***

Three SRP sections identified in Table 1.8-19 of the DCD Tier 2 that are listed as the responsibility of the COL applicant have not been included in either Table 1.9S-3 or Table 1.9S-4 of the applicant's FSAR. Respectively, these are Section 9.5.2, Communication Systems; Section 13.5.2, Operating and Maintenance Procedures; and Section 17.2, Quality Assurance during the Operations Phase. With respect to addressing 10 CFR Part 52, Section 52.79(a)(41), the staff requests that the applicant reconcile these apparent omissions accordingly.