PMSTPCOL PEmails

From: Keith, Felicia
Sent: Monday, August 24, 2009 4:12 PM
To: Bill Mookhoek; Scott Head; Chappell, Coley; STPCOL
Cc: Tai, Tom
Subject: Request for Addtional Information Letter No. 248 Related To SRP Section 10.02 For The South TExas Project combined License Application
Attachments: ML092360527.pdf

TO: Scott Head

FROM: Tom Tai

DATE: August 24, 2009

ADAMS Accession No. ML092350427

Felicia Keith, Secretary
ESBWR/ABWR Projects Branch 2
Division of New Reactor Licensing
Office of New Reactors
301-415-2950
Felicia.Keith@nrc.gov

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1686

Mail Envelope Properties (CEEA97CC21430049B821E684512F6E5ECA563D7C87)

Subject: Request for Addtional Information Letter No. 248 Related To SRP Section 10.02 For The South TExas Project combined License Application
Sent Date: 8/24/2009 4:12:29 PM
Received Date: 8/24/2009 4:12:32 PM
From: Keith, Felicia

Created By: Felicia.Keith@nrc.gov

Recipients:
"Tai, Tom" <Tom.Tai@nrc.gov>
Tracking Status: None
"Bill Mookhoek" <wemookhoek@stpegs.com>
Tracking Status: None
"Scott Head" <smhead@stpegs.com>
Tracking Status: None
"Chappell, Coley" <ccchappell@STPEGS.COM>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	291	8/24/2009 4:12:32 PM
ML092360527.pdf	93389	

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

August 24, 2009

Mr. Scott Head, Manager
Regulatory Affairs
STP Nuclear Operating Company
P. O. Box 289
Wadsworth, TX 77483

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 248 RELATED TO SRP SECTION 10.02 FOR THE SOUTH TEXAS PROJECT COMBINED LICENSE APPLICATION

Dear Mr. Head

By letter dated September 20, 2007, STP Nuclear Operating Company (STP) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter.

To support the review schedule, you are requested to respond within **30** days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 3085

Enclosure:
Request for Additional Information

cc: William Mookhoek
James Agles

If you have any questions or comments concerning this matter, I can be reached at 301-415-8484 or by e-mail at Tom.Tai@nrc.gov or you may contact George Wunder at 301-415-1494 or George.Wunder@nrc.gov.

Sincerely,

/RA/

Tom M. Tai, Senior Project Manager
ABWR Projects Branch
Division of New Reactor Licensing
Office of New Reactors

Docket Nos. 52-012
52-013

eRAI Tracking No. 3085

Enclosure:
Request for Additional Information

cc: William Mookhoek
James Agles

Distribution:
PUBLIC
NGE 1/2 R/F
GWunder, NRO
BAbeywickrama, NRO
NRay, NRO
GMakar, NRO
SKirkwood, OGC
RidsNroDeCib2
RidsNroDnrlNge2

ADAMS Accession No. ML092360527 NRO-002

OFFICE	CIB2/TR	CIB2/BC	NGE2/PM	OGC	NGE2/L-PM
NAME	GMakar	NRay	TTai	SKirkwood	GWunder
DATE	6/08/09	6/08/09	8/24/09	6/11/09	6/19/09

***Approval captured electronically in the electronic RAI system.**

OFFICIAL RECORD COPY

Request for Additional Information No. 3085 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 10.02.03 - Turbine Rotor Integrity
Application Section: 10.2

QUESTIONS for Component Integrity, Performance, and Testing Branch 2 (ESBWR/ABWR Projects) (CIB2)

10.02.03-1

Please modify FSAR Section 10.2.5.1 and Commitment 10.2-1 to state that the as-built material property data will be provided in the FSAR update after procurement and prior to initial fuel load.

Enclosure