

OPEN ITEMS 16.4.10

09/16/2009

US-APWR Design Certification

Mitsubishi Heavy Industries

Docket No. 52-021

**SRP Section: 16.4.10 – Plant Systems
Technical Specifications Branch**

[Open Item 16-9.2.1-26] This question is related to RAI 16-9.2.1-26.

- In RAI 9.2.1-26, the applicant was asked to address an inconsistency between GTS 3.7.8 and relevant information provided in DCD sections 8.3.1 and 9.2.1 regarding heat loads from the gas turbine generator (GTG) coolers. The response to this RAI has not been received from MHI. This is an open items (OI 9.2.1-26).