

TELECOPY TRANSMITTAL

DATE: 9/25/	
то:	lose Macatangaif
Fax Numbe	<u>(030-575-1078</u>
FROM:	Evin Bell
RE:	larian Amet
	Control #: 318361
COMMENTS:	Please let me know if
	- Please let me know if - you need further [Aformation.
	Information.
14	
This transmittal cons	sists of 3 pages (including transmittal cover sheet). Please
contact me if you ha	ve any questions or problems with this transmittal.
2309 Shelby Avenue Ann Arbor, MI 48103 (734) 662-9224 Fax (734) 662-3197	70 E. 91 st Street, Suite 106



September 25, 2009

Jose Macatangay NRC Region III 2443 Warrenville Road Lisle, Illinois 60532-4352

License Number: 13-32535-02

Control Number: 318361

Dear Mr. Macatangay:

Following, please find the answers to your request for further information regarding the decommissioning of two facilities managed by Clarian Arnett Health System.

Item 1: The Gadolinium sources have been moved along with the camera in which they are installed, to the 5165 McCarty Lane, Lafayette, Indiana address on the license. Please give guidance on assuring that this location is authorized to store the sources. Enclosed, please find a copy of the most recent leak test.

Item 2: The mailing address will now be 5165 McCarty Lane, Lafayette, Indiana 47905.

Item 3: No response required.

Item 4: No response required.

Please let me know if you need further information.

Sincerely,

Erin Bell, MHP

Medical Physics Consultants, Inc.

(p) 877.321.2207 x 342

(f) 317.581.1931



Sealed Source Leak Test

Licensee: Clarian Arnett Hospital

Date: 06/22/09

Performed by: Erin Bell

Marattal			Calibration			
Nuclide	Туре	Activity	Date	Location	M/N	S/N
Co-57	flood	10 mCi	12/01/08	Hot Lab	2700A DO408484	4000
Current Act	tivity: 5.9		12/01/00	HOLLAD	3709AD010MN	1326-111
Cs-137	vial	218 uCi	08/14/08	Hot Lab	Philodatecona	4.4
Current Act	ivity: 213.		00/11/00	TIOL EGD	BM06137E08224	41
Ba-133	vial	242.6 uCi	07/01/06	Hot Lab		4404 45 0
Current Act	ivity: 200.	19uCi		THE EGS		1194-15-6
Cs-137	vial	266.6 uÇi	07/01/06	Hot Lab		1145-97-10
Current Acti	vity: 248.	88uCi				1740-97-10
. Co-57	flood	10 mCi	12/01/08	Hot Lab	3709AD010MN	1326-121
Current Acti	vity: 5.94	49mCi			OT COMPO TOTAL	1320-121
	att src	20 mCi	02/01/09	Hot Lab		1355012A5
Current Activ	vity: 13.35	56mCi				13000 12A5
	att src	20 mCi	02/01/09	Hot Lab		1355012A6
Current Activ	vity: 13.35	6mCi				100001270
	att srç	20 mCi	02/01/09	Hot Lab		1355012A7
Current Activ		6mCi				1000012/1
	att src	20 mCi	02/01/09	Hot Lab		1355012A8
Current Activ		6mCi				1000012710
	att src	20 mCi	08/01/08	Hot Lab		1355077A1
Current Activ						
	att src	20 mCi	08/01/08	Hot Lab		1355077A2
Current Activi						
	itt src		08/01/08	Hot Lab		1355077A3
Current Activi						, , , , ,
	tt src	20 mCi	08/01/08	Hot Lab		1355077A4
Current Activi						

Comment: The sources listed above were leak tested using a dry wipe technique and were found to have less than 0.005 uCi removable activity. The following Minimum Detectable Activities are based upon a background at the indicated value. Background was at or below these levels when the above tests were completed.

Well Counter: Ludlum 2200 Scaler

<u>Nuclide</u>	MDA	Background
Cs-137	2.0 x 10 ⁻⁴ uCi	145 counts/1 min
Ba-133	8.8 x 10 ⁻⁵ uCi	
Co-57	· ·	204 counts/1 min
CO-07	1.7 x 10 ^{-∜} uCì	53 counts/1 min

RADIATION SAFETY OFFICER:

Sealed Source Leak Test Page 1