

## Pu Plant Laboratory Drain System

The laboratory drain system consisted of two separate drain systems. The uranium laboratory room drain system was located in Room 140 and exited the building through the east wall and terminated in the 10,000 gallon collection tanks. This system consisted of approximately fifty two feet of two inch durcon pipe under the floor of Room 140. The Plutonium laboratory rooms drain system serviced most of the laboratory area and exited through the buildings north wall and terminated in the 10,000 gallon collection tanks. This system consisted of approximately 335 feet of two inch durcon pipe.

Since the uranium drainage system was contaminated to approximately 500 dpm/100 cm<sup>2</sup> smearable and was concentrated in one room we decided that it would be easier to remove this small system (Figure #1). This was accomplished by using a concrete saw to cut around the up risers, breaking out the concrete, and digging up the pipe. We performed a release survey on all concrete that was removed. All dirt was drummed as it was removed. All joints were inspected for leakage and surveyed for detectable contamination. After the pipe was removed each hole was surveyed with an Eberline PRM-5 with PG-2 gamma probe and soil samples were taken. Since no contamination problems were detected the dirt was then returned to the hole.

Our initial plan was to clean and survey the Pu drain system (figure #2 and #2A). To accomplish this, we saw the need to acquire some special detectors and to prove that this system was leak proof. We initially removed a portion of this system outside of the building between the building and the 10,000 gallon tanks and installed a sight glass riser on the pipe at the lower level outside of the building (Figure #3). We proceeded to fill the entire system under the building with water to the floor level and marked the water level in the sight glass riser.

The results of our initial leak test indicated a leak rate of approximately 0.5 gallons of water per minute in this remaining system. In an attempt to locate this leak we decided to remove the line from under rooms 141, 142, 143, 140, and 132 since we already had access under the floor in room 140. We also decided to cut a hole in the northwest corner of room 129 and to separate the drain line there for our next leak test (figure #4).

Our second leak test consisted of the remaining drain system in the laboratory area only. We installed two standpipes, one in the northwest corner of room 129, and the other in room 132 northwest corner (Figure #4). After filling this portion of the drain system with water, we still indicated a leak rate of approximately 0.5 gallons per minute. Because of the results of this leak test we continued to remove Pu drain line until we found a wet area in room 135. This wet dirt was drummed separately and labeled as possibly contaminated dirt (Figure #5.) As we continued to remove dirt at this location we found an elbow at approximately 6 feet below floor level with the back of the elbow broken out. Since there was only approximately 35 feet of this drain system left in the laboratory area, we decided to complete removal of this system from the laboratory area (Figure #6). Our third leak test consisted of the drain line from the northwest corner of room 129 to the north wall of the Pu building (Figure #7). After this portion of the system was filled with water and left 24 hours it indicated no leakage from this part of the system. This is a straight run of approximately 82 feet of two inch durcon pipe that runs through the exhaust ventilation tunnel and under the production hall thru room 127 (Figure #7). Initial smearable results indicated approximately 1000 dpm/100 cm<sup>2</sup> smearable in this pipe. We used a rotating steel brush with a water flush to clean this pipe to less than 20 dpm/100 cm<sup>2</sup> smearable.

We built a cylindrical gas proportional alpha detector to pull through this line for our direct survey. Our initial survey indicated approximately 50% of our readings were still above 100 dpm/100 cm<sup>2</sup> and a maximum of 408 dpm/100 cm<sup>2</sup> (Figures #8A, B,C,). After recleaning the pipe with a brush hone our results were all less than 100 dpm/100 cm<sup>2</sup> direct and less than 20 dpm/100 cm<sup>2</sup> smearable (Figures #9A,B,C,D,E,F,G).


*W.A. Rogers*

W. A. Rogers

Pu-Plant Lab. Drain Survey

	<u>DIRECT</u>
TOTAL DPM	4986
# READINGS	533
AUG. DPM/100cm <sup>2</sup>	9.35
MAX. READING	81
MDA DPM/100cm <sup>2</sup>	13.66

Average smear was 1 DPM/100cm<sup>2</sup>



N

130

↑  
N

Pu Laboratory Area

131

129

132

135

134

133

136

To 10,000 gallon Tanks  
↑

138

139

137

140

Pu-PLANT  
URANIUM DRAIN LINE

← East Wall of Pu Building


143

142

141

Figure # 1


Per drain line to 10,000 gallon Tanks  
↓



↑  
N  
Per Laboratory  
Area

Figure # 2

N



Pu DRAIN LINE  
PAGE 2 OF 2

Figure # 2A




Figure # 3






Figure # 4




Figure # 5





Figure # 6



Pu DRAIN LINE

Figure # 7


2 inch Pipe Detector

Gas Proportional Detector


round cylinder with four windows

Each window =  $6.6 \text{ cm} \times 2.3 \text{ cm} = 15.18 \text{ cm}^2$

$15.18 \times 4 = 60.72 \text{ cm}^2$



Cage to center detector in pipe



Inside surface area of pipe =  $2 \pi r h$


$$2 \times 3.1416 \times \frac{5.1 \text{ cm}}{2} \times 6.6 \text{ cm} = 105.75 \text{ cm}^2$$

Calibrated detector to see  $360^\circ$  surface  
of pipe  $105.75 \text{ cm}^2 \approx 100 \text{ cm}^2$

COUNTER TEST - CHI SQUARED ( $\chi^2$ )

COUNT NUMBER*	NET COUNT (n)	AVERAGE COUNT # (n̄)	(n - n̄)	(n - n̄) <sup>2</sup>
1	13	12	1	1
2	15		3	9
3	15		3	9
4	7		-5	25
5	12		0	0
6	9		-3	9
7	14		2	4
8	16		4	16
9	6		-6	36
10	8		-4	16
11	11		-1	1
12	11		-1	1
13	6		-6	36
14	11		-1	1
15	13		1	1
16	17		5	25
17	19		7	49
18	17		5	25
19	12		0	0
20	11		-1	1
21				
TOTAL OF 20 COUNTS ( $\Sigma n$ )	243		TOTAL ( $\Sigma (n - \bar{n})^2$ )	265

DATE: 8-17-88  
 OPERATOR: W.G. Rogers  
 VOLTAGE SETTING: 1750  
 STANDARD SOURCE NO: 1840  
 VALUE: 700 dpm 4" II  
 Bkg 0.3 cpm



CHI LIMIT  
 95% C.L.  
 .4453 - 1.6464  
 $\bar{x} + \sigma = 19$   
 $\bar{x} = 12$   
 $\bar{x} - \sigma = 5$

\* DISCARD ONE UNUSUALLY HIGH OR LOW COUNT IN CALCULATING  $\bar{n}$ .

$$\bar{x} = \frac{\Sigma X}{N} = \frac{(243)}{20} = 12.15$$

$$\text{TOTAL (1) } \Sigma X = 243$$

$$\text{TOTAL (2) } \Sigma (x - \bar{x})^2 = 265$$

$$\text{CHI}^2 = \frac{\Sigma (x - \bar{x})^2}{\Sigma X} = \frac{(265)}{(243)} = 1.0905$$

$$\text{COUNTER EFFICIENCY} = \frac{\text{AVERAGE COUNT CPM}}{\text{SOURCE VALUE (dpm)}} = \frac{(12.15)}{(100)} = 0.1215$$

$$2\sigma = 1.96 \sqrt{\frac{1}{\bar{x}}} = 1.96 \times 3.4857 = 6.832 = \pm 7$$

$$\text{cpm} - \text{Bkg.} \times 9 = \text{dpm} / 100 \text{ cm}^2$$

Figure # 8A

2" Pipe Detector 1st count North end Date: 8-31-88 Initial Survey  
 Ludlum 2500 26465 H. P. W.C. Rogers  
 10 Min Bkg. = 0.9 cpm Source #1840 - 100 dpm 4π  
 Source Response = 16, 23, 7, 10, 9  
 Reading taken approx. every 2" detector face = 2 5/8" long

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
1	1	9	32	2	18	63	4	36
2	4	36	33	15	135	64	3	27
3	7	63	34	15	135	65	1	9
4	6	54	35	29	261	66	3	27
5	7	63	36	15	135	67	7	63
6	10	90	37	7	63	68	9	81
7	4	36	38	8	72	69	5	45
8	5	45	39	5	45	70	12	108
9	7	63	40	4	36	71	5	45
10	5	45	41	6	54	72	3	27
11	3	27	42	41	369	73	4	36
12	7	63	43	8	72	74	27	243
13	6	54	44	5	45	75	14	126
14	5	45	45	8	72	76	14	126
15	8	72	46	8	72	77	17	153
16	7	63	47	6	54	78	3	27
17	3	27	48	5	45	79	9	81
18	2	18	49	14	126	80	16	144
19	0	0	50	3	27	81	5	45
20	6	54	51	1	9	82	13	117
21	7	63	52	3	27	83	12	108
22	7	63	53	10	90	84	14	126
23	5	45	54	7	63	85	39	351
24	9	81	55	7	63	86	8	72
25	10	90	56	7	63	87	23	207
26	7	63	57	4	36	88	18	162
27	12	108	58	10	90	89	46	414
28	10	90	59	10	90	90	4	36
29	17	153	60	10	90	91	16	144
30	9	81	61	6	54	92	20	180
31	4	36	62	1	9	93	17	153

File # 8B






COUNTER TEST - CHI SQUARED ( $\chi^2$ )

COUNT NUMBER*	NET COUNT (m)	AVERAGE COUNT $\bar{x}$ (M)	(m - $\bar{x}$ )	(m - $\bar{x}$ ) <sup>2</sup>
1	10	11	-1	1
2	12		1	1
3	12		1	1
4	15		4	16
5	10		-1	1
6	11		-0	0
7	16		5	25
8	16		5	25
9	7		-4	16
10	9		-2	4
11	5		-6	36
12	20		9	81
13	16		5	25
14	8		-3	9
15	11		0	0
16	15		4	16
17	7		-4	16
18	8		-3	9
19	13		2	4
20	8		-3	9
21				
TOTAL OF 20 COUNTS ( $\Sigma m$ ) =	229		TOTAL ( $\Sigma (m - \bar{x})^2$ ) =	295

COUNTER # Ludlum 2500 DATE 10-24-88 W.G. Rogue VOLTAGE SETTING 1750 STANDARD SOURCE NO 1840  
 2" Pipe Detector COUNT TIME - ONE MINUTE HV-6.9 VALUE 100 dpm 4"  $\bar{x}$   
 Background - 0.3 cpm



CHI<sup>2</sup> LIMIT  
 95% C.L.  
 4453 - 1.6464  
 $\bar{x} + \sigma = 18$   
 $\bar{x} = 11$   
 $\bar{x} - \sigma = 4$

\* DISCARD ONE UNUSUALLY HIGH OR LOW COUNT IN CALCULATING  $\bar{x}$ .

$$\bar{x} = \frac{\Sigma X}{N} = \frac{(229)}{20} = 11.45$$

$$\text{TOTAL (1) } \Sigma X = 229$$

$$\text{TOTAL (2) } \Sigma (x - \bar{x})^2 = 295$$

$$\text{CHI}^2 = \frac{\Sigma (x - \bar{x})^2}{\Sigma X} = \frac{(295)}{(229)} = 1.2882$$

$$\text{COUNTER EFFICIENCY} = \frac{\text{AVERAGE COUNT CPM}}{\text{SOURCE VALUE (dpm)}} = \frac{(11.45)}{(100)} = .1145$$

$$2\sigma = 1.96 \sqrt{\frac{1}{\bar{x}}} = 1.96 \times 3.3838 = 6.63 = \pm 7$$

Figure # 9A

2" Pipe Detector 1st count North end Date: 10-24-88 Final Survey  
 Ludlum 2500 26465 H. P. W.O. Brown  
 10 Min Bkg. = 0.3 cpm Source #1840 - 100 dpm 4π  
 Source Response = 10, 12, 12, 11, 16  
 Reading taken approx. every 2" detector face = 2 5/8"

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
1	2	18	31	3	27	61	0	0
2	5	45	32	1	9	62	0	0
3	4	36	33	0	0	63	1	9
4	5	45	34	1	9	64	1	9
5	4	36	35	1	9	65	1	9
6	4	36	36	0	0	66	1	9
7	1	9	37	1	9	67	0	0
8	9	81	38	0	0	68	0	0
9	3	27	39	1	9	69	0	0
10	2	18	40	0	0	70	1	9
11	2	18	41	2	18	71	0	0
12	2	18	42	1	9	72	0	0
13	1	9	43	0	0	73	0	0
14	2	18	44	0	0	74	1	9
15	4	36	45	0	0	75	3	27
16	5	45	46	0	0	76	2	18
17	3	27	47	0	0	77	0	0
18	1	9	48	0	0	78	0	0
19	4	36	49	1	9	79	2	18
20	4	36	50	0	0	80	0	0
21	0	0	51	1	9	81	0	0
22	2	18	52	1	9	82	0	0
23	5	45	53	1	9	83	0	0
24	2	18	54	1	9	84	6	54
25	4	36	55	0	0	85	0	0
26	2	18	56	1	9	86	1	9
27	1	9	57	0	0	87	0	0
28	2	18	58	1	9	88	1	9
29	6	54	59	0	0	89	0	0
30	3	27	60	1	9	90	1	9

Figure # 9 B

2" Pipe Detector Page 2  
 Ludlum 2500 26465  
 10 Min Bkg. = 0.3 cpm  
 Source Response = 10, 12, 12, 11, 16  
 Reading taken approx. every 2" detector face = 2 5/8"

Date: 10-24-88  
 H. P. W. A. Roemer  
 Source #1840 - 100 dpm 4 π

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
91	2	18	121	1	9	151	2	18
92	2	18	122	1	9	152	1	9
93	0	0	123	0	0	153	1	9
94	0	0	124	1	9	154	0	0
95	1	9	125	0	0	155	0	0
96	1	9	126	1	9	156	1	9
97	0	0	127	0	0	157	0	0
98	1	9	128	2	18	158	0	0
99	0	0	129	1	9	159	1	9
100	0	0	130	0	0	160	1	9
101	0	0	131	0	0	161	0	0
102	1	9	132	0	0	162	2	18
103	2	18	133	1	9	163	1	9
104	0	0	134	0	0	164	1	9
105	2	18	135	2	18	165	1	9
106	1	9	136	0	0	166	2	18
107	0	0	137	1	9	167	1	9
108	0	0	138	0	0	168	0	0
109	0	0	139	2	18	169	2	18
110	1	9	140	4	36	170	0	0
111	1	9	141	3	27	171	1	9
112	0	0	142	2	18	172	2	18
113	0	0	143	3	27	173	3	27
114	1	9	144	0	0	174	0	0
115	0	0	145	1	9	175	2	18
116	1	9	146	0	0	176	1	9
117	1	9	147	0	0	177	1	9
118	0	0	148	0	0	178	0	0
119	1	9	149	0	0	179	0	0
120	1	9	150	0	0	180	1	9

2" Pipe Detector Page 3  
 Ludlum 2500 26465  
 10 Min Bkg. = 0.3 cpm  
 Source Response = 10, 12, 12, 11, 16  
 Reading taken approx. every 2" detector face = 2 5/8"

Date: 10-24-88  
 H. P. W. G. Agnes  
 Source #1840 - 100 dpm 4 π

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
181	0	0	211	1	9	241	1	9
182	1	9	212	1	9	242	7	63
183	1	9	213	3	27	243	0	0
184	0	0	214	1	9	244	1	9
185	0	0	215	0	0	245	0	0
186	0	0	216	1	9	246	0	0
187	1	9	217	2	18	247	0	0
188	1	9	218	1	9	248	0	0
189	2	18	219	2	18	249	1	9
190	0	0	220	0	0	250	1	9
191	1	9	221	0	0	251	1	9
192	1	9	222	2	18	252	2	18
193	0	0	223	2	18	253	1	9
194	0	0	224	2	18	254	1	9
195	2	18	225	1	9	255	1	9
196	2	18	226	0	0	256	0	0
197	0	0	227	1	9	257	0	0
198	1	9	228	0	0	258	0	0
199	0	0	229	2	18	259	1	9
200	1	9	230	1	9	260	0	0
201	2	18	231	0	0	261	1	9
202	0	0	232	0	0	262	0	0
203	1	9	233	1	9	263	1	9
204	1	9	234	0	0	264	0	0
205	1	9	235	0	0	265	3	27
206	1	9	236	2	18	266	4	36
207	1	9	237	0	0	267	0	0
208	2	18	238	0	0	268	0	0
209	2	18	239	1	9	269	0	0
210	0	0	240	0	0	270	0	0

Figure # 90

2" Pipe Detector Page 4

Date: 10-24-88

Ludlum 2500 26465

H. P. W.G. Jones

10 Min Bkg. = 0.3 cpm

Source #1840 - 100 dpm 4 π

Source Response = 10, 12, 12, 11, 16

Reading taken approx. every 2" detector face = 2 5/8"

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
271	0	0	301	2	18	331	0	0
272	0	0	302	0	0	332	2	18
273	0	0	303	0	0	333	0	0
274	0	0	304	0	0	334	2	18
275	0	0	305	1	9	335	0	0
276	0	0	306	0	0	336	1	9
277	0	0	307	0	0	337	1	9
278	2	18	308	1	9	338	0	0
279	1	9	309	0	0	339	0	0
280	0	0	310	1	9	340	0	0
281	3	27	311	0	0	341	0	0
282	0	0	312	2	18	342	0	0
283	1	9	313	1	9	343	2	18
284	0	0	314	0	0	344	0	0
285	0	0	315	0	0	345	1	9
286	2	18	316	0	0	346	0	0
287	1	9	317	0	0	347	0	0
288	1	9	318	1	9	348	0	0
289	2	18	319	1	9	349	1	9
290	2	18	320	0	0	350	4	36
291	0	0	321	0	0	351	0	0
292	0	0	322	1	9	352	1	9
293	0	0	323	0	0	353	2	18
294	0	0	324	1	9	354	0	0
295	0	0	325	0	0	355	0	0
296	3	27	326	0	0	356	0	0
297	0	0	327	2	18	357	2	18
298	2	18	328	0	0	358	1	9
299	2	18	329	0	0	359	2	18
300	1	9	330	1	9	360	1	9

Figure # 9 E

2" Pipe Detector Page 5  
 Ludlum 2500 26465  
 10 Min Bkg. = 0.3 cpm  
 Source Response = 10, 12, 12, 11, 16  
 Reading taken approx. every 2" detector face = 2 5/8"

Date: 10-24-88  
 H. P. W.C. Rogers  
 Source #1840 - 100 dpm 4π

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
361	0	0	391	0	0	421	3	27
362	1	9	392	2	18	422	3	27
363	2	18	393	0	0	423	1	9
364	0	0	394	2	18	424	4	36
365	1	9	395	1	9	425	4	36
366	0	0	396	2	18	426	4	36
367	0	0	397	2	18	427	0	0
368	0	0	398	4	36	428	0	0
369	2	18	399	4	36	429	2	18
370	1	9	400	0	0	430	2	18
371	0	0	401	2	18	431	0	0
372	2	18	402	1	9	432	3	27
373	0	0	403	0	0	433	3	27
374	1	9	404	3	27	434	3	27
375	1	9	405	1	9	435	1	9
376	1	9	406	1	9	436	0	0
377	2	18	407	0	0	437	1	9
378	1	9	408	2	18	438	0	0
379	2	18	409	0	0	439	1	9
380	0	0	410	0	0	440	4	36
381	2	18	411	2	18	441	2	18
382	0	0	412	0	0	442	0	0
383	4	36	413	1	9	443	1	9
384	2	18	414	0	0	444	1	9
385	1	9	415	2	18	445	4	36
386	0	0	416	2	18	446	4	36
387	2	18	417	2	18	447	0	0
388	0	0	418	4	36	448	3	27
389	1	9	419	3	27	449	3	27
390	1	9	420	1	9	450	2	18

FIGURE # 9 F

2" Pipe Detector Page 6  
 Ludlum 2500 26465  
 10 Min Bkg. = 0.3 cpm  
 Source Response = 10, 12, 12, 11, 16  
 Reading taken approx. every 2" detector face = 2 5/8"

Date: 10-24-88  
 H. P. W.G. Ayers  
 Source #1840 - 100 dpm 4 π

reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>	reading#	cpm-bkg	dpm/100cm <sup>2</sup>
451	0	0	481	1	9	511	3	27
452	0	0	482	0	0	512	1	9
453	0	0	483	0	0	513	2	18
454	0	0	484	0	0	514	2	18
455	0	0	485	0	0	515	0	0
456	1	9	486	0	0	516	1	9
457	1	9	487	1	9	517	1	9
458	0	0	488	0	0	518	2	18
459	1	9	489	2	18	519	1	9
460	0	0	490	1	9	520	0	0
461	1	9	491	1	9	521	1	9
462	1	9	492	1	9	522	1	9
463	2	18	493	0	0	523	0	0
464	1	9	494	1	9	524	1	9
465	1	9	495	2	18	525	1	9
466	2	18	496	0	0	526	2	18
467	1	9	497	0	0	527	3	27
468	2	18	498	0	0	528	2	18
469	1	9	499	2	18	529	0	0
470	0	0	500	2	18	530	0	0
471	0	0	501	2	18	531	1	9
472	0	0	502	1	9	532	2	18
473	1	9	503	0	0	533	0	0
474	2	18	504	1	9	Background = 0.5		
475	0	0	505	1	9	Source Check		
476	1	9	506	1	9		11	
477	0	0	507	1	9		10	
478	0	0	508	1	9		16	
479	0	0	509	3	27		10	
480	1	9	510	0	0		13	

Smearable results = 1 dpm/100 cm<sup>2</sup>

After completion of Survey

Figure # 9 C