

Pu-Plant Room 124

During production this room contained our pellet presses, calciner, Harper furnace, pellet grinder, inspection gloveboxes, and outgas furnace. After this equipment was removed, we started removal of the glovebox exhaust system. While removing this glovebox exhaust system, we had a section of this pvc pipe, that was just upstream of the pellet grinder box, fall to the floor. We increased room 124 negative and sealed all anchor holes, cracks, and floor seams immediately after this accident. This accident contaminated the entire room and we spent approximately three months steaming the walls, floor, and ceiling to remove smearable contamination. Levels of fixed contamination were from 500 dpm/100 cm² to 2000 dpm/100 cm² average on ceiling and walls, with a maximum of 100,000 dpm/100cm² on the east wall by the double doors that went to production hall. We removed these doors and framework and some blocks that had high levels of contamination. We then blasted wall and ceiling, removed the floor coating and then blasted the floor. We performed a scan survey and spot blasted the wall and blasted the entire floor again. Before starting our final release survey we took smears in all anchor holes in walls and floor and did a low energy gamma survey. Because of the results of these surveys one floor seam was removed and half of some wall blocks were removed. We also used a core drill to remove the anchors in the floor and then surveyed these holes in the floor.

We used a Ludlum 2220 with a Ludlum 43-17 low energy gamma probe to survey all cracks and seams. A Ludlum 2220 with a Ludlum 43-68, 43-4, or 43-27 was used with P-10 gas for all alpha release surveys. All smears were taken on Whatman smear paper and counted in a Hewlett-Packard 5560A (low background) automatic sample counter.

W. A. Rogers

W. A. Rogers

Pu PLANT RELEASE SURVEY PLAN

1. For initial decontamination all surfaces will be scanned with an Eberline PRM-6 with a Radeco alpha scintillation probe. Background will be maintained at less than 100 CPM(200 dpm). All areas greater than twice background will be marked and reading will be taken with a release survey instrument to document contamination levels and random large area smears will be taken.
2. After these initial areas are decontaminated, all floor surfaces and the base of each wall will be completely surveyed with a digital readout release instrument and a Ludlum large area gas proportional alpha detector and random smear samples will be taken. Release instrumentation shall have a minimum detectable level of at least 50 dpm/100 cm².
3. All hot spots greater than or equal to 100 dpm/100 cm² identified will be decontaminated.
4. A random survey with a release instrument will be taken on the walls and ceiling to try to identify any other problem areas.
5. If no problems are identified, each room will be gridded off into approximately 2 meter on a side square on the walls and floor and five readings will be taken in each grid. Readings shall be taken in the center and at the midpoint from the center to each corner.
6. Each ceiling has closely spaced rafters that will not be easily divided into 2 meter squares. Because of this, we will take readings on the bottom of each rafter at 2 meter intervals and one reading centered on the ceiling between rafters. Readings on each rafter will be staggered one meter.
7. These release readings will be documented on a map that is drawn to approximately scale measurements in meters.
8. Data provided on each map:
 1. Survey block numbers, identifiable on a scale drawings.
 - a. room or area name or number.
 - b. surface surveyed.
 - c. type of measurement and units.
 2. Name of surveyor taking measurements, date of survey, and location.

3. Type, model number, calibration data, sensitivity limit, background, and source response of instruments used in survey.
4. When a block surveyed is below the sensitivity of the instrument, the fact that such a measurement was made should be included as significant data.
9. All release survey smears will be taken on Whatman smear paper and counted in the automatic sample counters. Each smear will cover approximately 100 cm².
10. There will be at least 30 survey blocks in each area to be released.
11. Piping and ductwork will be surveyed on all accessible sides at 2 meter intervals. If more than one line is running parallel in a pipe rack, readings shall be staggered at one meter intervals.
12. All readings taken that only cover part of a probe area will be corrected to dpm/100 cm².
13. No survey block will measure less than one meter on a side.
14. No survey block will measure more than 3 meters on a side.
15. All portable release survey instruments will be calibrated quarterly and all instruments in use will be source checked daily.

Table I-1. Acceptable surface contamination levels

Nuclides ^a	Average ^{b,c,f}	Maximum ^{b,d,f}	Removable ^{b,e,f}
U-nat, U-235, U-238, and associated decay products	5,000 dpm α/100 cm ²	15,000 dpm α/100 cm ²	1,000 dpm α/100 cm ²
Transuranics, Ra-226, Ra-228, Th-230, Th-228, Pa-231, Ac-227, I-125, I-129	100 dpm/100 cm ²	300 dpm/100 cm ²	20 dpm/100 cm ²
Th-nat, Th-232, Sr-90, Ra-223, Ra-224, U-232, I-126, I-131, I-133	1,000 dpm/100 cm ²	3,000 dpm/100 cm ²	200 dpm/100 cm ²
Beta-gamma emitters (nuclides with decay modes other than alpha emission or spontaneous fission) except Sr-90 and other noted above.	5,000 dpm βγ/100 cm ²	15,000 dpm βγ/100 cm ²	1,000 dpm βγ/100 cm ²

^a Where surface contamination by both alpha- and beta-gamma-emitting nuclides exists, the limits established for alpha- and beta-gamma-emitting nuclides should apply independently.


^b As used in this table, dpm (disintegrations per minute) means the rate of emission by radioactive material as determined by correcting the counts per minute observed by an appropriate detector for background, efficiency, and geometric factors associated with the instrumentation.

^c Measurements of average contaminant should not be averaged over more than 1 square meter. For objects of less surface area, the average should be derived for each such object.

^d The maximum contamination level applies to an area of not more than 100 cm².

^e The amount of removable radioactive material per 100 cm² of surface area should be determined by wiping that area with dry filter or soft absorbent paper, applying moderate pressure, and assessing the amount of radioactive material on the wipe with an appropriate instrument of known efficiency. When removable contamination on objects of less surface area is determined, the pertinent levels should be reduced proportionally and the entire surface should be wiped.

^f The average and maximum radiation levels associated with surface contamination resulting from beta-gamma emitters should not exceed 0.2 mrad/hr at 1 cm and 1.0 mrad/hr at 1 cm, respectively, measured through not more than 7 milligrams per square centimeter of total absorber.



AREA KOOM 124
FINAL GRID

TYPE OF SURVEY ♀ DIRECT & SMEAR
TYPE OF INSTRUMENT LUDLUM 2220 / DET. 43-68
SERIAL NUMBER 37807 & 37800

COMPLETION DATE 4-26-89

SURVEY UNITS
DPM/100cm²

H.P. SIGNATURE W.A. Rogers

AUTO. SAMPLE COUNTER #:

F - FLOOR
C - CEILING
N - NORTH WALL
S - SOUTH WALL
E - EAST WALL
W - WEST WALL

D-DIRECT
S-SMEAR

MDA 15.68
DPM/100cm²
FIXED

SOURCE # 6811 VALUE: 10780 DPM

INSTRUMENT

DATE SOURCE RESPONSE %M BKGD %M

37807 4-20-89 244-238 1 (AM)

37807 4-20-89 243-241 2 (PM)

37807 4-21-89 275-267 1 (AM)

37807 4-21-89 237-241 1 (PM)

37807 4-24-89 236-243 2 (AM)

37807 4-24-89 238-260 1 (PM)

37807 4-26-89 255-247 2 (AM)

37807 4-25-89 235-243 2 (AM)

37807 4-25-89 245-261 2 (PM)

ASC#1

4-21-89 37 .3

ASC#2

4-25-89 28 .3

4-27-89 30 .3


TOTAL DAM 5516 501

READINGS 295 295

DPM/100cm² AVG 18.72 1.70

MDA DPM/100cm² 140 9

EAST WALL																					
	D-4 S-3	D-8 S-0	D-24 S-3	D-36 S-6	D-20 S-0	D-8 S-0	D-12 S-3	D-16 S-3	D-8 S-3	D-12 S-3	D-20 S-0	D-32 S-0	D-20 S-0	D-16 S-0	D-16 S-0	D-24 S-0	D-32 S-0	D-24 S-0	D-32 S-0	D-16 S-3	
	① D-12 S-0		② D-20 S-0		③ D-24 S-0		④ D-24 S-3		⑤ D-28 S-6		⑥ D-24 S-3		⑦ D-8 S-0		⑧ D-12 S-3		⑨ D-20 S-0		⑩ D-8 S-3		
	D-16 S-3	D-24 S-0	D-48 S-0	D-24 S-0	D-4 S-0	D-12 S-0	D-16 S-6	D-20 S-6	D-32 S-3	D-8 S-0	D-20 S-3	D-32 S-3	D-28 S-9	D-24 S-3	D-28 S-0	D-12 S-3	D-0 S-0	D-20 S-0	D-24 S-0	D-32 S-0	
37807	D-4 S-0	D-28 S-0	D-4 S-0	D-16 S-0	D-24 S-0	D-30 S-0	D-28 S-0	D-48 S-0	D-28 S-6	D-36 S-0	D-36 S-0	D-72 S-9	D-16 S-0	D-20 S-3	D-24 S-0	D-24 S-3	D-32 S-0	D-8 S-0	D-24 S-0	D-16 S-0	
37807	⑪ D-20 S-3		⑫ D-8 S-3		⑬ D-52 S-0		⑭ D-4 S-3		⑮ D-16 S-9		⑯ D-16 S-0		⑰ D-20 S-6		⑱ D-48 S-0		⑲ D-28 S-0		⑳ D-20 S-0		
37807	D-8 S-0	D-4 S-0	D-32 S-3	D-16 S-6	D-12 S-3	D-20 S-0	D-60 S-3		D-5 S-0	D-12 S-0	D-20 S-0	D-76 S-6	D-72 S-0	D-80 S-0	D-20 S-0	D-48 S-0	D-36 S-0	D-36 S-0	D-40 S-0	D-8 S-0	
37807	D-12 S-3	D-0 S-0	D-16 S-6	D-24 S-0	D-24 S-0	D-0 S-6			D-0 S-3	D-48 S-0	D-44 S-3	D-92 S-0	D-16 S-9	D-88 S-6	D-0 S-0	D-16 S-0	D-8 S-9	D-20 S-3	D-8 S-0	D-12 S-0	
37807	⑳ D-24 S-3		㉑ D-4 S-0		㉒ D-24 S-3				㉓ D-8 S-0		㉔ D-48 S-3		㉕ D-8 S-0		㉖ D-12 S-0		㉗ D-16 S-0		㉘ D-16 S-3		
37807	D-8 S-3	D-12 S-3	D-12 S-0	D-24 S-0	D-4 S-0		D-76 S-6		D-4 S-6	D-8 S-3	D-16 S-6	D-24 S-0	D-16 S-3	D-8 S-0	D-8 S-0	D-12 S-3	D-24 S-0	D-4 S-0	D-12 S-0	D-4 S-0	
37807																					
WEST WALL																					
	D-20 S-0	D-0 S-0	D-4 S-6	D-4 S-0	D-0 S-3	D-20 S-3	D-8 S-0	D-0 S-0	D-12 S-3	D-16 S-3	D-8 S-0	D-12 S-0	D-8 S-0	D-12 S-3	D-0 S-0	D-0 S-3	D-16 S-3	D-12 S-0	D-8 S-0	D-8 S-0	
	① D-8 S-3		② D-8 S-0		③ D-0 S-3		④ D-0 S-0		⑤ D-12 S-6		⑥ D-8 S-0		⑦ D-12 S-0		⑧ D-12 S-0		⑨ D-12 S-3		⑩ D-12 S-0		
	D-4 S-3	D-8 S-0	D-20 S-0	D-0 S-0	D-8 S-3	D-28 S-3	D-8 S-3	D-24 S-0	D-60 S-0	D-16 S-0	D-24 S-3	D-16 S-0	D-8 S-0	D-20 S-0	D-8 S-0	D-16 S-0	D-12 S-6	D-0 S-3	D-20 S-0	D-12 S-0	
	⑪ D-0 S-0		⑫ D-16 S-0		⑬ D-28 S-0		⑭ D-40 S-3		⑮ D-16 S-6		⑯ D-16 S-3		⑰ D-20 S-0		⑱ D-24 S-0		⑲ D-0 S-0		⑳ D-20 S-3		
	D-24 S-0	D-12 S-0	D-24 S-0	D-16 S-0	D-24 S-3	D-24 S-0	D-8 S-0	D-16 S-0	D-0 S-0	D-8 S-6	D-32 S-0	D-16 S-3	D-12 S-0	D-16 S-0	D-16 S-3	D-8 S-0	D-12 S-0	D-0 S-0	D-8 S-0	D-0 S-3	
	D-4 S-3	D-12 S-3	D-20 S-3	D-16 S-0	D-12 S-0	D-12 S-6	D-20 S-9	D-32 S-0	D-4 S-0	D-12 S-0	D-16 S-6	D-12 S-0	D-16 S-0	D-12 S-0	D-44 S-0	D-16 S-0	D-20 S-0	D-12 S-6	D-0 S-0	D-8 S-0	
	㉑ D-4 S-0		㉒ D-28 S-0		㉓ D-0 S-0		㉔ D-12 S-3		㉕ D-16 S-6		㉖ D-4 S-6		㉗ D-12 S-6		㉘ D-0 S-6		㉙ D-8 S-0		㉚ D-32 S-0		
	D-12 S-0	D-24 S-0	D-4 S-0	D-4 S-6	D-16 S-3	D-16 S-3	D-28 S-0	D-12 S-3	D-28 S-0	D-20 S-6	D-32 S-0	D-0 S-3	D-148 S-0	D-0 S-6	D-12 S-3	D-0 S-6	D-24 S-0	D-12 S-3	D-28 S-6	D-0 S-3	



1.5cm = 1 Meter

AREA ROOM 124

TYPE OF SURVEY of DIRECT & SMEAR

COMPLETION DATE 5/16/89

SURVEY UNITS

FINAL GRID
AFTER SUPPLY AIR DUCT REMOVED

TYPE OF INSTRUMENT LUDLUM 2220/DET. 43-68

H.P. SIGNATURE Charles W. Chapman

DPM/100cm²

SERIAL NUMBER 50669

AUTO. SAMPLE COUNTER # #1
83600115

F - FLOOR
C - CEILING
N - NORTH WALL
S - SOUTH WALL
E - EAST WALL
W - WEST WALL

D - DIRECT
S - SMEAR

110A 11.09
DPM/100cm²
FIXED

SOURCE # 7272 VALUE: 850 DPM

INSTRUMENT		
DATE	SOURCE C RESPONSE /M	BKGDS %M
5/16/89	182/184	1
5-17-89	ASC #1 32	2

D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
FLOOR										DIRECT					SMEAR					
										140 TOTAL DPM					51 TOTAL DPM					
										30 READINGS					30 SMEARS					
										4.67 DPM/100cm ² AVG					1.7 DPM/100cm ² AVG					
										20 MAX DPM/100cm ²					9 MAX DPM/100cm ²					
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	SUPPORT BEAM	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-	D- S-
CEILING - DUCT REMOVED																				

SUPPORT BEAM


BEAM

BEAMS

AIR DUCT REMOVED
Readings on
CEILING + BEAMS

BEAM 2

BEAM



Room 124

PIPE SURVEY

PAGE 1 OF 6

LINE NUMBER 551

DATE 5-2-89

INSTRUMENT 2220

SERIAL NUMBER 52834

DETECTOR 43-4

OPERATOR SV

SOURCE NUMBER AND VALUE 6498-890

SOURCE RESPONSE AND BACKGROUND AM 203-201

Bkg-2

SOURCE RESPONSE AND BACKGROUND PM 241-221

Bkg-1

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable dpm/100cm ²
				cpm	dpm/100cm ²	
East Wall	Conduit	3/4"	0 meter T	1	12	3
			B	4	48	
			2 meter T	4	48	0
			B	2	36	
			4 meter T	7	84	0
			B	2	24	
			END T	5	60	0
			B	5	120	
Direct Ion						
Total DPM				2508	33	
Reading				44	22	
DPM/100cm ² PVI				57.0	1.43	
Max DPM/100cm ²				96	6	
MDA 40.74						
DPM/100cm ² FIXED						

Room 124

PIPE SURVEY

PAGE 2 OF 6

LINE NUMBER 552

DATE 5-2-89

INSTRUMENT 2220

SERIAL NUMBER 52834

DETECTOR 43-4

OPERATOR SV

SOURCE NUMBER AND VALUE 6499 890 12

SOURCE RESPONSE AND BACKGROUND AM 203-201

Bkg 2

SOURCE RESPONSE AND BACKGROUND PM 241-221

Bkg 1

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable dpm/100cm ²
				cpm	dpm/100cm ²	
East Wall	Conduit	3/4"	0 meters T	2	24	6
			B	1	12	
			2 meter T	8	96	0
			B	6	72	
			4 meter T	4	48	3
			B	3	36	
			END T	7	84	0
			B	7	84	

Rm 124

PIPE SURVEY

PAGE 3 OF 6

LINE NUMBER 553

DATE 5-2-89

INSTRUMENT 2220

SERIAL NUMBER 52834

DETECTOR 43-4

OPERATOR SV

SOURCE NUMBER AND VALUE 6498 890

SOURCE RESPONSE AND BACKGROUND AM 203-201

Bkg 2

SOURCE RESPONSE AND BACKGROUND PM 241-221

Bkg 1

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable
				cpm	dpm/100cm ²	
East Wall	Conduit	3/4"	0 meters T	6	72	3
			B	3	36	
			2 meters T	5	60	6
			B	8	96	
			4 meters T	4	48	0
			B	5	60	
			END T	8	96	0
			B	6	72	

Rm 124

PIPE SURVEY

PAGE 4 OF 6

LINE NUMBER 554

DATE 5-2-89

INSTRUMENT 2220

SERIAL NUMBER 52834

DETECTOR 43-4

OPERATOR SV

SOURCE NUMBER AND VALUE 6498 - 890

SOURCE RESPONSE AND BACKGROUND AM 203-201

Bkg 2

SOURCE RESPONSE AND BACKGROUND PM 241-221

Bkg 1

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable
				cpm	dpm/100cm ²	
East Wall	Conduit	1/2"	0 meters T	7	84	0
			B	5	60	
			END N	2	24	0
			S	2	24	

Run 124

PIPE SURVEY

PAGE 5 OF 6

LINE NUMBER 555

DATE 5-2-89

INSTRUMENT 2220

SERIAL NUMBER 52830

DETECTOR 43-4

OPERATOR SV

SOURCE NUMBER AND VALUE 6498 890

SOURCE RESPONSE AND BACKGROUND AM 203-201

Bkg-2

SOURCE RESPONSE AND BACKGROUND PM 241-221

Bkg-1

0

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable dpm/100cm ²
				cpm	dpm/100cm ²	
East Wall	Conduit	1/2"	0 meters T	7	84	0
			B	4	48	
			2 meter T	7	84	0
			B	3	36	
			4 meter T	3	36	0
			B	7	84	
			END T	1	12	0
			B	5	60	

Run 124

PIPE SURVEY

PAGE 6 OF 6

LINE NUMBER 556

DATE 5-2-89

INSTRUMENT 2220

SERIAL NUMBER 52830

DETECTOR 42-4

OPERATOR SV

SOURCE NUMBER AND VALUE 6498 - 890

SOURCE RESPONSE AND BACKGROUND AM 203-201

Bkg-2

SOURCE RESPONSE AND BACKGROUND PM 241 221

Bkg-1

0

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable dpm/100cm ²
				cpm	dpm/100cm ²	
East Wall	Conduit	1/2"	0 meter T	7	84	6
			B	6	72	
			2 meter T	3	36	6
			B	7	84	
			4 meters T	4	48	0
			B	5	60	
			END T	4	48	0
			B	6	72	

RM 124


7-19-89

LOCATION OF COUNTS


DOOR #1

ILP

FRAME



DOOR



PLANT PU AREA 124
 SURVEYED BY ILP
 INST. INDIUM 2220 *52834 DET. 43-4
 SOURCE CK 289-282 BKG. 3(PM)
 DATE: 7-19-89 SOURCE # 112 VALUE: 1113 DPM

ASC # 83600115
 CTD. BY A. Black
 SOURCE CK. AVG. 26
 BKG. .3
 DATE: 7-20-89

READINGS IN DPM/100 cm²

SAMPLE # OR DESCRIPTION	DIRECT		
	CPH	DPH	SHEAR
DOOR #1 IN RM. 124			
DOOR			
D-1	3	18	3
D-2	1	6	3
D-3	14	94	0
D-4	4	24	0
D-5	1	6	3
6	4	24	6
7	3	18	3
8	11	66	3
9	2	12	3
10	0	0	3
11	2	12	0
12	9	54	0
13	7	42	0
14	0	0	3
15	1	6	0
16	0	0	0
17	0	0	0
18	2	12	0
19	7	42	3
20	1	6	9
21	13	78	6
22	3	18	6
23	7	42	0
	<i>Direct</i>	<i>Shear</i>	
Total DPM	924	114	
# Readings	41	41	
AVG DPM/100cm ²	22.54	2.78	
MAX DPM/100cm ²	94	9	
MDA			
29.81 DPM/100cm ²			

PLANT PU AREA 124
 SURVEYED BY ILP
 INST. INDIUM 2220 *52834 DET. 43-4
 SOURCE CK 289-282 BKG. 3(PM)
 DATE: 7-19-89 SOURCE # 112 VALUE: 1113 DPM

ASC # 83600115
 CTD. BY A. Black
 SOURCE CK. AVG. 26
 BKG. .3
 DATE: 7-20-89

READINGS IN DPM/100 cm²


SAMPLE # OR DESCRIPTION	DIRECT		
	CPH	DPH	SHEAR
DOOR #1 IN RM 124			
DOOR FRAME			
F-1	5	30	3
F-2	9	54	9
F-3	1	6	3
F-4	2	12	3
F-5	2	12	3
6	6	36	3
7	6	36	0
8	1	6	3
9	4	24	9
10	1	6	3
11	1	6	0
12	4	24	0
13	3	18	3
14	5	30	0
15	3	18	6
16	1	6	3
17	1	6	3
18	0	0	6

RM 124 DOOR#2

NORTH DOOR

LOCATION OF COUNTS


FRAME



7-27-89

ILP

DOOR



PLANT PU AREA RM 124
 SURVEYED BY ILP
 INST. 1.10111M 2220 * 52834 DET. 43-4
 SOURCE CK 302-299 BKG. 1(PM)
 DATE: 7-27-89 SOURCE # 112 VALUE: 1113 DPM

ASC # 1 83600115
 CTD. BY J. Black
 SOURCE CK. AVG. 27
 BKG. .3
 DATE: 7-28-89

READINGS IN DPM/100 cm²

SAMPLE # OR DESCRIPTION	DIRECT		SMEAR
	CPH	DPH	
RM 124 DOOR#2 DOOR			
(NORTH DOOR) D-1	3	18	3
EM. EXIT D-2	1	6	0
D-3	1	6	0
4	7	42	0
5	2	12	0
6	4	24	0
7	7	42	0
8	6	36	3
9	7	42	0
10	1	1	6
11	6	36	0
12	3	18	3
TOTAL DPM	984	30	
# READINGS	33	33	
AVG. DPM/100 cm ²	29.82	0.91	
MAX. DPM/100 cm ²	84	6	
MDA	16.63 DPM/100 cm ²		

PLANT Pu AREA RM 124
 SURVEYED BY ILP
 INST. 1.10111M 2220 * 52834 DET. 43-4
 SOURCE CK 302-299 BKG. 1(PM)
 DATE: 7-27-89 SOURCE #: 112 VALUE: 1113 DPM

ASC # 1 83600115
 CTD. BY J. Black
 SOURCE CK. AVG. 27
 BKG. 3
 DATE: 7-28-89

READINGS IN DPM/100 cm²

SAMPLE # OR DESCRIPTION	FRAME	DIRECT		SHEAR
		CPH	DPH	
RM 124 DOOR#2				
(NORTH DOOR)	F-1	0	0	0
EM. EXIT	F-2	12	72	0
	F-3	4	24	6
	F-4	4	24	0
	F-5	6	36	0
	6	3	12	3
	7	4	24	0
	8	13	72	0
	9	2	12	0
	10	3	12	0
	11	7	42	0
	12	3	42	3
	13	1	6	3
	14	0	60	0
	15	4	24	0
	16	3	12	0
	17	4	24	0
	18	3	12	0
	19	5	30	0
	20	4	24	0
	21	3	12	0

PLANT Pu AREA Room 124
 SURVEYED BY J. Handley
 INST. 1.10111M 2220 * 50064 DET. 43-4
 SOURCE CK 291/298 BKG. 0
 DATE: 8-3-89 SOURCE #: 6816 VALUE: 1078 DPM

ASC # 83600108
 CTD. BY J. Black
 SOURCE CK. AVG. 26
 BKG. 1
 DATE: 8-3-89

READINGS IN DPM/100 cm²

SAMPLE # OR DESCRIPTION	DIRECT		SHEAR	
	CPH	DPH		
Lights				
	1	4	48	0
	2	4	48	0
	3	7	84	0
	4	4	48	0
	5	5	60	3
	6	5	60	6
	7	3	36	9
	8	3	36	6
	9	6	72	9
	10	3	36	3
	11	0	0	3
	12	0	0	6
Total DPM	Direct	528	45	
# Readings		12	12	
Avg. DPM/100 cm ²		44.0	3.75	
Max. DPM/100 cm ²		84	9	
MVA = 23.52 dpm/100 cm ²				