

From: Hall, Randy
Sent: Tuesday, September 29, 2009 8:54 AM
To: Linda.Conklin@sce.com
Cc: Alan.Brough@sce.com
Subject: Acceptance Review for License Amendment Request for SONGS Units 2 and 3, re: TSTF-340, AFW Completion Time (TAC Nos. ME2133 & ME2134)

September 29, 2009

Linda Conklin
Manager, Nuclear Licensing
San Onofre Nuclear Generating Station
Southern California Edison

Linda,

By letter dated August 10, 2009, Southern California Edison submitted a license amendment for the San Onofre Nuclear Generating Station (SONGS) Units 2 and 3.

The proposed amendment would revise the Technical Specification (TS) requirements in Section 3.7.5, Auxiliary Feedwater (AFW) System, to allow a 7-day Completion Time for the turbine-driven AFW pump; if the inoperability occurs in Mode 3, following a refueling outage, and if Mode 2 had not been entered. This change is based on the Technical Specification Task Force (TSTF) Change Traveler, TSTF-340, Revision 3.

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-4032.

Randy Hall, Senior Project Manager
Plant Licensing Branch IV

Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
USNRC
(301) 415-4032
Randy.Hall@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: Acceptance Review for License Amendment Request for SONGS Units 2 and 3, re: TSTF-340, AFW Completion Time (TAC Nos. ME2133 & ME2134)
Sent Date: 9/29/2009 8:29:18 AM
Received Date: 9/29/2009 8:54:00 AM
From: Hall, Randy

Created By: Randy.Hall@nrc.gov

Recipients:

Linda.Conklin@sce.com (Linda.Conklin@sce.com)
Tracking Status: None
Alan.Brough@sce.com (Alan.Brough@sce.com)
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	8653	9/29/2009

Options

Expiration Date:
Priority: o!ImportanceNormal
ReplyRequested: False
Return Notification: False

Sensitivity: o!Normal
Recipients received: