

ROOM 128

Room 128 contained both wet and dry plutonium process glove-boxes. During production there had not only been a number of spills from these boxes but there was also a small fire in this room involving a small amount of nuclear material. After this fire the walls, floor, ceiling and all equipment in this room were painted.

After glovebox removal, this entire room was vacu-blasted and the floor coating was removed. We found approximately 2000 to 3000 dpm/100 cm<sup>2</sup> direct on isolated spots on the floor and ceiling support beam. Approximately 25% of the floor had reading of approximately 500 dpm/100 cm<sup>2</sup> direct and four spots on the walls also had approximately 500 dpm/100 cm<sup>2</sup> direct. A liquid process line that passed through the north block wall of this room had leaked down inside these blocks. The north wall was removed and the entire floor and hot spots on the other walls were reblasted. A number of pipe sleeves that were installed in room 128 floor had to be removed because of high gamma readings.

We used a Ludlum 2220 with a Ludlum 43-17 low energy gamma probe to identify all cracks and seams that might need decontamination. A Ludlum 2220 with a Ludlum 43-68, 43-4, or 43-27 was used with P-10 gas for all alpha release surveys. All smears were taken on Whatman smear paper and counted in a Hewlett-Packard 5560 A (low background) automatic sample counter.

W. A. Rogers

W. A. Rogers

## Pu PLANT RELEASE SURVEY PLAN

1. For initial decontamination all surfaces will be scanned with an Eberline PRM-6 with a Radeco alpha scintillation probe. Background will be maintained at less than 100 CPM(200 dpm). All areas greater than twice background will be marked and reading will be taken with a release survey instrument to document contamination levels and random large area smears will be taken.
2. After these initial areas are decontaminated, all floor surfaces and the base of each wall will be completely surveyed with a digital readout release instrument and a Ludlum large area gas proportional alpha detector and random smear samples will be taken. Release instrumentation shall have a minimum detectable level of at least 50 dpm/100 cm<sup>2</sup>.
3. All hot spots greater than or equal to 100 dpm/100 cm<sup>2</sup> identified will be decontaminated.
4. A random survey with a release instrument will be taken on the walls and ceiling to try to identify any other problem areas.
5. If no problems are identified, each room will be gridded off into approximately 2 meter on a side square on the walls and floor and five readings will be taken in each grid. Readings shall be taken in the center and at the midpoint from the center to each corner.
6. Each ceiling has closely spaced rafters that will not be easily divided into 2 meter squares. Because of this, we will take readings on the bottom of each rafter at 2 meter intervals and one reading centered on the ceiling between rafters. Readings on each rafter will be staggered one meter.
7. These release readings will be documented on a map that is drawn to approximately scale measurements in meters.
8. Data provided on each map:
  1. Survey block numbers, identifiable on a scale drawings.
    - a. room or area name or number.
    - b. surface surveyed.
    - c. type of measurement and units.
  2. Name of surveyor taking measurements, date of survey, and location.

3. Type, model number, calibration data, sensitivity limit, background, and source response of instruments used in survey.
4. When a block surveyed is below the sensitivity of the instrument, the fact that such a measurement was made should be included as significant data.
9. All release survey smears will be taken on Whatman smear paper and counted in the automatic sample counters. Each smear will cover approximately 100 cm<sup>2</sup>.
10. There will be at least 30 survey blocks in each area to be released.
11. Piping and ductwork will be surveyed on all accessible sides at 2 meter intervals. If more than one line is running parallel in a pipe rack, readings shall be staggered at one meter intervals.
12. All readings taken that only cover part of a probe area will be corrected to dpm/100 cm<sup>2</sup>.
13. No survey block will measure less than one meter on a side.
14. No survey block will measure more than 3 meters on a side.
15. All portable release survey instruments will be calibrated quarterly and all instruments in use will be source checked daily.

Table I-1. Acceptable surface contamination levels

Nuclides <sup>a</sup>	Average <sup>b,c,f</sup>	Maximum <sup>b,d,f</sup>	Removable <sup>b,e,f</sup>
U-nat, U-235, U-238, and associated decay products	5,000 dpm α/100 cm <sup>2</sup>	15,000 dpm α/100 cm <sup>2</sup>	1,000 dpm α/100 cm <sup>2</sup>
Transuranics, Ra-226, Ra-228, Th-230, Th-228, Pa-231, Ac-227, I-125, I-129	100 dpm/100 cm <sup>2</sup>	300 dpm/100 cm <sup>2</sup>	20 dpm/100 cm <sup>2</sup>
Th-nat, Th-232, Sr-90, Ra-223, Ra-224, U-232, I-126, I-131, I-133	1,000 dpm/100 cm <sup>2</sup>	3,000 dpm/100 cm <sup>2</sup>	200 dpm/100 cm <sup>2</sup>
Beta-gamma emitters (nuclides with decay modes other than alpha emission or spontaneous fission) except Sr-90 and other noted above.	5,000 dpm βγ/100 cm <sup>2</sup>	15,000 dpm βγ/100 cm <sup>2</sup>	1,000 dpm βγ/100 cm <sup>2</sup>

<sup>a</sup>Where surface contamination by both alpha- and beta-gamma-emitting nuclides exists, the limits established for alpha- and beta-gamma-emitting nuclides should apply independently.

<sup>b</sup>As used in this table, dpm (disintegrations per minute) means the rate of emission by radioactive material as determined by correcting the counts per minute observed by an appropriate detector for background, efficiency, and geometric factors associated with the instrumentation.


<sup>c</sup>Measurements of average contaminant should not be averaged over more than 1 square meter. For objects of less surface area, the average should be derived for each such object.

<sup>d</sup>The maximum contamination level applies to an area of not more than 100 cm<sup>2</sup>.

<sup>e</sup>The amount of removable radioactive material per 100 cm<sup>2</sup> of surface area should be determined by wiping that area with dry filter or soft absorbent paper, applying moderate pressure, and assessing the amount of radioactive material on the wipe with an appropriate instrument of known efficiency. When removable contamination on objects of less surface area is determined, the pertinent levels should be reduced proportionally and the entire surface should be wiped.

<sup>f</sup>The average and maximum radiation levels associated with surface contamination resulting from beta-gamma emitters should not exceed 0.2 mrad/hr at 1 cm and 1.0 mrad/hr at 1 cm, respectively, measured through not more than 7 milligrams per square centimeter of total absorber.





AREA K0014 128

TYPE OF SURVEY α DIRECT & SMEAR

COMPLETION DATE 12-5-1988

SURVEY UNITS

Large Area  
Probe Scan

TYPE OF INSTRUMENT LUOLUM 2220 / DET. 43-27

H.P. SIGNATURE S. Veenberg - K. Morcom


SERIAL NUMBER 58302 & 58318

AUTO. SAMPLE COUNTER #:

F - FLOOR D - DIRECT  
C - CEILING S - SMEAR  
N - NORTH WALL  
S - SOUTH WALL  
E - EAST WALL  
W - WEST WALL

SOURCE # 1832 VALUE: 342  
1201 VALUE: 273 DPM

INSTRUMENT		
DATE	SOURCE RESPONSE C/m	BKGD. %m
58302 12-2-88	107-104	2
58318 12-2-88	141-146	3.0m



NORTH WALL

SOUTH WALL

SUPPORT BEAM

TOP

BOTTOM

NORTH

SOUTH

DOORWAY  
To 127

D-  
S-

3.5k  
D-  
S-

1.4k

D- 1.2k  
S-

3-77  
67  
280

3-120

3-415

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-

D-  
S-


D-  
S-

D-  
S-









AREA ROOM 128  
FINAL GRID

TYPE OF SURVEY DIRECT & SMEAR  
TYPE OF INSTRUMENT LUDLUM 2220 / DET. 43-68  
SERIAL NUMBER 37800 + 37807 + 50068

COMPLETION DATE 2-15-89 SURVEY UNITS DPM/100cm<sup>2</sup>  
H.P. SIGNATURE W.A. Royen  
AUTO. SAMPLE COUNTER # 1 SN 83600115

F - FLOOR D-DIRECT  
C - CEILING S-SMEAR  
N - NORTH WALL MDA 1920  
S - SOUTH WALL DPM/100cm<sup>2</sup>  
E - EAST WALL FIXED  
W - WEST WALL

SOURCE # 6816 VALUE: 1078 DPM

INSTRUMENT		
DATE	SOURCE RESPONSE %	BKGD %
11-30-89	230-251	1
11-30-89	268-257	1
11-30-89	265-250	1
11-30-89	233-239	2
2-13-89	261-278	3
2-13-89	251-241	2
2-14-89	259-268	2
2-17-89	247-270	2
3-17-89	257	

D-28 S-0	D-24 S-9	D-24 S-0	D-12 S-3	D-12 S-0	D-4 S-0	D-24 S-3	D-12 S-0	D-4 S-3	D-8 S-0	D-12 S-0	D-16 S-3	D-20 S-3	D-16 S-0	D-12 S-0	D-16 S-0	D-12 S-6	D-12 S-12
D-48 S-0	D-40 S-3	D-12 S-3	D-28 S-0	D-0 S-0	D-4 S-3	D-20 S-0	D-8 S-0	D-0 S-0	D-20 S-0	D-12 S-0	D-16 S-3	D-24 S-0	D-0 S-3	D-0 S-3	D-0 S-3	D-8 S-0	
D-92 S-3	D-24 S-3	D-20 S-0	D-28 S-3	D-12 S-0	D-20 S-3	D-8 S-0	D-16 S-3	D-4 S-0	D-4 S-0	D-0 S-6	D-40 S-6	D-28 S-0	D-8 S-9	D-4 S-3	D-8 S-0		
D-12 S-0	D-12 S-9	D-16 S-3	D-4 S-0	D-24 S-6	D-12 S-0	D-0 S-6	D-24 S-6	D-0 S-6	D-0 S-6	D-12 S-3	D-0 S-3	D-0 S-3	D-4 S-0	D-8 S-6	D-12 S-0		
D-12 S-3	D-4 S-3	D-24 S-3	D-40 S-0	D-4 S-0	D-20 S-0	D-8 S-0	D-36 S-6	D-24 S-3	D-12 S-3	D-0 S-6	D-0 S-3	D-12 S-3	D-4 S-0	D-8 S-6	D-12 S-0		

EAST WALL

DIRECT  
4,128 TOTAL-DPM

ASC# 1  
2-15-89 30 13

210 READINGS  
19.66 DPM/100cm<sup>2</sup> AVG


D-4 S-0	D-20 S-0	D-24 S-0	D-16 S-0	D-24 S-0	D-36 S-3	D-20 S-0	D-20 S-3	D-80 S-3	S-36 S-3	D-40 S-0	D-52 S-0	D-36 S-0	D-88 S-3
D-24 S-0		D-24 S-0		D-36 S-0		D-20 S-0		D-24 S-3		D-36 S-0		D-40 S-0	
D-4 S-3	D-0 S-0	D-16 S-6	D-4 S-3	D-0 S-0	D-28 S-0	D-28 S-0	D-8 S-6	D-20 S-0	D-28 S-3	D-12 S-0	D-36 S-3	D-12 S-0	D-24 S-0
D-8 S-3	D-4 S-0	D-12 S-6	D-12 S-3	D-20 S-6	D-28 S-0	D-12 S-0	D-12 S-9	D-12 S-3	D-8 S-0	D-28 S-3	D-16 S-0	D-12 S-9	D-28 S-6
	D-20 S-3		D-16 S-0		D-4 S-0		D-12 S-3		D-40 S-0		D-52 S-0		D-20 S-0
D-4 S-0	D-4 S-0	D-36 S-6	D-8 S-0	D-44 S-0	D-28 S-0	D-28 S-3	D-20 S-0	D-16 S-6	D-28 S-0	D-20 S-0	D-44 S-0	D-36 S-0	D-8 S-3
D-8 S-6	D-20 S-0	D-24 S-6	D-32 S-0	D-16 S-0	D-24 S-0	D-16 S-6	D-44 S-0	D-12 S-6	D-12 S-0	D-12 S-0	D-24 S-0	D-44 S-0	D-24 S-6
	D-16 S-0		D-12 S-6		D-8 S-0		D-12 S-6		D-28 S-3		D-4 S-0		D-28 S-0
D-4 S-0	D-4 S-0	D-4 S-0	D-4 S-0	D-4 S-0	D-4 S-0	D-8 S-0	D-28 S-0	D-12 S-3	D-20 S-3	D-24 S-6	D-12 S-0	D-20 S-0	D-140 S-0

140 MAX DPM/100cm<sup>2</sup>

SMEAR

417 TOTAL-DPM  
210 SMEARS  
1.99 DPM/100cm<sup>2</sup> AVG  
12 MAX DPM/100cm<sup>2</sup>

WEST WALL



AREA PL-PLANT - ROOM 128

TYPE OF SURVEY DIRECT & SMEAR

COMPLETION DATE 3-21-89

SURVEY UNITS

FINAL GRID

TYPE OF INSTRUMENT LODUM 2220/DET. 43-68

H.P. SIGNATURE W.A. Rogers

DPM/100cm<sup>2</sup>

SERIAL NUMBER 37800-37807-50068

AUTO. SAMPLE COUNTER<sup>F</sup>: / S<sup>N</sup> 83600115

D - DIRECT  
S - SMEAR  
F - FLOOR  
C - CEILING  
N - NORTH WALL  
S - SOUTH WALL  
E - EAST WALL  
W - WEST WALL


MDA 19.20

DPM/100cm<sup>2</sup>

FIXED

SOURCE # 6816 VALUE: 1078 DPM

INSTRUMENT																					
DATE	SOURCE C RESPONSE/M	BKGS/M																			
11-30-89	230-257	1	37800																		
11-30-89	268-259	1	37800	DOORWAY																	
11-30-89	265-250	0	37807	To 127																	
11-30-89	233-229	0	37807																		
12-1-89	269-266	1	37800																		
12-1-89	251-245	2	37800																		
12-1-89	242-238	2	37807																		
12-1-89	233-242	3	37807																		
12-5-89	238-236	1	37800																		
12-5-89	244-228	1	37800	NORTH WALL						SOUTH WALL											
2-13-89	261-278	3	50068																		
2-13-89	251-241	2	50068																		
2-14-89	259-268	2	50068																		
2-14-89	279-257	1	50068	SUPPORT BEAM																	
2-15-89	274-294	3	50068	TOP																	
	ASC#1									DIRECT						SMEAR					
12-6-89	29	.3		BOTTOM						1988 TOTAL DPM						261 TOTAL DPM					
2-16-89	37	.2																			
3-21-89	28	.3		NORTH						103 READINGS						104 SMEARS					
				SOUTH						19.30 DPM/100cm <sup>2</sup> AVG						2.51 DPM/100cm <sup>2</sup> AVG					
										120 MAX DPM/100cm <sup>2</sup>						9 MAX DPM/100cm <sup>2</sup>					



AREA ROOM 128  
TOP OF WALL STORAGE TANKS

TYPE OF SURVEY DIRECT + SMEAR  
 TYPE OF INSTRUMENT LUDLUM 2220 / DET. 43-68  
 SERIAL NUMBER 37800-50064

COMPLETION DATE 2-13-89 SURVEY UNITS DPM/100cm<sup>2</sup>  
 H.P. SIGNATURE W.A. Roys  
 AUTO. SAMPLE COUNTER#: 1-83600115

2 cm = 1 Meter


F - FLOOR  
 C - CEILING  
 N - NORTH WALL  
 S - SOUTH WALL  
 E - EAST WALL  
 W - WEST WALL

MDA 15.68  
 DPM/100cm<sup>2</sup>  
 FIXED

SOURCE#: 6816 VALUE: 1078 DPM

INSTRUMENT		
DATE	SOURCE RESPONSE %	BKGDS %
2-12-89	223-253	2
2-12-89	242-244	2
2-13-89	243-258	1
	ASC# 1	
2-14-89	34	.3

Survey #	Location
1-35	Lining
36-70	West Wall
71-91	Floor
92-99	East Wall top
100-105	East Ledge Top
106-112	East Floor Lip
113-119	West Ledge
120-127	West Floor lip
128-132	South Wall
133-134	North Wall (side of beam)
135	Bottom of Beam
136	Top of Beam



	DIRECT	SMEAR
TOTAL DPM	2064	246
# READINGS	136	136
AVG. DPM/100cm <sup>2</sup>	15.18	1.81
MAX DPM/100cm <sup>2</sup>	56	9

Room 128 top of wall storage tanks

READING IN DPM/100cm<sup>2</sup>

SURVEY #	DIRECT	SMEAR	SURVEY #	DIRECT	SMEAR
1	16	0	36	8	3
2	8	3	37	0	3
3	12	0	38	16	3
4	20	0	39	24	3
5	8	0	40	8	3
6	0	3	41	0	0
7	8	3	42	0	0
8	20	0	43	16	0
9	4	0	44	0	6
10	0	0	45	0	0
11	16	0	46	8	0
12	8	0	47	24	0
13	12	3	48	24	0
14	12	0	49	8	3
15	8	3	50	4	3
16	0	3	51	4	0
17	0	0	52	24	0
18	0	0	53	12	0
19	0	0	54	8	3
20	16	0	55	12	3
21	8	0	56	56	3
22	8	0	57	20	0
23	16	0	58	16	6
24	8	3	59	4	0
25	16	0	60	24	0
26	0	0	61	24	6
27	0	0	62	12	3
28	16	3	63	36	0
29	0	0	64	8	0
30	8	3	65	24	3
31	16	0	66	44	0
32	24	0	67	24	3
33	0	3	68	20	0
34	0	0	69	24	9
35	16	6	70	16	3

READING IN DPM/100cm<sup>2</sup>

SURVEY #	DIRECT	SMEAR	SURVEY #	DIRECT	SMEAR
71	4	3	106	4	0
72	32	3	107	28	0
73	36	0	108	8	3
74	32	0	109	16	3
75	20	0	110	28	0
76	24	9	111	16	0
77	28	0	112	4	0
78	8	3	113	20	3
79	8	0	114	20	3
80	20	0	115	20	3
81	24	0	116	20	6
82	36	0	117	12	0
83	16	0	118	48	6
84	20	0	119	20	0
85	56	3	120	20	6
86	8	0	121	8	3
87	12	0	122	24	9
88	16	0	123	8	3
89	16	0	124	16	6
90	4	3	125	20	0
91	4	0	126	12	3
92	4	0	127	16	3
93	32	0	128	32	0
94	28	3	129	0	3
95	16	0	130	28	3
96	16	3	131	8	0
97	0	9	132	12	0
98	12	6	133	20	0
99	8	3	134	12	0
100	12	6	135	12	0
101	32	6	136	332	0
102	24	3			
103	40	3			
104	24	3			
105	8	6			

Decayed  
residual 16 3-6-89 WGN

RM 128

7-5-89

LUDLUM 2220

#58318, 43-4


SOURCE #6868, 1055 dpm

SOURCE CK., 260-263, BKG-3 (AM)

256-263, BKG-2 (PM)

ILP.

DOORS



	DIRECT	SMEAR
TOTAL DPM	616	78
READINGS	36	63
IDENTIFICATION # CIRCLED	DPM/100cm <sup>2</sup> AVG 17.11	2.17
SMEAR UNDER LINED	MAX DPM/100cm <sup>2</sup> 63	9


IN RED

MDA 33.61

DPM/100cm<sup>2</sup>

FIXED

FRAME



PLANT PH AREA Room 128 Doors  
 SURVEYED BY I POWELL  
 INST. LINDIUM 2220 \*# 58318 DET. 43-4  
 SOURCE CK 260-263 BKG. 3-2  
 DATE: 7-5-89 SOURCE # 6868 VALUE: 1055 DPM

ASC # 2 83600108  
 CTD. BY Jm Black  
 SOURCE CK AVG. 31  
 BKG. .3  
 DATE: 7-7-89

READINGS IN DPM/100 cm<sup>2</sup>

SAMPLE # OR DESCRIPTION	DIRECT			
	CPH	DPM	SHEAR	
Room 128 DOORS	1	3	21	0
	2	4	28	6
	3	0	0	0
	4	1	7	0
	5	3	21	3
	6	0	0	0
	7	3	21	6
	8	4	28	0
	9	4	28	0
	10	2	14	3
	11	5	35	3
	12	2	14	3
	13	5	35	9
	14	9	63	0
	15	1	7	3
	16	2	14	0
	17	5	35	0
	18	2	14	3

PLANT PH AREA Room 128 Door  
 SURVEYED BY I POWELL  
 INST. LINDIUM 2220 \*# 58318 DET. 43-4  
 SOURCE CK 260-263 BKG. 3-2  
 DATE: 7-5-89 SOURCE # 6868 VALUE: DPM

ASC # 2-83600108  
 CTD. BY Jm Black  
 SOURCE CK AVG. 31  
 BKG. .3  
 DATE: 7-7-89

READINGS IN DPM/100 cm<sup>2</sup>

SAMPLE # OR DESCRIPTION	DIRECT			
	CPH	DPM	SHEAR	
Room 128 DOOR FRAME	1	2	14	0
	2	2	14	0
	3	1	7	3
	4	5	35	0
	5	1	7	6
	6	1	7	0
	7	3	21	6
	8	2	14	0
	9	1	7	3
	10	1	7	3
	11	0	0	3
	12	4	28	6
	13	0	0	0
	14	1	7	0
	15	2	14	6
	16	2	14	0
	17	4	28	0
	18	1	7	3

PLANT PH AREA Room 128 Around Rail  
 SURVEYED BY Ainby H. Rail around Bot 4 area.  
 INST. INDIUM 2220 \* 58309 DET. 43-4  
 SOURCE CK 255-242 BKG. 50057 43-68  
210-197 BKG. 2-3  
 DATE: 7-6-89 7-7-89 SOURCE # 240 VALUE: 89 DPM

ASC # 2-83600108  
 CTD. BY Jm Black  
 SOURCE CK. AVG. 31  
 BKG. 12  
 DATE: 7-10-89


READINGS IN DPM/100 cm<sup>2</sup>

SAMPLE # OR DESCRIPTION		DIRECT		SNEAR
		CPH	DPM	
#1 TOP NORTH	HT	6	36	6
	HB	9	54	
	HE	16	96	0
	HW	5	30	
#2 TOP	HT	6	36	0
	HB	12	72	
	HE	3	18	0
	HW	3	18	
#3 TOP	HT	3	18	0
	HB	7	42	
	HE	13	78	0
	HW	8	48	
#4 TOP	HT	4	24	9
	HB	15	90	
	HE	6	36	0
	HW	2	12	
#5 TOP	HT	16	96	0
	HB	12	72	
	HE	7	42	0
	HW	0	0	
#6 TOP	HT		84	0
	HB		60	
	HE		24	0
	HW		60	
#7 TOP	HT		36	0
	HB		48	
	HE		30	0
	HW		54	

DIRECT  
 TOTAL DPM 4298  
 READINGS 104  
 DPM/100cm<sup>2</sup> 41.35  
 SNEAR  
 111  
 68  
 1.63  
 9

Room 128 Around Rail  
 INST # 58309 SOURCE 2498 VALUE 890  
 DET. 43-4  
 S/C 7-6-89 255-242 Bkg  
7-6-89 250-219 0  
7-7-89 240-236 3

MDA 28.81  
 DPM/100cm<sup>2</sup>  
 FIXED



INST # 50057 43-68  
 SOURCE 6498 VALUE 890  
 S/C 7-6-89 210-197 Bkg  
7-6-89 191-183 1  
7-7-89 202-203 4

PLANT PU AREA Room 128 Lined  
 SURVEYED BY ADDVH Rail around Bot 4 area  
 INST. LINDIUM 2220 \*# 58309 DET. 43-4  
 SOURCE CK 255-242 210-197 BKG. 50057 2-3 43-68  
 DATE: 7-6-89 7-7-89 SOURCE # 6498 VALUE: 890 DPM

ASC # 2-83600108  
 CTD. BY Jm Black  
 SOURCE CK. AVG. 31  
 BKG. .2  
 DATE: 7-10-89

READINGS IN DPM/100 cm<sup>2</sup>

SAMPLE # OR DESCRIPTION		DIRECT		SHEAR
		CPH	DPH	
TOP #8 North TOP	HT		84	6
	HB		90	
	HE		72	3
	HW		36	
TOP #9 South	HT		60	6
	HB		48	
	HN		30	0
	HS		18	
TOP #10	HT		6	3
	HB		54	
	HN		6	0
	HS		18	
TOP #11	HT		36	0
	HR		90	
	HN		6	0
	HS		30	
TOP #12	HT		12	0
	HB		54	
	HN		12	0
	HS		24	
#13 TOP	HN		60	0
#14 TOP END	HT		36	0
	HB		84	
#15 TOP SIDE	HS		30	3
#16 East TOP Vertical Post #4	VN		48	3
	VS		78	

PLANT PU AREA Room 128 Lined  
 SURVEYED BY Andy Rails around Bot 4 area  
 INST. LINDIUM 2220 \*# 58309 DET. 43-4  
 SOURCE CK 255-242 210-197 BKG. 50057 2-3 43-68  
 DATE: 7-6-89 7-7-89 SOURCE # 6498 VALUE: 890 DPM

ASC # 2-83600108  
 CTD. BY Jm Black  
 SOURCE CK. AVG. 31  
 BKG. .2  
 DATE: 7-10-89

READINGS IN DPM/100 cm<sup>2</sup>


SAMPLE # OR DESCRIPTION		DIRECT		SHEAR
		CPH	DPH	
#17 EAST TOP Vertical Post #4	VE		36	0
	VW		60	
#18 EAST Bottom Vertical Post #4	VN		42	3
	VS		72	
#19 TOP EAST TOE Board	HT		0	0
#20 EAST TOE Board TOP	HT		42	0
#21 EAST Toe Board TOP	HT		48	0
#22 Bottom Post #3	VE		96	3
	VW		12	
#23 TOP Toe Board	HT		78	3
#24 TOP Post #3	VE		78	3
	VW		36	
#25 TOP Post #3	VN	5	30	0
	VS		78	
#26 Bottom Post #3 North side	VN		36	0
	VS		72	
#27 TOP Toe Board North	HT		72	3
#28 TOP Toe Board North	HT		78	3
#29 TOP Toe Board North	HT		96	6
#30 Top Toe Board North	HT		42	3





SMEARS ON CABLE TO LIGHTS

LUDLUM 2220  
 #50064, 43-4  
 SOURCE # 6816  
 1078 dpm  
 SOURCE CK. ;  
 282-305, BKG-1 (AM)



DECONNED + SURVEYED

7-3-89  
 ILP

RM 127

PLANT PU AREA RM 128  
 SURVEYED BY ILP  
 INST. LUDLUM 2220 # 50064 DET. 43-4  
 SOURCE CK 282-305 BKG. 1 (PM)  
 DATE: 6-30-89 SOURCE # 6816 VALUE: 1078 dpm

ASC # 1-8360015  
 CTD. BY Am Black  
 SOURCE CK. AVG. 31  
 BKG. .2  
 DATE: 7-3-89

READINGS IN DPM/100 cm<sup>2</sup>

SAMPLE # OR DESCRIPTION	DIRECT		SHEAR
	CPH	DPM	
LIGHT FIXTURES			
①			
OUT	2	12	0
IN	0	0	3
②			
OUT	2	12	3
IN	3	18	0
③			
OUT	3	18	168-0*
IN	3	18	3-0
④			
OUT	2	12	0
IN	3	18	0
⑤			
OUT	3	18	3
IN	1	6	0
after Decorr			
③			
OUT	3	18	0
IN	3	18	0
Direct smear			
Total DPM/100cm <sup>2</sup> AVG	168	111	
Readings	12	22	
DPM/100cm <sup>2</sup> AVG	14.0	5.05	
Max DPM/100cm <sup>2</sup>	18	18	
MDA 16.63			
DPM/100cm <sup>2</sup>			
FIXED			

RM 128

LINE NUMBER 567 DATE 6-30-89  
 INSTRUMENT LUDLUM 2220 SERIAL NUMBER #50064  
 DETECTOR 43-4 OPERATOR ILP  
 SOURCE NUMBER AND VALUE #6816, 1078 dpm  
 SOURCE RESPONSE AND BACKGROUND AM  
 SOURCE RESPONSE AND BACKGROUND PM 282-305, 1 (PM)

START OF SURVEY	TYPE OF LINE	DIA.	READING LOCATION	Direct		Smearable			
				cpm	dpm/100cm <sup>2</sup>				
SOUTH WALL	M. STEEL	2 IN	0 METERS	E	5	60	3		
				W	4	48	0		
			2 METERS	E	4	48	0		
				W	4	48	6		
			3 METERS	E	6	72	3		
				W	5	60	3		
			TO SOUTH WALL FLOOR						
						Direct	Smear		
				Total DPM		336	15		
				Reading		6	6		
				DPM/100cm <sup>2</sup> AVG		56.0	2.5		
				Max DPM/100cm <sup>2</sup>		72	6		
	MDA 33.26								
	DPM/100cm <sup>2</sup>								
	FIXED								