



Progress Energy

Serial: HNP-09-095
10 CFR 50.55a

SEP 24 2009

U.S. Nuclear Regulatory Commission
ATTENTION: Document Control Desk
Washington, DC 20555

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF
REQUESTS 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, AND
2R2-011 FOR THE SECOND 10-YEAR INSERVICE INSPECTION PROGRAM (TAC NOS.
ME0608, ME0609, ME0610, ME0166, ME0612, ME0613, ME0614, AND ME0615)

- References:
1. Letter from D. H. Corlett to the Nuclear Regulatory Commission (SERIAL: HNP-08-045), "Second Ten-Year Interval Inservice Inspection Program – Final Documentation Including Requests for Relief in accordance with 10 CFR 50.55a," dated February 05, 2009
 2. Letter from M. Vaaler, Nuclear Regulatory Commission, to C. L. Burton, "Request for Additional Information Regarding Relief Requests 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, and 2R2-011 For The Second 10-Year Inservice Inspection Program (TAC NOS. ME0608, ME0609, ME0610, ME0611, ME0612, ME0613, ME0614, and ME0615)," dated July 21, 2009

Ladies and Gentlemen:

On July 21, 2009, Harris Nuclear Plant (HNP) received a request from the NRC (Reference 2) for additional information needed to facilitate the review of proposed Second 10-Year Inservice Inspection Interval Relief Requests 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, and 2R2-011. HNP submitted this original request as Serial: HNP-08-045 (Reference 1).

Per discussions with Marlayna Vaaler (NRC HNP Project Manager), HNP was allowed an extension to the September 18, 2009, response date specified in Reference 2. Accordingly, the Enclosures to this letter provide the requested additional information for the Relief Requests.

This document contains no new or revised Regulatory Commitments.

Please refer any questions regarding this submittal to me at (919) 362-3137.

Sincerely,



D. H. Corlett
Supervisor – Licensing/Regulatory Programs
Harris Nuclear Plant

DHC/kms

- Enclosures:
1. HNP's Response to the Request for Additional Information Regarding Relief Request I3R-02 for the Third 10-Year Inservice Inspection Interval
 2. Inservice Inspection Relief Request 2R1-018 Response to Request for Additional Information
 3. Inservice Inspection Relief Request 2R1-019 Response to Request for Additional Information
 4. Inservice Inspection Relief Request 2R1-020 Response to Request for Additional Information
 5. Inservice Inspection Relief Request 2R1-021 Response to Request for Additional Information
 6. Inservice Inspection Relief Request 2R1-022 Response to Request for Additional Information
 7. Inservice Inspection Relief Request 2R2-009 Response to Request for Additional Information
 8. Inservice Inspection Relief Request 2R2-010 Response to Request for Additional Information
 9. Inservice Inspection Relief Request 2R2-011 Response to Request for Additional Information

cc: Mr. J. D. Austin, NRC Sr. Resident Inspector, HNP
Mr. L. A. Reyes, NRC Regional Administrator, Region II
Ms. N. C. Ritchie-Slaughter, Harris Plant Authorized Nuclear Inservice Inspector
Ms. M. G. Vaaler, NRC Project Manager, HNP

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF
REQUESTS 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, AND
2R2-011 FOR THE SECOND 10-YEAR INSERVICE INSPECTION PROGRAM

Summary

Carolina Power & Light Company, now doing business as Progress Energy Carolinas, Inc., (PEC) (licensee) submitted Relief Requests (RRs) 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, and 2R2-011, for the Harris Nuclear Plant (HNP). The proposed RR's are for the second 10-year inservice inspection (ISI) interval, in which the licensee adopted the 1989 Edition of the ASME Code, Section XI, No Addenda, as the Code of Record.

The proposed RR's request relief in accordance with Title 10 of the *Code of Regulations* (10 CFR) Section 50.55a(g)(5)(iii) from applicable requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code (ASME Code), Section XI, "Rules for Inservice Inspection of Nuclear Power Plant Components," related to inspection of welds with limited coverage in ASME Code examination Categories B-F, B-A, B-D, B-B, C-A, C-B, and C-A. The ASME Code requires that 100 percent of the examination volumes or surface areas described in ASME Code, Section XI, Tables IWB-2500 and IWC-2500, be inspected during each interval. The licensee stated that 100 percent of the ASME Code-required volumes or surface areas are impractical to obtain at HNP.

10 CFR 50.55a(g)(5)(iii) states that when licensees determine that conformance with ASME Code requirements is impractical at their facility, they shall submit information to support this determination. The U.S. Nuclear Regulatory Commission (NRC) will evaluate such requests based on impracticality, and may impose alternatives, giving due consideration to public safety and the burden imposed on the licensee.

Pacific Northwest National Laboratory and the NRC have reviewed the information submitted by the licensee and have determined the following information is required to complete the evaluation.

Request 1: General – Information Required on All Requests for Relief

In all cases, the licensee has provided only general information regarding the impracticality of obtaining ASME Code-required volumetric or surface examinations, as applicable. Statements such as "physical obstructions and geometric surface conditions," "design configurations," or "inner diameter counterbore and root configuration," are inadequate to explain the bases for not obtaining the ASME Code-required examination volumes. No sketches with dimensional information showing the causes of limited accessibility have been included.

Please submit detailed and specific information to support the bases for limited examination in all requests for relief in order to demonstrate impracticality. Specifically:

- a) Include descriptions (written and/or sketches, as necessary) of the interferences present

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF
REQUESTS 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, AND
2R2-011 FOR THE SECOND 10-YEAR INSERVICE INSPECTION PROGRAM

for applied nondestructive examination (NDE) techniques.

- b) As applicable, describe NDE equipment (ultrasonic scanning apparatus), details of the listed obstructions (size, shape, proximity to the weld, etc.) to demonstrate accessibility limitations, and discuss whether alternative methods or advanced technologies could be employed to maximize ASME Code coverage.
- c) Fully clarify the wave modality and insonification angles used for all ultrasonic examinations.
- d) Provide cross-sectional coverage plots to describe the ASME Code volumes examined.
- e) If not included, state whether any indications were discovered as a result of these examinations, and how these indications have been dispositioned.

Response: The requested information is summarized in the following Enclosures:

Enclosure 2	2R1-018
Enclosure 3	2R1-019
Enclosure 4	2R1-020
Enclosure 5	2R1-021
Enclosure 6	2R1-022
Enclosure 7	2R2-009
Enclosure 8	2R2-010
Enclosure 9	2R2-011

Request 2: Request for Relief 2R2-010, ASME Code, Section XI, Examination Category C-B, Item C2.21, Nozzle-to-Shell Weld

The licensee has requested relief from the requirement to examine 100 percent of the ASME Code-required inspection volume for two Boron Injection Tank nozzle-to-vessel welds: II-BIT-01NTHW-03 and II-BIT-01NTHW-04.

- a) Please state whether the inspection techniques used to examine these welds included refracted longitudinal waves.

Response: Shear waves were used in all angle beam exams and longitudinal waves used in the 0 degree exam, as follows:

- 45 degree shear - ½ V
- 60 degree shear - ½ V
- 0 degree – longitudinal

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF
REQUESTS 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, AND
2R2-011 FOR THE SECOND 10-YEAR INSERVICE INSPECTION PROGRAM

- b) Please state the material used (austenitic or ferritic steel) and the wall thickness for each of these components.

Response: The material used is alloy steel – ASTM A 204 Standard Specification for Pressure Vessel Plates, Alloy Steel, Molybdenum with a 1.732” Thickness

Request 3: Request for Relief 2R1-018, ASME Code, Section XI, Examination Category B-F, Item B5.130, NPS 4 or Larger Dissimilar Metal Butt Welds

- a) The licensee has requested relief from the requirement to examine 100 percent of the ASME Code-required inspection volume for the following dissimilar metal welds on the primary coolant system:

RVNOZCI-N-05SE Inlet Nozzle DM weld at 95 degrees
RVNOZBI-N-03SE Inlet Nozzle DM weld at 215 degrees
RVNOZAI-N-01SE Inlet Nozzle DM weld at 335 degrees

It is unclear from the licensee’s submittal why inlet nozzle welds RVNOZCI-N-05SE and RVNOZBI-N-03SE were not included in the previous 10-year ISI request for relief. Please submit information explaining why these welds were not included previously.

Response: As discussed in Section 8.1 (“Changes in Circumstances”) of Relief Request Submittal (SERIAL: HNP-08-045), these examinations were performed by a different vendor during the first interval, resulting in different coverage limitations. Additionally, the second interval UT inspections were performed with examination personnel and examination procedures qualified to ASME Code, Appendix VIII, as administered by the EPRI Performance Demonstration Initiative (PDI). This improved method of examination also results in differing coverage limitations.

- b) Please provide more detailed information on the ultrasonic testing (UT) inspections performed (i.e., probe type, incident angle, geometrical interference, scanned coverage, etc).

Response: Information is provided in Enclosure 2 of this response.

- c) Please explain how the “Combined UT [Ultrasonic] Coverage Total Percentage” in Sections 6.1, 6.2, and 6.3 of 2R1-018 is obtained.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF
REQUESTS 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, AND
2R2-011 FOR THE SECOND 10-YEAR INSERVICE INSPECTION PROGRAM

Response: The Combined UT coverage totals as provided in Sections 6.1, 6.2 and 6.3 of 2R1-018 were obtained from averaging the individual (CCW, CS, UP, DOWN) 70° Longitudinal Wave Dual Scans as follows :

RVNOZC1-N-05SE: $(69.15 + 69.15 + 100 + 100)/4 = 84.58$

RVNOZB1-N-03SE: $(76.67 + 76.67 + 100 + 100)/4 = 88.34$

RVNOZA1-N-01SE: $(70.29 + 70.29 + 100 + 100)/4 = 85.15$

d) Please provide information regarding when the ultrasonic testing inspection for each weld was performed (e.g., what ASME Code criteria were required - Appendix VIII or Section V)?

Response: As discussed in Section 6.1 for RVNOZC1-N-05SE, Section 6.2 for RVNOZB1-N-03SE and Section 6.3 for RVNOZA1-N-01SE of the Relief Request Submittal (SERIAL: HNP-08-045), UT examinations were performed with examination personnel and examination procedures qualified to ASME Code, Appendix VIII, as administered by the EPRI Performance Demonstration Initiative (PDI).

e) Please provide more detailed information on the eddy current inspection methods performed, the inner diameter surface conditions of the affected welds, and an assessment of the ability to perform the eddy current testing exam effectively on these types of surface conditions.

Response: The Eddy Current procedure (provided separately) contains this information.

Request 4: Request for Relief 2R1-022, ASME Code, Section XI, Examination Category B-B, Item B2.40, Pressure Retaining Welds in Vessels Other than Reactor Vessels

The licensee has requested relief from the requirement to examine 100 percent of the ASME Code-required inspection volume for steam generator tubesheet-to-head weld II-SG-001SGA-TSTHW-06-1.

HNP is a 3-loop pressurized water reactor plant; there are three steam generators, each containing a tubesheet-to-head weld. The ASME Code states that “the examination may be limited to one vessel among the group of vessels performing similar functions.” Please clarify whether all three steam generator tubesheet-to-head welds were examined. Because the licensee was unable to meet the ASME Code-required inspection volume on tubesheet-to-head weld II-SG-001SGA-TSTHW-06-1, if the other tubesheet-to-head welds were examined, please describe whether the same coverage area limitations apply to these similar welds on the remaining two steam generators.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION REGARDING RELIEF
REQUESTS 2R1-018, 2R1-019, 2R1-020, 2R1-021, 2R1-022, 2R2-009, 2R2-010, AND
2R2-011 FOR THE SECOND 10-YEAR INSERVICE INSPECTION PROGRAM

Response: All three of HNP's steam generators have the same configuration and associated limitation. Since this examination category only requires one examination per similar vessel, only one of the steam generators was examined. Additionally, these steam generators were new in 2001.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category B-F, Item B5.130, NPS 4 or Larger Dissimilar Metal Butt Welds

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Welds are Cold leg elbow to nozzle weld.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). Volumetric examination for the subject welds at HNP is restricted due to geometric surfaces (inner diameter surface counter-bore and root configuration) which limit accessibility and make the 100 percent volumetric examination impractical for these areas.
1b	NDE Equipment	The following procedures are provided separately: PDI-ISI-254-SE WDI-STD-146 WDI-STD-088
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). To supplement the UT, areas of limitation were fully scanned using eddy current testing (ET), which is effective in detecting surface breaking flaws. This combination of UT and ET further validates that the proposed alternative provides an acceptable level of quality and safety, since these completed examinations would have detected any existing patterns of degradation.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (“70° Longitudinal Wave Dual Scan”).
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure.
1e	Results of the Examination Indications / No Indications	No indications detected.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

3a	It is unclear from the licensee's submittal why inlet nozzle welds RVNOZCIN 05SE and RVNOZBIN-03SE were not included in the previous 10 year ISI request for relief. Please submit information explaining why these welds were not included previously.	(Reference Relief Request submittal HNP-08-045 Section 8.1). During the first interval, these examinations were performed by a different vendor using different equipment, resulting in different coverage limitations. In addition, the second interval UT Examinations were performed with examination personnel and examination procedures qualified to ASME Code, Appendix VIII, as administered by the EPRI Performance Demonstration Initiative (PDI).
3b	Please provide more detailed information on the ultrasonic testing (UT) inspections performed (i.e., probe type, incident angle, geometrical interference, scanned coverage, etc).	Information follows in Enclosure.
3c	Please explain how the "Combined UT [Ultrasonic] Coverage Total Percentage" in Sections 6.1, 6.2, and 6.3 of 2R1-018 is obtained.	An averaging method is used.
3d	Please provide information regarding when the ultrasonic testing inspection for each weld was performed (e.g., what ASME Code criteria were required - Appendix VIII or Section V)?	(Reference Relief Request submittal HNP-08-045 Sections 6.1, 6.2 and 6.3). UT examinations were performed with examination personnel and examination procedures qualified to ASME Code, Appendix VIII, as administered by the EPRI Performance Demonstration Initiative (PDI).
3e	Please provide more detailed information on the eddy current inspection methods performed, the inner diameter surface conditions of the affected welds, and an assessment of the ability to perform the eddy current testing exam effectively on these types of surface conditions.	Eddy Current procedure provided separately: WDI-STD-146

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **RVNOZCI-N-05SE** ASME CATEGORY: B-F
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B5.130
 FIGURE:
 CONFIGURATION: ELBOW TO REACTOR VESSEL NOZZLE % CRV ACHIEVED: 84.58 %
 PROCEDURES: PDI-ISI-254-SE MATERIAL SS/CS
 WDI-STD-146
 WDI-STD-088

PDI TECHNIQUE USED: YES

70° LONGITUDINAL WAVE DUAL SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CCW	69.15%	ELBOW TO NOZZLE WELD ID COUNTER-BORE AND ROOT CONFIGURATION
CW	69.15%	ELBOW TO NOZZLE WELD ID COUNTER-BORE AND ROOT CONFIGURATION
UP	100%	
DOWN	100%	

EDDY CURRENT SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CCW	100%	
CW	100%	

The coverage achieved was the maximum extent practical with the elbow to nozzle weld ID counter-bore and root configuration obstructions in place and the results are representative of the entire weld.

UT COMBINED COVERAGE = 84.58 %

EXAMINATION RESULTS: NO INDICATIONS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **RVNOZBI-N-03SE** ASME CATEGORY: B-F
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B5.130
 FIGURE:
 CONFIGURATION: ELBOW TO REACTOR VESSEL NOZZLE % CRV ACHIEVED: 88.34 %
 PROCEDURES: PDI-ISI-254-SE MATERIAL SS/CS
 WDI-STD-146
 WDI-STD-088

PDI TECHNIQUE
 USED: YES

70° LONGITUDINAL WAVE DUAL SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CCW	76.67%	ELBOW TO NOZZLE WELD ID COUNTER-BORE AND ROOT CONFIGURATION
CW	76.67%	ELBOW TO NOZZLE WELD ID COUNTER-BORE AND ROOT CONFIGURATION
UP	100%	
DOWN	100%	

EDDY CURRENT SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CCW	100%	
CW	100%	

The coverage achieved was the maximum extent practical with the elbow to nozzle weld ID counter-bore and root configuration obstructions in place and the results are representative of the entire weld.

UT COMBINED COVERAGE = 88.34 %

EXAMINATION RESULTS: NO INDICATIONS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **RVNOZAI-N-01SE** ASME CATEGORY: B-F
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B5.130
 FIGURE:
 CONFIGURATION: ELBOW TO REACTOR VESSEL NOZZLE % CRV ACHIEVED: 85.15 %
 PROCEDURES: PDI-ISI-254-SE MATERIAL SS/CS
 WDI-STD-146
 WDI-STD-088

PDI TECHNIQUE
 USED: YES

70° LONGITUDINAL WAVE DUAL SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CCW	70.29%	ELBOW TO NOZZLE WELD ID COUNTER-BORE AND ROOT CONFIGURATION
CW	70.29%	ELBOW TO NOZZLE WELD ID COUNTER-BORE AND ROOT CONFIGURATION
UP	100%	
DOWN	100%	

EDDY CURRENT SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CCW	100%	
CW	100%	


The coverage achieved was the maximum extent practical with the elbow to nozzle weld ID counter-bore and root configuration obstructions in place and the results are representative of the entire weld.

UT COMBINED COVERAGE = 85.15 %

EXAMINATION RESULTS: NO INDICATIONS


SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-018
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

WELD CONFIGURATION IDENTIFICATION SHEET




SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

INLET NOZZLE DM WELD EXAM PROGRAM PLAN




SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

REACTOR VESSEL



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-018
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

REACTOR VESSEL



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-018
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENTS:

- A) Reactor Vessel Weld Results Summary RVNOZCI-N-05SE, including:
- Analysis Log # SE-95-1
 - ET Analysis Log # SE-95-1
 - Data Acquisition Log # SE-95-1
 - RPV Coverage Estimate Breakdown NOZ @ 95°
- B) Reactor Vessel Weld Results Summary RVNOZCI-N-03SE, including:
- Analysis Log # SE-215-1
 - ET Analysis Log # SE-215-1
 - Data Acquisition Log # SE-215-1
 - RPV Coverage Estimate Breakdown NOZ @ 215°
- C) Reactor Vessel Weld Results Summary RVNOZCI-N-01SE, including:
- Analysis Log # SE-335-1
 - ET Analysis Log # SE-335-1
 - Data Acquisition Log # SE-335-1
 - RPV Coverage Estimate Breakdown NOZ @ 335°

Enclosure 2 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-018
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT A
WesDyne International Reactor Vessel Weld Results Summary
RVNOZC1-N-05SE
(5 Pages)

WesDyne International
Reactor Vessel Weld Results Summary

SHEARON HARRIS UNIT 1

WELD NO. **RVNOZCI-N-05SE** DESCRIPTION **INLET NOZZLE DM WELD @ 95°**

LIMITATIONS

NO

YES

Coverage = 84.58%

Weld Configuration

RESULTS

NI

RI

NO. OF INDICATIONS 0
STATUS N/A

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

ANALYSIS LOG

ASSESSMENT SHEET

ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINTOUT

OTHER (specify)

COVERAGE BREAKDOWN

WESDYNE ANALYST





ANALYSIS LOG # SE-95-1

Utility:	Progress Energy	Plant:	Shearon Harris	Unit:	1	Outage:	RFO-13	
Procedure No.:	PDI-ISI-254-SE					Procedure Rev. No.:	2	
Weld No.:	RVNOZCI-N-05SE	Weld Type:	DM	Exam. Surface:	ID			
Applicable Sensitivity Calibration Data Sheet No.:	SE-01	Acquisition Log No.:		PARAGON Anal. Release:	6.1.6			
UT Examiner Signature:					Level:	II	Date:	4/18/06
Data File Name	UT Channel No.	Beam Angle / Beam Direction <small>(In or out, CW or CCW)</small>	NI	RI	RI Resolution / Comments / Limitations	Examiner ID / Date		
WN95SEPARDETIN	1	CCW	X			CSW 4/18/06		
WN95SEPARDETIN	2	CW	X			CSW 4/18/06		
WN95SEPRPDETIN	1	IN	X			CSW 4/18/06		
WN95SEPRPDETIN	2	OUT	X			CSW 4/18/06		



ET Analysis Log: SE95-1

Utility: Progress Energy		Plant: Shearon Harris			Unit: 1	Outage: RFO13
Procedure No: WDI-STD-146				Procedure Rev. No.: 5		
Weld No: RVNOZCI-N-05SE			Weld Type: INLET DM WELD AT 95°			
Applicable Sensitivity Calibration Data Sheet No: ET-1					Acquisition Log No: SE-95-1	
ET Examiner Signature: <i>Carl D. Wiff</i> Level III					Date: 4/18/06	
Data File Name	ET Probe No.	ET Probe Scan Direction [Axial/Circ.]	NI	RI	RI Resolution / Comments / Limitations	Examiner ID / Date
WN95SEPARDETIN	1	CIRC	X			CSW 4/18/06
WN95SEPARDETIN	2	CIRC	X			CSW 4/18/06
WN95SEPRPDETIN	1	AX	X			CSW 4/18/06
WN95SEPRPDETIN	2	AX	X			CSW 4/18/06



DATA ACQUISITION LOG # SE-95-1

Utility:	Progress Energy	Plant:	Shearon Harris	Unit:	1	Outage:	RFO-13			
Procedure No:	PDI-ISI-254-SE					Procedure Rev. No.:	2			
Applicable Sensitivity Calibration Data Sheet No:	SE-01									
UT Examiner Signature:						Level:	II	Date:	4/18/06	
Data File Name	Weld No.	Index Start	Scan Start	Total # of Sweeps	'AVE' Signal Amplitude	Gain Adj. (dB)	Operator Initials	Date (mm/dd/yy)	Time	Comments
WN95SEPARDETIN	N-05SE	125.51°	0°	54	16	0	ESO	4/18/06	1746	CHANNEL 1
WN95SEPARDETIN	N-05SE	125.51°	0°	54	17	0	ESO	4/18/06	1746	CHANNEL 2
WN95SEPRPDETIN	N-05SE	0°	114.74°	347	14	0	ESO	4/18/06	1842	CHANNEL 1
WN95SEPRPDETIN	N-05SE	0°	114.74°	347	12	0	ESO	4/18/06	1842	CHANNEL 2

SHEARON HARRIS #1

DIRECTION / ORIENTATION

RPV COVERAGE ESTIMATE BREAKDOWNS

PARALLEL SCANS
PERP. SCANS

CCW / CW
IN / OUT

ITEM / AREA INLET NOZZLE DM WELD @ 95°


WELD NO. RVNOZCI-N-05SE

Examination Probes

BEAM DIRECTION	70° Dual		*ET					
	Examination Volume	Examination Surface	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME
CCW	69.15	100						
CW	69.15	100						
UP	100	-						
DOWN	100	-						
UT Combined Coverage = 84.58% UT & ET Combined Coverage = 100%								

Circ Scans limited as per procedure PDQS due to ID Counter-bore and Root configuration.
ET used to supplement exam for full coverage.

ANALYST



Enclosure 2 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-018
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT B
WesDyne International Reactor Vessel Weld Results Summary
RVNOZB1-N-03SE
(5 Pages)

WesDyne International
Reactor Vessel Weld Results Summary

SHEARON HARRIS UNIT 1

WELD NO. RVNOZBI-N-3SE DESCRIPTION INLET NOZZLE DM WELD
@ 215°

LIMITATIONS

NO

YES

Coverage = 88.34%

Weld Configuration

RESULTS

NI

RI

NO. OF INDICATIONS 0
STATUS N/A

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

ANALYSIS LOG

ASSESSMENT SHEET

ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINTOUT


OTHER (specify)

COVERAGE BREAKDOWN

WESDYNE ANALYST



ANALYSIS LOG # SE-215-1

Utility:	Progress Energy	Plant:	Shearon Harris	Unit:	1	Outage:	RFO-13
Procedure No.:	PDI-ISI-254-SE					Procedure Rev. No.:	2
Weld No.:	RVNOZBI-N-03SE	Weld Type:	INTLET-DM	Exam. Surface:	ID		
Applicable Sensitivity Calibration Data Sheet No.:	SE-01	Acquisition Log No.:	SE215-1	PARAGON Anal. Release:	6.1.6		
UT Examiner Signature:						Level:	II
						Date:	4-18-06
Data File Name	UT Channel No.	Beam Angle / Beam Direction <small>(In or out, CW or CCW)</small>	NI	RI	RI Resolution / Comments / Limitations	Examiner ID / Date	
WN215-SE-PAR-DET-IN	1	70° / CCW	X			CSW 4/18/06	
WN215-SE-PAR-DET-IN	2	70° / CW	X			CSW 4/18/06	
WN215-SE-PRP-DET-IN	1	70° / IN	X			CSW 4/18/06	
WN215-SE-PRP-DET-IN	2	70° / OUT	X			CSW 4/18/06	



ET Analysis Log: SE 215-1

Utility: Progress Energy		Plant: Shearon Harris			Unit: 1	Outage: 1R13
Procedure No: WDI-STD-146				Procedure Rev. No.: 5		
Weld No: RVNOZBI-N-03SE				Weld Type: INLET DM WELD AT 216°		
Applicable Sensitivity Calibration Data Sheet No: ET-1					Acquisition Log No: SE215-1	
ET Examiner Signature: <i>C. L. W.</i>				Level: III		Date: 4-19-06
Data File Name	ET Probe No.	ET Probe Scan Direction [Axial/Circ.]	NI	RI	RI Resolution / Comments / Limitations	Examiner ID / Date
WN215SEPARDETIN	1	CIRC	X			CSW / 4-19-06
WN215SEPARDETIN	2	CIRC	X			CSW / 4-19-06
WN215SEPRPDETIN	1	AXIAL	X			CSW / 4-19-06
WN215SEPRPDETIN	2	AXIAL	X			CSW / 4-19-06



DATA ACQUISITION LOG # SE 215-1

Utility:	Progress Energy	Plant:	Shearon Harris	Unit:	1	Outage:	RFO-13			
Procedure No.:	PDI-ISI-254-SE					Procedure Rev. No.:	2			
Applicable Sensitivity Calibration Data Sheet No.:	SE-01									
UT Examiner Signature:	<i>Carl A. W. [Signature]</i>					Level:	II	Date:	4-18-06	
Data File Name	Weld No.	Index Start	Scan Start	Total # of Sweeps	'AVE' Signal Amplitude	Gain Adj. (dB)	Operator Initials	Date (mm/dd/yy)	Time	Comments
WN215-SE-PARDETIN	N-03SE	125.51"	0°	54	8	0	DS	4-18-06	22:26	CHANNEL 1
WN215-SE-PARDETIN	N-03SE	125.51"	0°	54	9	0	DS	4-18-06	22:26	CHANNEL 2
WN215-SE-PRPDETIN	N-03SE	0°	114.74"	346	15	0	DS	4-18-06	23:21	CHANNEL 1
WN215-SE-PRPDETIN	N-03SE	0°	114.74"	346	11	0	DS	4-18-06	23:21	CHANNEL 2

SHEARON HARRIS #1

DIRECTION / ORIENTATION

RPV COVERAGE ESTIMATE BREAKDOWNS

PARALLEL SCANS CCW / CW
PERP. SCANS IN / OUT

ITEM / AREA INLET NOZZLE DM WELD @ 215° **WELD NO.** RVNOZBI-N-03SE

Examination Probes

BEAM DIRECTION	70° Dual		ET					
	Examination Volume	Examination Surface	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME
CCW	76.67	100						
CW	76.67	100						
UP	100	-						
DOWN	100	-						
UT Combined Coverage = 88.34% UT & ET Combined Coverage = 100%								

Circ Scans limited as per procedure PDQS due to ID Counter-bore and Root configuration.
 ET used to supplement exam for full coverage.

ANALYST *[Signature]*

Enclosure 2 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-018
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT C
WesDyne International Reactor Vessel Weld Results Summary
RVNOZA1-N-01SE
(5 Pages)

WesDyne International
Reactor Vessel Weld Results Summary

SHEARON HARRIS UNIT 1

WELD NO. **RVNOZAI-N-01SE** DESCRIPTION **INLET NOZZLE DM WELD @ 335°**

LIMITATIONS

NO

YES

Coverage = 85.15%

Weld Configuration

RESULTS

NI

RI

NO. OF INDICATIONS 0
STATUS N/A

EXAM DOCUMENTATION

INDICATION DOCUMENTATION

ANALYSIS LOG

ASSESSMENT SHEET

ACQUISITION LOG

PARAGON HARD COPY

SCAN PRINTOUT

OTHER (specify)

COVERAGE BREAKDOWN

WESDYNE ANALYST





ANALYSIS LOG # SE-335-1

Utility:	Progress Energy	Plant:	Shearon Harris	Unit:	1	Outage:	RFO-13	
Procedure No:	PDI-ISI-254-SE					Procedure Rev. No.:	2	
Weld No:	RVNOZAI-N-01SE	Weld Type:	INLET-DM	Exam. Surface:	ID			
Applicable Sensitivity Calibration Data Sheet No:	SE-01	Acquisition Log No:	SE-335-1	PARAGON Anal. Release:	6.1.6			
UT Examiner Signature:					Level:	III	Date:	4-18-06
Data File Name	UT Channel No.	Beam Angle / Beam Direction <small>(In or out, CW or CCW)</small>	NI	RI	RI Resolution / Comments / Limitations	Examiner ID / Date		
WN335-SE-PAR-DET-IN	1	70° / CCW	X			SAS 4/18/06		
WN335-SE-PAR-DET-IN	2	70° / CW	X			SAS 4/18/06		
WN335-SE-PRP-DET-IN	1	70° / IN	X			SAS 4/18/06		
WN335-SE-PRP-DET-IN	2	70° / OUT	X			SAS 4/18/06		



ET Analysis Log: SE335-1

Utility: Progress Energy		Plant: Shearon Harris			Unit: 1	Outage: 1R13
Procedure No: WDI-STD-146					Procedure Rev. No.: 5	
Weld No: RVNOZAI-N-01SE				Weld Type: INLET DM WELD AT 335°		
Applicable Sensitivity Calibration Data Sheet No: ET-1					Acquisition Log No: SE335-1	
ET Examiner Signature: <i>CSW</i> Level III						Date: 4-18-06
Data File Name	ET Probe No.	ET Probe Scan Direction (Axial/Circ.)	NI	RI	RI Resolution / Comments / Limitations	Examiner ID / Date
WN335SEPARDETINA	1	CIRC	X			CSW / 4-18-06
WN335SEPARDETINA	2	CIRC	X			CSW / 4-18-06
WN335SEPRPDETIN	1	AXIAL	X			CSW / 4-18-06
WN335SEPRPDETIN	2	AXIAL	X			CSW / 4-18-06



DATA ACQUISITION LOG # SE335-1

Utility:	Progress Energy	Plant:	Shearon Harris	Unit:	1	Outage:	RFO-13			
Procedure No:	PDI-ISI-254-SE					Procedure Rev. No.:	2			
Applicable Sensitivity Calibration Data Sheet No:		SE-01								
UT Examiner Signature:						Level:	II	Date:	4-18-06	
Data File Name	Weld No.	Index Start	Scan Start	Total # of Sweeps	'AVE' Signal Amplitude	Gain Adj. (dB)	Operator Initials	Date (mm/dd/yy)	Time	Comments
WN335SEPARDEINA	N-01SE	122.49°	0°	52	17	0	CSW	4-18-06	0600	CHANNEL 1
WN335SEPARDEINA	N-01SE	122.49°	0°	52	14	0	CSW	4-18-06	0600	CHANNEL 2
WN335SEPRPDEIN	N-01SE	0°	114.74°	348	7	0	DS	4-18-06	0730	CHANNEL 1
WN335SEPRPDEIN	N-01SE	0°	114.74°	348	12	0	DS	4-18-06	0730	CHANNEL 2

SHEARON HARRIS #1

RPV COVERAGE ESTIMATE BREAKDOWNS

DIRECTION / ORIENTATION

PARALLEL SCANS
PERP. SCANS

CCW / CW
IN / OUT

ITEM / AREA INLET NOZZLE DM WELD @ 335°

WELD NO. RVNOZAI-N-01SE

Examination Probes

BEAM DIRECTION	70° Dual		*ET					
	Examination Volume	Examination Surface	WELD	VOLUME	WELD	VOLUME	WELD	VOLUME
CCW	70.29	100						
CW	70.29	100						
UP	100	-						
DOWN	100	-						
UT Combined Coverage = 85.15%								
UT & ET Combined Coverage = 100%								

Circ Scans limited as per procedure PDQS due to ID Counter-bore and Root configuration.
ET used to supplement exam for full coverage.

ANALYST



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-019
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category B-A, Item B1.11 and B1.21, Circumferential Shell/Head Welds

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Welds are Lower shell to lower circumferential shell weld and lower head circumferential weld.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). The limitation for Reactor Vessel Lower Head to Lower Shell Circumferential Weld STHW-RV-04 was due to the four core support lugs integrally attached to the reactor vessel. The limitation for Reactor Vessel Lower Head Circumferential Weld CHW-RV-17 was due to peripherally located Bottom Mounted Instrumentation (BMI) tubes integrally attached to the reactor vessel.
1b	NDE Equipment	The following procedure is provided separately: PDI-ISI-254
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). HNP is proposing to volumetrically UT examine the RPV pressure retaining welds STHW-RV-04 and CHW-RV-17 to the maximum extent possible in accordance with the Inservice Inspection Program schedule. A significant portion of the subject welds have been examined, obtaining 83.9% for weld STHW-RV-04 and 81.77% for weld CHW-RV-17. In addition, the subject welds are subject to visual (VT-2) system Leakage test during each refueling outage.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (“45° Longitudinal Wave Dual Scan”, “45° Longitudinal Wave Single Element Scan”, “45° Shear Wave Scan”).
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-019
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

1e	Results of the Examination Indications / No Indications	Information follows in Enclosure.
----	--	-----------------------------------

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **STHW-RV-04** ASME CATEGORY: B-A

ASME CODE IWB-2500-8 ASME ITEM NUMBER: B1.11
 FIGURE:

CONFIGURATION: CIRCUMFERENTIAL SHELL WELD % CRV ACHIEVED: 83.90 %

PROCEDURES: PDI-ISI-254 MATERIAL CS/CS

PDI TECHNIQUE USED: YES

45° LONGITUDINAL WAVE DUAL SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	75.56%	84.41%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
CW	75.56%	84.41%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
UP	79.11%	79.11%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
DOWN	79.11%	79.11%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

45° LONGITUDINAL WAVE SINGLE ELEMENT SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	82.04%	84.41%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
CW	82.04%	84.41%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
UP	79.11%	79.11%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
DOWN	79.11%	79.11%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL

45° SHEAR WAVE SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	82.04%	84.41%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
CW	82.04%	84.41%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
UP	100%	97.46%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL
DOWN	100%	97.46%	FOUR CORE SUPPORT LUGS INTEGRALLY ATTACHED TO THE REACTOR VESSEL


The coverage achieved was the maximum extent practical with the four core support lug obstructions in place and the results are representative of the entire weld.

UT COMBINED COVERAGE = 83.90 %

**EXAMINATION RESULTS: ONE RECORDABLE INDICATION
 ALLOWABLE PER ASME SECTION XI 1989, IWB-3510-1**


SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

REACTOR VESSEL




SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

VESSEL ROLLOUT DRAWING #1




SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

LOWER SHELL TO LOWER HEAD CIRC WELD
DRAWING # 19



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

LOWER SHELL TO LOWER HEAD CIRC WELD
DRAWING # 20



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **CHW-RV-17** ASME CATEGORY: B-A

ASME CODE IWB-2500-8 ASME ITEM NUMBER: B1.21
 FIGURE:

CONFIGURATION: CIRCUMFERENTIAL HEAD WELDS % CRV ACHIEVED: 81.77 %

PROCEDURES: PDI-ISI-254 MATERIAL CS/CS

PDI TECHNIQUE USED: YES

45° LONGITUDINAL WAVE DUAL SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	88.15%	88.15%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
CW	88.15%	88.15%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
UP	75.38%	75.38%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
DOWN	75.38%	75.38%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-019
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

45° LONGITUDINAL WAVE SINGLE ELEMENT SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	88.15%	88.15%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
CW	88.15%	88.15%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
UP	75.38%	75.38%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
DOWN	75.38%	75.38%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

45° SHEAR WAVE SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	88.15%	88.15%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
CW	88.15%	88.15%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
UP	75.38%	75.38%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL
DOWN	75.38%	75.38%	PERIPHERALLY LOCATED BOTTOM MOUNTED INSTRUMENTATION (BMI) TUBES INTEGRALLY ATTACHED TO THE REACTOR VESSEL


The coverage achieved was the maximum extent practical with the bottom mounted instrumentation tube obstructions in place and the results are representative of the entire weld.

UT COMBINED COVERAGE = 81.77 %

**EXAMINATION RESULTS: ONE RECORDABLE INDICATION
 ALLOWABLE PER ASME SECTION XI 1989, IWB-3512-1**


SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

LOWER HEAD CIRC WELD
DRAWING # 22



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-019
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

REACTOR VESSEL



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

**Examination Category B-A, Item B1.30, Shell to Flange Weld,
and Item B 1.40, Head to Flange Weld**

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Welds are Vessel Flange to Upper shell weld and Vessel Flange to Head weld.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). The limitation that reduces the amount of UT examination coverage for Vessel Flange to Upper Shell Weld FTSW-RV-01 is the vessel configuration at the flange. The limitations for the Vessel Flange to Head Weld FTHW-RV-18 is due to the component configuration (flange directly adjacent to the weld) and the vessel head lifting lugs.
1b	NDE Equipment	The following procedures are provided separately: PDI-ISI-254 (FTSW-RV-01) WDI-STD-146, WDI-STD-088 (FTHW-RV-18)
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). HNP is proposing to volumetrically UT examine the RPV pressure retaining welds FTSW-RV-01 and FTHW-RV-18 to the maximum extent possible in accordance with the Inservice Inspection Program schedule. In addition, the subject welds are subject to visual (VT-2) system Leakage test during each refueling outage. For FTHW-RV-18 Vessel Flange to Head Weld, the Code required MT Examination was also performed in accordance with the ASME Code Section XI.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (“45° Longitudinal Wave Dual Scan”, 45° Longitudinal Wave Single Element Scan”, “45° Shear Wave Scan”, “Longitudinal Wave Manual Scans from Flange Face”, 0° Longitudinal Wave Scan”, 45° and 60° Shear Wave ½ Vee Scan”).
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

1e	Results of the Examination Indications / No Indications	No indications detected.
----	--	--------------------------

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **FTSW-RV-01** ASME CATEGORY: B-A

ASME CODE IWB-2500-4 ASME ITEM NUMBER: B1.30
 FIGURE:

CONFIGURATION: VESSEL FLANGE TO UPPER SHELL WELD % CRV ACHIEVED: 87.5 %

PROCEDURES: PDI-ISI-254 MATERIAL CS/CS
 WDI-SSP-1063

PDI TECHNIQUE
 USED: YES

45° LONGITUDINAL WAVE DUAL SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	100%	50%	VESSEL CONFIGURATION AT THE FLANGE
CW	100%	50%	VESSEL CONFIGURATION AT THE FLANGE
UP	100%	100%	
DOWN	100%	100%	

45° LONGITUDINAL WAVE SINGLE ELEMENT SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	100%	50%	VESSEL CONFIGURATION AT THE FLANGE
CW	100%	50%	VESSEL CONFIGURATION AT THE FLANGE
UP	100%	100%	
DOWN	100%	100%	

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

45° SHEAR WAVE SCAN

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
CCW	100%	50%	VESSEL CONFIGURATION AT THE FLANGE
CW	100%	50%	VESSEL CONFIGURATION AT THE FLANGE
UP	100%	100%	
DOWN	100%	100%	

0°, 6° in, 6° out, 12° out and 16° out LONGITUDINAL WAVE MANUAL SCANS FROM FLANGE FACE

SCAN	% WELD VOLUME ACHIEVED	% VOLUME ACHIEVED	LIMITATION
DOWN	100%	100%	


The coverage achieved was the maximum extent practical due to the vessel configuration at the flange and the results are representative of the entire weld.

UT COMBINED COVERAGE = 87.5 %

**EXAMINATION RESULTS: ONE RECORDABLE INDICATION
 ALLOWABLE PER ASME SECTION XI 1989, IWB-3510-1**


SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

VESSEL ROLLOUT
DRAWING #1




SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FLANGE TO SHELL
DRAWING #4



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FLANGE TO SHELL
DRAWING #5




Parallel Scan Index = 0.5°
 Perp. Scan Index = 0.37° (0.5°)

Perform parallel scans @ both
 0° and 180° sled rotations
 to maximize coverage

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FLANGE TO SHELL
DRAWING #5a



WELD - FTSW-RV-01

Parallel Scan Index = 0.5'
 Perp. Scan Index = 0.37' (0.5')

Perform parallel scans @ both
 0° and 180° sled rotations
 to maximize coverage.

SHEARON HARRIS - CQL	
WesDyne International	
SHEET TITLE	FLANGE TO SHELL
EXAM PROGRAM PLAN	
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE NOTED	SHEET 5a OF 23

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-020
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **FTHW-RV-18** ASME CATEGORY: B-A

ASME CODE IWB-2500-5 ASME ITEM NUMBER: B1.40
 FIGURE:

CONFIGURATION: HEAD TO FLANGE WELD % CRV ACHIEVED: 71.7 %

PROCEDURES: ISI-210-T MATERIAL CS/CS
 WDI-STD-146
 WDI-STD-088

PDI TECHNIQUE
 USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	65%	VESSEL HEAD CONFIGURATION AT THE FLANGE

45° and 60° SHEAR WAVE ½ VEE SCAN


SCAN	% VOLUME ACHIEVED	LIMITATION
CIRCUMFERENTIAL SCAN	65%	VESSEL HEAD CONFIGURATION AT THE FLANGE
AXIAL SCAN	85%	VESSEL HEAD CONFIGURATION AT THE FLANGE

UT COMBINED COVERAGE = 71.7 %

EXAMINATION RESULTS: NO INDICATIONS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

REACTOR VESSEL TOP HEAD TO FLANGE WELD
MATERIAL AND WELD IDENTIFICATION SHEET



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FTHW-RV-18 SKETCH "A"


Date: 5/1/00 2107-00-002

SUPPLEMENTAL ULTRASONIC SHEET

FTHW-RV-18 F.A.B.C.

PAGE 4 OF 17

SKETCH "A" 0° COVERAGE



- EXAM AREA
- (A B C D) = 7" x 10" = 70 in²
 - 0° EXAM
 - (E B F D) = 7" x 6.5" = 45.5 in²
 - 45.5 / 70 = 65%

EXAMINER James Collier LEVEL II DATE 4/21/00
 EXAMINER Michael Pitt LEVEL II DATE 4/21/00

Michael Pitt 4/21/00

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FTHW-RV-18 SKETCH "B"


Date: 5/26/00 2107-001002

SUPPLEMENTAL ULTRASONIC SHEET

FTHW-RV-18 F.A.B.C.

PAGE 5 OF 17

SKETCH "B" CIRC EXAM COVERAGE 45° + 60°



EXAM. AREA
• (ABCD) = $7" \times 10" = 70 \text{ in}^2$
CIRC EXAM.
• (EBFD) = $7" \times 6.5" = 45.5 \text{ in}^2$
• $45.5 / 70 = 6.5\%$

EXAMINER Jim Collier LEVEL II DATE 4/26/00
EXAMINER Michael S. Pelt LEVEL II DATE 4/26/00

Deals Memorandum 4/26/00

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FTHW-RV-18 SKETCH "C"


Data sheet 2107-001001x

SUPPLEMENTAL ULTRASONIC SHEET

FTHW-RV-18.F.A.B.C.

PAGE 6 OF 17

SKETCH "C" AXIAL EXAM OF WELD 45° & 60°



EXAM AREA
 • (A B C D) = 7" x 10" = 70 in²

WELD AREA
 • (E F G H) = 7 [(3" + 1.4") / 2] = 15.4 in²
 • 15.4 / 70 = 0.22
 • WELD AREA = 22% OF EXAM AREA

EXAMINER *[Signature]* LEVEL II DATE 4/21/00
 EXAMINER *[Signature]* LEVEL IC DATE 4/21/00

Edel M... 4/21/00

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FTHW-RV-18 SKETCH "D"


Data sheet 2105-00-002

SUPPLEMENTAL ULTRASONIC SHEET

FTHW-RV-18(A,B,C)

PAGE 7 OF 17

SKETCH "D" AXIAL EXAM OF BASE METAL 45" x 60"



- EXAM AREA
• (A B C D) = 7" x 10" = 70 in²
- BASE METAL AREA
• (A E C G) + (F B H D) = 70 in² - WELD AREA = 54.6 in²
• BASE METAL = 78% OF EXAM AREA.

EXAMINER *Jim Collins* LEVEL II DATE 4/21/00
EXAMINER *Michael P. ...* LEVEL II DATE 4/21/00

Paul M... 4/24/00

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FTHW-RV-18 COVERAGE CALC.

Data sheet 2107-00-002

SUPPLEMENTAL ULTRASONIC SHEET

FTHW-RV-18 F.A.B.C.

PAGE 8 OF 12

AXIAL EXAM COVERAGE CALC.

WELD: REQUIREMENT = 2 ANGLES X 2 DIRECTIONS = 4 BEAMS

EXAM AREA (SKETCH C) = 15.4 in²

- 4 BEAMS (E'F'J') = $(3.2 \times 1.4) / 2 = 2.24 \text{ in}^2$
 $2.24 / 15.4 = 15\%$ $15\% \times 4/4 \text{ BEAMS} = 15\%$
- 3 BEAMS (E'J'K) = $(4 \times 0.8) / 2 = 3.20 \text{ in}^2$
 $3.20 / 15.4 = 21\%$ $21\% \times 3/4 \text{ BEAMS} = 16\%$
- 2 BEAMS (E'K'G'H) = $100\% - 15\% - 21\% = 64\%$
 $64\% \times 2/4 \text{ BEAMS} = 32\%$
- TOTAL = $15\% + 16\% + 32\% = 63\%$

BASE METAL: REQUIREMENT = ANY COMBINATION ANGLES/DIRECTIONS = 2 BEAMS

EXAM AREA (SKETCH D) = 54.6 in²

- UNEXAMINED (AEL) = $(3.5 \times 2) / 2 = 3.5 \text{ in}^2$
 $3.5 / 54.6 = 6\%$
- 1 BEAM (LEM) = $(5 \times 1) / 2 = 2.5 \text{ in}^2$
 $2.5 / 54.6 = 5\%$ $5\% \times 1/2 \text{ BEAMS} = 2.5\%$
- 2 BEAMS = (MECG) + (FBND) = $100\% - 6\% - 5\% = 89\%$
- TOTAL = $2.5\% + 89\% = 91.5\%$

EXAMINER J. Collins LEVEL II DATE 4/21/00
 EXAMINER Michael R. Pitt LEVEL II DATE 4/21/00
Deal Michael 4/21/00

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-020
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

FTHW-RV-18 COVERAGE SUMMARY

Data sheet 2107-00-002

SUPPLEMENTAL ULTRASONIC SHEET

FTHW-RV-18.F.A.B.C.

PAGE 7 OF 17

COVERAGE SUMMARY

0° (SKETCH "A") = 6.5%

CIRC EXAM (SKETCH B) = 6.5%

AXIAL EXAM

• WELD (SKETCH "C") = 6.3%

• BASE METAL (SKETCH "D") = 91.5%

• TOTAL = (6.3% × 2.2%) + (91.5% × 7.8%) = 8.5%

Total Coverage = $\frac{6.5 + 6.5 + 8.5}{3} = 7.17\%$

EXAMINER Simon Crotter LEVEL II DATE 4/21/00
EXAMINER Michael P. Blum LEVEL II DATE 4/21/00

Del. Mardak 4/21/00

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category B-D, Item B3.110, Pressurizer Nozzle-to-Vessel Welds

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Welds are Pressurizer Nozzle to Head Welds.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). Nozzle to vessel welds are not conducive to two-sided volumetric examinations due to nozzle configurations.
1b	NDE Equipment	Information follows in Enclosure.
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). HNP is proposing to volumetrically UT examine the pressurizer nozzle welds NTHW-08/-09/-10/-11/-12/-13 to the maximum extent possible in accordance with the Inservice Inspection Program schedule. In addition, the welds are subject to visual (VT-2) tests during each refueling outage.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (“0° Longitudinal Wave Scan”, “45° and 60° Shear Wave ½ Vee Scan”).
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure Attachments 1 through 5.
1e	Results of the Examination Indications / No Indications	No indications detected.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-021
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **NTHW-08** ASME CATEGORY: B-D
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B3.110
 FIGURE:
 CONFIGURATION: PRESSURIZER NOZZLE-TO-VESEL WELD % CRV ACHIEVED: 66 %
 PROCEDURES: ISI-210-T MATERIAL CS/CS
 PDI TECHNIQUE USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	79.6%	NOZZLE TO SHELL CONFIGURATION AND THE PRESSURIZER HEATER OBSTRUCTIONS

45° and 60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
PARALLEL SCAN	79.6%	NOZZLE TO SHELL CONFIGURATION AND THE PRESSURIZER HEATER OBSTRUCTIONS
AXIAL SCAN	38.7%	NOZZLE TO SHELL CONFIGURATION AND THE PRESSURIZER HEATER OBSTRUCTIONS

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the pressurizer heater obstructions in place and the results are representative of the entire weld.


UT COMBINED COVERAGE = 66 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH KBA 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

PRESSURIZER SURGE NOZZLE TO HEAD WELD
CONFIGURATION IDENTIFICATION SHEET



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-021
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **NTHW-09** ASME CATEGORY: B-D
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B3.110
 FIGURE:
 CONFIGURATION: PRESSURIZER NOZZLE-TO-VESEL WELD % CRV ACHIEVED: 67.14 %
 PROCEDURES: ISI-210-T MATERIAL CS/CS
 PDI TECHNIQUE USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	66.31%	NOZZLE TO SHELL CONFIGURATION

45° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.85%	NOZZLE TO SHELL CONFIGURATION

60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.26%	NOZZLE TO SHELL CONFIGURATION

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the results are representative of the entire weld.


UT COMBINED COVERAGE = 67.14 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH AEROTECH 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

PRESSURIZER NOZZLE TO HEAD WELDS
CONFIGURATION IDENTIFICATION SHEET



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-021
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **NTHW-10** ASME CATEGORY: B-D

ASME CODE IWB-2500-8 ASME ITEM NUMBER: B3.110
 FIGURE:

CONFIGURATION: PRESSURIZER NOZZLE-TO- VESSEL WELD % CRV ACHIEVED: 67.14 %

PROCEDURES: ISI-210-T MATERIAL CS/CS

PDI TECHNIQUE
 USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	66.31%	NOZZLE TO SHELL CONFIGURATION

45° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.85%	NOZZLE TO SHELL CONFIGURATION

60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.26%	NOZZLE TO SHELL CONFIGURATION

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the results are representative of the entire weld.


UT COMBINED COVERAGE = 67.14 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH AEROTECH 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

PRESSURIZER NOZZLE TO HEAD WELDS
CONFIGURATION IDENTIFICATION SHEET
(TYPICAL)



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-021
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **NTHW-11** ASME CATEGORY: B-D
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B3.110
 FIGURE:
 CONFIGURATION: PRESSURIZER NOZZLE-TO- VESSEL WELD % CRV ACHIEVED: 67.14 %
 PROCEDURES: ISI-210-T MATERIAL CS/CS
 PDI TECHNIQUE
 USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	66.31%	NOZZLE TO SHELL CONFIGURATION

45° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.85%	NOZZLE TO SHELL CONFIGURATION

60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.26%	NOZZLE TO SHELL CONFIGURATION

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the results are representative of the entire weld.


UT COMBINED COVERAGE = 67.14 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH AEROTECH 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

PRESSURIZER NOZZLE TO HEAD WELDS
CONFIGURATION IDENTIFICATION SHEET
(TYPICAL)



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-021
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **NTHW-12** ASME CATEGORY: B-D
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B3.110
 FIGURE:
 CONFIGURATION: PRESSURIZER NOZZLE-TO- VESSEL WELD % CRV ACHIEVED: 67.14 %
 PROCEDURES: ISI-210-T MATERIAL CS/CS
 PDI TECHNIQUE USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	66.31%	NOZZLE TO SHELL CONFIGURATION

45° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.85%	NOZZLE TO SHELL CONFIGURATION

60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.26%	NOZZLE TO SHELL CONFIGURATION

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the results are representative of the entire weld.


UT COMBINED COVERAGE = 67.14 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH AEROTECH 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

PRESSURIZER NOZZLE TO HEAD WELDS
CONFIGURATION IDENTIFICATION SHEET
(TYPICAL)



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-021
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **NTHW-13** ASME CATEGORY: B-D
 ASME CODE IWB-2500-8 ASME ITEM NUMBER: B3.110
 FIGURE:
 CONFIGURATION: PRESSURIZER NOZZLE-TO- VESSEL WELD % CRV ACHIEVED: 67.14 %
 PROCEDURES: ISI-210-T MATERIAL CS/CS
 PDI TECHNIQUE USED: YES

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	66.31%	NOZZLE TO SHELL CONFIGURATION

45° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.85%	NOZZLE TO SHELL CONFIGURATION

60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	67.26%	NOZZLE TO SHELL CONFIGURATION

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the results are representative of the entire weld.


UT COMBINED COVERAGE = 67.14 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH AEROTECH 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

PRESSURIZER NOZZLE TO HEAD WELDS
CONFIGURATION IDENTIFICATION SHEET
(TYPICAL)



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENTS:

- A. Supplemental Ultrasonic Sheets NTHW-08
- B. Supplemental Ultrasonic Sheets NTHW-09
- C. Supplemental Ultrasonic Sheets NTHW-10
- D. Supplemental Ultrasonic Sheets NTHW-11
- E. Supplemental Ultrasonic Sheets NTHW-12
- F. Supplemental Ultrasonic Sheets NTHW-13

Enclosure 5 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT A
Supplemental Ultrasonic Sheets
NTHW-08
(4 Pages)

SUPPLEMENTAL ULTRASONIC SHEET

PAGE 4 OF 7

Sketch "A" 0°, 45° //, 60° //, coverage

NTFW 08

"A"

Heater
Nozzle

Pressure
Head


$$\text{Exam Area} = ABCD = (4.6'')(3.55'') + (45'')(4.1'') \\ = 16.51 \text{ in}^2$$

$$0^\circ \text{ \& \parallel exams (ABEF)} \\ = (3.55)(3.7) = 13.14 \text{ in}^2$$

$$\frac{13.14}{16.51} = 79.6\%$$

Dale Mendenhall
4/25/00


NOZZLE



SUPPLEMENTAL ULTRASONIC SHEET

PAGE 5 OF 7

Sketch 'B'



Exam Area (ABCD) = 16.51 in²

WELD Area (RSTU) = 3.55 * (1.05 + 1.9) / 2 = 5.2 in²

⇒ Weld Area = 5.2 / 16.51 = 31.5% of Exam Area

⇒ Base material = 100 - 31.5 = 68.5% of Exam Area

Weld Requirement = 2 angles x 2 Directions
= 4 Beams

4 Beams = 0%

3 Beams = 0%

2 Beams = RPNP = 1.6 in² = 30.8%
(30.8%) (2/4 Beams) = 15.4%

1 Beam = (PGHO) + (FNM) = 1.03 + .05 = 1.08 in²
1.08 / 5.2 = 20.8% (2.08) (1/4 Beams) = 5.2%

Total weld = 15.4% + 5.2% = 20.6%

Dale Mundak 4/25/00

SUPPLEMENTAL ULTRASONIC SHEET

PAGE 6 OF 7


Sketch "C"

NTHW 08
"C"

Heater
NOZZLE

Pressurizer
Head

Exam Area (ABCD) = 16.51 in^2
 Base material exam area = 11.3 in^2
 Base material requirement = any 2 Beams
 2 BEAMS = (N05K) + (EPR) = $.9 \text{ in}^2 + .38 \text{ in}^2 = 1.28 \text{ in}^2$
 $\frac{1.28}{11.3} = 11.3\%$
 1 Beam = (EGP) + (H0XCJ)
 = $.16 \text{ in}^2 + 1.38 \text{ in}^2 = 1.54 \text{ in}^2$
 $\frac{1.54}{11.3} = 13.6\%$ (13.6)(1/2 Beams) = 6.8%
 Total Base metal = 18.1%



Dale Mendenhall 4/25/00

NOZZLE

SUPPLEMENTAL ULTRASONIC SHEET

PAGE 7 OF 7

Total Coverage

NTTW 08
Coverage
Summary

0° - sketch "A" - 79.6%

Parallel Exams - sketch "A" - 79.6%

Axial Exams - sketches B & C

Weld	20.6%
B.M.	18.1%
<hr/>	
	38.7%

66%
AV

$$\Rightarrow \text{Total Coverage} = \frac{79.6 + 79.6 + 38.7}{3} = 70\%$$

Dale Murdock 4/25/00

Enclosure 5 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT B
Supplemental Ultrasonic Sheets
NTHW-09
(10 Pages)

NES, Inc.

WELD LENGTH = 40.05 in

REQUIRED EXAM VOLUME = (ABEF)(40.05) = 637.2 in³

VOLUME NOT EXAMINED = (ABCD)(40.05) = 214.7 in³

% INCOMPLETE = $\left[\frac{214.7}{637.2} \right] 100 = 33.7\%$

% COMPLETE = 100 - 33.7 = 66.3


DATA SHEET # 210-98-01

PAGE 2 OF 15

ISO # 1-ISI-PER-1

WELD # NTHW-09

0°



ABEF = 15.91 in²
 ABCD = 5.36 in²
 CDEF = 10.55 in²

09
 Profile
 Sketch

11/25/98
 DATE

CB 11-19-98

EXAMINER Glen R. Dawson LEVEL II DATE 10/30/98
 EXAMINER John M. ... LEVEL III DATE 10/31/98
 REVIEWER Scott ... LEVEL III DATE 11-3-98

P 3 of 15
 ISO # 1-ISI-PZR-1
 DATA SHT # 210-98-01

WELD NO.: NTHW-09	0 DEGREE ONLY												
TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %	
HEAD SIDE BASE MATERIAL AXIAL COVERAGE	40.05	40.05	100.00%	0	0.00%	15.91	10.55	66.31%	0	0.00%	66.31%	0.00%	66.31%

Adunk Block, CPL LII, 11-19-98

0° Coverage Summary
 09

ANN REVIEW
 ANN EBA/kl
 DATE 11-25-98

NES, Inc.

DATA SHEET # 210-5⁹⁸ 01
PAGE 6 OF 15^{30.11.98}
ISO# 1-ESI-PZR-1
WELD# NTHW-09


45° SCAN TOWARD HEAD

CIRCUMFERENCE = 40.055"
3.214 SQ IN = TOTAL WELD AREA
12.696 SQ IN = TOTAL BASE MATERIAL WRV AREA
15.91 SQ IN = TOTAL WRV AREA

RESTRICTED LENGTH = 40.055"

4.02 SQ IN = ~~UNRESTRICTED~~ WELD AREA SCANNED
~~ON 11-19-98~~
2.812 SQ IN = ~~RESTRICTED~~ WELD AREA NOT SCANNED
~~ON 11-19-98~~

3.160 SQ IN = ~~UNRESTRICTED~~ BASE MATERIAL WRV AREA
~~ON 11-19-98~~ SCANNED
9.536 SQ IN = ~~RESTRICTED~~ BASE MATERIAL WRV AREA
~~ON 11-19-98~~ NOT SCANNED



APPROVED
DATE 11-25-98

45°
Toward
Head

EXAMINER T. Hub LEVEL II DATE 10/30/98
EXAMINER [Signature] LEVEL II DATE 10/30/98
REVIEWER [Signature] LEVEL III DATE 11-3-98

NES, Inc.

DATA SHEET # 210-98 ²⁰¹ ₁₁₋₁₁₋₉₈

PAGE 2 OF 15

ISO# 1-ISI-P2R-1

WELD# NTHW-09

CIRCUMFERENCE = 40.055

45° SCAN TOWARD NOZZLE

EXIT POINT

CF

RESTRICTED LENGTH = 40.055

3.214 = TOTAL WELD SQ IN

12.696 = TOTAL BASE MATERIAL WRV SQ IN

15.91 = TOTAL WRV SQ IN

NOT SCANNED ^{QWB 11-19-98}

1.62 SQ IN = RESTRICTED BASE MATERIAL WRV

11.076 SQ IN = ^{SCANNED} UNRESTRICTED BASE MATERIAL WRV _{QWB 11-19-98}

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

09
45°
Scan
toward
nozzle

DATE 11-25-98

EXAMINER T. Hurl LEVEL II DATE 10/30/98

EXAMINER Tom D. Bug LEVEL II DATE 10/30/98

REVIEWER Scott James LEVEL III DATE 11-3-98


NES, Inc.

45° CIRC

NOZZLE SIDE CIRC

HEAD SIDE CIRC

φ



DATA SHEET # 210-98-01

PAGE 8 OF 15

ISO# HSL-PZR-1

WELD# NTHW-09

CIRCUMFERENCE = 40.055"
 HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 40.055"

5.297 SQ IN = RESTRICTED ^{DATE 11-19-98} BASE MATERIAL
 WRV AREA NOT SCANNED

1.177 SQ IN = UNRESTRICTED ^{DATE 11-19-98} BASE MATERIAL
 WRV AREA

NOZZLE SIDE WELD IS 100% COMPLETE

HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

DATE 11-25-98
 BY DBA

09
 45°
 CIRC
 SEAM

EXAMINER T. Huh LEVEL II DATE 10/30/98
 EXAMINER D.B. [Signature] LEVEL II DATE 10/30/98
 REVIEWER Scott Larson LEVEL III DATE 11-3-98

COVERAGE CALCULATION SHEET

P.90F15
 ISO# 1-ISI-PZR-1
 DATA SHEET 210-98-01

WELD NO.:NTHW-09	45 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	40.055	40.055	100.00%	0	0.00%	12.686	0.16	24.89%	0	0.00%	24.89%	0.00%	24.89%
TOWARD HEAD WELD AXIAL COVERAGE	40.055	40.055	100.00%	0	0.00%	3.214	0.402	12.51%	0	0.00%	12.51%	0.00%	12.51%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	40.055	40.055	100.00%	0	0.00%	12.686	11.076	87.24%	0	0.00%	87.24%	0.00%	87.24%
TOWARD NOZZLE WELD AXIAL COVERAGE	40.055	0	0.00%	40.055	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	40.055	0	0.00%	40.055	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	40.055	0	0.00%	40.055	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	40.055	0	0.00%	40.055	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	40.055	40.055	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.85%

Chwin Burk CPL LTD, 11-19-98


60
 450
 Coverage Summary

ANN REVIEW
 ANN SBM
 DATE 12598

NES, Inc.

DATA SHEET # 210-98-01
PAGE 12 OF 15
ISO# 1-ISI-P2A-1
WELD# NTHW-09

60° SCAN TOWARD HEAD
FROM NOZZLE SIDE



CIRCUMFERENCE = 40.055
3.214 SQIN = TOTAL WELD AREA
12.696 SQIN = TOTAL BASE MATERIAL WRV AREA
15.91 SQIN = TOTAL WRV AREA

RESTRICTED LENGTH = 40.055

489 SQIN = UNRESTRICTED WELD AREA
2.725 SQIN = RESTRICTED WELD AREA NOT SCANNED

1.856 SQIN = UNRESTRICTED BASE MATERIAL WRV AREA
10.84 SQIN = RESTRICTED BASE MATERIAL WRV AREA
NOT SCANNED
11-19-98

API REVIEW
DATE 11-25-98

Paul S Blecker
11-19-98

11-19-98


EXAMINER Paul S Blecker LEVEL II DATE 10/30/98
EXAMINER N/A LEVEL N/A DATE N/A
REVIEWER [Signature] LEVEL III DATE 11-3-98

NES, Inc.

DATA SHEET # 210-98-01
PAGE 13 OF 15
ISO# I-ESI-P2A-1
WELD# NTHW-09

60° SCAN TOWARD NOZZLE
FROM HEAD SIDE

CIRCUMFERENCE = 40.055"
3.214 = TOTAL WELD SQ IN
12.696 = TOTAL BASE MATERIAL WRV SQ IN
15.91 = TOTAL WRV SQ IN



RESTRICTED LENGTH IS ~~47.124~~ ^{40.055} ~~40.055~~ " ^{DATE 11-19-98}
NOT SCANNED ^{DATE 11-19-98}
1.26 SQ IN = RESTRICTED BASE MATERIAL WRV
11.436 SQ IN = UNRESTRICTED BASE MATERIAL WRV
SCANNED ^{DATE 11-19-98}

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

3.15" ANII REVIEW
ANII B. D. [Signature]
DATE 11-25-98

Scan
Toward
Nozzle
000
09

CoB
11-19-98

EXAMINER Paul S. Bleche LEVEL II DATE 10/30/98
EXAMINER N/A LEVEL N/A DATE N/A
REVIEWER [Signature] LEVEL III DATE 11-3-98

NES, Inc.

60° CIRC SCAN

DATA SHEET # 210-98-1
 PAGE 14 OF 15
 ISO# 1-ISI-PZR-1
 WELD# NTHW-09

NOZZLE SIDE CIRC

HEAD SIDE CIRC

CIRCUMFERENCE = 40.055"
 HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 40.055"

NOT SCANNED ENB 11-19-98
 5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA

SCANNED ENB 11-19-98
 1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA

NOZZLE SIDE WELD IS 100% COMPLETE

HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

60° CIRC SCAN

ENB 11-19-98

CIVIL REVIEWED
 P.S.M.
 11-25-98

EXAMINER Paul S Blecha LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott L... LEVEL III DATE 11-3-98

DOB 11-19-98
 15
 PL# of 15

ISS# 1-ISE-PER-1
 DATA SHEET # 210-98-01

REVISIONS

WELD NO.: NTHW-09	60 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	GROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	40.055	40.055	100.00%	0	0.00%	12.690	1.856	14.62%	0	0.00%	14.62%	0.00%	14.62%
TOWARD HEAD WELD AXIAL COVERAGE	40.055	40.055	100.00%	0	0.00%	3.214	0.489	15.21%	0	0.00%	15.21%	0.00%	15.21%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	40.055	40.055	100.00%	0	0.00%	12.698	11.438	90.08%	0	0.00%	90.08%	0.00%	90.08%
TOWARD NOZZLE WELD AXIAL COVERAGE	40.055	0	0.00%	40.055	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	40.055	0	0.00%	40.055	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	40.055	0	0.00%	40.055	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	40.055	0	0.00%	40.055	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	40.055	40.055	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.25%

John Black, CP III, 11-19-98

Coverage Summary
 600
 09

88A
 DATE 11-25-98

Enclosure 5 to SERIAL: HNP-09-095


SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT C
Supplemental Ultrasonic Sheets
NTHW-10
(10 Pages)

NES, Inc.

WELD LENGTH = 47.1 in
 REQUIRED EXAM VOLUME = (ABEF) (47.1) = 799.4 in³
 VOLUME NOT EXAMINED = (ABCD) (47.1) = 252.5 in³
 % INCOMPLETE = $\left[\frac{252.5}{799.4} \right] 100 = 33.7\%$
 % COMPLETE = 100 - 33.7 = 66.3%

DATA SHEET # 210-98-0
 PAGE 2 OF 15
 ISO# I-JSJ-P2R-1
 WELD# NTHW-10



ABEF = 15.91 in²
 ABCD = 5.36 in²
 CDEF = 10.55 in²

0°

EXAMINER REVIEWED
 BY SPD
 DATE 11-25-98

EXAMINER Edmund R. Donagan LEVEL II DATE 10-30-98
 EXAMINER Dale M. Mudgett LEVEL III DATE 10/31/98
 REVIEWER Scott L. ... LEVEL III DATE 11-3-98

NES, Inc. 11-19-98

P 3 of 15

ISO 1-ISE-PCR-1

DATA SHEET# 210-98-02

WELD NO.: NTHW-10	0 DEGREE ONLY												
TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %	
HEAD SIDE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	15.91	10.55	66.31%	0	0.00%	66.31%	0.00%	66.31%


John Black, CPA III, 11-19-98

AUTH REVIEW
 AUTH *SB Dyer*
 DATE 11-25-98

NES, Inc.

DATA SHEET # 210-9-22-98-02 ^{SLU-11-98}
PAGE 6 OF 15
ISO# I-ISI-PZR-1
WELD# NTHW-10

45° SCANT TOWARD HEAD



CIRCUMFERENCE = 47.124"
 3.214 SQ IN = TOTAL WELD AREA
 12.696 SQ IN = TOTAL BASE MATERIAL WRV AREA
 15.91 SQ IN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124
 .402 SQ IN = UNRESTRICTED WELD AREA
 2.812 SQ IN = RESTRICTED WELD AREA

3.160 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
 9.536 SQ IN = RESTRICTED BASE MATERIAL WRV AREA

FINAL REVIEW
 BY EB/A
 DATE 11-25-98

DB
 11-19-98

EXAMINER T. Huda LEVEL II DATE 10/30/98
 EXAMINER Joseph D. Bury LEVEL II DATE 10/30/98
 REVIEWER Scott Law LEVEL III DATE 11-3-98


NES, Inc.

4.4.91 2010 15.6.00

DATA SHEET # 210-98-202 ⁹²¹¹⁷¹⁻⁹⁸
PAGE 7 OF 15
ISO# 1-ISI-P2R-1
WELD# NTHW-10

CIRCUMFERENCE = 47.124"

45° SCAN TOWARD NOZZLE



3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

RESTRICTED LENGTH = 47.124"

3.214 = TOTAL WELD SQ IN.

12.696 = TOTAL BASE MATERIAL WRV SQ IN.

15.91 = TOTAL WRV SQ IN.

1.62 SQ IN = RESTRICTED BASE MATERIAL WRV

11.076 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

ANTI REVIEW
ANTI EB
DATE 11-25-98

CB 11-19-98

EXAMINER T. H. H. LEVEL II DATE 10/30/98
EXAMINER Don B. LEVEL II DATE 10/30/98
REVIEWER Scott LEVEL III DATE 11-3-98

NES, Inc.


0441 9810 6600

45° CIRC SCAN

NOZZLE SIDE CIRC

HEAD SIDE CIRC

⊕



DATA SHEET # 210-98-402
 PAGE 8 OF 15
 ISO# 1-ISI-P2R-1
 WELD# NTHW-10

CIRCUMFERENCE = 47.124
 HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124
 5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA
 1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
 NOZZLE SIDE WELD IS 100% COMPLETE
 HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

AMN REVIEW
 AMN MB/A
 DATE 11-25-98

CB
 11-19-98

EXAMINER T. Hulse LEVEL II DATE 10/30/98
 EXAMINER Tom D. B... LEVEL II DATE 10/30/98
 REVIEWER Scott... LEVEL III DATE 11-3-98

COVERAGE CALCULATION SHEET

P9 of 15

ISO # 1-ISI-PZR-1

DATA SHEET# 210-98-02

WELD NO.: NTHW-10	45 DEGREE												
TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %	
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.630	3.16	24.89%	0	0.00%	24.89%	0.00%	24.89%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	1.214	0.402	12.51%	0	0.00%	12.51%	0.00%	12.51%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.695	11.076	87.24%	0	0.00%	87.24%	0.00%	87.24%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	8.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.85%


Chwick Block CPL III, 11-19-98

REVIEWED BY
 DATE 11-25-98

NES, Inc.

60° SCAN TOWARD HEAD

DATA SHEET # 210-98-02
PAGE 12 OF 15
ISO# 1-ISI-PZR-1
WELD# NTHW-10



CIRCUMFERENCE = 47.124"
3.214 SQIN = TOTAL WELD AREA
12.696 SQIN = TOTAL BASE MATERIAL WRV AREA
15.91 SQIN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"

.489 SQIN = UNRESTRICTED WELD AREA
2.725 SQIN = RESTRICTED WELD AREA

1.856 SQIN = UNRESTRICTED BASE MATERIAL WRV AREA
10.84 SQIN = RESTRICTED BASE MATERIAL WRV AREA

INSPECTED BY
DATE 11-25-98

db
11-19-98

EXAMINER Paul S. Blecker LEVEL II DATE 10/30/98
EXAMINER N/A LEVEL N/A DATE N/A
REVIEWER Scott Lamm LEVEL III DATE 11-3-98


NES, Inc.

6057 8810 8600

DATA SHEET # 210-98-02
PAGE 13 OF 15
ISO# 1-ISI-P2R-1
WELD# NTHW-10

60° SCAN TOWARD NOZZLE

CIRCUMFERENCE = 47.124"
3.214 = TOTAL WELD SQ IN
12.696 = TOTAL BASE MATERIAL WRV SQ IN
15.91 = TOTAL WRV SQ IN



RESTRICTED LENGTH IS 47.124"

1.26 SQ IN = RESTRICTED BASE MATERIAL WRV
11.436 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

SB
DATE: 11-25-98

SB
11-19-98

EXAMINER Paul S Blech LEVEL II DATE 11/30/98
EXAMINER N/A LEVEL N/A DATE N/A
REVIEWER Scott Lauer LEVEL III DATE 11-3-98


NES, Inc.

60° CIRC SCAN

NOZZLE SIDE CIRC

HEAD SIDE CIRC

Q



DATA SHEET # 210-98-02

PAGE 14 OF 15

ISO# 1-ESI-P2P-1

WELD# NTHW-10

CIRCUMFERENCE = 47.124"
 HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124"

5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA

1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA

NOZZLE SIDE WELD IS 100% COMPLETE

HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

AMT REV 1
 AMT 830
 DATE 11-23-98

QMB
11-19-98

EXAMINER Paul S Blecha LEVEL II DATE 10/30/98

EXAMINER N/A LEVEL N/A DATE N/A

REVIEWER Scott LEVEL III DATE 11-3-98

WELD NO.: NTHW-10	60 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	0	100.00%	0.00%	12.596	1.856	14.62%	0	0.00%	14.62%	0.00%	14.62%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	0	100.00%	0.00%	3.214	0.489	15.21%	0	0.00%	15.21%	0.00%	15.21%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	0	100.00%	0.00%	12.596	11.436	90.08%	0	0.00%	90.08%	0.00%	90.08%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	47.12	0.00%	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	47.12	0.00%	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	47.12	0.00%	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	47.12	0.00%	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	0	100.00%	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.25%

Edwin Beck, CAP LIII, 11-19-98

11-25-98

Enclosure 5 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION


ATTACHMENT D
Supplemental Ultrasonic Sheets
NTHW-11
(10 Pages)

NES, Inc.

WELD LENGTH = 47.1 in
 REQUIRED EXAM VOLUME = (ABEF)(47.1) = 749.4 in³
 VOLUME NOT EXAMINED = (ABCD)(47.1) = 252.5 in³
 % INCOMPLETE = $\left[\frac{252.5}{749.4} \right] 100 = 33.7\%$
 % COMPLETE = 100 - 33.7 = 66.3%

DATA SHEET # 210-98-03
 PAGE 2 OF 15
 ISO# 1-SSI-PER-1
 WELD# NTHW-11

0°



ABEF = 15.91 in²
 ABCD = 5.36 in²
 CDEF = 10.55 in²

ANII REVIEW
 APR 1998
 DATE 11-25-98

EXAMINER Edmund Dargatzis LEVEL II DATE 10-30-98
 EXAMINER Wally Mendenhall LEVEL III DATE 10/30/98
 REVIEWER Scott Lane LEVEL III DATE 11-3-98

P30F15

ISO # 1-ISI-PLR-1

DATA SHEET # 210-98-05

WELD NO. JTHW-11	0 DEGREE ONLY												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
HEAD SIDE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	15.91	10.55	66.31%	0	0.00%	66.31%	0.00%	66.31%

Edwin Black CPL III, 11-19-98

AMR REVIEW
 DATE 11-25-98
EDW


NES, Inc.

DATA SHEET # 210-9 803
PAGE 6 OF 15
ISO# 1-ISI-P2R-1
WELD# NTHW-11

45° SCANT TOWARD HEAD

CIRCUMFERENCE = 47.124"
3.214 SQ IN = TOTAL WELD AREA
12.696 SQ IN = TOTAL BASE MATERIAL WRV AREA
15.91 SQ IN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"
.402 SQ IN = UNRESTRICTED WELD AREA
2.812 SQ IN = RESTRICTED WELD AREA
3.160 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
9.536 SQ IN = RESTRICTED BASE MATERIAL WRV AREA



3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

DATE 11-25-98

ChB
11-19-98

EXAMINER T. H. H. LEVEL II DATE 10/30/98
EXAMINER Tom D. B. LEVEL II DATE 10/30/98
REVIEWER Scott Larson LEVEL III DATE 11-3-98

NES, Inc.

0 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99

DATA SHEET # 210-98-03

PAGE 2 OF 15

ISO# 1-ISI-PZR-1

WELD# NTHW-11

CIRCUMFERENCE = 47.124

45° SCAN TOWARD NOZZLE

EXIT POINT

Q

RESTRICTED LENGTH = 47.124

3.214 = TOTAL WELD SQ IN

12.696 = TOTAL BASE MATERIAL WRV SQ IN

15.91 = TOTAL WRV SQ IN

1.62 SQ IN = RESTRICTED BASE MATERIAL WRV

11.076 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35"

3.35"


3.2"

3.15"

3.15"

3.15"

3.15"



EXAMINER T. Huh LEVEL III DATE 10/30/98

EXAMINER D. B. LEVEL II DATE 10/30/98

REVIEWER John Law LEVEL III DATE 11-3-98

QNB
11-19-98


NES, Inc.

11-18-98

45° CIRC

NOZZLE SIDE CIRC

HEAD SIDE CIRC



DATA SHEET # 210-98-03
 PAGE 8 OF 15
 ISO# 1-ISI-A2A-1
 WELD# NTHW-11

CIRCUMFERENCE = 47.124
 HEADSIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124
 5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA
 1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
 NOZZLE SIDE WELD IS 100% COMPLETE
 HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

ANTI REVERS
 REVISED 11/25/98
 DATE 11-25-98

EXAMINER T. Hurl LEVEL II DATE 10/30/98
 EXAMINER Tom D. B... LEVEL II DATE 10/30/98
 REVIEWER Scott... LEVEL III DATE 11-3-98

P 9 of 15

ISO# 1-ISE-PZR-1

DATA SHT# 210-98-03

210-98-03

WELD NO.:NTHW-11	45 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	3.16	24.89%	0	0.00%	24.89%	0.00%	24.89%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	3.214	0.402	12.51%	0	0.00%	12.51%	0.00%	12.51%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	11.078	87.24%	0	0.00%	87.24%	0.00%	87.24%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZ SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.85%


Edwin Black, CPL LIII, 11-19-98

ANN REVIEW
 APR 830 JF
 DATE 11-25-98

NES, Inc.

60° SCAN TOWARD HEAD

DATA SHEET # 210-98- SC 11-11-98
03
 PAGE 12 OF 15
 I.S.O.# 1-IST-PZR-1
 WELD# NTHW-11



CIRCUMFERENCE = 47.124"
 3.214 SQIN = TOTAL WELD AREA
 12.696 SQIN = TOTAL BASE MATERIAL WRV AREA
 15.91 SQIN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"

.489 SQIN = UNRESTRICTED WELD AREA
 2.725 SQIN = RESTRICTED WELD AREA

1.856 SQIN = UNRESTRICTED BASE MATERIAL WRV AREA
 10.84 SQIN = RESTRICTED BASE MATERIAL WRV AREA

DATE 11/25/98
 DATE 11/25/98

duB
11-11-98

EXAMINER Paul S Blecha LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott Lauer LEVEL III DATE 11-3-98

NES, Inc.

60° SCAN TOWARD NOZZLE

DATA SHEET # 210-98-0 ⁵²¹¹⁻¹¹⁻⁸⁸ 03
PAGE 13 OF 15
ISO# 1-ISI-P2R-1
WELD# NTHW-11

CIRCUMFERENCE = 47.124"

3.214 = TOTAL WELD SQ IN
12.696 = TOTAL BASE MATERIAL WRV SQ IN
15.91 = TOTAL WRV SQ IN

RESTRICTED LENGTH IS 47.124"

1.26 SQ IN = RESTRICTED BASE MATERIAL WRV
11.436 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

SBK
11-25-98

OB
11-19-98

EXAMINER Paul S Bleker LEVEL II DATE 10/30/98
EXAMINER N/A LEVEL N/A DATE N/A
REVIEWER Scott Lannon LEVEL III DATE 11-3-98


NES, Inc.

60 CIRC SCAN

NOZZLE SIDE CIRC

HEAD SIDE CIRC

Q



DATA SHEET # 210-98-0 ⁴ 11-11-98
 PAGE 14 OF 15
 ISO# 1-ISI-P2R-1
 WELD# NTHW-11

CIRCUMFERENCE = 47.124"
 HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124"

5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA

1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA

NOZZLE SIDE WELD IS 100% COMPLETE

HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

INSPECTED
 BY Paul S. Blecha
 DATE 11-25-98

GF
 11-19-98

EXAMINER Paul S Blecha LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott L... LEVEL III DATE 11-3-98

PIS of 15
 ISO# 4-ISI-P2R-1
 DATA SHEET 210-93-03

WELD NO.-NTHW-51	90 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.698	1.856	14.62%	0	0.00%	14.62%	0.00%	14.62%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	3.214	0.489	15.21%	0	0.00%	15.21%	0.00%	15.21%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.098	17.436	90.08%	0	0.00%	90.08%	0.00%	90.08%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.25%

John M. Black, CPL III, 11-19-98

DATE 11-25-98

Enclosure 5 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT E
Supplemental Ultrasonic Sheets
NTHW-12
(10 Pages)

NES, Inc.

POST 0310 6800

WELD LENGTH = 47.1 in

REQUIRED EXAM VOLUME = (ABEF) (47.1) = 749.4 in³


VOLUME NOT EXAMINED = (ABCD) (47.1) = 252.5 in³

% INCOMPLETE = $\left[\frac{252.5}{749.4} \right] 100 = 33.7\%$

% COMPLETE = 100 - 33.7 = 66.3%

DATA SHEET # 210-98-0
 PAGE 2 OF 15
 ISO# 1-55-PCR-1
 WELD# NTHW-12

0°



ABEF = 15.91 in²
 ABCD = 5.36 in²
 CDEF = 10.55 in²

FINAL REVIEW
 BY EBD
 DATE 11-25-98

EXAMINER Charles R. Donovon LEVEL II DATE 10-30-98
 EXAMINER Dale Mungro LEVEL IV DATE 11-30-98
 REVIEWER Scott Lauer LEVEL III DATE 11-2-98

EB
 11-19-98

WELD NO.: NTHW-12	0 DEGREE ONLY												TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %					
HEAD SIDE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	15.91	10.55	66.31%	0	0.00%	66.31%	0.00%	66.31%		

Adwin Black, CPL UTI, 11-19-98

DATE: 11-25-98
 [Signature]
 [Stamp]

8041 8010 65011


NES, Inc.

DATA SHEET # 210-98 04
PAGE 6 OF 15
ISO# 1-ISI-PZR-1
WELD# NTHW-12

45° SCANT TOWARD HEAD

CIRCUMFERENCE = 47.124"
3.214 SQ IN = TOTAL WELD AREA
12.696 SQ IN = TOTAL BASE MATERIAL WRV AREA
15.91 SQ IN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"
.402 SQ IN = UNRESTRICTED WELD AREA
2.812 SQ IN = RESTRICTED WELD AREA
3.160 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
9.536 SQ IN = RESTRICTED BASE MATERIAL WRV AREA



3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

ANR REVIEW
DATE 11-25-98

QFB
11-19-98

EXAMINER T. H. H. LEVEL II DATE 10/30/98
EXAMINER J. B. B. LEVEL II DATE 10/30/98
REVIEWER J. L. L. LEVEL III DATE 11-2-98


NES, Inc.

DATA SHEET # 210-98-04
PAGE 2 OF 15
ISO# 1-ISI-PZR-1
WELD# NTAW-12

SC 11-11-98

CIRCUMFERENCE = 47.124"

45° SCAN TOWARD NOZZLE



RESTRICTED LENGTH = 47.124"

3.214 = TOTAL WELD SQ IN

12.696 = TOTAL BASE MATERIAL WRV SQ IN

15.91 = TOTAL WRV SQ IN

1.62 SQ IN = RESTRICTED BASE MATERIAL WRV

11.076 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

REVIEWED
 BY SB
 DATE 11-25-98


dwB
11-9-98

EXAMINER T. Hule LEVEL II DATE 10/30/98
 EXAMINER Tom D. Big LEVEL II DATE 10/30/98
 REVIEWER Scott Lane LEVEL III DATE 11-2-98

NES, Inc.

45° CIRC SCAN

DATA SHEET # 210-98-09
PAGE 8 OF 15
ISO# 1-151P2R1
WELD# NTHW-12



CIRCUMFERENCE = 47.124
HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
HEAD SIDE WELD AREA = 1.607 SQ IN
NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124
5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA
1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
NOZZLE SIDE WELD IS 100% COMPLETE
HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

FBNT
11-25-98

dB
11-19-98

EXAMINER T. Huh LEVEL II DATE 10/30/98
EXAMINER J. D. B... LEVEL II DATE 10/30/98
REVIEWER [Signature] LEVEL III DATE 11-2-98

P 9 of 15

ISO# 1-ISI-PZR-1

DATA SHEET# 210-98-04

WELD NO.: NTHW-12	45 DEGREE													
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %	
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.636	3.18	24.89%	0	0.00%	24.89%	0.00%	24.89%	
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	3.214	0.402	12.51%	0	0.00%	12.51%	0.00%	12.51%	
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.898	11.076	87.24%	0	0.00%	87.24%	0.00%	87.24%	
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%	
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%	
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%	
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%	
NOZZ SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%	
TOTAL WELD VOLUME COVERAGE													87.85%	

Adwin Black, CPL LITE, 11-19-98

FINAL REVIEW
 APPROVED
 DATE 11-25-98

NES, Inc.

60° SCAN TOWARD HEAD


DATA SHEET # 210-98-1 ⁵⁶¹¹⁻¹¹⁻⁹⁸ 04
 PAGE 12 OF 15
 ISO# 1-ESI-PZR-1
 WELD# NTHW-12

CIRCUMFERENCE = 47.124"
 3.214 SQ IN = TOTAL WELD AREA
 12.696 SQ IN = TOTAL BASEMATERIAL WRV AREA
 15.91 SQ IN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"

4.89 SQ IN = UNRESTRICTED WELD AREA
 2.725 SQ IN = RESTRICTED WELD AREA

1.856 SQ IN = UNRESTRICTED BASEMATERIAL WRV AREA
 10.84 SQ IN = RESTRICTED BASEMATERIAL WRV AREA



ANTI REVIEW
 ANTI EBD
 DATE 11-25-98

EXAMINER Paul S. Blecke LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott Lane LEVEL III DATE 11-2-98

CSB
 11-17-98

NES, Inc.

60° SCAN TOWARD NOZZLE

DATA SHEET # 210-98-06 09521141-98
 PAGE 13 OF 15
 ISO# 1-ISI-PZR-1
 WELD# NTHW-12


CIRCUMFERENCE = 47.124"

3.214 = TOTAL WELD SQ IN
 12.696 = TOTAL BASE MATERIAL WRV SQ IN
 15.91 = TOTAL WRV SQ IN

RESTRICTED LENGTH IS 47.124"

1.26 SQ IN = RESTRICTED BASE MATERIAL WRV
 11.436 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
 SCAN TOWARD NOZZLE



3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

ANII REVIEW
 ANII SPD/E
 DATE 11-25-98

JP
 11-19-98

EXAMINER Paul S Blecha LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott L... LEVEL III DATE 11-2-98

NES, Inc.


00000000000000000000

60° CIRC SCAN

NOZZLE SIDE CIRC

HEAD SIDE CIRC

Q



SE 11-11-98
 DATA SHEET # 210-98-2 04
 PAGE 14 OF 15
 ISO# 1-ISI-P2R-1
 WELD# NTHW-12

CIRCUMFERENCE = 47.124"
 HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124"
 5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA
 1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
 NOZZLE SIDE WELD IS 100% COMPLETE
 HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

ANTI REVERSE
 SB
 DATE 11-25-98

CB
 11-19-98

EXAMINER Paul S Blecker LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER [Signature] LEVEL III DATE 11-2-98

PIS of IS

ISOA I-ISI-PZR-1

DATA SHEET# 210-98-0A

WELD NO. NTHW-12	60 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	1.856	14.62%	0	0.00%	14.62%	0.00%	14.62%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	3.214	0.489	15.21%	0	0.00%	15.21%	0.00%	15.21%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	11.438	90.08%	0	0.00%	90.08%	0.00%	90.08%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.26%

Edwin Black, CR III, 11-19-98

DATE RECEIVED
 BY: SPB/Day
 DATE: 11-25-98

Enclosure 5 to SERIAL: HNP-09-095

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-021
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

ATTACHMENT F
Supplemental Ultrasonic Sheets
NTHW-13
(10 Pages)

NES, Inc.

WELD LENGTH = 47.1 in

REQUIRED EXAM VOLUME = (ABEF) (47.1) = 749.4 in³

VOLUME NOT EXAMINED = (ABCD) (47.1) = 252.5 in³

% INCOMPLETE = $\left[\frac{252.5}{749.4} \right] 100 = 33.7\%$

% COMPLETE = 100 - 33.7 = 66.3%


DATA SHEET # 210-98-05

PAGE 2 OF 15

ISO# 1-ISO-PER-1

WELD# NTHW-13

0°



ABEF = 15.91 in²
 ABCD = 5.36 in²
 CDEF = 10.55 in²

AMT REVIEW
 AMT EB/LE
 DATE 11-25-98

EXAMINER Chuck Rowley LEVEL II DATE 10-30-98

EXAMINER Nely Murok LEVEL III DATE 10/30/98

REVIEWER Joe Lane LEVEL III DATE 11-2-98

CLB
11-19-98

P3 of 15

ISO# 1-ISI-PZR-1

DATA SHEET # 210-98-05

WELD NO./NTHW-13	0 DEGREE ONLY												
TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %	
HEAD SIDE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	15.81	10.55	66.31%	0	0.00%	66.31%	0.00%	66.31%

Edwin Black, CAPT III, 11-19-98

INSPECTED
 DATE 11-25-98


NES, Inc.

DATA SHEET # 200-9 ^{SC11-11-98} ~~1505~~
PAGE 6 OF 15
ISO# 1-151-P2R-1
WELD# NTHW-13

45° SCANT TOWARD HEAD

CIRCUMFERENCE = 47.124"
3.214 SQ IN = TOTAL WELD AREA
12.696 SQ IN = TOTAL BASE MATERIAL WRV AREA
15.91 SQ IN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"
.402 SQ IN = UNRESTRICTED WELD AREA
2.812 SQ IN = RESTRICTED WELD AREA
3.160 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
9.536 SQ IN = RESTRICTED BASE MATERIAL WRV AREA



3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

KNOW REVIEWER
APPROVED EBD
DATE 11-25-98

DEB
11-19-98


EXAMINER T. Hnd LEVEL IV DATE 10/30/98
EXAMINER Joseph D. Bug LEVEL II DATE 10/30/98
REVIEWER John J. Russo LEVEL III DATE 11-2-98

NES, Inc.

0000000000

DATA SHEET # 210-98 ⁵²⁻¹¹⁻¹¹⁻⁹⁸ / 05
 PAGE 7 OF 15
 ISO# 1-ISI-P2A1
 WELD# NTHW-13
 CIRCUMFERENCE = 47.124"

45° SCAN TOWARD NOZZLE



RESTRICTED LENGTH = 47.124"

3.214 = TOTAL WELD SQ IN

12.696 = TOTAL BASE MATERIAL WRV SQ IN

15.91 = TOTAL WRV SQ IN

1.62 SQ IN = RESTRICTED BASE MATERIAL WRV

11.076 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

APII REVIEW
 ANDI SP/Date
 DATE 11-25-98

CUB
11-19-98

EXAMINER T. Hark LEVEL II DATE 10/30/98
 EXAMINER Jerry D. B... LEVEL II DATE 10/30/98
 REVIEWER John... LEVEL III DATE 11-2-98

5011-11-98

DATA SHEET # 210-98 / 05
PAGE 8 OF 15
ISO# 1-ISI-PZR-1
WELD# NTHW 13

NES, Inc.

45° CIRC SCAN

NOZZLE SIDE CIRC

HEAD SIDE CIRC

CF

CIRCUMFERENCE = 47.124"
HEAD SIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
HEAD SIDE WELD AREA = 1.607 SQ IN
NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124"

5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA

1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA

NOZZLE SIDE WELD IS 100% COMPLETE

HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

QUALITY REVIEW
BY PB Duff
DATE 11-25-98

dB
11-19-98

EXAMINER T. Hurl LEVEL II DATE 10/30/98
EXAMINER David B... LEVEL II DATE 10/30/98
REVIEWER ... LEVEL III DATE 11-2-98

P 9 of 15

ISO # 1-ISI-PZR-1

DATA SHEET # 210-98-05

WELD NO.:NTHW-13	45 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED RESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	3.16	24.89%	0	0.00%	24.89%	0.00%	24.89%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	3.214	0.402	12.51%	0	0.00%	12.51%	0.00%	12.51%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	11.076	87.24%	0	0.00%	87.24%	0.00%	87.24%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.85%


Adwin Beck, CAP III, 11-19-98

ANII REVIEW
 ANII P/S/yt
 DATE 11-25-98

NES, Inc.

60° SCAN TOWARD HEAD

DATA SHEET # 210-98- ^{SC 11-11-98} 05
 PAGE 12 OF 15
 ISO# 1-ESI-PZA-1
 WELD # NTHW-13



CIRCUMFERENCE = 47.124"
 3.214 SQIN = TOTAL WELD AREA
 12.696 SQIN = TOTAL BASEMATERIAL WRV AREA
 15.91 SQIN = TOTAL WRV AREA

RESTRICTED LENGTH = 47.124"

4.89 SQIN = UNRESTRICTED WELD AREA
 2.725 SQIN = RESTRICTED WELD AREA

1.856 SQIN = UNRESTRICTED BASEMATERIAL WRV AREA
 10.84 SQIN = RESTRICTED BASEMATERIAL WRV AREA

ANII REVIEW
ANII <u>EB Deyle</u>
DATE <u>11-25-98</u>

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

EXAMINER Paul S. Blaska LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott Lancia LEVEL III DATE 11-2-98

JB
11-19-98

NES, Inc.

60° SCAN TOWARD NOZZLE

DATA SHEET # 210-98-05
 PAGE 13 OF 15
 ISO# 1-ISI-PZP-1
 WELD# NTHU-13

CIRCUMFERENCE = 47.124"

3.214 = TOTAL WELD SQ IN

12.696 = TOTAL BASE MATERIAL WRV SQ IN

15.91 = TOTAL WRV SQ IN


RESTRICTED LENGTH IS 47.124"

1.26 SQ IN = RESTRICTED BASE MATERIAL WRV

11.436 SQ IN = UNRESTRICTED BASE MATERIAL WRV

3.214 SQ IN = TOTAL WELD AREA 100% COMPLETE
SCAN TOWARD NOZZLE

EST. 8810 6810



3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

ANII REVIEW
ANII <u>PS</u>
DATE <u>11-25-98</u>

chb
11-9-98

EXAMINER Paul S. Blecha LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott L... LEVEL III DATE 11-2-98

NES, Inc.


0 1 2 3 4 5 6 7 8 9 10

60° CIRC SCAN

NOZZLE SIDE CIRC.

HEAD SIDE CIRC

Q



SL 11-11-98
 DATA SHEET # 210-98-a 05
 PAGE 14 OF 15
 ISO# 1-ESI-PZR-1
 WELD# NTHW-13

CIRCUMFERENCE = 47.124
 HEADSIDE AREA = 6.222 SQ IN BASE MATERIAL WRV
 NOZZLE SIDE AREA = 6.474 SQ IN BASE MATERIAL WRV
 HEAD SIDE WELD AREA = 1.607 SQ IN
 NOZZLE SIDE WELD AREA = 1.607 SQ IN

RESTRICTED LENGTH = 47.124
 5.297 SQ IN = RESTRICTED BASE MATERIAL WRV AREA
 1.177 SQ IN = UNRESTRICTED BASE MATERIAL WRV AREA
 NOZZLE SIDE WELD IS 100% COMPLETE
 HEAD SIDE WELD + BASE MATERIAL WRV IS 100% COMPLETE

3.35" 3.35" 3.2" 3.15" 3.15" 3.15" 3.15"

AMH REVIEW
 BY SB
 DATE 11-25-98

DB
 11-19-98

EXAMINER Paul S Blecker LEVEL II DATE 10/30/98
 EXAMINER N/A LEVEL N/A DATE N/A
 REVIEWER Scott Larson LEVEL III DATE 11-2-98

P 15 of 15

ISO# 1-ISI-PZR-1

DATA SHEET 210-98-05

WELD NO.: NTHW-13	60 DEGREE												
	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED (INCHES)	LENGTH EXAMINED RESTRICTED %	WELD LENGTH EXAMINED UNRESTRICTED (INCHES)	WELD LENGTH EXAMINED UNRESTRICTED %	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL UNRESTRICTED COVERAGE (LENGTH X CROSS SECTION) %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD HEAD BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	1.858	14.62%	0	0.00%	14.62%	0.00%	14.62%
TOWARD HEAD WELD AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	3.214	0.489	15.21%	0	0.00%	15.21%	0.00%	15.21%
TOWARD NOZZLE BASE MATERIAL AXIAL COVERAGE	47.12	47.12	100.00%	0	0.00%	12.696	11.438	90.08%	0	0.00%	90.08%	0.00%	90.08%
TOWARD NOZZLE WELD AXIAL COVERAGE	47.12	0	0.00%	47.12	100.00%	3.214	0	0.00%	3.214	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
HEAD SIDE CIRC COVERAGE BASE MATERIAL	47.12	0	0.00%	47.12	100.00%	6.222	0	0.00%	6.222	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE WELD	47.12	0	0.00%	47.12	100.00%	1.607	0	0.00%	1.607	100.00%	0.00%	100.00%	100.00%
NOZZLE SIDE CIRC COVERAGE BASE MATERIAL	47.12	47.12	100.00%	0	0.00%	6.474	1.177	18.18%	0	0.00%	18.18%	0.00%	18.18%
TOTAL WELD VOLUME COVERAGE													67.26%

Robert Black, CPL LIII, 11-19-98

ANN REVIEW
 DATE 12-25-98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO: 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R1-022
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category B-B, Item B2.40, Tubesheet-to-Head Weld

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Welds is Tubesheet-to-Head Weld.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	Information follows in Enclosure.
1b	NDE Equipment	Information follows in Enclosure.
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). HNP is proposing to volumetrically UT examine the steam generator Tubesheet-to-head weld, II-SG-001SGA-TSTHW-06-1, to the maximum extent possible in accordance with the Inservice Inspection Program schedule. In addition, the subject weld will be subject to system pressure tests during each refueling outage.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (0° Longitudinal, 45° Shear, 60° Shear).
1e	Results of the Examination Indications / No Indications	No indications detected.
4a	Please clarify whether all three steam generator tubesheet-to-head welds were examined. Because the licensee was unable to meet the ASME Code-required inspection volume on tubesheet-to-head weld II-SG-001SGA-TSTHW-06-1, if the other tubesheet-to-head welds were examined, please describe whether the same coverage area limitations apply to these similar welds on the remaining two steam generators.	All three of the steam generators have the same configuration / limitation. Since B-B, B2.40 Note 1 only requires one per similar vessel, the examination was performed on one of the three steam generators. (Note: These steam generators were new in 2001).

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-022
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **II-SG-001SGA-TSTHW-06-1** ASME CATEGORY: B-B

ASME CODE IWB-2500-6 ASME ITEM NUMBER: B2.40
 FIGURE:

CONFIGURATION: TUBESHEET TO HEAD WELD % CRV ACHIEVED:
 WELD 70.106%
 BASE METAL 74.20%

PROCEDURES: NDEP-0450 MATERIAL CS/CS

PDI TECHNIQUE USED: NO

BASE METAL AND WELD METAL VOLUME COVERAGE

SCAN	% VOLUME ACHIEVED	% WELD VOLUME ACHIEVED	LIMITATION
0°	72.74%	76.6%	Lower lateral support pads
45°	73.38%	68.852%	Lower lateral support pads
60°	76.48%	64.867%	Lower lateral support pads
TOTAL	74.2%	70.106%	Lower lateral support pads

The coverage achieved was the maximum extent practical with the four lower lateral support pad obstructions in place and the results are representative of the entire weld.

UT COMBINED COVERAGE:


Total base metal volume coverage 74.20 %
 Total weld volume coverage 70.11 %

EXAMINATION RESULTS: NO RECORDABLE INDICATIONS


NDE EQUIPMENT: STAVELEY, SONIC-136, WITH KBA 1.0", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" x 1.0", 2.25MHZ, SHEAR 45° AND KBA 0.5" x 1.0", 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-022
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

STEAM GENERATOR "A"



ITEM NO.	DESCRIPTION	MATERIAL SPEC.
01	CHANNEL HEAD	SA-508 CL. 3a
02	TUBE PLATE	SA-508 CL. 3a
03	STUB BARREL	SA-533 TYPE B CL. 2
04	LOWER SHELL BARREL "A"	SA-533 TYPE B CL. 2
05	LOWER SHELL BARREL "B"	SA-533 TYPE B CL. 2
06	TRANSITION CONE	SA-508 CL. 3a
07	UPPER SHELL BARREL "H"	SA-533 TYPE B CL. 2
08	UPPER SHELL BARREL "J"	SA-533 TYPE B CL. 2
09	UPPER HEAD (WITH INTEGRAL NOZZLE)	SA-508 CL. 3a
10	FEEDWATER INLET NOZZLE 16" O.D.	SA-508 CL. 3a
11	AUXILIARY FEEDWATER NOZZLE 7" O.D.	SA-508 CL. 3a
12	SECONDARY SIDE MANWAYS (2)	SA-508 CL. 3a
13	LOWER SHELL TRUNNIONS	SA-508 CL. 3a
14	UPPER SHELL TRUNNIONS	SA-508 CL. 3a
15	PRIMARY NOZZLES (2)	SA-508 CL. 3a
16	PRIMARY MANWAYS (2)	SA-508 CL. 3a



7	THIS DRAWING HAS BEEN ELECTRONICALLY SIGNED AND THE SIGNATURE MEETS THE REQUIREMENTS AND IS DEEMED TO BE VALID FOR THE PURPOSES OF THIS DRAWING.	ELECTRONICALLY SIGNED
REV	DESCRIPTION	APPROVED
Progress Energy		
PLANT: SHEARON HARRIS - UNIT 1 SCALE: N/A		
TITLE: STEAM GENERATOR 'A'		
DRAWN BY: 1-ISI-SG-1		

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-022
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-SG-001SGA-TSTHW-06-1
COVERAGE SUMMARY
WELD MATERIAL



**Determination of Percent Coverage for
 UT Examinations - Vessels**

Site/Unit: <u>HNP / 1</u>	Procedure: <u>NDEP-0450</u>	Outage No.: <u>IRFO-12</u>
Summary No.: <u>H-03849</u>	Procedure Rev.: <u>0</u>	Report No.: <u>UT-04-023</u>
Workscope: <u>ISI</u>	Work Order No.:	Page: <u>4</u> of <u>6</u>

WELD MATERIAL

0 deg Planar

Scan 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for 0 deg

45 deg

Scan 1 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for Scan 1

Scan 2 76.600 % Length X 59.540 % volume of length / 100 = 45.608 % total for Scan 2

Scan 3 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for Scan 3

Scan 4 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for Scan 4

Add totals and divide by # scans = 58.852 % total for 45 deg

Other deg 60°

Scan 1 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for Scan 1

Scan 2 76.600 % Length X 38.730 % volume of length / 100 = 29.667 % total for Scan 2

Scan 3 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for Scan 3

Scan 4 76.600 % Length X 100.000 % volume of length / 100 = 76.600 % total for Scan 4

Add totals and divide by # scans = 64.867 % total for 60° deg

Percent complete coverage

Add totals for each angle and scan required and divide by # of angles to determine:

70.106 % Total for complete exam.

Note:

Supplemental coverage may be achieved by use of other angles / methods. When used, the coverage for volume not obtained with angles as noted above shall be calculated and added to the total to provide the percent total for the complete examination.

Site Field Supervisor: MWD

Date: 11/1/04

This Document is a QA Record

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-022
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-SG-001SGA-TSTHW-06-1
COVERAGE SUMMARY
BASE MATERIAL



Supplemental Report

Report No.: UT-04-023
 Page: 5 of 6

Summary No.: H-03849

Sketch or Photo: Y:\Shared\Ideas\HNP_Data\DataSheet_Info\UT-04-023-3.tif

<u>BASE MATERIAL</u>				
<u>0 deg Planar</u>				
Scan:	<u>76.6</u>	% Length X:	<u>94.96</u>	% volume of length / 100 = <u>72.74</u> % total for 0 deg
<u>45 deg</u>				
Scan 1:	<u>76.6</u>	% Length X:	<u>99.13</u>	% volume of length / 100 = <u>75.93</u> % total for Scan 1
Scan 2:	<u>N/A</u>	% Length X:	<u>N/A</u>	% volume of length / 100 = <u>N/A</u> % total for Scan 2
Scan 3:	<u>76.6</u>	% Length X:	<u>100</u>	% volume of length / 100 = <u>76.6</u> % total for Scan 3
Scan 4:	<u>76.6</u>	% Length X:	<u>100</u>	% volume of length / 100 = <u>76.6</u> % total for Scan 4
Add totals and divide by # scans = <u>73.30</u> % total for 45 deg				
<u>60</u>				
Scan 1:	<u>76.6</u>	% Length X:	<u>99.54</u>	% volume of length / 100 = <u>76.24</u> % total for Scan 1
Scan 2:	<u>N/A</u>	% Length X:	<u>N/A</u>	% volume of length / 100 = <u>N/A</u> % total for Scan 2
Scan 3:	<u>76.6</u>	% Length X:	<u>100</u>	% volume of length / 100 = <u>76.6</u> % total for Scan 3
Scan 4:	<u>76.6</u>	% Length X:	<u>100</u>	% volume of length / 100 = <u>76.6</u> % total for Scan 4
Add totals and divide by # scans = <u>76.48</u> % total for <u>60</u> deg				
<u>Percent complete coverage</u>				
Add totals for each angle and scan required and divide by # of angles to determine: <u>74.2</u> % Total for complete exam				

Note:

Supplemental coverage may be achieved by use of other angles / methods. When used, the coverage for volume not obtained with angles as noted above shall be calculated and added to the total to provide the percent total for the complete examination.

Site Field Supervisor: [Signature] Date: 11/1/04

This Document is a QA Record

This Document is a QA Record

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R1-022
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-SG-001SGA-TSTHW-06-1
LIMITATION SKETCH


Limitation Record

NGG Nuclear Generator Group

Site/Unit: HNP 1 Procedure: NDEP-0460 Outage No.: IRFO-12
 Summary No.: H-03849 Procedure Rev.: 0 Report No.: UT-04-023
 Workscope: ISI Work Order No.: _____ Page: 6 of 6

Description of Limitation:

Sketch of Limitation: Y:\Shared\ideal\HNP_Data\DataSheet_Info\UT-04-023-4.tif



Limitations removal requirements:

Radiation field:

Examiner	Level	Signature	Date	Reviewer	Signature	Date
Lester, Robert	II-PDI	<i>Robert Lester</i>	10/25/2004	Michael P. Dugan (TI UT Level III)	<i>Michael P. Dugan</i>	10/29/2004
N/A	N/A			Edwin M. Black	<i>Edwin M. Black</i>	10/27/2004
Other	N/A			ANII Review		
N/A	N/A			Larry Jones ANII	<i>Larry Jones</i>	10/27/2004

This Document is a QA Record:

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category C-A, Item C1.10, Shell Circumferential Welds

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Weld is Pressure Retaining Welds in Pressure Vessels.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). Weld configuration (flange to shell) and obstructions (flange bolting) prevent 100 percent volumetric examination to be performed during inservice inspection activities.
1b	NDE Equipment	Information follows in Enclosure.
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). HNP is proposing to volumetrically UT examine the restricted areas of Weld RHRACSW-02 to the maximum extent possible in accordance with the Inservice Inspection Program schedule. In addition, this weld is subject to visual (VT-2) system leakage testing during each refueling period. To supplement the volumetric examination, a 70 degree ½ vee shear wave UT examination was performed. A code compliant surface examination (PT) was also performed, although not required by code.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (“45° Shear Wave ¾ Vee Scan”).
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure.
1e	Results of the Examination Indications / No Indications	Information follows in Enclosure.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-009
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **II-RHR-01RHRA-CSW-02** ASME CATEGORY: C-A

ASME CODE IWC-2500-1 ASME ITEM NUMBER: C1.10
 FIGURE:

CONFIGURATION: SHELL CIRCUMFERENTIAL WELDS % CRV ACHIEVED: 66.50

PROCEDURES: ISI-211T MATERIAL SS/SS

PDI TECHNIQUE USED: NO

45° SHEAR WAVE ¼ VEE SCAN

SCAN	% WELD REQUIRED VOLUME ACHIEVED	LIMITATION
AXIAL TOWARD FLANGE	96.01%	FLANGE TO SHELL WELD CONFIGURATION AND INTERFERENCE FROM THE CLOSE PROXIMITY OF THE FLANGE CONNECTION BOLTING
AXIAL TOWARD SHELL	38.63%	FLANGE TO SHELL WELD CONFIGURATION AND INTERFERENCE FROM THE CLOSE PROXIMITY OF THE FLANGE CONNECTION BOLTING
CIRC FLANGE SIDE	31.37%	FLANGE TO SHELL WELD CONFIGURATION AND INTERFERENCE FROM THE CLOSE PROXIMITY OF THE FLANGE CONNECTION BOLTING
CIRC SHELL SIDE	100%	FLANGE TO SHELL WELD CONFIGURATION AND INTERFERENCE FROM THE CLOSE PROXIMITY OF THE FLANGE CONNECTION BOLTING

The coverage achieved was the maximum extent practical with the four core support lug obstructions in place and the results are representative of the entire weld.

A 70° shear wave, ½ vee examination was performed from both sides of the weld for additional coverage but was not listed on the coverage calc.

UT COMBINED COVERAGE = 66.50 %


EXAMINATION RESULTS: GEOMETRIC INDICATION NOTED (ROOT GEOMETRY), NO RECORDABLE INDICATION

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH KBA 0.375", 2.25MHZ, SHEAR 45° AND KBA 0.375", 2.25MHZ, SHEAR 70°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 11 OF 12
COMPONENT DRAWING

DATASHEET # 211-98-001
ISO # 1-IST-RHR-1
PAGE 11 OF 12
WELD # RHRA-CSW-02



ANTI REVIEW
ANTI PUP
DATE 11/1/98


clb 10-18-98 EXAMINER Edwin R. Dwyer LEVEL I DATE 10-20-98
REVIEWER Edwin R. Dwyer L II 10/27/98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-009
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 10 OF 12
INTERFERENCE MEASUREMENT DRAWING

DATA SHEET # 211-98-001
 ISO # 1-IST-RHR-1 NES, Inc.
 PAGE: 10 OF 12
 CIRCUMFERENCE = 123.25"
 TOTAL NUTS = 44

WELD # RHRA-CSW-02
 ① FLANGE SIDE CIRC. COVERAGE .788 SQ IN TOTAL
 ② PIPE SIDE CIRC. COVERAGE .672 SQ IN TOTAL




EXAMINER Edward R. Downer
 REVIEWER John J. ... LEVEL II DATE 10-20-98
 DATE 11-18-98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 4 OF 12
PROFILE SCAN

DATA SHEET # 211-98-001
ISO # 1-ISI-RHR-1 NES, Inc.
PAGE 4 OF 12



WELD # RHRA-CSW-02


① .76 x 1.72 = 1.307 SQ IN
② 1.2 x .25 = 0.3 = 2 = 0.15 SQ IN
③ .3 x .1 = 0.03 = 2 = 0.015 SQ IN
1.307 + 0.15 + 0.015 = 1.472 SQ IN THRU WALL
1.472 TOTAL THRU WALL SQ IN

AMR REVIEW
AMR (D) DeA
DATE 11-14-98

EXAMINER Elmer R. Duvon LEVEL II DATE 10-20-98
REVIEWER DeA 10/23/98 03111898

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 2 OF 12
45° SCAN TOWARD SHELL



DATA SHEET # 211-98-001
ISO # I-IST-RHR-1 NES, Inc.
PAGE 2 OF 12
CIRCUMFERENCE = 1232.5"
TOTAL NUTS = 44
1.5" SCAN LENGTH BETWEEN NUTS

WELD # RHRA-CSW-02
① 45° SCAN TOWARD SHELL BETWEEN NUTS
46.2 RESTRICTED SQIN
1.010 UNRESTRICTED SQIN

ANTI REVIEW
ANTI PSD
DATE 11-19-98

EXAMINER E. J. Donovan LEVEL II DATE 10-20-98
REVIEWER John K. ... 10852 10/27/98 03 11-18-98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 3 OF 12
45° SCAN TOWARD FLANGE

DATA SHEET # 211-98-001

ISO# 1-JSI-RHR-1 NES, Inc.


PAGE 3 OF 12

CIRCUMFERENCE = 123.25"

TOTAL NUTS = 44

1.5" SCAN LENGTH BETWEEN NUTS

WELD# RHRA-CSW-02



① 45° SCAN TOWARD FLANGE UNDER NUTS.

.126 SQ IN RESTRICTED
1.346 SQ IN UNRESTRICTED

② 45° SCAN TOWARD FLANGE BETWEEN NUTS.

IS UNRESTRICTED 100%

ANTI REVIEW
ANTI <u>CSW</u>
DATE <u>7-14-98</u>


EXAMINER Edmund R. Downum LEVEL I DATE 10-20-98

REVIEWER John MacArthur L II 10/22/98 CSW 11-18-98


SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 5 OF 12
CIRCUMFERENTIAL SCAN

DATA SHEET # 211-98-001
ISO# I-JSI-RHR-1 NES, Inc.
PAGE 5 OF 12
CIRCUMFERENCE = 123.25
TOTAL NUTS = 44
1.1" SCAN LENGTH BETWEEN EACH NUT



WELD# RHR-ESW-02
CIRC SCAN FLANGE + SHELL SIDE
SHELL SIDE IS UNRESTRICTED 100%
.672 TOTAL SQ IN

 RESTRICTED AREA CIRC SCAN
.7" OBSTRUCTED BY NUT ON CIRC SCAN
.659 SQ IN RESTRICTED BY NUTS ON FLANGE SIDE
788 TOTAL SQ IN
- .659 SQ IN
729 SQ IN UNRESTRICTED BY NUTS ON FLANGE SIDE

APII REVIEW
APII BSM
DATE 11-19-98


EXAMINER Chuck Davon LEVEL II DATE 10-20-98
REVIEWER Dale ... L III 11-19-98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-009
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 9 OF 12
70° SUPPLEMENTAL SCAN

DATA SHEET # 211-98-001
ISO # I-IST-RHR-1 NES, Inc.
PAGE 9 OF 12

WELD # RHRA-CSW-02



ANN REVIEW
ANN <u>SPD</u>
DATE <u>11-19-98</u>

EXAMINER Clarence R. D... LEVEL II DATE 10-20-98
REVIEWER Dale ... L III DATE 10/27/98 JB 11-18-98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-009
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 12 OF 12
COVERAGE SUMMARY

ISO# 1-151-RHA-1 WELD# RHRA-CSW-02 DATE 11-18-98 DATA SHEET# 211-98-001
151-RHR-154 11-18-98 02 11-18-98 211-98-001
 PAGE 12 OF 12

WELD NO.	RHRA-CSW-02	TOTAL WELD LENGTH (INCHES)	WELD LENGTH EXAMINED (INCHES)	WELD LENGTH RESTRICTED (INCHES)	WELD LENGTH EXAMINED RESTRICTED %	WELD LENGTH UNRESTRICTED %	CROSS SECTION THICKNESS (INCHES)	CROSS SECTION LENGTH (INCHES)	CROSS SECTION AREA (SQ. INCHES)	RESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION RESTRICTED COVERAGE %	UNRESTRICTED CROSS SECTION AREA EXAMINED (SQ. INCHES)	TOTAL CROSS SECTION UNRESTRICTED COVERAGE %	TOTAL RESTRICTED COVERAGE LENGTH X CROSS SECTION %	TOTAL UNRESTRICTED COVERAGE LENGTH X CROSS SECTION %	TOTAL COVERAGE (RESTRICTED + UNRESTRICTED) %
TOWARD FLANGE AXIAL COVERAGE		123.25	57.25	66.00	46.45%	53.55%	0.856	1.72	1.4722	1.346	91.42%	1.4722	100.00%	49.47%	50.53%	98.01%
TOWARD SHELL AXIAL COVERAGE		123.25	57.25	66.00	46.45%	53.55%	0.856	1.72	1.4722	0.00	0.00%	1.07	89.64%	1.99%	91.63%	98.93%
FLANGE SIDE CIRC COVERAGE		123.25	12.65	110.60	10.26%	89.74%	0.818	0.86	0.7028	0.30	42.83%	0.119	13.11%	29.44%	5.90%	37.37%
SHELL SIDE CIRC COVERAGE		123.25	0	123.25	0.00%	100.00%	0.781	0.86	0.67166	0	0.00%	0.67166	100.00%	0.00%	100.00%	100.00%
TOTAL WELD JOINT COVERAGE																98.50%

ANII REVIEW
 ANII SAD
 DATE 11-18-98

11-18-98

EXAMINER Edward R. Dawson LEVEL II DATE 10/26/98
 REVIEWER Dale Muddak TD 10/27/98

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-009
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

DATA SHEET 211-98-001
PAGE 1 OF 1
NDE REPORT SUMMARY

CAROLINA POWER & LIGHT COMPANY		Report No. _____
NDE REPORT/SUMMARY		Page <u>1</u> Of <u>1</u>
Plant/Unit: HNP	Component(s) or Item(s) Examined: II-RHR-01RHRA-CSW-02	
Procedure(s) ISI-211T		
<p>Per the ISI Program Plan, Interval 2, Period 1, Outage 1 (RFO-8), ultrasonic examinations (UT) were performed on the subject weld. These examinations meet the requirements of ASME Section XI, 1989 Ed. and are acceptable to the evaluation criteria of IWA-3000.</p> <p>This weld only requires a UT examination. A code compliant PT was also performed. No indications were detected.</p> <p>The UT exams were performed using procedure, techniques and personnel that meet the requirements of Appendix III of ASME, Section XI. A 45° shear wave, ¼ vcc exam was performed from both sides. For additional coverage, a 70° ¼ vcc shear wave was used to scan on both sides of the welds. Examination is incomplete. Scanning was limited due to the flange to shell weld configuration and interference from the close proximity of the flange connection bolting. Total volume of weld and base material coverage was calculated to be 66.5%. Coverage plots and calculations are attached.</p>		
Reported By: Scott Larson	Level: III	Date: 10-29-98
Reviewed By: <i>John Blank</i>	Title: CPL III	Date: 11-13-98

CPL NDE 30, Rev. 0, 03/94

0099 0188 1683

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-010
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category C-B, Item C2.21, Nozzle-to-Shell Weld

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Weld BIT-01NTHW-03 is the Outlet Nozzle to Head Weld located on the top of the Boron Injection Tank and Weld BIT-01NTHW-04 is the Inlet Nozzle to Head Weld located on the bottom of the Boron Injection Tank.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). Nozzle to vessel welds are not conducive to two-sided volumetric examinations due to nozzle configurations.
1b	NDE Equipment	Information follows in Enclosure.
1b	Alternative Methods	(Reference Relief Request submittal HNP-08-045 Section 6.0). HNP is proposing to volumetrically examine the pressure retaining nozzle to vessel welds BIT-01NTHW-03 and BIT-01NTHW-04 to the maximum extent possible in accordance with the Inservice Inspection Program schedule using Ultrasonic (UT) Examination. A significant portion of the subject welds have been examined, obtaining greater than 75 percent coverage for each nozzle to shell weld. In addition, the welds are subject to visual (VT-2) tests during each refueling outage.
1c	Wave Modality/ Insonification Angles	Information follows in Enclosure (“0° Longitudinal Wave Scan”, 45° Shear Wave ½ Vee Scan”, 60° Shear Wave ½ Vee Scan”).
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure.
1e	Results of the Examination Indications / No Indications	No indications detected.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-010
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

2a	Please state whether the inspection techniques used to examine these welds included refracted longitudinal waves.	All angle beam exams used shear waves, only the 0 degree exam used longitudinal waves. 45 degree shear – ½ V 60 degree shear - ½ V 0 degree longitudinal
2b	Please state the material used (austenitic or ferritic steel) and the wall thickness for each of these components.	Material used is alloy steel – ASTM A 204 Standard Specification for Pressure Vessel Plates, Alloy Steel, Molybdenum (Austenitic); 1.732” Thickness

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-010
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: II-BIT-01NTHW-03 ASME CATEGORY: C-B
II-BIT-01NTHW-04

ASME CODE IWC-2500-4 ASME ITEM NUMBER: C2.21
 FIGURE:

CONFIGURATION: PRESSURE RETAINING % CRV ACHIEVED: 77.14%
 NOZZLE WELDS IN 0 DEGREES 100%
 VESSELS 45 DEGREES 58 %
 60 DEGREES 73.43%

PROCEDURES: NDEP-0448 MATERIAL SS/SS

PDI TECHNIQUE
 USED: NO

0° LONGITUDINAL WAVE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
	100%	

45° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CIRCUMFERENTIAL SCAN HEADSIDE	100%	
CIRCUMFERENTIAL SCAN NOZZLE SIDE	100%	
AXIAL SCAN TOWARD HEAD	0%	NOZZLE TO SHELL CONFIGURATION
AXIAL SCAN TOWARD NOZZLE	32%	NOZZLE TO SHELL CONFIGURATION

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-010
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

60° SHEAR WAVE ½ VEE SCAN

SCAN	% VOLUME ACHIEVED	LIMITATION
CIRCUMFERENTIAL SCAN HEADSIDE	100%	
CIRCUMFERENTIAL SCAN NOZZLE SIDE	100%	
AXIAL SCAN TOWARD HEAD	0%	NOZZLE TO SHELL CONFIGURATION
AXIAL SCAN TOWARD NOZZLE	93.7%	NOZZLE TO SHELL CONFIGURATION

The coverage achieved was the maximum extent practical with the nozzle to shell configuration and the results are representative of the entire weld.


UT COMBINED COVERAGE = 77.14 %

EXAMINATION RESULTS: NO INDICATIONS

NDE EQUIPMENT: STAVELEY, SONIC-136, WITH KBA 0.75", 2.25MHZ, LONGITUDINAL 0°, KBA 0.5" DIA., 2.25MHZ, SHEAR 45° AND KBA 0.5" DIA., 2.25MHZ, SHEAR 60°

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-010
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

BORON INJECTION TANK NOZZLE TO HEAD WELD
CONFIGURATION IDENTIFICATION SHEET
TYPICAL FOR BOTH THE INLET NOZZLE
AND THE OUTLET NOZZLE



SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-010
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-BIT-01NTHW-03
COVERAGE SUMMARY



**Determination of Percent Coverage for
 UT Examinations - Vessels**

Site/Unit: HNP / 1	Procedure: NDEP-0448	Outage No.: IRFO-12
Summary No.: H-01353	Procedure Rev.: 0	Report No.: UT-04-003
Workscope: ISI	Work Order No.:	Page: 2 of 3

0 deg Planar:

Scan 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for 0 deg

45 deg:

Scan 1 100.000 % Length X 32.000 % volume of length / 100 = 32.000 % total for Scan 1

Scan 2 0.000 % Length X 0.000 % volume of length / 100 = 0.000 % total for Scan 2

Scan 3 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 3

Scan 4 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 4

Add totals and divide by # scans = 58.000 % total for 45 deg

Other deg: 60°

Scan 1 100.000 % Length X 93.700 % volume of length / 100 = 93.700 % total for Scan 1

Scan 2 0.000 % Length X 0.000 % volume of length / 100 = 0.000 % total for Scan 2

Scan 3 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 3

Scan 4 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 4

Add totals and divide by # scans = 73.425 % total for 60° deg

Percent complete coverage:

Add totals for each angle and scan required and divide by # of angles to determine:

77.142 % Total for complete exam

Note:

Supplemental coverage may be achieved by use of other angles / methods. When used, the coverage for volume not obtained with angles as noted above shall be calculated and added to the total to provide the percent total for the complete examination.

Site Field Supervisor: Michael W. Blew

Date: 10/22/2004

This Document is a QA Record

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-010
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-BIT-01NTHW-03
ULTRASONIC SKETCH



Supplemental Report


Report No.: **UT-04-003**
Page: **3** of **3**

Summary No.: H-D1353	Examiner: Burgess, Ron	Level: II-PDI	Reviewer: Michael P. Dugan UT Level III	Date: 10/22/2004
	Examiner: N/A	Level: N/A	Site Review: Edwin M. Black	Date: 10/23/2004
	Other: N/A	Level: N/A	ANII Review: Larry Jones ANII	Date: 10/23/2004

Comments: **WELD LOCATION AND DIMENSIONS TAKEN FROM DRAWING #: 1219E77 SHEET 2.**

Sketch or Photo: **Y:\Shared\ddoa\HNP_Data\DataSheet_Info\UT-04-003.tif**

Sketch or Photo:



This Document is a QA Record.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-010
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-BIT-01NTHW-04
COVERAGE SUMMARY



**Determination of Percent Coverage for
 UT Examinations - Vessels**

Site/Unit: HNP 7 1 Procedure: NDEP-0448 Outage No.: IRFO-12
 Summary No.: H-01354 Procedure Rev.: 0 Report No.: UT-04-006
 Workscope: ISI Work Order No.: _____ Page: 3 of 3

0 deg Planar

Scan: 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for 0 deg

45 deg

Scan 1: 100.000 % Length X 32.000 % volume of length / 100 = 32.000 % total for Scan 1

Scan 2: 0.000 % Length X 0.000 % volume of length / 100 = 0.000 % total for Scan 2

Scan 3: 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 3

Scan 4: 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 4

Add totals and divide by # scans = 58.000 % total for 45 deg

Other deg 60

Scan 1: 100.000 % Length X 93.700 % volume of length / 100 = 93.700 % total for Scan 1

Scan 2: 0.000 % Length X 0.000 % volume of length / 100 = 0.000 % total for Scan 2

Scan 3: 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 3

Scan 4: 100.000 % Length X 100.000 % volume of length / 100 = 100.000 % total for Scan 4

Add totals and divide by # scans = 73.425 % total for 60 deg

Percent complete coverage

Add totals for each angle and scan required and divide by # of angles to determine:

77.142 % Total for complete exam

Note:

Supplemental coverage may be achieved by use of other angles / methods. When used, the coverage for volume not obtained with angles as noted above shall be calculated and added to the total to provide the percent total for the complete examination.

Site Field Supervisor: Michael W. Blew

Date: 10/22/2004

This Document is a QA Record

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-010
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-BIT-01NTHW-04
ULTRASONIC SKETCH



Supplemental Report


Report No.: UT-04-006
Page: 2 of 3

Summary No.: H-01354
Examiner: Burgess, Ron Level: II-PDI Reviewer: Michael P. Dugan UT Level III Date: 10/22/2004
Examiner: N/A Level: N/A Site Review: Edwin M. Black Date: 10/23/2004
Other: N/A Level: N/A ANII Review: Larry Jones ANII Date: 10/23/2004

Comments:

Sketch or Photo: Y:\Shared\Ideas\HNP_Data\DataSheet_Info\UT-04-006.tif

Sketch or Photo:



This Document is a QA Record.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-011
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

Examination Category C-C, Item C3.30, Pumps Integrally Welded Attachments

RAI	REQUEST	RESPONSE
1a	Description	(Reference Relief Request submittal HNP-08-045 Section 1.0). Welds II-CSIP-1CSIP-A-WA1, II-CSIP-1CSIP-A-WA2, II-CSIP-1CSIP-A-WA3 and IICSIP-1CSIP-A-WA4 are integral attachments for the support legs located on the bottom of the Charging Safety Injection Pump.
1a	Sketch	Information follows in Enclosure.
1a	Interference/Obstruction	(Reference Relief Request submittal HNP-08-045 Section 5.0). Due to the restricted access caused by the configuration of the components, structural support steel limits, access to one side of the welded attachment, 100 percent surface examinations are limited.
1b	NDE Equipment	Information follows in Enclosure.
1b	Alternative Methods	No additional alternative methods or advanced technologies have been employed.
1c	Wave Modality/ Insonification Angles	Penetrant Examination.
1d	Cross Sectional Coverage Plots to describe the ASME Code coverage	Information follows in Enclosure.
1e	Results of the Examination Indications / No Indications	No recordable indications.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-011
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **II-CSIP-1CSIP-A-WA1** ASME CATEGORY: C-C

ASME CODE IWC-2500-5 ASME ITEM NUMBER: C3.30
 FIGURE:

CONFIGURATION: INTEGRAL ATTACHMENTS FOR VESSELS, PIPING, PUMPS AND VALVES % CRV ACHIEVED: 77.10%

PROCEDURES: NDEP-0201 MATERIAL SS

PDI TECHNIQUE USED: NO

LIQUID PENETRANT EXAMINATION

% VOLUME ACHIEVED	LIMITATION
77.1%	FLANGE MATING SURFACE AND STRUCTURAL STEEL

The coverage achieved was the maximum extent practical with the pump fillet weld configuration and the results are representative of the entire weld.

UT COMBINED COVERAGE = 77.14 %

EXAMINATION RESULTS: NO RECORDABLE INDICATIONS

NDE EQUIPMENT: MAGNAFLUX MATERIALS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-011
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-CSIP-1CSIP-A-WA1
COVERAGE SUMMARY




Supplemental Report

Report No.: PT-04-002
 Page: 2 of 2

Summary No.: H-01858

Sketch or Photo: Y:\Shared\Ideas\HNP_Data\DataSheet_Info\PT-04-002.tif



II-CSIP-1CSIP-A-WA1

Examination completion calculations:

Total examination area:

$5.50'' + 1.0'' + 3.00'' + 4.00'' + 3.00'' + 1.0'' + 5.50'' + 6.00''$ (linear weld dimension) X $1.75''$ (weld width + .50'' either side) = $50.75''^2$

Incomplete examination area:

1. $.75''$ (weld width) + $1.0''$ (.50'' exam area either side of weld) X $6.00''$ (length of incomplete examination area) = $10.5''^2$
2. $20''$ X $5.50''$ = $110''^2$

Total incomplete examination area = $11.60''^2$

Completed percentage:

$11.60''^2 + 50.75''^2 = 22857 = 22.96\%$ incomplete = 77.10% complete.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-011
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **II-CSIP-1CSIP-A-WA2** ASME CATEGORY: C-C

ASME CODE IWC-2500-5 ASME ITEM NUMBER: C3.30
FIGURE:

CONFIGURATION: INTEGRAL ATTACHMENTS FOR VESSELS, PIPING, PUMPS AND VALVES % CRV ACHIEVED: 82.35%

PROCEDURES: NDEP-0201 MATERIAL SS

PDI TECHNIQUE USED: NO

LIQUID PENETRANT EXAMINATION

% VOLUME ACHIEVED	LIMITATION
82.35%	STRUCTURAL STEEL

The coverage achieved was the maximum extent practical with the pump fillet weld configuration and the results are representative of the entire weld.

UT COMBINED COVERAGE = 82.35%

EXAMINATION RESULTS: NO RECORDABLE INDICATIONS

NDE EQUIPMENT: MAGNAFLUX MATERIALS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-011
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-CSIP-1CSIP-A-WA2
COVERAGE SUMMARY




Supplemental Report

Report No.: PT-04-003
 Page: 2 of 2

Summary No.: M-01859

Sketch or Photo: Y:\Shared\Ideas\HNP_Data\DataSheet\Info\PT-04-003.H



II-CSIP-1CSIP-A-WA2

Examination/completion calculation:

Total examination area:

$7.0'' + 1.0'' + 4.00'' + 4.00'' + 4.00'' + 1.0'' + 7.00'' + 6.00''$ (linear weld dimension) X $1.75''$ (weld width + .50'' either side) = $59.5''^2$

Incomplete examination area:

$.75''$ (weld width) + $1.0''$ (.50'' exam area either side of weld) X $6.00''$ (length of incomplete examination area) = $10.5''^2$

Completed percentage:

$10.5''^2 + 59.5''^2 = .1765 = 17.65\%$ incomplete = 82.35% complete.

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-011
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **II-CSIP-1CSIP-A-WA3** ASME CATEGORY: C-C

ASME CODE IWC-2500-5 ASME ITEM NUMBER: C3.30
 FIGURE:

CONFIGURATION: INTEGRAL ATTACHMENTS % CRV ACHIEVED: 80%
 FOR VESSELS, PIPING,
 PUMPS AND VALVES

PROCEDURES: NDEP-0201 MATERIAL SS

PDI TECHNIQUE
 USED: NO

LIQUID PENETRANT EXAMINATION

% VOLUME ACHIEVED	LIMITATION
80%	STRUCTURAL STEEL

The coverage achieved was the maximum extent practical with the pump fillet weld configuration and the results are representative of the entire weld.

UT COMBINED COVERAGE = 80%

EXAMINATION RESULTS: NO RECORDABLE INDICATIONS

NDE EQUIPMENT: MAGNAFLUX MATERIALS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-011
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-CSIP-1CSIP-A-WA3
COVERAGE SUMMARY




Supplemental Report

Report No.: **PT-04-004**
 Page: **2** of **2**

Summary No.: **H-01860**

Sketch or Photo: Y:\Shared\Media\HNP_Data\DataSheet_Info\PT-04-004.tif



II-CSIP-1CSIP-A-WA3

Examination completion calculation:

Total examination area:

$$7.0'' + 1.0'' + 4.00'' + 4.00'' + 2.00'' + 1.0'' + 5.00'' + 6.00'' \text{ (linear weld dimension)} \times 1.75'' \text{ (weld width + .50'' either side)} = 52.50''^2$$

Incomplete examination area:

$$.75'' \text{ (weld width)} + 1.0'' \text{ (.50'' exam area either side of weld)} \times 6.00'' \text{ (length of incomplete examination area)} = 10.50''^2$$

Completed percentage:

$$10.50''^2 + 52.50''^2 = 1.20 = 20\% \text{ incomplete} = 80\% \text{ complete.}$$

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
INSERVICE INSPECTION RELIEF REQUEST 2R2-011
RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

COMPONENT ID: **II-CSIP-1CSIP-A-WA4** ASME CATEGORY: C-C

ASME CODE IWC-2500-5 ASME ITEM NUMBER: C3.30
FIGURE:

CONFIGURATION: INTEGRAL ATTACHMENTS FOR VESSELS, PIPING, PUMPS AND VALVES % CRV ACHIEVED: 75%

PROCEDURES: NDEP-0201 MATERIAL SS

PDI TECHNIQUE USED: NO

LIQUID PENETRANT EXAMINATION

% VOLUME ACHIEVED	LIMITATION
75%	FLANGE MATING SURFACE AND STRUCTURAL STEEL

The coverage achieved was the maximum extent practical with the pump fillet weld configuration and the results are representative of the entire weld.

UT COMBINED COVERAGE = 75%

EXAMINATION RESULTS: NO RECORDABLE INDICATIONS

NDE EQUIPMENT: MAGNAFLUX MATERIALS

SHEARON HARRIS NUCLEAR POWER PLANT, UNIT NO. 1
 DOCKET NO. 50-400/RENEWED LICENSE NO. NPF-63
 INSERVICE INSPECTION RELIEF REQUEST 2R2-011
 RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION

II-CSIP-1CSIP-A-WA4
COVERAGE SUMMARY




Supplemental Report

Report No.: PT-04-005
 Page: 2 of 2

Summary No.: H-01861

Sketch or Photo: Y:\Shared\ideas\HNP_Data\History\RFQ-12\RF-04-005.tif



II-CSIP-1CSIP-A-WA4

Examination completion calculation:

Total examination area:

$5.50'' + 1.0'' + 3.00'' + 4.00'' + 3.00'' + 1.0'' + 5.50'' + 6.00''$ (linear weld dimension) X

$1.75''$ (weld width + .50'' either side) = $50.75''^2$

Incomplete examination area:

1. $.75''$ (weld width) + $1.0''$ (.50'' exam area either side of weld) X $6.00''$ (length of incomplete examination area) = $10.50''^2$

2. $.40''$ X $5.50''$ = $2.20''^2$

Total incomplete examination area = $12.70''^2$

Completed percentage:

$12.70''^2 \div 50.75''^2 = .2502 = 25.00\%$ Incomplete = 75.00% complete.

This Document is a QA Record.