

From: Kim, James
Sent: Friday, October 02, 2009 8:27 AM
To: 'Devincentis, James M'
Cc: Mannai, David J
Subject: Vermont Yankee Nuclear Power Station – Acceptance of LAR Application for Inoperable Containment Isolation Valves (TAC NO. ME2267)

SUBJECT: Vermont Yankee Nuclear Power Station – Acceptance of License Amendment Request Application for Inoperable Containment Isolation Valves (TAC NO. ME2267)

By letter dated September 16, 2009, you submitted a license amendment request to revise the Technical Specification (TS) to allow reactor operation to continue, in the event any containment isolation valve becomes inoperable, provided the affected penetration flow path is isolated by the use of at least one closed and de-activated automatic valve, closed manual valve, or blind flange. The purpose of this communication is to provide the results of the NRC staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence. If you have any questions, please contact me.

James Kim
Licensing Project Manager
U. S. NRC, NRR/DORL
301-415-4125(Office)
301-415-2102 (Fax)
James.Kim@nrc.gov

E-mail Properties

Mail Envelope Properties ()

Subject: Vermont Yankee Nuclear Power Station ? Acceptance of LAR Application
for Inoperable Containment Isolation Valves (TAC NO. ME2267)

Sent Date: 10/02/2009 8:17:38 AM

Received Date: 10/02/2009 8:26:00 AM

From: Kim, James

Created By: James.Kim@nrc.gov

Recipients:

jdevinc@entergy.com ('Devincentis, James M')

Tracking Status: None

dmannai@entergy.com (Mannai, David J)

Tracking Status: None

Post Office:

| Files | Size | Date & Time |
|---------|-------|-------------|
| MESSAGE | 11174 | 10/02/2009 |

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: