

**From:** Poole, Justin  
**Sent:** Friday, October 02, 2009 3:33 PM  
**To:** 'Hale, Steve'  
**Subject:** Draft EPU Acceptance Review Question from the Mechanical and Civil Engineering Branch

Steve,

Below is the draft acceptance review question from the Mechanical & Civil Engineering Branch on the EPU.

*Justin C. Poole*  
*Project Manager*  
*NRR/DORL/LPL3-1*  
*U.S. Nuclear Regulatory Commission*  
*(301)415-2048*  
*email: [Justin.Poole@nrc.gov](mailto:Justin.Poole@nrc.gov)*

~~~~~

**DRAFT**

Acceptance Review for Point Beach proposed extended power uprate application.

Pipe evaluations for MFW, steam lines, and AFW piping at EPU conditions need to have been completed (at EPU application submittal) and pipe stress summaries need to be submitted including HELB evaluations to support the licensee's statements that there are no changes in the existing HELB evaluations and that these lines are structurally acceptable for EPU conditions. In addition, detail descriptions of affected piping and supports are also required to be completed (at EPU application submittal) and affected summaries of results of pipe support evaluations to be available for staff review.

If these items (above) are not available at time of EPU staff review, the staff finds the proposed EPU LAR unacceptable with opportunity to supplement. Confirm that the analyses for all piping systems and supports for the above systems are now complete.

**DRAFT**

---

**E-mail Properties**

Mail Envelope Properties ()

**Subject:** Draft EPU Acceptance Review Question from the Mechanical and Civil Engineering Branch  
**Sent Date:** 10/2/2009 3:18:13 PM  
**Received Date:** 10/2/2009 3:33:00 PM  
**From:** Poole, Justin

**Created By:** Justin.Poole@nrc.gov

**Recipients:**  
Steve.Hale@fpl.com ('Hale, Steve')  
Tracking Status: None

Post Office:

| Files   | Size  | Date & Time |
|---------|-------|-------------|
| MESSAGE | 11565 | 10/2/2009   |

Options

Expiration Date:

Priority: olImportanceNormal

ReplyRequested: False

Return Notification: False

Sensitivity: olNormal

Recipients received: