

## Regulatory Observations

1. Except as specifically noted (e.g., in 10 CFR 50.65), the requirements of 10 CFR 50 apply to safety-related cables only.
2. 10 CFR 50.49, and associated “qualification” requirements, do not apply to cables in mild environments.
3. Submerged safety-related cables need to be evaluated for Operability.
4. If the scope of 10 CFR 50.65 is used for MVC then the substantive requirements of 10 CFR 50.65 apply.