ATTACHMENT 6

AREVA NP Inc. Affidavit and Non-Proprietary Version of Attachment 3

AFFIDAVIT

COMMONWEALTH OF VIRGINIA)) CITY OF LYNCHBURG)

1. My name is Gayle F. Elliott. I am Manager, Product Licensing, for AREVA NP Inc. and as such I am authorized to execute this Affidavit.

SS.

2. I am familiar with the criteria applied by AREVA NP to determine whether certain AREVA NP information is proprietary. I am familiar with the policies established by AREVA NP to ensure the proper application of these criteria.

3. I am familiar with the AREVA NP information contained in the report ANP-2843(P), Revision 1, entitled "LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex," dated August 2009 and referred to herein as "Document." Information contained in this Document has been classified by AREVA NP as proprietary in accordance with the policies established by AREVA NP for the control and protection of proprietary and confidential information.

4. This Document contains information of a proprietary and confidential nature and is of the type customarily held in confidence by AREVA NP and not made available to the public. Based on my experience, I am aware that other companies regard information of the kind contained in this Document as proprietary and confidential.

5. This Document has been made available to the U.S. Nuclear Regulatory Commission in confidence with the request that the information contained in this Document be withheld from public disclosure. The request for withholding of proprietary information is made in accordance with 10 CFR 2.390. The information for which withholding from disclosure is requested qualifies under 10 CFR 2.390(a)(4) "Trade secrets and commercial or financial information."

6. The following criteria are customarily applied by AREVA NP to determine whether information should be classified as proprietary:

- (a) The information reveals details of AREVA NP's research and development plans and programs or their results.
- (b) Use of the information by a competitor would permit the competitor to significantly reduce its expenditures, in time or resources, to design, produce, or market a similar product or service.
- (c) The information includes test data or analytical techniques concerning a process, methodology, or component, the application of which results in a competitive advantage for AREVA NP.
- (d) The information reveals certain distinguishing aspects of a process, methodology, or component, the exclusive use of which provides a competitive advantage for AREVA NP in product optimization or marketability.
- (e) The information is vital to a competitive advantage held by AREVA NP, would be helpful to competitors to AREVA NP, and would likely cause substantial harm to the competitive position of AREVA NP.

The information in the Document is considered proprietary for the reasons set forth in paragraphs 6(b) and 6(c) above.

7. In accordance with AREVA NP's policies governing the protection and control of information, proprietary information contained in this Document have been made available, on a limited basis, to others outside AREVA NP only as required and under suitable agreement providing for nondisclosure and limited use of the information. 8. AREVA NP policy requires that proprietary information be kept in a secured file or area and distributed on a need-to-know basis.

9. The foregoing statements are true and correct to the best of my knowledge, information, and belief.

8

SUBSCRIBED before me this _____

day of August 2009.

Sherry L. McFaden NOTARY PUBLIC, COMMONWEALTH OF VIRGINIA MY COMMISSION EXPIRES: 10/31/10 Reg. # 7079129

SHERRY L. MCFADEN Notary Public Commonwealth of Virginia 7079129 My Commission Expires Oct 31, 2010

An AREVA and Siemens company

ANP-2843(NP) Revision 1

LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex



August 2009

AREVA NP Inc.

ANP-2843(NP) Revision 1

LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex

AREVA NP Inc.

ANP-2843(NP) Revision 1

-

Copyright © 2009

AREVA NP Inc. All Rights Reserved

Nature of Changes

Item	Page	Description and Justification
1	2-4	Punctuation corrected
2	2-5	4 °C added for clarification
3	4-4,6-13	Proprietary markings removed from insert parameters
4	5-1	Space added

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page ii

Contents

1.0	Introdu	ction	1-1
2.0	Summa	ary	2-1
3.0	Critical	ity Safety Design Criteria	3-1
4.0	Fuel ar 4.1 4.2	nd Storage Array Description Fuel Assembly Design Fuel Storage Racks	4-1 4-1 4-1
5.0	Calcula 5.1 Are	ation Methodology a of Applicability	5-1 5-2
6.0	Critical 6.1 6.2 6.3 6.4 6.5 6.6 6.7 6.8 6.9 6.10	ity Safety Analysis Geometry Model Definition of REBOL Lattices Storage Array Reactivity Uncertainties Abnormal and Accident Conditions Determination of Maximum Rack Assembly k-eff Uniform vs. Distributed Enrichment Distributions Arrays of Mixed BWR Fuel Types Inaccessible Storage Locations Interfaces between Areas with Different Storage Conditions	6-1 6-1 6-3 6-4 6-4 6-6 6-7 6-7 6-8 6-8
7.0	Conclu	sions	7-1
8.0	Refere	nces	8-1
Appen	dix A	Sample CASMO-4 Input	. A-1
Appen	dix B	Reactivity Comparison for Assemblies Used in the LaSalle Reactors	. B-1
Appen	dix C	KENO V.a Bias and Bias Uncertainty Evaluation	. C-1
Appen	dix D	CASMO-4 Benchmarking for In-Rack Modeling	. D-1

.

Tables

2.1	Criticality Safety Limitations for ATRIUM-10 Fuel Assemblies Stored in the LaSalle Unit 2 Nuclear Power Station Spent Fuel Pool	2-4
4.1	ATRIUM-10 Fuel Assembly Parameters	4-3
4.2	Fuel Storage Rack Parameters	4-4
6.1	Summary of CASMO-4 Maximum Reactivity Results for the ATRIUM-10 Fuel Assembly	6-10
6.2	Summary of KENO V.a Maximum In-Rack Reactivity for ATRIUM-10 Fuel	6-12
6.3	Manufacturing Reactivity Uncertainties	6-13
6.4	Evaluation for Inaccessible Storage Locations	6-14

Figures

2.1	ATRIUM-10 Reference Bounding Assembly	2-6
4.1	Representative ATRIUM-10 Fuel Assembly	4-5
4.2	Calculational Model of Storage Cell	4-6
4.3	Storage Rack with Inserts	4-7

Nomenclature

BAF BOL BWR	bottom of active fuel beginning of life boiling-water reactor
CPR CW	critical power ratio clock-wise
EALF	the energy of the average lethargy causing fission
GWd	energy unit, giga-watt-day
k-eff k∞	effective neutron multiplication factor infinite lattice neutron multiplication factor
LHGR	linear heat generation rate
PLR	part-length fuel rod
NRC	Nuclear Regulatory Commission, U. S.
REBOL	reactivity-equivalent at beginning of life (fresh fuel, no Gd_2O_3 , no fission products)
TD H/X	theoretical density atomic ratio of hydrogen (H) to fissile isotopes (X)

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 1-1

1.0 Introduction

This report presents the results of a criticality safety evaluation performed for the LaSalle Unit 2 Nuclear Power Station spent fuel storage pool assuming complete Boraflex degradation and the use of neutron absorbing inserts in each accessible storage cell. Reference 1 is the last criticality safety evaluation that was submitted for NRC review for the LaSalle Unit 2 spent fuel pool.

In this report, a reference bounding assembly has been defined to bound the reactivity of all past and current fuel assembly types delivered to the LaSalle station (both Units 1 and 2). This reference bounding assembly is based on an AREVA NP Inc.* ATRIUM[†]-10 fuel assembly. This analysis demonstrates that with the reference bounding assembly, complete Boraflex degradation, and a neutron absorbing NETCO-SNAP-IN insert in each storage cell, the pool k-eff remains below the 0.95 k-eff acceptance criterion established by the NRC.

^{*} AREVA NP Inc. is an AREVA and Siemens company.

[†] ATRIUM is a trademark of AREVA NP.

2.0 Summary

Criticality analyses have been performed and are documented herein for the LaSalle Unit 2 spent fuel pool assuming no Boraflex and the presence of a NETCO-SNAP-IN insert in each accessible storage cell of the rack. The criticality analyses are based on the use of a reference fuel assembly design that is bounding of (i.e., more reactive than) all fuel designs used in Units 1 and 2 at the LaSalle station. The KENO V.a code was used for all calculations that do not require fuel depletion. The CASMO-4 code is used to compare lattice k_∞ values at peak reactivity conditions and in defining the gadolinia manufacturing uncertainty. Benchmarking is included for both the KENO V.a and CASMO-4 codes.

The calculations documented herein demonstrate that the ATRIUM-10 reference bounding assembly design has been selected to be more reactive, in an in-rack configuration without Boraflex and with the NETCO-SNAP-IN inserts, than any of the current or past fuel assembly designs used in the LaSalle reactors. These comparisons are based upon actual GE 8x8, ATRIUM-9, GE14, ATRIUM 10XM and ATRIUM-10 lattice geometries and enrichment distributions and the results are shown in Appendix B. This evaluation establishes that the fuel assemblies previously manufactured for use in the LaSalle reactors can be safely stored in the LaSalle Unit 2 spent fuel storage pool with NETCO-SNAP-IN inserts.

The reference bounding assembly is defined with two U235 enrichment / gadolinia concentration zones. The bottom enrichment / gadolinia zone is divided into two separate axial zones by the ATRIUM-10 geometry transition at 96". This creates the 3 zones shown in Figure 2.1. Three REBOL lattices have been defined to represent the lattices of the reference bounding assembly in KENO calculations. The reactivity of the REBOL lattices have been increased to compensate for the uncertainties associated with defining these maximum reactivity lattices.

This evaluation includes manufacturing uncertainties for the ATRIUM-10 fuel design and the fuel pool storage racks, code modeling uncertainties, reactivity increases due to accident or abnormal conditions, and one-sided tolerance multipliers to determine the 95/95 upper limit k-eff. The conditions and uncertainties assumed in this analysis are described in Section 6.

This evaluation demonstrates that the reference ATRIUM-10 fuel assembly does not exceed an array k-eff of 0.95 in the LaSalle Unit 2 spent fuel storage pool without Boraflex, provided the

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 2-2

neutron absorbing insert depicted in Figure 4.2 has been installed in each accessible storage cell. As defined in Table 2.1, ATRIUM-10 fuel that contains equivalent or less enrichment and equivalent or higher Gd_2O_3 concentrations in the fuel zones depicted in Figure 2.1 can be safely stored in the LaSalle Unit 2 spent fuel storage pool. In addition, ATRIUM-10 fuel that contains more enrichment and/or lower Gd_2O_3 concentrations than the reference assembly design can be safely stored provided each zone of the assembly is less reactive than the corresponding zone of the reference assembly design. This can be established using the storage rack model in the CASMO-4 lattice physics code as described in Appendix A.

This analysis considers unchanneled fuel assemblies as well as assemblies with the AREVA 100 mil fuel channel.* Additionally, there is no limitation for bundle orientation or position in the storage cell since these are accounted for in the analysis.

To assure that the actual reactivity will always be less than the calculated reactivity, the following conservative assumptions have been made:

- The results are based on a moderator temperature of 4°C (39.2°F), which gives the highest reactivity for the fuel storage pool for a configuration assuming no Boraflex with NETCO-SNAP-IN inserts.
- Fuel assemblies are assumed to contain the high reactivity reference bounding lattices for the entire length of the assembly, (natural uranium blankets are not modeled).
- Each lattice in each fuel assembly in the array is assumed to be at its lifetime maximum reactivity level, (no credit is taken for assembly burnup).
- The most limiting orientation or position of each assembly in its rack cell is accounted for in the analysis.
- The analysis takes into account storage with or without fuel channels. (The array k-eff is higher with a fuel channel present).
- Neutron absorption in fuel assembly structural components (spacers[†], tie plates, etc) is neglected.[‡]
- The maximum reactivity value includes all significant manufacturing and calculational uncertainties.

^{*} The AREVA advanced fuel channel and the AREVA 80 mil fuel channel are also acceptable.

[†] It is conservative to neglect the spacers because this spent fuel pool contains no soluble boron and the region around the fuel rods is under-moderated and neglecting the spacer places more water within the calculational model. In addition, the inconel springs are a stronger neutron absorber than water.

[‡] The active fuel region repeats periodically in the vertical direction. Therefore, neutron absorption in upper and lower tie plates, fuel plenums, etc. is neglected.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 2-3

• The reactivity of the REBOL lattices used in the KENO analysis have been designed to be at least 0.010 Δk more reactive than the reference bounding lattices they represent. This is more than the uncertainty associated with defining these maximum reactivity lattices.

aSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 2-4

Table 2.1 Criticality Safety Limitations for ATRIUM-10 Fuel Assemblies Stored in the LaSalle Unit 2 Nuclear Power Station Spent Fuel Pool

1. ATRIUM-10 Fuel Configuration

<u>Parameter</u>	Nominal ATRIUM-10 Value
Clad OD, in.	0.3957
Clad ID, in.	0.3480
Pellet Diameter, in.	0.3413
Rod Pitch, in.	0.510
Fuel Density % Theoretical	95.85 to 96.26
Water Rods	Internal Channel

- 2. Fuel may be stored with or without fuel channels.
- 3. Fuel Design Limitations for Enriched Lattices*

The U235 enrichment and gadolinia concentration levels must meet the requirements specified below and shown graphically in Figure 2.1 (dimensions represent fuel column height above BAF).

Above 126"	Maximum Lattice Average Enrichment, wt% U-235	4.47
	Minimum Number of Rods containing Gd ₂ O ₃	10
	Minimum wt% Gd ₂ O ₃ in each Gd Rod	3.5
		·····
Below 126" [†]	Maximum Lattice Average Enrichment, wt% U-235	4.57
Below 126" [†]	Maximum Lattice Average Enrichment, wt% U-235 Minimum Number of Rods containing Gd ₂ O ₃	4.57

Eight gadolinia rods must be loaded one row in from the edge of the lattice such that rows 2 and 9 and columns 2 and 9 each contain 2 gadolinia rods.

4. ATRIUM-10 fuel assemblies which do not meet the limitations above may be stored in the LaSalle Unit 2 spent fuel pool provided the reactivity of any enriched lattice does not exceed the following in-rack k_∞ values at any point during their lifetime. (The CASMO-4 storage rack model that must be used for this calculation is defined in Appendix A and the

^{*} These are the reference bounding lattices described on Page 6-2.

[†] This is actually two axial zones divided by the geometry of the ATRIUM-10 part-length rod transition at 96" above BAF.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 2-5

transition between top and bottom lattice geometries occurs at 96 inches from the bottom of the fueled length.)

Zone	Lattice Geometry	Distance from BAF	Max. in-rack k _∞ (4°C)
3	A10T (83 rods)	126" to 149"	0.9185
2	A10T (83 rods)	96" to 126"	0.8869
1	A10B (91 rods)	0" to 96"	0.8843

5. The spent fuel storage rack design parameters and dimensions are as defined in Reference 4, and a general description of the NETCO-SNAP-IN inserts is provided in Reference 5.

1

LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex

ANP-2843(NP) Revision 1 Page 2-6



Figure 2.1 ATRIUM-10 Reference Bounding Assembly

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 3-1

3.0 Criticality Safety Design Criteria

The criticality safety design criteria defined in the following documents are applicable for this LaSalle Unit 2 Nuclear Power Station spent fuel storage facility evaluation:

- A. Subsection B.4 of 10CFR 50.68, (Criticality Accident Requirements), (Reference 6).
- B. Section 9.1.1 (Fresh and Spent Fuel Storage and Handling) of the Standard Review Plan (Reference 7).
- C. ANSI/ANS American National Standard 57.2-1983 (*Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants*) issued by the American Nuclear Society (Reference 8).*
- D. ANSI/ANS American National Standard 8.17-1984 (*Criticality Safety Criteria for the Handling, Storage and Transportation of LWR Fuel Outside Reactors*) issued by the American Nuclear Society, January 1984 (Reference 9).
- E. "OT Position for the Review and Acceptance of Spent Fuel Storage and Handling Applications," issued by the NRC in 1978 and amended in 1979 (Reference 10).
- F. "Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light-Water Reactor Power Plants," issued by the NRC in 1998 (Reference 11).

These documents define the assumptions and acceptance criteria used in this evaluation. In descending order (from A to F), these documents go from "least" to "most" detail relative to explicitly defining what needs to be addressed in the criticality safety evaluation. In general, the criticality safety acceptance criterion applicable to this evaluation is as defined by Section 9.1.1 of the Standard Review Plan (Reference 7):

...the k-eff will not exceed 0.95 for all normal and credible abnormal conditions.

This is consistent with requirements in the LaSalle FSAR and Technical Specifications.

^{*} ANSI/ANS 57.1 and 57.3 are endorsed in combination with ANSI/ANS 57.2 in item B. ANSI/ANS 57.1 and 57.3 are not cited here because they do not apply to spent fuel pool criticality.

4.0 Fuel and Storage Array Description

LaSalle Units 1 and 2 have loaded four different product lines—GE 8x8 fuel, ATRIUM-9 fuel, GE14 fuel, and ATRIUM-10 fuel. The ATRIUM-10 fuel product line is the fuel currently being loaded in reload quantities in both LaSalle reactors. All four of these designs are stored in the LaSalle Unit 2 spent fuel storage pool. In an in-rack configuration assuming no Boraflex and NETCO-SNAP-IN inserts, the reference ATRIUM-10 design has a higher reactivity than all previously loaded fuel assembly designs. Appendix B provides information from which this conclusion can be made. As such, the ATRIUM-10 reference bounding assembly design forms the basis for demonstrating that the maximum k-eff of the spent fuel pool storage array without Boraflex with NETCO-SNAP-IN inserts remains less than 0.95.

4.1 Fuel Assembly Design

The ATRIUM-10 fuel assembly is a 10x10 fuel rod array with an internal square water channel offset in the center of the assembly (taking the place of nine fuel rod locations). The assembly contains part-length fuel rods (PLR); therefore, a "top" lattice geometry will apply above the PLR boundary and a "bottom" lattice geometry will apply below the PLR boundary. The ATRIUM-10 mechanical design parameters are summarized in Table 4.1. A representation of the ATRIUM-10 assembly design is depicted in Figure 4.1. The ATRIUM-10 fuel in the LaSalle Nuclear Power Station has used and will use the standard 100 mil fuel channel design.

4.2 Fuel Storage Racks

The spent fuel storage rack dimensions and details are shown in Reference 4. The key rack assembly dimensions and tolerances are listed in Table 4.2. The fuel pool storage cell with ATRIUM-10 fuel has been modeled in CASMO-4 as shown in Figure 4.2 with small variations in KENO V.a. Each rack consists of an array of stainless steel boxes with a separation of 0.075" between each box wall. Originally this separation was filled with a layer of Boraflex material; however, for this analysis it is assumed that the Boraflex has been removed and is now replaced with water.

For this evaluation, a chevron shaped neutron absorbing insert (NETCO-SNAP-IN) is modeled in each of the storage cells (see the general description in Reference 5). These inserts will extend over the full length of the fueled zone and will maintain the same orientation in each

LaSalle Unit 2 Nuclear Power Station Spent Fuel	
Storage Pool Criticality Safety Analysis with	
Neutron Absorbing Inserts and Without Boraflex	

storage cell. Based on the insert configuration of Figure 4.3, peripheral storage cells on the north and east sides of the storage pool will not be completely surrounded by four wings of the absorbing insert. In the actual Unit 2 pool configuration, there will also be a minimal number of peripheral cells on all sides of the storage pool that will not be completely surrounded by four wings of the absorbing insert due to geometric layout and inaccessible storage locations.

Table 4.1 ATRIUM-10 Fuel Assembly Parameters

Fuel Assembly	
Fuel Rod Array	10x10
Fuel Rod Pitch, in.	0.510
Number of Fuel Rods Per Assembly	91
Water Channel	. 1
Fuel Rods	
Fuel Material	UO ₂
Pellet Density, % of Theoretical	96.26*
Pellet Diameter, in.	0.3413
Pellet Void Volume, %	
Enriched UO ₂	1.2 [†]
Cladding Material	Zircaloy-2
Cladding OD, in.	0.3957
Cladding ID, in.	0.3480
Internal Water Channel	
Outside Dimension, in.	1.378
Inside Dimension, in.	1.321
Channel Material	Zircaloy 2 or Zircaloy-4
<u>Fuel Channel</u> (standard 100 mil) [‡]	
Outside Dimension, in.	5.478
Inside Dimension, in.	5.278
Channel Material	Zircaloy-2, Zircaloy-4, or Zirc-BWR
Fuel Column Lengths	
Distance from the bottom of the fuel	
to the top of the fuel in the part length	96.0
fuel rods, in.	
Total Fueled Length, in.	149.0

* Criticality safety analysis is valid for nominal pellet densities between 95.85% and 96.26% TD.

[†] Depending on pellet L/D, the pellet void volume can vary. A nominal value of 1.2% was assumed for the criticality safety analysis. Variations of the void volume are not significant relative to impact on storage array criticality safety. (Use of chamfered pellets with higher void volumes are also acceptable)

[‡] The conclusions in this report are equally valid for fuel channels that may differ. Hence, conclusions remain valid for other fuel channel types, e.g., advanced channels etc. (See discussion about fuel channels in Section 6.2).

Table 4.2 Fuel Storage Rack Parameters

Parameter	<u>Value</u>
Insert, B-10 areal density, g/cm ²	0.0086 minimum
Insert wing thickness, in. Material	0.065 ± 0.005 Aluminum and B-10
Insert modeled wing length, in.	5.98*
Storage cell Inside Dimension, in.	6.00 ± 0.02
Inner rack box wall thickness, in. Box material	0.090 ± 0.009 Stainless steel
Original Boraflex thickness, in. Material	0.075 ± 0.007 Originally Boraflex, now modeled as water
Nominal rack cell pitch, in.	6.255 []

^{*} Value used in the KENO model. 6.00" was used in the CASMO-4 model which requires the insert wing to extend to the inside wall of the fuel storage cell.

LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex



Figure 4.1 Representative ATRIUM-10 Fuel Assembly

(Assembly length and number of spacers has been reduced for pictorial clarity.)

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex ANP-2843(NP) Revision 1 Page 4-6



Figure 4.2 Calculational Model of Storage Cell

LaSalle Unit 2 Nuclear Power Station Spent Fuel Storage Pool Criticality Safety Analysis with Neutron Absorbing Inserts and Without Boraflex ANP-2843(NP) Revision 1 Page 4-7



Not to Scale



LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 5-1

5.0 Calculation Methodology

The spent fuel storage criticality safety evaluation is performed with the KENO V.a Monte Carlo code, which is part of the SCALE 4.4a Modular Code System (Reference 2). The ENDF/B-V, 44 energy group data library is used by the SCALE driver module CSAS25, which uses modules BONAMI-2 and NITAWL to perform spatial and energy self-shielding adjustments of the cross sections for use in KENO V.a. AREVA has benchmarked KENO V.a in accordance with NUREG/CR-6698 (Reference 3) using critical experiments related to the storage of fuel assemblies in water - including neutron absorbing materials such as stainless steel and BORAL. For applications using the 44 energy group data libraries, the KENO V.a bias and standard deviation are 0.00542 and 0.00511, respectively (see Appendix C).

KENO V.a is run on the AREVA NP scientific computer cluster using the Linux operating system. The hardware and software configurations are governed by AREVA NP procedures to ensure calculational consistency in licensing applications. The code modules are installed on the system and the installation check cases are run to ensure the results are consistent with the installation check cases that are provided with the code. The binary executables are put under configuration control so that any changes in the software will require re-certification. The hardware configuration of each machine in the cluster is documented so that any significant change in hardware or operating system that could result in a change in results is controlled. In the event of such a change in hardware or operating system, the hardware validation suite is rerun to confirm that the system still performs as it did when the code certification was performed.

In this analysis the SCALE 4.4a code system is employed to:

- Calculate Dancoff coefficients
- Calculate absolute k-effective results for the LaSalle Unit 2 spent fuel pool
- Evaluate accident conditions, alternate loading conditions, and manufacturing tolerance conditions

The CASMO-4 code is used when conditions require fuel and gadolinia depletion. CASMO-4 is a multigroup, two-dimensional transport theory code with an in-rack geometry option where typical storage rack geometries can be defined on an infinite lattice basis. This code is used for fuel depletion and relative reactivity comparisons in a manner that is consistent with AREVA's

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 5-2

NRC approved CASMO-4 / MICROBURN-B2 methodology (Reference 12). CASMO-4 has been approved at LaSalle for BWR calculations and is included as a methodology reference (via Reference 12) in Section 5.6.5.B of the LaSalle Technical Specifications. The CASMO-4 computer code is controlled by AREVA procedures and the version used in this analysis meets the requirements of Reference 12.

In this analysis CASMO-4 is employed to:

- Perform in-core isotopic depletion at [] void history levels for fuel lattices.
- Perform in-rack k_{∞} assessments to identify the lattices with maximum reactivity.
- Define lattices for a reference bounding assembly that represent the maximum reactivity condition supported by the analysis.
- Define the reactivity equivalent, beginning-of-life (REBOL) lattices with fresh fuel and no gadolinia, for the subsequent KENO V.a base case criticality calculations. Note that for the REBOL lattices, the U-235 content is manually adjusted upward until the REBOL k_∞ is at least 0.01 Δk greater than the lattices of the reference bounding assembly. This 0.01 Δk is used to account for calculational and depletion uncertainties of the CASMO-4 code as discussed in Appendix D.
- Evaluation of the manufacturing uncertainty for gadolinia content. This is needed since a lower gadolinia concentration will deviate from the nominal case more near peak reactivity than it will at beginning of life (i.e., in a REBOL assembly).

5.1 Area of Applicability

Table C.6 in Appendix C shows the ranges of key parameters represented in the KENO V.a benchmark analysis. Parameters such as rectangular lattices of zircaloy clad UO2 fuel rods in a pool of water with stainless steel and boron are sufficiently general to not require comparison. The remaining parameters are compared in the following table and show that the KENO V.a portion of this analysis has been performed within the range of experimental conditions used in the KENO V.a benchmark.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 5-3

Parameter	Benchmark Values	Values in this Analysis
Enrichment (wt% U-235)	2.46 to 9.83	2.66 to 4.57
Pitch (cm)	1.04 to 2.64	1.27 to 1.31
H/X ratio	17.4 to 473	250 to 350
Energy of the Average Lethargy Causing Fission (eV)	0.11 to 2.51	0.19 to 0.26

For the CASMO-4 qualification, ATRIUM-10 fuel lattices were modeled using the LaSalle fuel storage rack geometry. Therefore, the CASMO-4 calculations performed for this evaluation are within the area of applicability of the comparisons shown in Appendix D.

.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-1

6.0 Criticality Safety Analysis

The criticality safety evaluation uses a reference bounding assembly comprised of two top and one bottom geometry reference bounding lattices* to demonstrate that the upper limit $k_{95/95}$ k-eff for the LaSalle Unit 2 Nuclear Power Station spent fuel pool can be met. These evaluations include the worst credible conditions and uncertainties as defined in the references documented in Section 3.0. The reference bounding ATRIUM-10 bundle is comprised of three axial zones each with ten gadolinia rods. These zones are described in the following table and are shown graphically in Figure 2.1.

Zone	Lattice Geometry	Distance from BAF	U235 wt%	Gadolinia wt%
3	A10T	126" to 149"	4.47	3.5
2	A10T	96" to 126"	4.57	6.0
1	A10B	0" to 96"	4.57	6.0

6.1 Geometry Model

The ATRIUM-10 fuel assembly parameters are given in Table 4.1. The key fuel pool storage rack parameters are given in Table 4.2. The main KENO storage rack geometry model used for analysis is an infinite array of stainless steel fuel storage boxes with a chevron shaped neutron absorbing insert in each accessible box. All inserts will have the same orientation throughout the entire spent fuel pool; therefore, the fuel assemblies loaded on 2 sides of the perimeter will not be completely enclosed by the inserts (see Figure 4.3). All accessible storage rack cells are modeled with an ATRIUM-10 fuel assembly.

6.2 **Definition of REBOL Lattices**

The CASMO-4 lattice depletion calculations are performed at hot operating, uncontrolled, [

] void history conditions[†]. The calculation results are based upon the nominal fuel design parameters (defined in Table 4.1) and assume a standard 100 mil fuel channel. Cold xenon-free restart calculations are performed as a function of exposure and void history to establish the highest in-rack reactivity (k_{∞}) at any time throughout the life of the fuel lattice. The maximum CASMO-4 in-rack k_{∞} of the reference bounding lattices are 0.8843, 0.8869, and

It is demonstrated in Appendix B that the ATRIUM-10 reference design in the spent fuel pool geometry without Boraflex and with NETCO-SNAP-IN inserts is more reactive than the other fuel types used in the LaSalle reactors.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-2

0.9185, for Zones 1 though 3 respectively. These limiting results are based upon a water temperature of 4 °C, 40% void history, and lattice exposures of 16.5, 16.0, and 11.5 GWd/MTU, respectively for each axial zone. The results of the CASMO-4 comparison calculations are summarized in Table 6.1.

The following table is provided to summarize the differences between the fuel assembly and lattice names used in this evaluation.

Fuel Lattice Type	Description	
ATRIUM-10 REBOL Lattices (top and bottom zone geometries)	Defined for use in the KENO calculations, 2.66 wt% U235 (Zone 1), 2.72 wt% (Zone 2), and 3.05 wt% U235 (Zone 3), no gadolinia, uniform enrichment distribution, selected to be at least 0.01 Δ k more reactive than the reference bounding lattices.	
ATRIUM-10 Reference Bounding Lattices (top and bottom zone geometries)	The most reactive lattices supported by this evaluation with distributed enrichment distribution, 4.57 wt% U235 with 10 Gd_2O_3 rods at 6.0 wt% gadolinia (Zones 1 and 2), and 4.47 wt% U235 with 10 Gd_2O_3 rods at 3.5 wt% gadolinia in Zone 3. These lattices are defined to establish the minimum reactivity required for the REBOL lattices.	
As-Fabricated Assemblies (ATRIUM-10, ATRIUM-9, GE14, and GE 8x8)	The actual assemblies built for and/or used in the LaSalle reactors. CASMO-4 in-rack k _∞ comparisons are included in Appendix B.	

In support of the KENO rack calculations, reactivity equivalent beginning of life (REBOL) lattice enrichments are selected using the top and bottom ATRIUM-10 lattice geometries. Two REBOL lattices are created with the ATRIUM-10 top geometry and one with the ATRIUM-10 bottom geometry. The REBOL lattices have the same enrichment in all rods and no gadolinia. The REBOL lattice enrichments as well as the CASMO-4 in-rack k_{∞} at 4°C are shown in Table 6.1.

As discussed in the methodology section, a 0.01 Δ k adder is included in the generation of the REBOL lattices to address CASMO-4 code, geometry, material, and depletion uncertainties.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-3

6.3 Storage Array Reactivity

For the general KENO rack array calculations, an infinite array of fuel storage cells was assumed – using periodic boundary conditions in all three directions. All fuel locations in the rack array model contain an ATRIUM-10 REBOL assembly comprised of a 3.05 wt% U-235 top zone (above 126"), a 2.72 wt% U-235 intermediate zone (96" to 126"), and a 2.66 wt% U-235 bottom zone (below 96"). The array k-eff is highest when the assembly is centered in the available water space in the storage cell and the assembly orientation shown in Figure 4.2 is as limiting as the other 3 simple rotation possibilities. Calculations were performed at temperatures of 4 °C, 20 °C, 100 °C and 120 °C*. As shown in Table 6.2, the limiting base case KENO k-eff is 0.916.

The KENO model assumes a standard 100 mil fuel channel. The array k-eff is about 0.006 Δ k lower when the fuel channels are removed.[†] There is no significant difference in array reactivity between the AREVA standard 100 mil fuel channel and the AREVA advanced fuel channel.[‡]

As discussed in Section 4.2 and illustrated in Figure 4.3, assemblies loaded in storage cells on the top and left hand sides of the figure will not be completely surrounded by neutron absorbing inserts. (The entire spent fuel pool is shown in Figure 1.1 of Reference 1 and contains irregular regions). Since the main KENO calculations used an infinite 3-D model it is necessary to evaluate whether the lack of neutron absorbing inserts on these 2 edges of the pool will have a non-conservative effect. This was evaluated using finite 3-D KENO calculations with a 24x24 array of storage cells surrounded by water and concrete, (each cell contained an assembly and a NETCO-SNAP-IN insert). The initial case modeled the condition where all fuel assemblies are enclosed by inserts and was achieved by adding additional inserts[§] along the top and left hand edges of the array in the outer water region. The comparison case modeled the more realistic condition where the additional inserts in the water region were removed. Based on this comparison the infinite lattice results will be increased by 0.001 Δk to account for this peripheral edge condition and to ensure conservative results are reported.

^{* 120 °}C addresses the higher temperature conditions that are possible with fuel assemblies near the bottom of a 30 to 40 foot pool of water.

[†] This is because the storage array is over-moderated between the fuel assemblies.

[‡] This analysis also supports the use of a standard 80 mil fuel channel.

[§] The additional inserts were modeled outside of the storage rack array with the same overall spacing and orientation as the inserts in the storage rack cells.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-4

The limiting conditions for the KENO rack calculations are shown in Table 6.2. Except as specifically noted, the reactivity values presented in Tables 6.1 and 6.2 do not include adjustments for uncertainties or code biases. Section 6.6 presents the determination of the upper limit 95/95 reactivity for the storage rack array.

6.4 Uncertainties

Uncertainties associated with defining bounding REBOL lattices are addressed in Appendix D. Specifically uncertainties associated with CASMO-4 code depletion and modeling capabilities are included within the REBOL definition process.

The unadjusted reactivity result reported in Table 6.2 is based upon the nominal bundle position and orientation in the storage rack shown in Figure 4.2. Simple rotation of the assembly or movement within the storage cell does not produce higher (statistically significant) results. As discussed in Section 6.3 a 0.001 Δk adder has been identified to account for the lack of B-10 absorber along 2 peripheral edges of the storage rack array. The manufacturing tolerance values and the calculated reactivity uncertainties for the ATRIUM-10 fuel are shown in Table 6.3. The gadolinia manufacturing uncertainty effect on reactivity was evaluated with a combination of KENO V.a and CASMO-4. All other uncertainties reported in Table 6.3 were evaluated with KENO V.a. The ATRIUM-10 rack calculations are conservatively performed for a minimum B10 areal density of the insert. BOL dimensions have been assumed, except the fuel rod pitch and channel bulge results are based upon conservative spacer and channel growth dimensions.*

6.5 Abnormal and Accident Conditions

In addition to the nominal storage cell arrangement, abnormal and accident conditions have also been considered. All Δk values provided in this section are based upon comparative KENO V.a calculations - only the most limiting scenario will be reflected in the $k_{95/95}$ calculation in Section 6.6.

For the misloaded assembly scenario, only the misplacement of a fuel assembly outside of and adjacent to the storage rack was analyzed because spent fuel pool rack drawings show that there is no gap between the racks wide enough to allow insertion of an assembly. No fuel

^{*} The presence of activated corrosion and wear products (CRUD) is neglected because most of these compounds have higher neutron absorption cross sections than water.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-5

channel was present on the misplaced assembly* and it was placed up against the stainless steel storage rack wall in a location where there is no neutron absorbing insert (see Figure 4.3) between the misplaced assembly and the adjacent assembly. Because this occurs on the edge of the rack array, where neutron leakage is high, only a small reactivity increase was observed (less than 0.001 Δk).

The situation where a single neutron absorbing insert is missing from an interior position of the storage rack was also evaluated. This was found to be the most reactive accident condition with a worth of 0.003 Δk .

The positioning of the assemblies within the storage cell was also evaluated for conditions with and without[†] a fuel channel. (This bounds the likely condition of an assembly being centered at the bottom and leaning against the storage cell wall at the top). Different configurations that pushed the assemblies toward each other in several combinations were investigated. The most reactive condition was found to occur when all assemblies are centered in the water region of the storage cell with a fuel channel installed. Since this is the nominal condition assumed for this analysis the effect of abnormal (or eccentric) assembly positioning is zero.

The orientation of the bundles within the storage rack is not restricted; therefore, the slightly asymmetric nature of the ATRIUM-10 fuel lattices has the potential to increase the pool reactivity if an optimal configuration is achieved. The 4 simple uniform rotation conditions were considered in Section 6.3, and 5 more complicated rotational combinations were evaluated as abnormal conditions. These complicated combinations investigated the effects of how rows, columns, and groups of assemblies could be oriented. From these cases, the worth of abnormal assembly orientation was found to be less than 0.001 Δk . This value is from a case where four rotation conditions are combined.

For the case of dropping a fuel assembly onto an assembly in the storage rack, the deformation of either assembly will not be sufficiently large to exceed the reactivity worth of these other limiting accident conditions. This is because it only involves 2 assemblies in a localized area. There will also be no effect on the array reactivity when the dropped assembly comes to rest in a horizontal or inclined position on top of the storage rack because the dropped assembly will

^{*} To also evaluate minimum separation scenarios.

[†] To also evaluate minimum separation scenarios.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-6

be neutronically isolated from the fuel in the storage cells (greater than 12 inches of water between the dropped assembly and the top of the active fuel zone of the fuel in the storage rack).

A dropped assembly falling into an empty storage cell would potentially deform the baseplate at the bottom of the storage cell. This could place the dropped assembly at a lower elevation than the other assemblies in the array which would decrease the array reactivity because of increased neutron leakage. If the impact deformed the dropped assembly a higher reactivity condition could be achieved; however, it would be bounded by these other limiting accident conditions because it is limited to a localized area.

6.6 **Determination of Maximum Rack Assembly k-eff**

For the ATRIUM-10 fuel design with REBOL lattice enrichments of 3.05 wt% U-235 (above 126"), 2.72 wt% U-235 (from 96" to 126"), and 2.66 wt% U-235 (from 0" to 96"), the maximum KENO calculated in-rack reactivity from Table 6.2 is 0.916. This k-eff value is used with the following equation to determine the upper limit 95/95 reactivity:

$$k_{95/95} = k_{eff} + bias_m + \Delta k_{sys} + (C^2 \sigma_k^2 + C_m^2 \sigma_m^2 + C^2 \sigma_{sys}^2 + \Delta k_{tot}^2)^{\frac{1}{2}},$$

where:

k _{eff}	=	in-rack reactivity from KENO V.a, (0.916, Table 6.2)	
------------------	---	--	--

bias_m = KENO V.a validation methodology bias (0.00542, page C-18)

 Δk_{sys} = Summation of applicable system variables: maximum k-eff increase due to abnormal and accident conditions from Section 6.5 (0.003) and edge effect adder from Section 6.3 (0.001).

C = 95% confidence level consistent with KENO V.a (2)

 $C_m = 95/95$ one-sided tolerance multiplier for a sample size of 100 (1.927)

 σ_k = k-eff standard deviation from KENO V.a, (0.001, Table 6.2)

 σ_m = KENO V.a methodology uncertainty (0.00511, page C-18)

$$\sigma_{sys} = (\sigma_{sys1}^2 + \sigma_{sys2}^2 \dots + \sigma_{sys_n}^2)^{\frac{1}{2}}$$
, for Δk_{sys} uncertainties

 Δk_{tol} = Statistical combination of manufacturing reactivity uncertainties (0.0105, Table 6.3)*

^{*} The uncertainty value for non-ATRIUM-10 fuel types will not differ significantly.

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-7

The following table provides a summary of the Δk_{sys} and σ_{sys} parameters applicable to this analysis. (The σ values are standard deviation results from KENO)

Description	Δk _{sys}	σ_{sys}
Edge Effect (Insert Orientation, Section 6.3)	0.001	0.0007
Limiting Accident (Missing Insert, Section 6.5)	0.003	0.0006
Combined Values	0.004	0.0009

The standard deviations and tolerance uncertainties are included as the square root of the sum of the squares since they represent independent events. Solving for $k_{95/95}$ yields a 95/95 upper limit k-eff of 0.940. The above determination of the upper limit 95/95 k-eff is consistent with the method documented in Reference 8 and allows one to state that at least 95% of the normal population is less than the 95/95 k-eff value calculated with a 95% confidence.

The results demonstrate the postulated configuration with the ATRIUM-10 REBOL assembly lattices meets the NRC criticality safety acceptance criterion that the array k-eff under the worst credible conditions is ≤ 0.95 . Since the REBOL infinite lattices have a higher reactivity than the reference bounding lattices as shown in Table 6.1, the reference bounding lattices also meet the k-eff ≤ 0.95 regulatory limit.

6.7 Uniform vs. Distributed Enrichment Distributions

A uniform enrichment distribution increases the BWR lattice reactivity because low enriched rods in the corners of the lattice are replaced with rods at an average enrichment level. Relative to the reference bounding lattices described in Table 6.1 a uniform enrichment distribution is more reactive by 0.005 to 0.007 Δk . This increase in reactivity is primarily due to increasing the enrichment in corner pins. This does not affect the results of this evaluation since a BWR assembly will always require low enrichments in the corners to maintain margin to LHGR and CPR limits.

6.8 Arrays of Mixed BWR Fuel Types

It is shown in Table B.1 that the ATRIUM-10 reference bounding lattices are equal to or more reactive in the in-rack configuration than the limiting lattices of the legacy fuel. Because the
AREVA NP

GE14, ATRIUM-9, and ATRIUM-10 lattices have similar water and fuel characteristics the neutron energy spectra will be similar for these lattice types. Additionally, it is also shown in Table B.6 that the legacy 8x8 lattices have margin relative to the limiting lattices. It then follows that the ATRIUM-10 lattices used in this evaluation can reasonably represent past assembly fuel types.

The assembly enrichment and gadolinia limitations defined in Table 2.1 will be applied to all future ATRIUM-10 fuel assemblies that are built for LaSalle Unit 1 and Unit 2. Therefore, there will not be a more reactive assembly to consider in a misloaded assembly accident and an array composed of a mixture of these fuel types will not exceed the reactivity calculated for an array of limiting ATRIUM-10 assemblies.

6.9 Inaccessible Storage Locations

There are fuel storage locations around the edges of the LaSalle Unit 2 spent fuel pool which are physically inaccessible primarily due to crane interference with piping above the fuel storage racks. These locations will not contain an insert or a fuel assembly. The impact on the storage array k-eff was evaluated for different geometric configurations of empty storage locations without inserts.

The evaluation was performed using a 24X24 storage configuration. Originally all storage locations were fully loaded and contained inserts. Additional evaluations were completed with various storage locations containing neither fuel assemblies nor inserts. The locations and configurations evaluated are given in Table 6.4. These locations were selected to represent the irregular edge shape of the storage pool as well as configurations which could occur during the process of installing the inserts. For all cases the fully loaded array with inserts had the highest k-eff. The array reactivity is lower (by up to $0.002 \Delta k$) with no neutron absorbing inserts and no fuel assemblies as defined by the geometries in Table 6.4. Therefore, empty cell locations without an assembly and without an insert do not increase the storage array k-eff.

6.10 Interfaces between Areas with Different Storage Conditions

As the inserts are installed the storage pool will become a mixture of degraded Boraflex regions and insert regions. The criticality safety evaluations for each of these loading configurations has demonstrated that on an independent (or single region) basis the storage pool multiplication factor is less than the 0.95 regulatory limit. The multiplication factor for a mixture of these

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-9

regions would be expected to also remain below 0.95 if the net transfer of neutrons from one region to another does not increase significantly.

Exelon commits to expand the placement of inserts into one row and one column of the adjacent region as necessary to completely surround all assemblies that are part of the insert region with four wings of the NETCO-SNAP-IN inserts*. As addressed in Section 6.8, the reactivity of future ATRIUM-10 fuel assemblies will not exceed the reference bounding assembly of this analysis. With these restrictions in place, the system k-eff of a pool comprised of insert regions mixed with degraded Boraflex regions will be lower than the maximum reported single region value. This occurs because replacement of a large portion of the storage area with another that has a lower multiplication factor decreases the multiplication factor of the entire storage area. KENO evaluations have demonstrated that the resulting k-eff for a system composed of two regions is between that of the individual systems composed of single regions.

The overall conclusion from this multi-region analysis is that the spent fuel pool will have a $k_{95/95}$ value less than or equal to 0.95. This conclusion is reached without crediting residual boron within the insert region.

^{*} An exception to this would be peripheral regions of the rack that have no adjacent region.

ANP-2843(NP) Revision 1 Page 6-10

Table 6.1 Summary of CASMO-4 Maximum Reactivity Results for the ATRIUM-10 Fuel Assembly

Characteristics of the Reference Bounding Fuel Lattices

ATRIUM-10 lattice 4.57 wt% U-235 distributed enrichment up to 126" 4.47 wt% U-235 distributed enrichment above 126" 10 gadolinia rods with 3.5 wt% Gd₂O₃ above 126" and 6.0 wt% Gd₂O₃ from 0" to 126" Standard 100 mil Channel No xenon in cold calculations Top and bottom lattice geometry explicitly modeled Reflective boundary for in-core Periodic boundary for in-rack

Limiting Conditions

Top Lattice Exposure 11.5 GWd/MTU 40% void history

Intermediate Lattice Exposure 16.0 GWd/MTU 40% void history

Bottom Lattice Exposure 16.5 GWd/MTU 40% void history

Calculated Bounding Lattice Reactivity

Condition		<u>Maximum k</u> _∞	
<u>oonanion</u>	Top Lattice	Intermediate Lattice	Bottom Lattice
In-Core, 20°C (68°F)	1.288	1.244	1.241
In-Rack*, 20°C (68°F)	0.917	0.886	0.883
In-Rack, 4°C (39.2°F)	0.9185	0.8869	0.8843

* In-Rack implies the Unit 2 spent fuel pool without Boraflex and with NETCO-SNAP-IN inserts.

Table 6.1 Summary of CASMO-4 Maximum Reactivity Results for the ATRIUM-10 Fuel Assembly (Continued)

REBOL Lattice Conditions

ATRIUM-10 top or bottom geometry with uniform enrichment distribution 3.05 wt% U-235 (above 126") 2.72 wt% U-235 (from 96" to 126") 2.66 wt% U-235 (from 0" to 96") No gadolinia BOL (zero exposure) Standard 100 mil Channel No xenon Top and bottom lattice geometry explicitly modeled Reflective boundary for in-core Periodic boundary for in-rack

Calculated REBOL Lattice Reactivity

Condition		<u>Maximum k</u> _∞	
Onduon	Top Lattice	Intermediate Lattice	Bottom Lattice
In-Core, 20°C (68°F)	1.342	1.309	1.308
In-Rack*, 20°C (68°F)	0.926	0.895	0.892
In-Rack, 4°C (39.2°F)	0.929	0.898	0.895

^{*} In-Rack implies the Unit 2 spent fuel pool without Boraflex and with NETCO-SNAP-IN inserts.

ANP-2843(NP) Revision 1 Page 6-12

Table 6.2 Summary of KENO V.a Maximum In-Rack Reactivity for ATRIUM-10 Fuel

Fuel Assembly

ATRIUM-10 top geometry REBOL Lattice (above 126") 3.05 wt% U-235 uniform enrichment ATRIUM-10 top geometry REBOL Lattice (96" to 126") 2.72 wt% U-235 uniform enrichment ATRIUM-10 bottom geometry REBOL Lattice (from 0" to 96") 2.66 wt% U-235 uniform enrichment

No gadolinia No xenon Zero exposure Standard 100 mil Channel* Top and bottom lattice geometry explicitly modeled Periodic boundary conditions

Storage Array Configuration

13x13 array with periodic boundary conditions in all directions Storage cell pitch preserved across storage rack boundaries Neutron absorbing, chevron shaped insert in each storage cell Assembly centered in cell water volume (not centered relative to stainless steel box) 4°C moderator and fuel temperatures

Maximum Rack Reactivity

Description	k-eff	
In-Rack 4°C (39.2°F) k-eff	0.916 ± 0.001	
Maximum $k_{95/95}$ Reactivity (including uncertainties, biases, manufacturing tolerances and worst accident or abnormal loading conditions)	0.940	

^{*} Relative to array reactivity there is no significant difference between the 100 mil and the AREVA Advanced Fuel Channel.

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 6-13

Table 6.3 Manufacturing Reactivity Uncertainties

(Based upon BOL conditions using KENO V.a except as noted. Δk results of 0.0007 indicate cases where the differences were less than the uncertainty of the calculation)

Quantity	Nominal Value	Tolerance	Δk	ζ _∞
(Reactivity L	Incertainty of Fuel Assem	bly Tolerance Values)		
Fuel rod pitch	0.510 in.	[]
Fuel enrichment	4.57 wt% U235	[]
Fuel density	96.26% TD	[]
Channel bulge	0	[]
Pellet diameter	0.3413 in.	ſ]
Clad diameter - outer/inner	0.3957/0.3480 in.	[]
Pellet void volume [‡]	1.2%	[]		-
Gadolinia concentration§	3.5 wt%	[]		
	6.0 wt%	[]
(Reacti	vity Uncertainty of Rack T	olerance Values)		
Areal B-10 density	≥0.0086 g B10/cm ²	Min value was used		-
Insert thickness	0.065 in.	±0.005 in.		-
SS wall thickness	0.090 in.	±0.009 in.	[]
Storage cell pitch	6.255 in.	Ĩ]
Storage cell inside dimension	<u>6.0 in.</u>	<u>±0.020 in.</u>	1	1
Statistical combination of uncertainties ^{††}			[]
Reported Value			0.01	105

[†] This value is equally valid for a fuel density of 95.85% TD.

^{*} Value is based upon component measurements at approximate peak reactivity exposures.

[‡] This is an insignificant parameter; its effect was combined with the U235 enrichment result.

 $^{^{\$}}$ The gadolinia uncertainty Δk includes a CASMO-4 based 0.002 Δk adder which accounts for differences at peak reactivity conditions.

^{**} Calculations confirmed that the storage vault reactivity is not affected by the thickness of the insert. This is expected because the B-10 density is defined as an areal density.

^{tt} This is based upon the square root of the sum of the squares for all independent tolerance conditions.

Storage Cell Configuration* (X,Y)	Location within 24X24 array [†]
1x1	Center of array
2x2	Center of array
1X1	NE corner of array
4x1	NE corner of array
2x2	NE corner of array
1X4	NE corner of array
1X2	Center East side of array
2X1	Center East side of array
2x2	Center East side of array
3x3	Center East side of array
2x2	Center West side of array
1X4	SW corner of array
4X1	SW corner of array

Table 6.4 Evaluation for Inaccessible Storage Locations

^{*} These locations do not contain a neutron absorbing insert or a fuel assembly.

[†] Locations (N, S ,E, or W) are relative to the computer model only.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	
Storage Pool Criticality Safety Analysis with	
Neutron Absorbing Inserts and Without Boraflex	

7.0 Conclusions

This analysis demonstrates that all fuel assemblies delivered to the LaSalle Station (both Units 1 and 2) as of July 2009 can be safely stored in the LaSalle Unit 2 spent fuel pool with NETCO-SNAP-IN inserts. Future ATRIUM-10 fuel designs that meet the design requirements specified in Table 2.1 or that can be shown to be bounded by the reference bounding assembly can be safely stored in the LaSalle Unit 2 spent fuel pool. The array k-eff determined herein for the reference assembly, including all uncertainties, biases, manufacturing tolerances and worst accident or abnormal loading conditions is 0.940.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page 8-1

8.0 **References**

- 1. Commonwealth Edison LaSalle Station Unit 2 Spent Fuel Storage Capacity Modification Safety Analysis Report, 8601-00-0084, Revision 8, August 1986.
- 2. NUREG/CR-0200 Revision 6, SCALE Version 4.4 A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluation, Oak Ridge National Laboratory, May 2000.
- 3. NUREG/CR-6698, *Guide for Validation of Nuclear Criticality Safety Calculational Methodology*, Nuclear Regulatory Commission, January 2001.
- 4. US Tool and Die Drawing 8601-7 Revision 4, "Commonwealth Edison Co. LaSalle County Station Unit-2 Spent Fuel Storage Racks Fuel Box Assembly & Groups", released by Sargent & Lundy, April 1990.
- 5. NET-259-03 Revision 5, "Material Qualification of ALCAN Composite for Spent Fuel Storage," Northeast Technology Corp., July 2009.
- 6. Code of Federal Regulations, Title 10, Part 50, Section 68, "Criticality Accident Requirements."
- 7. NUREG-0800, Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, Section 9.1.1 Revision 3 (Criticality Safety of Fresh and Spent Fuel Storage and Handling), U.S. Nuclear Regulatory Commission, March 2007.
- Design Requirements for Light Water Reactor Spent Fuel Storage Facilities at Nuclear Power Plants, ANSI/ANS American National Standard 57.2-1983, American Nuclear Society, October 1983, (withdrawn 1993).
- 9. Criticality Safety Criteria for the Handling, Storage and Transportation of LWR Fuel Outside Reactors, ANSI/ANS American National Standard 8.17-1984, American Nuclear Society, January 1984, (withdrawn 2004).
- 10. Letter, Brian K. Grimes, Assistant Director for Engineering and Projects Division of Operating Reactors, U.S. Nuclear Regulatory Commission, to All Power Reactor Licensees, "OT Position for the Review and Acceptance of Spent Fuel Storage and Handling Applications," April 14, 1978, as amended by letter, January 18, 1979.
- 11. Letter, Laurence Kopp (Reactor Systems Branch, NRC) to Timothy Collins, Chief (Reactor Systems Branch-NRC), Subject: "Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light-Water Reactor Power Plants," August 19, 1998.
- 12. EMF-2158(P)(A) Revision 0, Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2, Siemens Power Corporation, October 1999.

Appendix A Sample CASMO-4 Input

Tables A.1, A.2, and A.3 provide the in-rack CASMO-4 models for the reference bounding lattices defined by this analysis.

ATRIUM-10 fuel which does not conform to the enrichment and gadolinia requirements described in Table 2.1 and Figure 2.1 can be analyzed for storage in the spent fuel pool racks by adapting the CASMO-4 sample inputs presented in Table A.1, A.2 or A.3. For bottom lattices the evaluation should be completed with both [_____] depletions. Intermediate and top lattices should be evaluated at both [_____] depletions. If the lifetime maximum in-rack k_{∞} of the new lattice is less than the k_{∞} of the corresponding reference bounding lattice, the ATRIUM-10 fuel assembly can be safely stored in the LaSalle Unit 2 Nuclear Power Station spent fuel storage rack.

If a different version of CASMO-4 is used, it is recommended that the sample cases for the reference bounding lattices (provided in Tables A.1 through A.3) be re-evaluated to establish that the version of CASMO-4 and the underlying libraries being used are consistent with those used in this report. Small changes, less than $0.005 \Delta k$ from the results in this report, are acceptable and can be used to establish new k_∞ limits for comparison to the new lattices (i.e. the comparison should be performed based upon the same calculational basis). Larger changes from the results contained in this report represent more significant changes in the underlying model and may require additional CASMO-4 to KENO benchmarking.

Table A.1 CASMO-4 Input for ATRIUM-10 Top Reference Bounding Lattice

```
TTL * A10T-4470L-10G35 BL - .40 VB
TFU= 814.3
TMO= 560.3
VOI=40
FUE, 1,10.42349/ 2.5000
FUE, 2,10.42349/ 3.4000
FUE, 3,10.42349/ 4.2000
FUE, 4,10.29433/ 4.4100,64016= 3.5000
FUE, 5,10.42349/ 4.6900
FUE, 6,10.42349/ 4.8000
FUE, 7,10.42349/ 4.9500
BWR, 10, 1.29540, 13.40612, 0.25400, 0.66294, 0.66294, 1.2700, 1
THE,0
FUM,0,2
PIN, 1,0.43345,0.44196,0.50254
PIN, 2,1.67767,1.75006/'MOD', 'BOX'//-9
PIN, 3,0.44196,0.50254/'COO','COO'
LPI
1
1 3
1 1 1
1 1 1 1
1 3 1 1 2
1 1 1 1 2 2
1 1 1 1 2 2 2
1 1 1 1 1 1 1 1
1 3 1 1 1 3 1 1 3
1 1 1 1 1 1 1 1 1 1
LFU
 1
 2
    0
       7
  3
    7
          7
 5
       7
    4
 5
    0 7
          7
             0
    4 7
  5
          7
             0 0
  5
    7
       7
          7
             0 0 0
  3
    7
       7
          7
             4 6 3 3
       7
             7
  2
    0
          4
                0 4
                         0
                      7
 1 2 3 6
             5
                5
                    6
                      3 2 1
     51.9538, 'KWL'
PDE,
DEP 0.0,0.1,0.5,1,1.5,2,2.5,3,3.5,4,4.5,5,5.5,6,6.5,7,7.5,8,8.5,9,9.5,10,10.5,
   11,11.5,12,12.5,13,13.5,14,14.5,15
STA
TTL *+LaSalle Rack at 4 deg. C (No BF with Boral Insert)
RES,,0,9,-15
VOI,00
TMO, 277.1 TFU, 277.1 PDE,0
CNU, 'FUE', 54135, 1.0E-14
BCO 'PER'
GAP 4*0.49784
MI1 0.05209/5010=100.0
MI2 5.8408/347=94.89 1001=0.57 8000=4.54
FST 4*0.16510/4*0.32385/2*'MOD' 5*'MI1' 'MOD'/8*'MI2'/
STA
END
```

ANP-2843(NP) Revision 1 Page A-3

Table A.2 CASMO-4 Input for ATRIUM-10 Intermediate Reference Bounding Lattice

```
TTL * A10T-4570L-10G60 BL - .40 VB
TFU= 814.3
TMO= 560.3
VOI=40
FUE, 1,10.42349/ 2.5000
FUE, 2,10.42349/ 3.6000
FUE, 3,10.42349/ 4.4000
FUE, 4,10.20471/ 4.5500,64016= 6.0000
FUE, 5,10.42349/ 4.8000
FUE, 6,10.42349/ 4.9500
BWR, 10, 1.29540, 13.40612, 0.25400, 0.66294, 0.66294, 1.2700, 1
THE,0
FUM, 0, 2
PIN, 1,0.43345,0.44196,0.50254
PIN, 2,1.67767,1.75006/'MOD','BOX'//-9
PIN, 3,0.44196,0.50254/'COO','COO'
LPI
1
1 3
 1 1 1
1 1 1 1
1 3 1 1 2
 1 1 1 1 2 2
 1 1 1 1 2 2 2
1 1 1 1 1 1 1 1
1 3 1 1 1 3 1 1 3
 1 1 1 1 1 1 1 1 1 1
LFU
  1
  2
    0
  3
       6
    6
  6
     4
        6
           6
  6
    0
       6
          60
    4 6
  6
          600
  6
     6
        6
           6
              0
                 0
                    0
  3
        6
           6
              4
                 5
                    3
                       3
     6
  2
    0
        6
           4
              6
                 0
                    4
                       6
                         0
  1
    2 3 5 6 6 5
                       3 2 1
       51.9538, 'KWL'
PDE,
DEP 0.0,0.1,0.5,1,1.5,2,2.5,3,3.5,4,4.5,5,5.5,6,6.5,7,7.5,8,8.5,9,9.5,10,10.5,
    11,11.5,12,12.5,13,13.5,14,14.5,15,15.5,16,16.5,17,17.5,18,18.5,19,19.5,20,
    20.5, 21, 21.5, 22, 22.5, 23, 23.5, 24, 24.5, 25
STA
TTL *+LaSalle Rack at 4 deg. C (No BF with Boral Insert)
RES,,0,11,-25
VOI,00
TMO, 277.1 TFU, 277.1 PDE,0
CNU, 'FUE', 54135, 1.0E-14
BCO 'PER'
GAP 4*0.49784
MI1 0.05209/5010=100.0
MI2 5.8408/347=94.89 1001=0.57 8000=4.54
FST 4*0.16510/4*0.32385/2*'MOD' 5*'MI1' 'MOD'/8*'MI2'/
STA
END
```

ANP-2843(NP) Revision 1 Page A-4

Table A.3 CASMO-4 Input for ATRIUM-10 Bottom Reference Bounding Lattice

```
TTL * A10B-4570L-10G60 BL - .40 VB
TFU= 791.6
TMO= 560.3
VOI=40
FUE, 1,10.42349/ 2.5000
FUE, 2,10.42349/ 3.6000
FUE, 3,10.42349/ 4.4000
FUE, 4,10.20471/ 4.4600,64016= 6.0000
FUE, 5,10.42349/ 4.8000
FUE, 6,10.42349/ 4.9500
BWR, 10, 1.29540, 13.40612, 0.25400, 0.66294, 0.66294, 1.2700, 1
THE,0
FUM, 0, 2
PIN, 1,0.43345,0.44196,0.50254
PIN, 2,1.67767,1.75006/'MOD','BOX'//-9
LPI
 1
1 1
1 1 1
1 1 1 1
1 1 1 1 2
1 1 1 1 2 2
1 1 1 1 2 2 2
 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1
1 1 1 1 1 1 1 1 1 1
LFU
  1
  2
    3
  3
    66
  6
    4
       66
    6 6 6 0
  6
  6
    4 6 6 0 0
  6
    6 6 6 0 0 0
  3 6 6 6 4 5 3 3
  2 3 6 4
             6 6 4 6 3
  1 2 3 5
             6 6 5 3 2 1
     51.9538, 'KWL'
PDE,
DEP 0.0,0.1,0.5,1,1.5,2,2.5,3,3.5,4,4.5,5,5.5,6,6.5,7,7.5,8,8.5,9,9.5,10,10.5,
   11, 11.5, 12, 12.5, 13, 13.5, 14, 14.5, 15, 15.5, 16, 16.5, 17, 17.5, 18, 18.5, 19, 19.5, 20,
   20.5,21,21.5,22,22.5,23,23.5,24,24.5,25
STA
TTL *+LaSalle Rack at 4 deg. C (No BF with Boral Insert)
RES,,0,11,-25
VOI,00
TMO, 277.1 TFU, 277.1 PDE,0
CNU, 'FUE', 54135, 1.0E-14
BCO 'PER'
GAP 4*0.49784
MI1 0.05209/5010=100.0
MI2 5.8408/347=94.89 1001=0.57 8000=4.54
FST 4*0.16510/4*0.32385/2*'MOD' 5*'MI1' 'MOD'/8*'MI2'/
STA
END
```

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page B-1

Appendix B Reactivity Comparison for Assemblies Used in the LaSalle Reactors

The following tables present a comparison of in-rack CASMO-4 k_∞ values* (without Boraflex and with NETCO-SNAP-IN inserts) of the more reactive lattices of the different fuel assembly types used at or manufactured for the LaSalle Unit 1 or Unit 2 reactors prior to July 2009. For each assembly type, the more reactive lattices have been identified using a comparison of the U235 enrichment levels and the gadolinia concentrations. The comparisons are made based on three axial zones, 0" to 96", 96" to 126", and 126" to 149". The ATRIUM-9 458L-8G6 lattice is the most reactive as-fabricated design from 0" to 96" and from 96" to 126", and the ATRIUM-10T-4444L-12G40 lattice is the most reactive as fabricated design from 126" to 149". In the following tables LSA and LSB refer to LaSalle unit 1 or 2, respectively.

The following comparison table shows that the ATRIUM-10 reference bounding lattices described in Table 6.1 are equal to or more reactive than any of the lattices used in the LaSalle reactors. (Also note that the REBOL lattices used in the KENO V.a calculations are more reactive than the reference bounding lattices).

* [

Limiting As-Fabricated Intermediate

Table B.1 Lattice Reactivity Comparisons(REBOL, Bounding, and Limiting)

		Maximum In-Rack k∞ (CASMO-4)		
Case Description	Lattice Description	4 °C	20 °C	
REBOL, Top Lattice 126" to 149"	A10T-305L0G0	0.929	0.926	
Reference Bounding Top Lattice 126" to 149"	A10T-447L10G35	0.919	0.917	
Limiting As-Fabricated Top Lattice 126" to 149"	A10T-4444L12G40	0.907	0.906	
REBOL, Intermediate Lattice 96" to 126"	A10T-272L0G0	0.898	0.895	
Reference Bounding Intermediate Lattice 96" to 126"	A10T-457L10G60	0.887	0.886	

Lattice 96" to 126"	//3-4002000	0.004	0.000
REBOL, Bottom Lattice 0" to 96"	A10B-266L0G0	0.895	0.892
Reference Bounding Bottom Lattice 0" to 96"	A10B-457L10G60	0.884	0.883
Limiting As-Fabricated Bottom Lattice 0" to 96"	A9-458L8G6	0.884	0.883

A9-458L8G6

0.884

0.883

Case*	Lattice [†]	Maxi	Unit and Cycle		
		4 °C	20 °C	100 °C	Loaded
Т	A10T-4444L12G40	0.907	0.906	0.895	
	I	r			
1	A10T-2111L0G0	0.825	0.822	0.803	LSB Cy10
2	A10T-3947L13G38	0.882	0.881	0.870	LSB Cy13
3	A10T-4444L12G40	0.907	0.906	0.895	LSA Cy13
4	A10T-4409L10G45	0.907	0.905	0.895	LSB Cy12
4a	A10T-4400L10G45	0.907	0.905	0.895	LSA Cy12
I	A9-458L8G6	0.884	0.883	0.875	
1	A10T-2111L0G0	0.825	0.822	0.803	LSB Cy10
5	A10T-4313L15G65	0.860	0.859	0.850	LSB Cy10
6	A10T-4524L13GV70	0.860	0.858	0.849	LSB Cy13
7	A10T-4511L15GV80	0.840	0.839	0.830	LSB Cy13

Table B.2 ATRIUM-10 Fuel Lattice Reactivity Comparison

^{*} T, I, and B indicate the most reactive top, intermediate, and bottom lattice cases, respectively.

[†] Note that A10T and A10B indicate top and bottom ATRIUM-10 lattice geometry. A9 indicates ATRIUM-9.

Case*	Lattice [†]	Мах	Unit and Cycle		
		4 °C	20 °C	100 °C	Loaded
В	A9-458L8G6	0.884	0.883	0.875	
				.	• • •
8	A10B-1831L-0G0	0.785	0.782	0.764	LSB Cy10
9	A10B-4399L12G65	0.871	0.869	0.860	LSA Cy13
10	A10B-4537L13GV70	0.857	0.856	0.847	LSB Cy13
11	A10B-4510L13G75	0.863	0.862	0.853	LSA Cy10
12	A10B-4538L13GV80	0.844	0.843	0.834	LSB Cy13

Table B.2 ATRIUM-10 Fuel Lattice Reactivity Comparison (Continued)

^{*} T, I, and B indicate the most reactive top, intermediate, and bottom lattice cases, respectively.

[†] Note that A10T and A10B indicate top and bottom ATRIUM-10 lattice geometry. A9 indicates ATRIUM-9.

Case*	Lattice [†]	Maxi	Unit and Cycle		
		4 °C	20 °C	100 °C	Loaded
Т	A10T-4444L12G40 0.907		0.906	0.895	
1	DXMT-4056L12G40	0.880	0.879	0.869	LSB Cy13 [‡]
I	A9-458L8G6	0.884	0.883	0.875	
2	DXMT-4176L14GV60	0.852	0.851	0.842	LSB Cy13
	1		· · · ·		Y •••
В	A9-458L8G6	0.884	0.883	0.875	
2	DXMT-4176L14GV60	0.852	0.851	0.842	LSB Cy13
3	DXMB-4365L14GV80	0.840	0.839	0.830	LSB Cy13

Table B.3 ATRIUM 10XM Fuel Lattice Reactivity Comparison

^{*} T, I, and B indicate the most reactive top, intermediate, and bottom lattice cases, respectively.

[†] Note that A10T and A10B indicate top and bottom ATRIUM-10 lattice geometry. A9 indicates ATRIUM-9.

^{* 8} ATRIUM 10XM lead use assemblies have been manufactured as part of the reload fuel for LaSalle Unit 2 Cycle 13.

Casat		Max	Unit and		
Case		4 °C	20 °C	100 °C	Cycle Loaded
Т	A10T-4444L12G40	0.907	0.906	0.895	
					· · · · · · · · · · · · · · · · · · ·
1 & B	A9-458L8G6	0.884	0.883	0.875	
				-	
1	A9-396L8G5	0.875	0.874	0.865	LSA&B Cy9
2	A9-458L8G6	0.884	0.883	0.875	LSA&B Cy9
3	A9-459L12G7	0.870	0.869	0.861	LSA Cy9
4	A9-459L12G8	0.858	0.857	0.850	LSA Cy9

Table B.4 ATRIUM-9 Fuel Lattice Reactivity Comparison

^{*} T, I, and B indicate the most reactive top, intermediate, and bottom lattice cases, respectively.

[†] Note that A10T indicates top ATRIUM-10 lattice geometry and A9 indicates ATRIUM-9.

Case*		Maxi	Unit and		
Case"	Lattice	4 °C	20 °C	100 °C	Cycle Loaded
Т	A10T-4444L12G40	0.907	0.906	0.895	
1	GE14-429L6G70-9G60	0.849	0.847	0.838	LSB Cy11
2	GE14-430L2G80-7G70-5G60	0.844	0.843	0.834	LSB Cy11
3	GE14-446L-10G80-4G70	0.844	0.842	0.834	LSA Cy11
	•			<u> </u>	· · · · · · · · · · · · · · · · · · ·
I	A9-458L8G6	0.884	0.883	0.875	
		-			
1	GE14-429L6G70-9G60	0.849	0.847	0.838	LSB Cy11
2	GE14-430L2G80-7G70-5G60	0.844	0.843	0.834	LSB Cy11
3	GE14-446L-10G80-4G70	0.844	0.842	0.834	LSA Cy11
	· · · · · · · · · · · · · · · · · · ·	1	· · · · · · · · · · · · · · · · · · ·	·	r
В	A9-458L8G6	0.884	0.883	0.875	
	1			•	
4	GE14-435L6G70-9G60	0.841	0.840	0.830	LSB Cy11
5	GE14-437L2G80-7G70-5G60	0.834	0.832	0.823	LSB Cy11
6	GE14-451L10G80-4G70	0.834	0.833	0.824	LSA Cy11
6a	GE14-451L11G80-4G70	0.842	0.841	0.832	LSA Cy11

Table B.5 GE14 Fuel Lattice Reactivity Comparison

^{*} T, I, and B indicate the most reactive top, intermediate, and bottom lattice cases, respectively.

[†] Note that A10T indicates top ATRIUM-10 lattice geometry and A9 indicates ATRIUM-9. GE14 indicates GE14 geometry.

Case* Lattice [†]	t	Max	Unit and		
	Lattice	4 °C	20 °C	100 °C	Cycle Loaded
Т	A10T-4444L12G40	0.907	0.906	0.895	
1&B	A9-458L8G6	0.884	0.883	0.875	
1	8x8_2-319L6G30	0.858	0.857	0.844	LSB Cy3
2	8x8_2-340L7G30	0.869	0.867	0.855	LSB Cy3
3	8x8_4-338L7G30	0.863	0.861	0.850	LSB Cy5
4	8x8_4-388L8G40	0.875	0.874	0.863	LSA Cy8

Table B.6 GE 8x8 Fuel Lattice Reactivity Comparison

^{*} T, I, and B indicate the most reactive top, intermediate, and bottom lattice cases, respectively.

[†] Note that A10T indicates top ATRIUM-10 lattice geometry and A9 indicates ATRIUM-9. 8x8_2 implies an 8x8 lattice with 2 water rods and 8x8_4 indicates an 8x8 lattice with a large internal water rod encompassing the area of 4 pin cells, i.e. GE9 fuel.

Appendix C KENO V.a Bias and Bias Uncertainty Evaluation

The purpose of the present analysis is to determine the bias of the k_{eff} calculated with the SCALE 4.4a computer code for spent fuel pool criticality analysis. A statistical methodology is used to evaluate criticality benchmark experiments that are appropriate for the expected range of parameters. The scope of this report is limited to the validation of the KENO V.a module and CSAS25 driver in the SCALE 4.4a code package for use with the 44 energy group cross-section library 44GROUPNDF5 for spent fuel criticality analyses.

This calculation is performed according to the general methodology described in Reference C.2 (NUREG/CR-6698 "Guide for Validation of Nuclear Criticality Safety Calculational Methodology") that is also briefly described in Section C.1. The critical experiments selected to benchmark the computer code system are discussed in Section C.3. The results of the criticality benchmark calculations, the trending analysis, the basis for the statistical technique chosen, the bias, and the bias uncertainty are presented in Sections C.4—C.7. Final results are summarized in Section C.8.

C.1 Statistical Method for Determining the Code Bias

As presented in Reference C.2 (NUREG/CR-6698), the validation of the criticality code must use a statistical analysis to determine the bias and bias uncertainty in the calculation of k_{eff} . The approach involves determining a weighted mean of k_{eff} that incorporates the uncertainty from both the measurement (σ_{exp}) and the calculation method (σ_{calc}). A combined uncertainty can be determined using the Equation 3 from Reference C.2, for each critical experiment:

$$\sigma_{\rm t} = (\sigma_{\rm caic}^2 + \sigma_{\rm exp}^2)^{1/2}$$

The weighted mean of k_{eff} (\bar{k}_{eff}), the variance about mean (s), and the average total uncertainty of the benchmark experiments ($\bar{\sigma}^2$) can be calculated using the weighting factor $1/\sigma_r^2$ (see Eq. 4, 5, and 6 in Reference C.2). The final objective is to determine the square root of the pooled variance, defined as (Eq. 7 from Reference C.2): The above value is used as the mean bias uncertainty, where bias is determined by the relation:

$$Bias = \vec{k}_{eff} - 1$$
, if \vec{k}_{eff} is less than 1, otherwise Bias = 0 (Eq.8 from Reference C.2)

The approach for determining the final statistical uncertainty in the calculational bias relies on the selection of an appropriate statistical treatment. Basically, the same steps and methods suggested in Reference C.2 for determining the upper safety limit (USL) can be applied also for determining the final bias uncertainty.

First, the possible trends in bias need to be investigated. Trends are identified through the use of regression fits to the calculated k_{eff} results. In many instances, a linear fit is sufficient to determine a trend in bias. Typical parameters used in these trending analyses are enrichment, H/X or a generic spectral parameter such as the energy of the average lethargy causing fission (EALF).

Reference C.2 indicates that the use of both weighted or unweighted least squares techniques is an appropriate means for determining the fit of a function. For the present analysis linear regression was used on both weighted and unweighted k_{eff} values to determine the existence of a trend in bias. Typical numerical goodness of fit tests were applied afterwards to confirm the validity of the trend.

When a relationship between a calculated k_{eff} and an independent variable can be determined, a one-sided lower tolerance band may be used to express the bias and its uncertainty (Reference C.2). When no trend is identified, the pool of k_{eff} data is tested for normality. If the data is normally distributed, then a technique such as a one-sided tolerance limit is used to determine bias and its uncertainty. If the data is not normally distributed, then a non-parametric analysis method must be used to determine the bias and its uncertainty (Reference C.2). Similar examples of application of these techniques are included in References C.4 and C.5.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	
Storage Pool Criticality Safety Analysis with	
Neutron Absorbing Inserts and Without Boraflex	

C.2 Area of Applicability Required for the Benchmark Experiments

BWR spent fuel pools will primarily contain commercial nuclear fuel in uranium oxide pins in a square array. This fuel is characterized by the typical parameter values provided in Table C.1. These typical values were used as primary tools in selecting the benchmark experiments appropriate for determining the code bias.

Benchmark calculations have been made on selected critical experiments, chosen, in so far as possible, to bound the range of variables in the spent fuel rack analyses. In rack designs, the most significant parameters affecting criticality are: (1) the fuel enrichment, (2) the ¹⁰B loading in the neutron absorber, and (3) the lattice spacing. Other parameters have a smaller effect but have been also included in the analyses.

One possible way of representing the data is through a spectral parameter that incorporates influences from the variations in other parameters. Such a parameter is computed by KENO V.a, which prints the "energy of the average lethargy causing fission" (EALF). The expected range for this parameter in the analyses was also included in Table C.1.

Table C.1 Range of Values of Key Parameters in Spent Fuel Pool

Parameter Fissile material – Physical/Chemical Form Enrichment Moderation/Moderator Lattice Pitch Clad Anticipated Absorber/Materials H/X ratio Reflection

Neutron Energy Spectrum (Energy of the Average Lethargy Causing Fission) Range of Values UO₂ rods natural to 5.00 wt% U-235 Heterogeneous/Water Square 1.2 to 1.45 cm Zircaloy Aluminum, Boron Stainless Steel 0 to 473 Water, Stainless Steel 0.1 to 2.5 eV

C.3 Description of the Criticality Experiments Selected

The set of criticality benchmark experiments has been constructed to accommodate large variations in the range of parameters of the rack configurations and also to provide adequate statistics for the evaluation of the code bias.

One hundred critical configurations were selected from various sources. These benchmarks include configurations performed with lattices of UO_2 fuel rods in water having various enrichments and moderating ratios (H/X). A set of MOX criticality benchmarks is also included in the present set. The area of applicability (AOA) is established within this range of benchmark experiment parameter values.

A brief description of the selected benchmark experiments is presented in Table C.2. The table includes the references where detailed descriptions of the experiments are presented.

ANP-2843(NP) Revision 1 Page C-5

Table C.2 Descriptions of the Critical Benchmark Experiments

Case Name d K _{eff} MUREC/CR:0073 PNL experiments (Reference C.3) None Water and acylic plates as well as a boot on 25.4 c006b 1.0000 0.0021 UC, pellets with 4.31 wt% ⁴⁵ U 0.625 cm Al plates acylic plates as well as a boot acylic plates as well as a boot acylic plates as boot acylic plates as boot acylic plates as a disorber plates with a 1.0000 Water and acylic plates as a disorber plates with aboot acylic plates and the acylic plates acylic plates and the acylic plates acylic plates and the acylic plates a	Experiment	Measure	σexp	Brief Description	Neutron Absorber	Reflector
NURE G/CR:0073 PNL experiments (Reference C.3) None Water and accord	Case Name	d k _{eff}				The second s
Clocketor Levols PNL experiments (relefance C.3) None Water and 0.625 cm Al plates c006b 1.0000 0.0021 Cluster of fuel rods on a 25.4 m printch. Moderator; water or borated water. None 0.625 cm Al plates 0.302 cm SS-304L plates Water and outplates as plates of material. A material. A materi				D.C. DAV		
C004 1.0000 0.0020 Cluster of fuel rods on a 25.4 mm pitch. Moderator; water or 0.007a None Water and 0.625 cm Al plates Water and 0.625 cm Al plates 0008b 1.0000 0.0021 Various separation distances used between clusters. Those of loci 1b 0.625 cm Al plates 0.626 cm Al plates	NUREG/CR-U	JU/3 PNL ex	periments (N	NAC 1 1
Cluster Cluster <t< td=""><td>C004</td><td>1.0000</td><td>0.0020</td><td>UU_2 pellets with 4.31 wt% = U</td><td>None</td><td>water and</td></t<>	C004	1.0000	0.0020	UU_2 pellets with 4.31 wt% = U	None	water and
c005b 1.0000 0.0021 biological shield serve as primary reflector c007a 1.0000 0.0021 Various separation distances used between clusters to indicated have plates of neutron absorbing material poison placed between clusters of fuel rods. 0.293 cm SS-304L, asother plates in the water into the variable into variable into the variable into the variable into v	C005b	1.0000	0.0018	Cluster of fuel rods on a 25.4	0.625 cm Al plates	acrylic plates as
c007a 1.0000 0.0021 Doraced Water. 0.302 cm S3.04L biological sheed c008b 1.0000 0.0021 various separation distances 0.238 cm S3.04L biological sheed c010b 1.0000 0.0021 various separation distances 0.238 cm S3.04L biological sheed c011b 1.0000 0.0021 oindicated have plates of 0.485 cm S3.04L biological sheed c011b 1.0000 0.0021 of fuel rods. various separation distances various separation dis	C006b	1.0000	0.0019	mm pitch. Woderator, water or	0.625 cm Al plates	well as a
c003b 1.0000 0.0021 Various separation distances plates plates serve as primary c010b 1.0000 0.0021 used between clusters bisonber plates with absorber plates with noinor contribution c011b 1.0000 0.0021 poison placed between clusters of fuel rods. 0.485 cm SS304L bisonber plates contribution c013b 1.0000 0.0021 of fuel rods. 0.485 cm SS304L plates contribution c030b 1.0000 0.0021 contribution contribution contribution c031b 1.0000 0.0021 3.33 array of fuel clusters. Zircaloy-4 absorber bisolved as metron absorbers. aclp1 1.0000 0.0005 Stel and boron-aluminum sheets None aluminum base aclp5 1.0000 0.0007 Stel and boron-aluminum sheets None None None aclp6 1.0007 0.0006 ses oindicated also had Stel and boron None None aclp3 1.0000 0.0007	c00/a	1.0000	0.0021	borated water.	0.302 cm SS-304L	biological shield
C009b 1.0000 0.0021 Description Description Constrained frame plates of poison placed between clusters of poison placed between clusters of fuel rods. Description Contribution C	c008b	1.0000	0.0021	various separation distances	plates	serve as primary
C010b 1.0000 0.0021 So finiticated have plates of oneutron absorbing material poison placed between clusters of fuel rods. absorbing material of with 8 absorbing material out with 8 absorbing material with 8 absorbing material with 8 absorbing material with 8 absorbing material with 8 absorbing with 8 absorbing material with 8 <td>c009b</td> <td>1.0000</td> <td>0.0021</td> <td>as indicated have plates of</td> <td>0.298 cm SS-304L</td> <td>reliector</td>	c009b	1.0000	0.0021	as indicated have plates of	0.298 cm SS-304L	reliector
c011b 1.0000 0.0021 Pleaded association association material poison placed between clusters of fuel rods. 1.05 W7 90 1.62 contribution comes from the channel that supports the rod clusters of fuel rods. c012b 1.0000 0.0021 of fuel rods. 2/2 realoy-4 absorber plates contribution steel tank wall. c030b 1.0000 0.0021 of fuel rods. 2/2 realoy-4 absorber plates gran carbon steel tank wall. c031b 1.0000 0.0021 contribution association and the gran carbon steel tank wall. 9.52 mm carbon steel tank wall. c031b 1.0000 0.0005 Enrichments of 2.459 wt% ²⁵ U None Water and aluminum bases aclp1 1.0000 0.0005 Sax3 array of fuel clusters. None None None aclp5 1.0000 0.0007 cases so indicated also had disolved boron in the water None None None None aclp7 0.9998 0.0007 cases so indicated also had disolved boron in the water None None None None aclp11 1.0007 0.0006 aclp11 0.0007 aclp11 nono	c010b	1.0000	0.0021	so indicated have plates of	absorber plates with	material. A
c012b 1.0000 0.0021 poison placed between clusters Wite b Contribution c013b 1.0000 0.0021 of fuel rods. 0.485 cm SS304L plates comes from the channel that supports the rod clusters and the 9.52 mm carbon steel tank wall. c030b 1.0000 0.0021 0.0001 0.0021 Signal absorber Signal absorber Signal absorber BAW:1484-7 experiments (Reference C:4) X3 array of fuel clusters. None Various B_2C pins and stainless aclp3 1.0000 0.0005 Signal absorber Signal absorber Aluminum sheets plate are the primary reflective materials in the experiments. None None Aluminum sheets plate are the primary reflective materials in the experiments. aclp5 1.0000 0.0007 Cases so indicated also had dissolved boron in the water moderator. None	c011b	1.0000	0.0021	neutron absorbing material	1.05 Wt % Of 1.62	minor
c013b 1.0000 0.0021 of the folds. 0.485 cm SS304L plates c0.memol has upports the rod clusters and the supports and stainless were used as neutron absorbers. None None Water and aluminum base primary reflective materials in the experiments. Minor contribution from the steel tank walls. aclp5 1.0000 0.0007 0.0006 Adverters. None None aclp10 1.0001 0.0006 aclp111 1.0007 0.0006 Adverters. None aclp111 1.0007 0.0006 Adverters. None None aclp111 1.0007 0.0006 Adverters. None None aclp111 1.0007	c012b	1.0000	0.0021	of fuel rods	W170 D	comos from the
c014b 1.0000 0.0021 plates Channel nate c029b 1.0000 0.0021 Zircaloy-4 absorber plates Sircaloy-4 absorber steel and well. c031b 1.0000 0.0021 Boral absorber Boral absorber Steel and well. aclp1 1.0002 0.0005 Enrichments of 2.459 wt% ⁴³⁵ U None Water and aluminum sheet aclp1 1.0000 0.0005 Enrichments of 2.459 wt% ⁴³⁵ U None Water and aluminum sheet aclp1 1.0000 0.0006 Various B ₄ C pins and stainless were used as neutron absorbers. None None None aclp6 1.0097 0.0012 Cases so indicated also had dissolved boron in the water moderator. None N	c013b	1.0000	0.0021	or ider rous.	0.485 cm SS304L	comes nom me
c.029b 1.0000 0.0021 Zircaly-4 absorber Zircaly-4 absorber Clusters and the glates c030b 1.0000 0.0021 Boral absorber Boral absorber Steel tank wall. BAW-1484*7(experiments) (Reference C.4) Enrichments of 2.459 wt% 528U None Water and aluminum base aclp1 1.0000 0.0005 3x3 array of fuel clusters. 1037 ppm boron Justers and the 9.52 mm carbon steel and boron-aluminum sheets aclp5 1.0000 0.0007 Sta array of fuel clusters. None Mater and aluminum base plate are the primary reflective were used as neutron absorbers. None Mater and aluminum base aclp6 1.0097 0.0007 Cases so indicated also had disolved boron in the water moderator. None None Minor aclp11 1.0001 0.0007 ess so indicated also had disolved boron in the water None None None aclp11b 1.0007 0.0006 432 ppm boron S14 ppm boron S14 ppm boron aclp11d 1.0007 0.0006 432 ppm boron S2 ppm boron S2 ppm boron aclp114	c014b	1.0000	0.0021		plates	supports the red
c030b 1.0000 0.0021 plates 0.52 mm carbon stell tank wall. Boral absorber Boral absorber 9.52 mm carbon stell tank wall. BAW:1484:7/experiments (Reference C:4) Water and aluminum base aclp1 1.0000 0.0005 Baral absorber Water and aluminum base aclp2 1.0001 0.0005 Baral absorbers. None Mater and aluminum base aclp3 1.0000 0.0006 Various B,C pins and stainless steel and boron-aluminum sheets None None Mater and aluminum base aclp5 1.0000 0.0007 Cases so indicated also had disolved boron in the water None None Minor contribution from the stell tank wall. aclp7 0.9998 0.0007 Cases so indicated also had disolved boron in the water None None None None Minor contribution from the stell tank walls. aclp11a 1.0007 0.0006 Comon Si1 ppm boron Si1 ppm boron Si1 ppm boron Si2 ppm boron Si1 ppm boron S	c029b	1.0000	0.0021		Zircaloy-4 absorber	clusters and the
c031b 1.0000 0.0021 Boral absorber Steel tank wall. BAW-1484-7 experiments. (Reference C.4) steel tank wall. steel tank wall. aclp1 1.0002 0.0005 Brrichments of 2.459 wt%. None 1037 ppm boron plate are the aclp3 1.0000 0.0006 stall and boron-aluminum sheets None None plate are the aclp6 1.0007 0.0012 Cases so indicated also had None None None Minor aclp6 1.0007 0.0012 Cases so indicated also had None None None None Minor aclp1 1.0001 0.0006 deartor. None Non	c030b	1.0000	0.0021		plates	9 52 mm carbon
BAW:1484-7/experiments (Reference C.4) aclp1 1.0002 0.0005 Enrichments of 2.459 wt% ²⁵⁵ U None Water and aluminum base aclp3 1.0000 0.0006 Various B,C pins and stainless steel and boron-aluminum sheets None None numinum base aclp6 1.0097 0.0012 Cases so indicated also had dissolved boron in the water None None materials in the experiments. aclp6 1.0033 0.0012 Cases so indicated also had dissolved boron in the water None None Minor aclp10 1.0001 0.0009 Monor Contribution from the steel tank walls. aclp11a 1.0007 0.0006 Contribution from the steel tank walls. None aclp111 1.0007 0.0006 Contribution from the steel tank walls. Si10 ppm boron aclp111 1.0007 0.0006 Contribution from the steel tank walls. Si12 ppm boron aclp111 1.0007 0.0006 Contribution from the steel tank walls. Si12 ppm boron aclp111 1.0007 0.0006 Contribution from the steel tank walls. </td <td>c031b</td> <td>1.0000</td> <td>0.0021</td> <td></td> <td>Boral absorber</td> <td>steel tank wall.</td>	c031b	1.0000	0.0021		Boral absorber	steel tank wall.
BAW:1484:7 experiments (Reference C.4) None Water and aclp1 1.0002 0.0005 sx3 array of fuel clusters. 1037 ppm boron aluminum base aclp3 1.0000 0.0006 sx3 array of fuel clusters. Various B4C pins and stainless 1037 ppm boron aluminum base aclp4 0.9999 0.0006 steel and boron-aluminum sheets None None primary reflective aclp6 1.0007 0.0002 Cases so indicated also had dissolved boron in the water None None None aclp7 0.9998 0.0009 aclp11 1.0001 0.0009 aclp111 None None None None aclp11 1.0001 0.0009 aclp111 1.0001 0.0006 aclp111 None None <td< td=""><td></td><td></td><td></td><td></td><td>2 2</td><td></td></td<>					2 2	
aclp1 1.0002 0.0005 Enrichments of 2.459 wt% ²⁵⁰ U None Water and aluminum base aclp3 1.0000 0.0006 3x3 array of fuel clusters. 1037 ppm boron aluminum base aclp4 0.9999 0.0006 steel and boron-aluminum sheets None primary reflective aclp5 1.0000 0.0007 cases so indicated also had None materials in the experiments. aclp6 1.0037 0.0012 issolved boron in the water None materials in the experiments. aclp10 1.0030 0.0009 dissolved boron in the water None water see indicated also had aclp7 0.9998 0.0009 dissolved boron in the water None water see indicated also had aclp10 1.0030 0.0009 0.0006 dissolved boron in the water None None water see indicated also had aclp11 1.0007 0.0006 dissolved boron in the water None None walls. aclp111c 1.0007 0.0006 dissolved boron fd2 ppm boron 514 ppm boron </td <td>BAW-1484-7</td> <td>experiments</td> <td>(Reference</td> <td>e C.4)</td> <td></td> <td></td>	BAW-1484-7	experiments	(Reference	e C.4)		
aclp2 1.0001 0.0005 3X array of fuel clusters. 1037 ppm boron aluminum base aclp3 1.0000 0.0006 Various B₄C pins and stainless 764 ppm boron plate are the aclp5 1.0000 0.0007 Various B₄C pins and stainless None plate are the aclp6 1.0097 0.0012 Steel and boron-aluminum sheets None materials in the aclp6 1.0083 0.0012 Cases so indicated also had None None contribution from aclp9 1.0030 0.0009 output moderator. None None None contribution from aclp10 1.0001 0.0006 aclp11a 1.0007 0.0006 143 ppm boron 510 ppm boron 514 ppm boron salls. aclp11e 1.0007 0.0006 474 ppm boron 422 ppm boron 422 ppm boron 422 ppm boron 395 ppm boron aclp13 1.0000 0.0010 395 ppm boron 320 ppm boron 320 ppm boron aclp14 1.0002 0.0010 320 ppm boron 320 ppm boron 320 ppm boron	aclp1	1.0002	0.0005	Enrichments of 2.459 wt% ²³⁵ U	None	Water and
aclp3 1.0000 0.0006 Various B_4C pins and stainless steel and boron-aluminum sheets aclp5 764 ppm boron plate are the primary reflective materials in the experiments. aclp6 1.0097 0.0012 steel and boron-aluminum sheets aclp6 None materials in the experiments. aclp7 0.9998 0.0009 dissolved boron in the water None materials in the experiments. aclp8 1.0030 0.0009 dissolved boron in the water None None aclp10 1.0001 0.0006 aclp11a 1.0000 nonor None aclp11a 1.0007 0.0006 aclp116 1.0007 0.0006 493 ppm boron aclp11d 1.0007 0.0006 432 ppm boron 501 ppm boron aclp111 1.0007 0.0006 432 ppm boron 217 ppm boron aclp13 1.0000 0.0010 395 ppm boron 325 ppm boron aclp14 1.0001 0.0010 395 ppm boron 320 ppm boron aclp14 1.0000 0.0011 634 ppm boron 320 ppm boron	aclp2	1.0001	0.0005	3x3 array of fuel clusters.	1037 ppm boron	aluminum base
aclp4 0.9999 0.0006 steel and boron-aluminum sheets were used as neutron absorbers. Cases so indicated also had dissolved boron in the water moderator. None primary reflective materials in the experiments. aclp5 1.0007 0.0012 Cases so indicated also had dissolved boron in the water moderator. None None Minor aclp3 1.0083 0.0012 None None Minor aclp4 1.0083 0.0012 None None Minor aclp10 1.0001 0.0009 None None None aclp11 1.0001 0.0006 None None None None aclp111 1.0007 0.0006 None None None None aclp113 1.0000 0.0010 None	aclp3	1.0000	0.0006	Various B₄C pins and stainless	764 ppm boron	plate are the
aclp5 1.0000 0.0007 were used as neutron absorbers. Cases so indicated also had dissolved boron in the water moderator. None materials in the experiments. aclp7 0.9998 0.0009 dissolved boron in the water moderator. None None Minor aclp3 1.0033 0.0009 dissolved boron in the water None None Minor aclp10 1.0001 0.0009 dissolved boron None None None aclp10 1.0001 0.0009 dissolved boron None None None aclp11 1.0001 0.0006 dissolved boron None None None aclp11c 1.0007 0.0006 dissolved boron 510 ppm boron 511 ppm boron aclp11d 1.0007 0.0006 dissolved boron 474 ppm boron 422 ppm boron aclp13 1.0007 0.0006 dissolved boron 325 ppm boron 217 ppm boron aclp13 1.0000 0.0010 395 ppm boron 395 ppm boron 395 ppm boron aclp14	aclp4	0.9999	0.0006	steel and boron-aluminum sheets	None	primary reflective
aclp6 1.0097 0.0012 Cases so indicated also had dissolved boron in the water moderator. None experiments. Minor contribution from the steel ank walls. aclp3 1.0083 0.0012 None None None Contribution from the steel tank walls. aclp10 1.0001 0.0009 0.0006 143 ppm boron 510 ppm boron 514 ppm boron aclp111 1.0007 0.0006 493 ppm boron 422 ppm boron 422 ppm boron aclp111 1.0007 0.0006 474 ppm boron 422 ppm boron 217 ppm boron aclp13 1.0000 0.0010 395 ppm boron 395 ppm boron 395 ppm boron aclp17 1.0001 0.0010 395 ppm boron 320 ppm boron 320 ppm boron aclp18 1.0002 0.0011 320 ppm boron 320 ppm boron 320 ppm boron	aclp5	1.0000	0.0007	were used as neutron absorbers.	None	materials in the
aclp7 0.9998 0.0009 dissolved boron in the water None Minor contribution from aclp9 1.0030 0.0009 aclp10 1.0001 0.0009 143 ppm boron 151 ppm boron 151 ppm boron	aclp6	1.0097	0.0012	Cases so indicated also had	None	experiments.
aclp8 1.0083 0.0012 Moderator. None Contribution from the steel tank walls. aclp10 1.0001 0.0009 143 ppm boron 143 ppm boron 143 ppm boron 143 ppm boron 510 ppm boron 510 ppm boron 514 ppm boron	aclp7	0.9998	0.0009	dissolved boron in the water	None	Minor
aclp9 1.0030 0.0009 None The steer tank walls. aclp10 1.0001 0.0009 143 ppm boron steer tank walls. aclp11a 1.0000 0.0006 510 ppm boron steer tank walls. aclp11b 1.0007 0.0007 511 ppm boron steer tank walls. aclp11c 1.0007 0.0006 511 ppm boron aclp11d 1.0007 0.0006 493 ppm boron aclp11e 1.0007 0.0006 462 ppm boron aclp12 1.0007 0.0006 432 ppm boron aclp12 1.0000 0.0007 217 ppm boron aclp13a 1.0000 0.0010 28 ppm boron aclp14 1.0001 0.0010 28 ppm boron aclp15 0.9998 0.0016 395 ppm boron aclp17 1.0000 0.0010 487 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp19 1.0002 0.0011 320 ppm boron aclp19 1.0003 0.0011 320 ppm boron	aclp8	1.0083	0.0012	moderator.	None	contribution from
aclp10 1.0001 0.0009 aclp11a 1.0000 0.0006 aclp11b 1.0007 0.0007 aclp11c 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11f 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp13 1.0000 0.0007 aclp13 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0011 aclp19 1.0002 0.0011 aclp20 1.0003 0.	aclp9	1.0030	0.0009		None	the steel tank
aclp11a 1.0000 0.0006 aclp11b 1.0007 0.0007 aclp11c 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0011 aclp19 1.0002 0.0011 aclp19 1.0002 0.0011 aclp20 1.0003 0.0	aclp10	1.0001	0.0009		143 ppm boron	walls.
aclp11b 1.0007 0.0007 aclp11c 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11f 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0011 aclp19 1.0002 0.0011 aclp19 1.0002 0.0011 aclp19 1.0003 0.0011 aclp19 1.0003 0.0011	aclp11a	1.0000	0.0006		510 ppm boron	
aclp11c 1.0007 0.0006 aclp11d 1.0007 0.0006 aclp11e 1.0007 0.0006 aclp11f 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0003 0.0011	aclp11b	1.0007	0.0007		514 ppm boron	
aclp11d 1.0007 0.0006 493 ppm boron aclp11e 1.0007 0.0006 474 ppm boron aclp11g 1.0007 0.0006 432 ppm boron aclp12 1.0000 0.0007 217 ppm boron aclp13 1.0000 0.0010 15 ppm boron aclp13 1.0000 0.0010 28 ppm boron aclp14 1.0001 0.0010 28 ppm boron aclp15 0.9998 0.0016 395 ppm boron aclp16 1.0001 0.0019 121 ppm boron aclp17 1.0000 0.0010 395 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp19 1.0002 0.0010 320 ppm boron	aclp11c	1.0007	0.0006		501 ppm boron	
aclp11e 1.0007 0.0006 aclp11f 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0011	aclp11d	1.0007	0.0006		493 ppm boron	
aclp11f 1.0007 0.0006 aclp11g 1.0007 0.0006 aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0010 aclp20 1.0003 0.0011	aclp11e	1.0007	0.0006		474 ppm boron	
aclp11g 1.0007 0.0006 aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp13a 1.0001 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0010 aclp20 1.0003 0.0011	aclp11f	1.0007	0.0006		462 ppm boron	
aclp12 1.0000 0.0007 aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp13a 1.0001 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp20 1.0003 0.0011 aclp20 1.0003 0.0015	aclp11g	1.0007	0.0006		432 ppm boron	
aclp13 1.0000 0.0010 aclp13a 1.0000 0.0010 aclp14 1.0001 0.0010 aclp15 0.9998 0.0016 aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 aclp18 1.0002 0.0011 aclp19 1.0002 0.0010 aclp19 1.0003 0.0011	aclp12	1.0000	0.0007		217 ppm boron	
aclp13a 1.0000 0.0010 28 ppm boron aclp14 1.0001 0.0010 92 ppm boron aclp15 0.9998 0.0016 395 ppm boron aclp16 1.0001 0.0019 121 ppm boron aclp17 1.0000 0.0010 487 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp20 1.0003 0.0011 320 ppm boron	aclp13	1.0000	0.0010		15 ppm boron	
aclp14 1.0001 0.0010 92 ppm boron aclp15 0.9998 0.0016 395 ppm boron aclp16 1.0001 0.0019 121 ppm boron aclp17 1.0000 0.0010 487 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp20 1.0003 0.0011 320 ppm boron aclp21 0.0007 0.0015 320 ppm boron	aclp13a	1.0000	0.0010		28 ppm boron	
aclp15 0.9998 0.0016 395 ppm boron aclp16 1.0001 0.0019 121 ppm boron aclp17 1.0000 0.0010 487 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp19 1.0002 0.0010 634 ppm boron aclp20 1.0003 0.0011 320 ppm boron	aclp14	1.0001	0.0010		92 ppm boron	
aclp16 1.0001 0.0019 aclp17 1.0000 0.0010 487 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp19 1.0002 0.0010 634 ppm boron aclp20 1.0003 0.0011 320 ppm boron	aclp15	0.9998	0.0016		395 ppm boron	
aclp17 1.0000 0.0010 487 ppm boron aclp18 1.0002 0.0011 197 ppm boron aclp19 1.0002 0.0010 634 ppm boron aclp20 1.0003 0.0011 320 ppm boron	aclp16	1.0001	0.0019		121 ppm boron	
aclp18 1.0002 0.0011 197 ppm boron aclp19 1.0002 0.0010 634 ppm boron aclp20 1.0003 0.0011 320 ppm boron aclp21 0.0007 0.0015 72 ppm boron	aclp17	1.0000	0.0010		487 ppm boron	
aclp19 1.0002 0.0010 634 ppm boron aclp20 1.0003 0.0011 320 ppm boron aclp21 0.0007 0.0015 72 ppm boron	aclp18	1.0002	0.0011		197 ppm boron	
aclp20 1.0003 0.0011 320 ppm boron	aclp19	1.0002	0.0010		634 ppm boron	
	aclp20	1.0003	0.0011		320 ppm boron	
	aclp21	0.9997	0.0015		72 ppm boron	

ANP-2843(NP) Revision 1 Page C-6

9.00					
BAW-1645-4	experiments	s (Referenc	e C.5)		
rcon01	1.0007	0.0006	2.46 wt% ²³⁵ U	435 ppm boron	Water and
rcon02	1.0007	0.0006	5x5 array of fuel cluster. Rod	426 ppm boron	aluminum base
rcon03	1.0007	0.0006	pitch between 1.2093 cm and	406 ppm boron	plate are the
rcon04	1.0007	0.0006	1.4097 cm. Cases so indicated	383 ppm boron	primary reflective
rcon05	1.0007	0.0006	also had dissolved boron in the	354 ppm boron	materials in the
rcon06	1.0007	0.0006	water moderator.	335 ppm boron	experiments.
rcon07	1.0007	0.0006		361 ppm boron	
rcon08	1.0007	0.0006		121 ppm boron	the steal tank
rcon09	1.0007	0.0006		886 ppm boron	une steer tank
rcon10	1.0007	0.0006		871 ppm boron	walls.
rcon11	1.0007	0.0006		852 ppm boron	
rcon12	1.0007	0.0006		834 ppm boron	
rcon13	1.0007	0.0006		815 ppm boron	
rcon14	1.0007	0.0006		781 ppm boron	
rcon15	1.0007	0.0006		746 ppm boton	
rcon16	1.0007	0.0006		1156 ppm boron	
rcon17	1.0007	0.0006		1141 ppm boron	
rcon18	1.0007	0.0006		1123 ppm boron	
rcon19	1.0007	0.0006		1107 ppm boron	
rcon20	1.0007	0.0006		1093 ppm boron	
rcon21	1.0007	0.0006		1068 ppm boron	
rcon28	1.0007	0.0006		121 ppm boron	
and the second second					Substantia Substantia
CEA Valduc	Critical Mass	s Laboratory	Experiments (Reference C.6)		
mdis01	1.0000	0.0014	4.738 wt% ²³⁵ U	None	The actual
mdis02	1.0000	0.0014	CEA Valduc Critical Mass		reflector
mdis03	1.0000	0.0014	Laboratory experiments. A key		boundaries vary
mdis04	1.0000	0.0014	aspect of these experiments was		from case to
mdis05	1.0000	0.0014	to examine the reactivity effects		case.
mdis06	1.0000	0.0014	bydrogonous materials within a		
mdis07	1.0000	0.0014	cross shaped chapped box		
mdis08	1.0000	0.0014	placed between a two by two		
1 12 22					
mdis09	1.0000	0.0014	array of fuel rod assemblies.		
mdis09 mdis10	1.0000	0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted		
mdis09 mdis10 mdis11	1.0000 1.0000 1.0000	0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum		
mdis09 mdis10 mdis11 mdis12	1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet		
mdis09 mdis10 mdis11 mdis12 mdis13	1.0000 1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet columns.		
mdis09 mdis10 mdis11 mdis12 mdis13 mdis14	1.0000 1.0000 1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet columns.		
mdis09 mdis10 mdis11 mdis12 mdis13 mdis14 mdis15	1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet columns.		
mdis09 mdis10 mdis11 mdis12 mdis13 mdis14 mdis15 mdis16	1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet columns.		
mdis09 mdis10 mdis11 mdis12 mdis13 mdis14 mdis15 mdis16 mdis17	1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet columns.		
mdis09 mdis10 mdis11 mdis12 mdis13 mdis14 mdis15 mdis16 mdis17 mdis18	1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000 1.0000	0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014 0.0014	array of fuel rod assemblies. The assemblies each consisted of an 18 x 18 array of aluminum alloy clad fuel UO2 pellet columns.		

LEU-COMP-	THERM-022	, -024, -025	Experiments (Reference C.1)		
leuct022-02	1.0000	0.0046	9.83 and 7.41 wt% enriched UO2	None	Water is the
leuct022-03	1.0000	0.0036	rods of varying numbers in		primary reflector.
leuct024-01	1.0000	0.0054	hexagonal and square lattices in		Minor
leuct024-02	1.0000	0.0040	water.		contribution from
leuct025-01	1.0000	0.0041			the steel tank
leuct025-02	1.0000	0.0044			walls.
i i i i i i i i i i i i i i i i i i i					
Mixed Oxide	(Reference	C.1, Experi	ment MIX-COMP-THERM 002)		
epri70b	1.0009	0.0047	Experiments with mixtures of	687.9 ppm B	Reflected by
(PNL-31)	4 000 4		atural UO2-2wt%PuO2	4	water and Al.
epri/0un	1.0024	0.0060	(8%240Pu).	1.7 ppm B	
(PNL-30)	4.0004	0.0004	A 779 are 0.0000 are and	1000 1 5	-
	1.0024	0.0024	1.778 cm, 2.2098 cm, and	1090.4 ppm B	
(PNL-33)	1.0040	0.0004	2.5146 cm pitch in borated or	0.0	
	1.0042	0.0031	pure water moderator.	0.9 ppm B	
(PINL-32)	1 0020	0.0027	-	767.2 ppm D	-
	1.0029	0.0027		767.2 ppm B	
	1 0038	0.0025	-	16 ppm B	-
(DNI _34)	1.0050	0.0025			
	(Reference	C 1 Experi	ment MIX-COMP-THERM (003)		
saxtn104	1 0000	0.0023	Experiments with mixtures of	None	Reflected by
(case 6)			natural UO2-6.6wt%PuO2		water and Al.
saxtn56b	1.0000	0.0054	mixed-oxide (MOX), square-	337 ppm B	
(case 3)			pitched, partial moderator height		
saxtn792	1.0049	0.0027	lattices.	None	
(case 5)			Moderator: borated or pure		
saxton52	1.0028	0.0072	water moderator.	None	1
(case 1)					
saxton56	1.0019	0.0059]	None	
(case 2)					
(PNL-35)					

C.4 **Results of Calculations with SCALE 4.4.a**

The critical experiments described in Section C.3 were modeled with the SCALE 4.4a computer system. The resulting k_{eff} and calculational uncertainty, along with the experimental k_{eff} and experimental uncertainty are tabulated in Table C.3. The parameters of interest in performing a trending analysis of the bias (Including EALF calculated by SCALE 4.4a) are also included in the table.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page C-8

Table C.3 SCALE 4.4a Results for the Selected Benchmark Experiments

No Case name Benchmark values SCALE 4.4a EALF Enr	В	H/X
Calculated Values (eV) wt%	(ppm)	
$k_{eff} = \sigma_{exp} = k_{eff} = \sigma_{calc}$	•	
1 c004 1.0000 0.0020 0.9966 0.0008 0.1126 4.31	0	255.92
2 C005b 1.0000 0.0018 0.9950 0.0008 0.1128 4.31	0	255.92
3 C006b 1.0000 0.0019 0.9964 0.0008 0.1130 4.31	0	255.92
4 c00/a 1.0000 0.0021 0.99/3 0.0009 0.1128 4.31	0	255.92
5 c008b 1.0000 0.0021 0.9966 0.0008 0.1135 4.31	0	255.92
6 c009b 1.0000 0.0021 0.9967 0.0008 0.1136 4.31	0	255.92
7 c010b 1.0000 0.0021 0.9977 0.0008 0.1142 4.31	0	255.92
8 c011b 1.0000 0.0021 0.9949 0.0009 0.1143 4.31	0	255.92
9 c012b 1.0000 0.0021 0.9967 0.0008 0.1148 4.31	0	255.92
10 c013b 1.0000 0.0021 0.9969 0.0008 0.1130 4.31	0	255.92
11 c014b 1.0000 0.0021 0.9958 0.0008 0.1133 4.31	0	255.92
12 c029b 1.0000 0.0021 0.9972 0.0008 0.1126 4.31	0	255.92
13 c030b 1.0000 0.0021 0.9972 0.0009 0.1132 4.31	0	255.92
14 c031b 1.0000 0.0021 0.9993 0.0009 0.1144 4.31	0	255.92
15 aclp1 1.0002 0.0005 0.9912 0.0007 0.1725 2.46	0	215.57
16 aclp2 1.0001 0.0005 0.9951 0.0006 0.2504 2.46	1037	215.79
17 aclp3 1.0000 0.0006 0.9958 0.0006 0.1963 2.46	764	215.83
18 aclp4 0.9999 0.0006 0.9889 0.0008 0.1912 2.46	0	215.91
19 aclp5 1.0000 0.0007 0.9906 0.0007 0.1660 2.46	0	215.87
20 aclp6 1.0097 0.0012 0.9899 0.0009 0.1712 2.46	0	215.87
21 aclp7 0.9998 0.0009 0.9891 0.0008 0.1496 2.46	0	215.87
22 aclp8 1.0083 0.0012 0.9873 0.0007 0.1537 2.46	0	215.87
23 aclp9 1.0030 0.0009 0.9908 0.0008 0.1409 2.46	0	215.87
24 aclp10 1.0001 0.0009 0.9916 0.0007 0.1495 2.46	143	215.22
25 acp11a 1.0000 0.0006 0.9948 0.0007 0.1996 2.46	510	215.32
26 acp11b 1.0007 0.0007 0.9947 0.0007 0.1994 2.46	514	215.73
27 acp11c 1.0007 0.0006 0.9944 0.0006 0.2019 2.46	501	215.32
28 acp11d 1.0007 0.0006 0.9952 0.0007 0.2028 2.46	493	215.14
29 acp11e 1.0007 0.0006 0.9940 0.0006 0.2037 2.46	474	214.70
30 acp11f 1.0007 0.0006 0.9932 0.0007 0.2050 2.46	462	214.52
31 acp11g 1.0007 0.0006 0.9954 0.0007 0.2045 2.46	432	215.97
32 aclp12 1.0000 0.0007 0.9930 0.0008 0.1700 2.46	217	215.05
33 aclp13 1.0000 0.0010 0.9933 0.0008 0.1965 2.46	15	215.67
34 acp13a 1.0000 0.0010 0.9902 0.0007 0.1981 2.46	28	215.91
35 aclp14 1.0001 0.0010 0.9891 0.0008 0.2011 2.46	92	215.83
36 aclp15 0.9998 0.0016 0.9855 0.0007 0.2063 2.46	395	215.83
37 aclp16 1.0001 0.0019 0.9856 0.0007 0.1730 2.46	121	215.83
38 aclp17 1.0000 0.0010 0.9899 0.0006 0.2053 2.46	487	215.89
39 aclp18 1.0002 0.0011 0.9886 0.0008 0.1725 2.46	197	215.89
40 aclp19 1.0002 0.0010 0.9912 0.0006 0.2061 2.46	634	215.89
41 aclp20 1.0003 0.0011 0.9899 0.0007 0.1730 2.46	320	215.89
42 aclp21 0.9997 0.0015 0.9883 0.0008 0.1532 2.46	72	216.19
43 rcon01 1 0007 0 0006 0 9997 0 0007 2 4282 2 46	435	17 41
44 rcon02 1.0007 0.0006 1.0004 0.0007 2.4360 2.46	426	17 40
45 rcon03 1.0007 0.0006 0.9985 0.0008 2.4972 2.46	406	17 40
	400	17.40
46 rcon04 1.0007 0.0006 0.9983 0.0007 2.4989 2.46	406 383	17.40

•

.....

L S N	aSalle Unit 2 Nuclear F Storage Pool Criticality S Jeutron Absorbing Inse	Power Stati Safety Ana rts and Wit	on Spent F lysis with hout Borafle	uel ex				ANP-284 Rev Paç	I3(NP) ision 1 ge C-9
No	Case name	Benchma	ark values	SCAL Calculate	E 4.4a ed Values	EALF (eV)	Enr wt%	B (ppm)	H/X
		k _{eff}	σevo	k _{eff}	Ocale	, ,	²³⁵ U	,	
48	rcon06	1.0007	0.0006	0.9982	0.0007	2.5119	2.46	335	17.41
49	rcon07	1.0007	0.0006	0.9984	0.0006	1.6313	2.46	361	17.43
50	rcon08	1.0007	0.0006	1.0155	0.0008	1.1134	2.46	121	17.43
51	rcon09	1.0007	0.0006	0.9973	0.0007	1.4481	2.46	886	44.81
52	rcon10	1.0007	0.0006	0.9982	0.0008	1.4623	2.46	871	44.81
53	rcon11	1.0007	0.0006	0.9958	0.0007	1.5006	2.46	852	44.79
54	rcon12	1.0007	0.0006	0.9979	0.0007	1.4942	2.46	834	44.81
55	rcon13	1.0007	0.0006	0.9971	0.0006	1.4973	2.46	815	44.81
56	rcon14	1.0007	0.0006	0.9967	0.0007	1.5185	2.46	781	44.79
57	rcon15	1.0007	0.0006	0.9980	0.0006	1.5122	2.46	746	44.79
58	rcon16	1.0007	0.0006	0.9954	0.0006	0.4182	2.46	1156	118.47
59	rcon17	1.0007	0.0006	0.9963	0.0007	0.4293	2.46	1141	118.47
60	rcon18	1.0007	0.0006	0.9929	0.0007	0.4354	2.46	1123	118.44
61	rcon19	1.0007	0.0006	0.9952	0.0007	0.4371	2.46	1107	118.44
62	rcon20	1.0007	0.0006	0.9952	0.0007	0.4367	2.46	1093	118.44
63	rcon21	1.0007	0.0006	0.9945	0.0007	0.4404	2.46	1068	118.44
64	rcon28	1.0007	0.0006	0.9970	0.0008	0.9984	2.46	121	17.44
65	mdis01	1.0000	0.0014	0.9929	0.0008	0.2822	4.74	0	137.61
66	mdis02	1.0000	0.0014	0.9862	0.0009	0.2641	4.74	0	137.61
67	mdis03	1.0000	0.0014	0.9845	0.0009	0.2636	4.74	0	137.61
68	mdis04	1.0000	0.0014	0.9895	0.0008	0.2513	4.74	0	137.61
69	mdis05	1.0000	0.0014	0.9901	0.0009	0.2411	4.74	0	137.61
70	mdis06	1.0000	0.0014	1.0010	0.0008	0.2292	4.74	0	137.61
71	mdis07	1.0000	0.0014	0.9901	0.0009	0.2250	4.74	0	137.61
72	mdis08	1.0000	0.0014	0.9858	0.0008	0.2493	4.74	0	137.61
73	mdis09	1.0000	0.0014	0.9856	0.0009	0.2483	4.74	0	137.61
74	mdis10	1.0000	0.0014	0.9928	0.0009	0.2221	4.74	0	137.61
75	mdis11	1.0000	0.0014	1.0029	0.0009	0.2043	4.74	0	137.61
76	mdis12	1.0000	0.0014	1.0080	0.0008	0.1946	4.74	0	137.61
77	mdis13	1.0000	0.0014	0.9916	0.0009	0.1947	4.74	0	137.61
78	mdis14	1.0000	0.0014	0.9887	0.0008	0.2299	4.74	0	137.61
79	mdis15	1.0000	0.0014	0.9881	0.0010	0.2270	4.74	0	137.61
80	mdis16	1.0000	0.0014	1.0015	0.0008	0.1905	4.74	0	137.61
81	mdis17	1.0000	0.0014	0.9987	0.0008	0.1794	4.74	0	137.61
82	mdis18	1.0000	0.0014	0.9961	0.0008	0.1747	4.74	0	137.61
83	mdis19	1.0000	0.0014	0.9928	0.0009	0.1/4/	4.74	0	137.61
84	leuct022-02	1.0000	0.0046	1.0056	0.0013	0.2920	9.83	0	80.00
85	leuct022-03	1.0000	0.0036	1.0048	0.0013	0.1253	9.83	0	151.00
86	leuct024-01	1.0000	0.0054	0.9990	0.0015	1.0568	9.83	0	41.00
87	leuct024-02	1.0000	0.0040	1.0048	0.0014	0.1435	9.83	0	128.00
88	leuct025-01	1.0000	0.0041	0.9851	0.0014	0.4401	7.41	0	66.30
89		1.0000	0.0044	0.9936	0.0013	0.2015	7.41	0	106.10
90	epri/Ub (PINL-31)	1.0009	0.0047	0.9995	0.0016	0.7631	-	688	146.15
91		1.0024	0.0060	0.9967	0.0015	0.5648	-	2	146.20
92	eprio/d (PNL-33)	1.0024	0.0024	1.0046	0.0013	0.2780	-	1090	308.83
93	eprio/un (PNL-32)	1.0042	0.0031	1.0034	0.0013	0.1894	-] 707	308.99
94 05	eprisso (PNL-35)	1.0029	0.0027	1.0000	0.0009	0.1802	-	/6/	445.41
90	eprissun (PNL-34)	1.0038	0.0025		0.0019	0.1353	-	2	445.5/
90 97	saxtn104 (case 6) saxtn56b (case 3)	1.0000	0.0023	0.9980	0.0017	0.6523	-	337	473.11 95.24

AREVA NP Inc.

AREVA NP

L S N	aSalle Unit 2 Nuclear F Storage Pool Criticality S Ieutron Absorbing Inse	ANP-2843(NP) Revision 1 Page C-10							
No	Case name	Case name Benchmark value		SCALE 4.4a Calculated Values		EALF (eV)	Enr wt%	B (ppm)	H/X
		k _{eff}	σ_{exp}	k _{eff}	σ_{calc}		²³⁵ U		
98	saxtn792 (case 5)	1.0049	0.0027	1.0027	0.0019	0.1547	-	0	249.70
99	saxton52 (case 1)	1.0028	0.0072	0.9987	0.0013	0.8878	-	0	73.86
100	saxton56 (case 2)	1.0019	0.0059	0.9997	0.0018	0.5450	-	0	95.29

In order to address situations in which the critical experiment being modeled was at other than a critical state (i.e., slightly super or subcritical), the calculated k_{eff} is normalized to the experimental k_{exp} , using the following formula (Eq.9 from Reference C.2):

$$k_{norm} = k_{calc} / k_{exp}$$

In the following, the normalized values of the k_{eff} were used in the determination of the code bias and bias uncertainty.

C.5 Trending Analysis

The next step of the statistical methodology used to evaluate the code bias for the pool of experiments selected is to identify any trend in the bias. This is done by using the trending parameters presented in Table C.4.

Table C.4 Trending Parameters

Energy of the Average Lethargy causing Fission (EALF)
Fuel Enrichment (wt% ²³⁵ U)
Atom ratio of the moderator to fuel (H/X)
Soluble Boron Concentration

The first step in calculating the bias uncertainty limit is to apply regression-based methods to identify any trending of the calculated values of k_{eff} with the spectral and/or physical parameters. The trends show the results of systematic errors or bias inherent in the calculational method used to estimate criticality.

For the critical benchmark experiments that were slightly super or subcritical, an adjustment to the k_{eff} value calculated with SCALE 4.4a (k_{calc}) was done as suggested in Reference C.2. This adjustment is done by normalizing the calculated (k_{calc}) value to the experimental value (k_{exp}). This normalization does not affect the inherent bias in the calculation due to very small differences in k_{eff} . Unless otherwise mentioned, the normalized k_{eff} values (k_{norm}) have been used in all subsequent calculations.

Each subset of normalized k_{eff} values is first tested for trending against the spectral and/or physical parameters of interest (in this case, presented in Table C.4 above), using the built-in regression analysis tool from any general statistical software (e.g., Excel). Trending in this context is linear regression of unweighted calculated k_{eff} on the predictor variable(s) (spectral and/or physical parameters). In addition, the equations presented in Reference C.2 are also applied to check for a linear dependency in case of weighted k_{eff}, using as weight the factor $1/\sigma_r^2$ as previously discussed.

The linear regression fitted equation is in the form y(x) = a + bx, where y is the dependent variable (k_{eff}) and x is any of the predictor variables mentioned in Table C.4. The difference between the predicted y and actual value is known as the random error component (residuals).

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page C-12

The final validity of each linear trend is checked using well-established indicators or goodnessof-fit tests concerning the regression parameters. As a first indicator, the coefficient of determination (r^2) that is available as a result of using linear regression statistics, can be used to evaluate the linear trending. It represents the proportion of the sum of squares of deviations of the y values about their mean that can be attributed to a linear relation between y and x.

Another assessment of the adequacy of the linear model can be done by checking the goodness-of-fit against a null hypothesis on the slope (b) (Reference C.7, p. 371). The slope test requires calculating the test statistic "T" as in the following equation along with the corresponding statistical parameters (Reference C.7, p. 371).

$$T = \frac{\beta_1}{s / \sqrt{S_{xx}}}$$

where, $\hat{\beta}_1$ is the estimated slope of the fitted linear regression equation,

$$S_{xx} = \sum_{i=1,n} (x_i - \overline{x})^2$$

and,

$$s = \frac{1}{(n-2)} \sum_{i=1,n} (y_i - \hat{y}_i)^2$$

where, \hat{y}_i is the estimated value using the regression equation.

The test statistic is compared to the Student t-distribution $(t_{\alpha/2,n-2})$ with 95% confidence and n-2 degrees of freedom (Reference C.8, p.T-5), where n is the initial number of points in the subset. Given a null hypothesis H₀: β_1 =0, of "no statistically significant trend exists (slope is zero)", the hypothesis would be rejected if $|T| > t_{\alpha/2,n-2}$. By only accepting linear trends that the data supports with 95% confidence, trends due to the randomness of the data are eliminated. A good indicator of this statistical process is evaluation of the P-value probability that gives a direct estimation of the probability of having linear trending due only to chance.

The last step of the regression analysis is determining whether or not the final requirements of the simple linear regression model are satisfied. The error components (residuals) need to be normally distributed with mean zero, and also the residuals need to show a random scatter

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page C-13

about the center line (no pattern). These requirements were verified for the present calculation by applying an omnibus normality test (Reference C.8, p.372) on the residuals.

The results of the trending parameter analysis for the criticality benchmark set (unweighted k_{eff}) are summarized in Table C.5.

Trend Parameter	n	Intercent	Slope	, 2	т	t	P-value	Goodness-of-	Valid
EALF	100	0.9937	0.002	0.061	2.53	1.987	0.013	Not Passed (residuals not normal and show a pattern -see Figure C.5)	No
Enrichment (wt% ²³⁵ U)	90 ^a	0.9911	0.0008	0.070	2.57	1.991	0.012	Not passed (residuals not normal and show a pattern – see Figure C.6)	No
H/X	100	0.9952	-2.2E-06	0.001	-0.37	1.987	0.714	Not Passed	No
Boron in moderator (ppm)	100	0.9945	1.5E-06	0.009	0.95	1.987	0.345	Not passed	No

Table C.5 Summary of Trending Analysis

^a Benchmark experiments with MOX fuel excluded.

The results in Table C.5 show that there are no statistically significant or valid trends of k_{eff} with the trending parameters. An additional check was done by checking if there are any trends on the weighted data. The results of the regression analysis obtained using weighted k_{eff} (with the weight factor $1/\sigma_r^2$ as previously discussed) show that the determination coefficient (r^2) has similar low values as in the above table, indicating very weak and statistically insignificant trends.

Figures C.1 to C.4 show the distribution of the normalized k_{eff} values versus the trending parameters investigated.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page C-14



Figure C.1 Distribution of k_{eff} Data versus EALF for the Selected Pool of Benchmark Experiments



Figure C.2 Distribution of k_{eff} Data versus Enrichment (²³⁵U) for the Selected Pool of Benchmark Experiments

LaSalle Unit 2 Nuclear Power Station Spent Fuel
Storage Pool Criticality Safety Analysis with
Neutron Absorbing Inserts and Without Boraflex



Figure C.3 Distribution of k_{eff} Data versus H/X for the Selected Pool of Benchmark Experiments



Figure C.4 Distribution of k_{eff} Data versus Soluble Boron Concentration for the Selected Pool of Benchmark Experiments
ANP-2843(NP) Revision 1 Page C-16



Figure C.5 Plot of Standard Residuals for Regression Analysis with EALF as Trending Parameter



Figure C.6 Plot of Standard Residuals for Regression Analysis with Enrichment as Trending Parameter

C.6 Bias and Bias Uncertainty

For situations in which no significant trending in bias is identified, the statistical methodology presented in Reference C.2 suggests to first check the normality of the pool of k_{eff} data. Applying the Shapiro-Wilk test (Reference C.2) the null hypothesis of a normal distribution is not rejected. A visual inspection of the normal probability plot of the k_{eff} data shows that the pool of k_{eff} data for the selected benchmarks can be considered normally distributed.

This situation allows the application of the weighted single-sided lower tolerance limit to determine the bias uncertainty (Reference C.2). First by determining the factor for 95% probability at the 95% confidence level ($C_{95/95}$) and then multiplying it with the evaluated squared-root of the pooled variance, the uncertainty limit is determined.

From Reference C.9, $C_{95/95}$ for n equal to 100 is 1.927. The squared root of the pooled variance calculated using the formulas presented is:

$$s_P = \sqrt{s^2 + \overline{\sigma}^2} = (2.45212\text{E}-05+1.63005\text{E}-06)^{0.5} = 0.00511$$

Bias Uncertainty = $C_{95/95} * s_p$ = 1.927 * 0.00511 = 0.00985

The bias is obtained using the formula that includes the weighted average of keff

Bias =
$$\overline{k}_{eff} - 1 = 0.99458 - 1 = -0.00542$$

These represent the final results which can be used to evaluate the maximum k_{eff} and $k_{95/95}$ values in the criticality analysis of the spent fuel pool. Note that this bias will be applied as a positive penalty in the equation for computation of $k_{95/95}$.

C.7 Area of Applicability

A brief description of the spectral and physical parameters characterizing the set of selected benchmark experiments is provided in Table C.6.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page C-18

Parameter	Range of Values
Geometrical shape	Heterogeneous lattices; Rectangular and hexagonal
Fuel type	UO ₂ rods MOX fuel rods
Enrichment (for UO ₂ fuel)	2.46 to 9.83 wt % ²³⁵ U
Lattice pitch	1.04 to 2.6416 cm
H/X	17.4 to 473
EALF	0.11 to 2.51 eV
Absorbers	Soluble boron Boron in plates:
Reflectors	Water Stainless Steel Aluminum

Table C.6 Range of Values of Key Parameters in Benchmark Experiments

C.8 Bias Summary and Conclusions

This evaluation considers a selected set of criticality benchmark experiments with enrichments ranging from about 2.5 to about 10 wt% ²³⁵U and includes some experiments with MOX fuel rods. The results of the evaluation provide the following information relative to the SCALE4.4a bias:

Bias =
$$\overline{k}_{eff} - 1 = 0.99458 - 1 = -0.00542^*$$

Note that this bias will be applied as a positive penalty in the equation for computation of k_{95/95}:

Bias Uncertainty =
$$C_{95/95} * s_p = 1.927 * 0.00511^{\dagger} = 0.00985$$

The bias and its uncertainty (95/95 weighted single-sided tolerance limit) was obtained applying the appropriate steps of the statistical methodology presented in NUREG 6698 (Reference C.2) taking into account the possible trending of k_{eff} with various spectral and/or physical parameters.

^{*} This will be applied as $bias_m = 0.00542$ in Section 6.6.

[†] s_{p} will be applied as $\sigma_{m} = 0.00511$ in Section 6.6. This is because the one sided tolerance multiplier is applied to the combined uncertainties in Section 6.6.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page C-19

C.9 References

- C.1 Nuclear Energy Agency, "International Handbook of Evaluated Criticality Safety Benchmark Experiments," NEA/NSC/DOC(95)03, Nuclear Energy Agency, Organization for Co-operation and Development, 2008.
- C.2 Nuclear Regulatory Commission, "Guide for Validation of Nuclear Criticality Safety Calculational Methodology", NUREG/CR-6698, January 2001.
- C.3 Bierman, S.R., Durst, B.M., Clayton, E.D., "Critical Separation Between Subcritical Clusters of 4.29 Wt% ²³⁵U Rods in Water With Fixed Neutron Poisons," Battelle Pacific Northwest Laboratories, NUREG/CR-0073(PNL-2615).
- C.4 Baldwin, M.N., et.al., "Critical Experiments Supporting Close Proximity Water Storage Of Power Reactor Fuel," BAW-1484-7, July 1979.
- C.5 Hoovler, G.S., et.al., "Critical Experiments Supporting Underwater Storage of Tightly Packed Configurations of Spent Fuel Pins," BAW-1645-4, November 1981.
- C.6 "Dissolution and Storage Experimental Program with U(4.75)O₂ Rods," Transactions of the American Nuclear Society, Vol. 33, pg. 362.
- C.7 Rosenkrantz W.A., Introduction to Probability and Statistics for Scientists and Engineers, The McGraw-Hill, New York, NY, 1989.
- C.8 D'Agostino, R.B. and Stephens, M.A., Goodness-of-fit Techniques. Statistics, Textbooks and Monographs, Volume 68, New York, New York, 1986.
- C.9 Owen, D.B., Handbook of Statistical Tables, Addison-Wesley, Reading, MA.

Appendix D CASMO-4 Benchmarking for In-Rack Modeling

D.1 Introduction

The purpose of this Appendix is to provide qualification of the CASMO-4 code for use in the evaluation of the LaSalle Unit 2 Spent Fuel Pool with NETCO-SNAP-IN inserts. While the CASMO-4 code is not being used for the actual criticality calculation methodology, it is used for the selection of peak reactivity lattices and the determination of manufacturing uncertainties which have a depletion dependence. This evaluation is performed to address the guidance of References D.1 and D.2. The format and presentation follows the sample format presented in Section 6 of Reference D.2.

D.2 Code System

CASMO-4 is a multi-group, two-dimensional transport theory code with an in-rack geometry option where typical storage rack geometries can be defined on an infinite lattice basis. This code is used for fuel depletion and relative reactivity comparisons in a manner that is consistent with AREVA's NRC approved CASMO-4 / MICROBURN-B2 methodology (Reference D.3). The library files used in the evaluation are the standard CASMO-4 70 group library based on ENDFB-IV. The CASMO-4 computer code and data library are controlled by AREVA procedures and the version used in this analysis meets the requirements of Reference D.3. The CASMO-4 program is run on AREVA's HP-UX11 engineering workstations.

D.3 Benchmarking Methodology

Since the CASMO-4 code is a two-dimensional code that models the storage rack in an infinite array, it cannot be used to provide a stand-alone benchmark of finite criticality experiments. Consequently, the evaluation in this appendix takes a different approach – it provides a code to code comparison of the CASMO-4 code to the SCALE 4.4a KENO code. Benchmarking of the KENO code to criticality experiments was previously described in Appendix C.

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page D-2

The benchmarking of the CASMO-4 code in this Appendix is performed in two steps to demonstrate its acceptability for the two different ways that CASMO-4 is used in the LaSalle analysis.

- Identify the relative reactivity of a lattice with the use of the storage rack geometry option. This is addressed by determining the CASMO-4 uncertainty relative to KENO by comparison of calculated k-infinities from the two codes.
- Evaluate relative changes in reactivity associated with changes in manufacturing tolerances. For this evaluation, the differential k-infinities from the two codes are compared based upon the same input perturbations.

These different approaches are described in more detail in the following sections.

In addition to benchmarking against KENO, the CASMO-4 depletion uncertainty is established based on Reference D.3.

D.3.1 CASMO-4 Uncertainty for Absolute k-infinite Relative to KENO

The approach that is taken for the benchmarking of the in-rack CASMO-4 model is to perform a series of calculations with varied enrichments, geometries, and temperatures. The results of the CASMO-4 calculations are then compared to KENO results for the same configurations. The validation guidance of NUREG/CR-6698 (Reference D.2) is followed to determine a code uncertainty for CASMO-4 relative to KENO. The KENO calculations are treated as the critical experiments in the validation process. The validation includes ATRIUM-10 top and bottom lattices as well as ATRIUM-9 lattices.

D.3.2 CASMO-4 Uncertainty for Δk-infinite Relative to KENO

The capability of the CASMO-4 code to predict the change in reactivity associated with a perturbation of fuel parameters is demonstrated by comparison of Δk values obtained with KENO to those obtained with CASMO-4. The approach taken is to evaluate small perturbations in reactivity by varying the enrichment relative to a base case. The same cases used in the evaluation of the uncertainty of the absolute multiplication factor are used in this evaluation. The Δk values will be determined for both KENO and CASMO-4 for enrichment perturbations from the reference case.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page D-3

The Δk values are compared between the two codes and a statistical evaluation similar to that identified in Reference D.2 is used to establish an uncertainty for the determination of Δk values with CASMO-4 relative to KENO.

D.3.3 CASMO-4 Depletion Uncertainty

· · · ·

The CASMO-4 depletion uncertainty is derived from the AREVA licensing topical report based on the extensive benchmarking that is documented within Reference D.3. Comparisons against critical experiments were performed by Studsvik with results reported in Table 2.1 of AREVA's CASMO-4/MICROBURN-B2 licensing topical report (Reference D.3). In addition, the beginning of cycle cold critical calculations reported in Table 2.2 of this same licensing topical report also provide comparisons to critical data. Results of these comparisons indicate that CASMO-4 results will have a standard deviation of [] Δk (Table 2.1 of Reference D.3) without depletion and a standard deviation of [] Δk (Table 2.2 of Reference D.3) when the majority of assemblies have been depleted*.

In addition to depletion effects, the [] Δk standard deviation from Reference D.3 also includes manufacturing and measurement uncertainties. Since it is difficult to separate these uncertainties, this entire value ([] Δk) will be used for the CASMO-4 depletion uncertainty when using the discrete void history levels from Reference D.3.

D.4 **Experiment Descriptions**

As noted, KENO calculations are used as the reference experiments. The evaluations are based on the LaSalle Unit 2 Spent Fuel Pool with NETCO-SNAP-IN inserts. The validation is performed using both bottom and top ATRIUM-10 and ATRIUM-9 lattice geometries within the LaSalle Unit 2 Spent Fuel Pool with NETCO-SNAP-IN inserts. Enrichment is varied in 0.05 increments above and below an assumed base enrichment level up to maximum delta of 0.25. The maximum peak reactivity of the fuel manufactured for LaSalle in the given geometry is represented within the range of enrichments evaluated. The calculations are reported for 4°C, 20°C and 100°C (277°K, 293°K and 373°K).

^{*} The uncertainty of cold critical benchmarks effectively includes a depletion uncertainty since the majority of the bundles in the core are exposed. It is noted, that a cold in-sequence critical has significant similarities to an in-rack calculation since the majority of the control blades remain inserted effectively surrounding the majority of the fuel with a strong neutron absorber on two sides.

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page D-4

The minimum, base, and maximum enrichments for the ATRIUM-10 bottom (A10B), the ATRIUM-10 top (A10T) and the ATRIUM-9 (AT9) lattices are:

The fuel assembly data, rack geometry, and NETCO-SNAP-IN insert are the same as those for the LaSalle Unit 2 Spent Fuel Pool configuration.

1

D.5 Analysis of Validation Results

ſ

D.5.1 CASMO-4 Uncertainty for Absolute k-effective Relative to KENO

The calculated multiplication factors from KENO and CASMO were tabulated. The σ_{keno} terms are taken from each individual KENO calculation and the σ_{casmo} terms are set to the CASMO-4 convergence criteria for the individual case. (Use of the CASMO convergence is consistent with footnote 1 on page 6 of Reference D.2.) A combined uncertainty σ_{tot} was determined consistent with equation 3 of Reference D.2.

$$\sigma_{tot} = \sqrt{\sigma_{keno}^2 + \sigma_{casmo}^2}$$

The tabulated results are provided in Table D.1. The geometry is identified as either A10B (bottom lattice), A10T (top lattice), or AT9 (ATRIUM-9) along with the temperature and enrichment variations.

ANP-2843(NP) Revision 1 Page D-5

]

Table D.1 CASMO4 and KENO Validation Case Information

[

ANP-2843(NP) Revision 1 Page D-6

]

Table D.1 CASMO4 and KENO Validation Case Information (Continued)

[

ANP-2843(NP) Revision 1 Page D-7

]

Table D.1 CASMO4 and KENO Validation Case Information (Continued)

[

Since this is a comparison between two codes, the differences of the calculated values for the multiplication factor are determined. The results of the difference along with the components used in the statistical evaluation are provided in Table D.2.

[

ANP-2843(NP) Revision 1 Page D-8

]

Table D.2 CASMO - KENO Difference and Statistical Parameters

^{*} Δk is $k_{CASMO} - k_{KENO}$

AREVA NP Inc.

ANP-2843(NP) Revision 1 Page D-9

]

Table D.2 CASMO - KENO Difference and Statistical Parameters (Continued)

[

 $[\]Delta k$ is $k_{CASMO} - k_{KENO}$

ANP-2843(NP) Revision 1 Page D-10

]

Table D.2 CASMO - KENO Difference and Statistical Parameters (Continued)

l

The weighted average difference ($\Delta kbar$), the variance about the mean s², and the average total uncertainty σ^2 are calculated using the weighting factor $1/\sigma_t^2$. The square root of the pooled variance is determined per Equation 7 of Reference D.2

 $[\]Delta k$ is $k_{CASMO} - k_{KENO}$

ANP-2843(NP) Revision 1 Page D-11

$$S_p = \sqrt{s^2 + \sigma^2}$$

Weighted mean difference	∆kbar	[]	Ref D.2 Eq 6
Average total uncertainty	σ^2	[]	Ref D.2 Eq 5
Variance about mean	s ²	[]	Ref D.2 Eq 4
Square root of pooled variance	Sp	[]	Ref D.2 Eq 7

The CASMO-4 bias relative to KENO is []. The bias uncertainty value is rounded up to

[].

Normality test

Normality tests were performed on the combined data and the results were somewhat indeterminate but indicated potential non-normality. The data was then subdivided by temperature which is consistent with the use of CASMO-4 in comparing lattice results at the same temperature. In this comparison each temperature data set was determined to be a normal distribution. A single uncertainty for the combined data set is conservatively reported rather than individual temperature dependent uncertainty values.

Since this uncertainty value is only used to demonstrate that the CASMO-4 code can select the most reactive lattices for a given temperature, a 95/95 confidence multiplier is not determined.

Data Trending

No specific trending of the code bias was completed since CASMO-4 is not used directly for the determination of the absolute value of the multiplication factor. It is noted that the agreement is better at 4 °C than 100 °C.

Area of Applicability

The fuel and rack geometry as well as fuel enrichment were evaluated consistent with the LaSalle Unit 2 spent fuel pool. Therefore the area of applicability is specific to the LaSalle Unit 2 spent fuel pool with inserts.

D.5.2 CASMO-4 Uncertainty for Δk-effective

The actual KENO and CASMO calculations used in this evaluation are those used in Section D.5.1. In this evaluation, the relative reactivity change is evaluated by taking the delta with respect to the initial reference reactivity. A difference is then determined between the Δk values obtained with KENO and the Δk values obtained with CASMO-4 for the same perturbation.

[

ANP-2843(NP) Revision 1 Page D-13

]

Table D.3 Lattice Evaluations at 4°C

ANP-2843(NP) Revision 1 Page D-14

]

Table D.4 Lattice Evaluations at 20°C

[

ANP-2843(NP) Revision 1 Page D-15

Table D.5 Lattice Evaluations at 100°C

The average difference between the Δk values was [

] with a standard deviation of

[

].

[

AREVA NP

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page D-16

The Shapiro-Wilk data normality test and the Anderson-Darling goodness of fit for normality (see section 9.5.4.1 of Reference D.4) were performed on the Δk comparisons. Based on the test results and a visual inspection of the data, it is considered normally distributed.

For the data sample of 50 the single sided tolerance factor is 2.065 from Table 2.1 of Reference D.2. This is conservatively applied for 90 data samples.

Therefore, the 95/95 uncertainty is [].

Data Trending

A code bias is not used in the evaluation of incremental reactivity. Therefore, trending of the bias was not completed.

Area of Applicability

The fuel and rack geometry as well as fuel enrichment were evaluated consistent with the LaSalle Unit 2 spent fuel pool. Therefore the area of applicability is specific to the LaSalle Unit 2 spent fuel pool with inserts.

D.6 Total CASMO-4 Uncertainty

When applied on a differential basis a Δk predicted by CASMO-4 agrees with the KENO V.a based Δk with an uncertainty less than [] Δk , (see Section D.5). This can be combined with the [] Δk depletion uncertainty discussed in Section D.3.3 to obtain the total CASMO-4 uncertainty. A 95/95 uncertainty result is also obtained by multiplying these uncertainties by an appropriate multiplier. Since these values are independent they will be combined using the square root of the sum of the squares as shown in the following table. This process results in a total CASMO-4 uncertainty value of less than 0.007* Δk .

Uncertainty Value		σ	95/95 Multiplier	95/95 Uncertainty
Depletion	[]	2.0	[]
Calculational (Δk based)	[]	2.065	[]]
Combined				[]

] Therefore, the uncertainty of a single assembly made up of these lattices will not differ significantly from the 0.007 Δk determined here.

An alternate approach for determining the reactivity worth of the uncertainty in the fuel depletion calculation is discussed in Section 5.A.5 of Reference D.1. "In the absence of any other determination of the depletion uncertainty, an uncertainty equal to 5% of the reactivity decrement to the burnup of interest is an acceptable assumption." While this section of Reference D.1 explicitly addresses analyses that credit reactivity depletion due to fuel burnup (i.e. burnup credit), recent discussions with the NRC indicate that 5% of the reactivity increment (BOL to peak reactivity) would be an acceptable representation of the depletion uncertainty to peak reactivity. Based on this information, 5% of the reactivity increment from BOL to peak reactivity was determined for the three reference bounding lattices. [

D.7 Conclusions

A code bias uncertainty of [] was determined for CASMO-4 relative to KENO V.a in the determination of the absolute value of the multiplication factor. Based on this, it is demonstrated that the CASMO-4 code can be used for the characterization of the in-rack reactivity of fuel designs in the LaSalle Unit 2 spent fuel pool.

A standard deviation of [] was established for determining Δk with CASMO-4 relative to the Δk determined with KENO V.a. A 95/95 confidence multiplier of 2.065 is applicable for this uncertainty.

The evaluation of the ATRIUM-9, ATRIUM-10 bottom, and ATRIUM-10 top lattices demonstrated that there is no specific fuel geometry dependence relative to the use of CASMO-4 with respect to evaluating the in-rack reactivity.

The 0.01 Δk adder used when defining the REBOL lattices conservatively bounds the CASMO-4 uncertainty. Consequently, no CASMO bias or uncertainty is required in the final $k_{95/95}$ calculation.

LaSalle Unit 2 Nuclear Power Station Spent Fuel	ANP-2843(NP)
Storage Pool Criticality Safety Analysis with	Revision 1
Neutron Absorbing Inserts and Without Boraflex	Page D-19

D.8 References

- D.1 Memorandum L. Kopp to T. Collins, "Guidance on the Regulatory Requirements for Criticality Analysis of Fuel Storage at Light-Water Reactor Power Plants," NRC, August 19, 1998. (NRC –ADAMS Accession Number ML072710248)
- D.2 NUREG/CR-6698, "Guide for Validation of Nuclear Criticality Safety Calculational Methodology," USNRC, January 2001.
- D.3 EMF-2158(P)(A) Revision 0, Siemens Power Corporation Methodology for Boiling Water Reactors: Evaluation and Validation of CASMO-4/MICROBURN-B2, Siemens Power Corporation, October 1999.
- D.4 MIL-HDBK-5J, "Metallic Materials and Elements for Aerospace Vehicle Structures", Department of Defense, January 2003.

Distribution

Controlled Distribution

Richland

- RJ DeMartino
- RE Fowles
- R Fundak
- SW Jones
- DP Jordheim
- CD Manning
- CM Powers
- EE Riley
- AW Will
- PD Wimpy

ATTACHMENT 7 Summary of Regulatory Commitments

 \mathbf{X}

The following list identifies those actions committed to by Exelon Generation Company, LLC, (EGC) in this submittal. Any other actions discussed in the submittal represent intended or planned actions by EGC, are described only for information, and are not regulatory commitments.

		COMMITMENT TYPE	
COMMITMENT	COMMITTED DATE OR "OUTAGE"	ONE-TIME ACTION (YES/NO)	PROGRAM- MATIC (YES/NO)
The ATRIUM-10 fuel assembly design limitations will be incorporated in reload design documents and SFP criticality compliance procedures. Additionally, the design limitations will be reflected in Sections 9.1.2.1 and 9.1.2.2 of the LaSalle County Station (LSCS) Updated Final Safety Analysis Report (UFSAR).	Upon implementation of the proposed change	No	Yes
The Boraflex monitoring program will continue to be maintained for as long as EGC continues to credit Boraflex for criticality control, regardless of the implementation of NETCO-SNAP-IN® rack inserts.	Complete	No	Yes
The rack inserts will be installed in stages, with each stage of installation resulting in the use of a rack insert in all the spent fuel storage rack cells of a given individual spent fuel storage rack and all the cells of the first row and first column of adjoining spent fuel storage racks, such that all sides of the fuel assemblies within the spent fuel storage rack are adjacent to a face of the rack insert's wing.	Prior to crediting the neutron absorption capabilities of the NETCO-SNAP-IN® rack inserts for each individual Unit 2 spent fuel storage rack	Yes	No

ATTACHMENT 7 Summary of Regulatory Commitments

		COMMITN	IENT TYPE
		ONE-TIME ACTION	PROGRAM- MATIC
COMMITMENT	OR "OUTAGE"	(YES/NO)	(YES/NO)
EGC will implement the Rio Tinto Alcan Composite Surveillance Program as described in Section 3.9 of Attachment 1 to ensure that the performance requirements of the Rio Tinto Alcan composite in the NETCO-SNAP-IN® rack inserts are met over the lifetime of the spent fuel storage racks with the rack inserts installed. A description of the program will be added to the LSCS UFSAR upon implementation of the proposed change.	Upon implementation of the proposed change	No	Yes