# WATTS BAR NUCLEAR PLANT A.1-1 RO

A.1-1 RO Calculate Shutdown Margin

# WATTS BAR NUCLEAR PLANT A.1-1 RO

#### ADMINISTRATIVE JOB PERFORMANCE MEASURE

Task: Calculate Shutdown Margin

- Alternate Path: N/A
- Facility JPM #: 3-OT-JPMADA-1.3

2.1.7 [3.7/4.4] 2.1.25 [2.8/3.1] K/A Rating(s): 001A4.11 [3.5/4.1]

Task Standard: Performer completes a Conservative SDM Hand Calculation per 1-SI-0-10 Section 6.2. Determines Required RCS Boron Concentration, determines present boron concentration is inadequate for cooldown

#### **Preferred Evaluation Location:**

Simulator X In-Plant

References: 1-SI-0-10, "Shutdown Margin", Rev. 21; NUPOP, "Nuclear Parameters and Operating Package for Watts Bar Unit 1, Cycle 9", Rev 2; NOB, "Unit 1 Nuclear Operating Book, Sheet A-3" Rev 59.

Task Number: RO-085-SI-0-10-001 APPLICABLE FOR: RO/SRO

**Preferred Evaluation Method:** 

Perform X Simulate

#### 10CFR55.45: 1, 5, 12

Validation Time: 20 min. Time Critical: No 

Performer:			Time Start:
_	NAME	SSN	Time Finish:
Performance R	ating: SAT UNSAT		Performance Time
Examiner:	NAME	SIGNATU	/ JRE DATE

#### COMMENTS

**Tools/Equipment/Procedures Needed:** 

Rev. 0

Latest revision of 1-SI-0-10 NUPOP for WBN Unit 1 Cycle 9 NOB for WBN Unit 1 Ruler or straight edge. Calculator

NOTE: START THIS JPM AT A LOCATION WHERE PERFORMER HAS ACCESS TO PROCEDURES (Simulator, Main Control Room, TIC or provide performer with procedure).

## READ TO OPERATOR

#### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit has tripped and requires a cooldown to 160 °F.
- 2. ICS Point U7981 indicates core average burnup is 7500 MWD/MTU.
- 3. All control rods have fully inserted into the core.
- 4. At least one reactor coolant pump will remain in operation until cooldown is complete. RCP #2 is running and is desired to remain running for the entire cooldown.
- 5. RCS boron concentration is 1500 ppm.
- 6. You are an extra Unit Operator.

#### **INITIATING CUES:**

The SM/Unit SRO has directed you to perform a Conservative SDM Hand Calculation per 1-SI-0-10 "Shutdown Margin", Section 6.2 based on the conditions stated above.

- 1. Determine the Required RCS Boron concentration.
- 2. Determine if acceptance criteria are met.
- 3. Notify SM/Unit SRO of the Required RCS Boron Concentration.

<u>STEP 1</u> :	Obtain a copy of the instruction.	SV1
STANDARD:	A copy of 1-SI-0-10 has been obtained.	SAT
EXAMINER'S	CUE: Provide the Performer a copy of the instruction.	UNSAT
COMMENTS:		
NOTE Due to the an pass accepta Sections 6.3 (	nount of conservatism factored into this calculation, this instrunce criteria if performed in MODES 1 or 2. During MODES 1 or 6.4.	uction may NOT 2, perform
<u>STEP 2</u> : <b>[1]</b>	<b>ENSURE</b> precautions and limitations in Section 3.0 have been reviewed.	
<u>STANDARD</u> :	Performer reviews Section 3.0 Precautions and Limitations.	SAT
COMMENTS:		UNSAT
<u>STEP 3</u> : <b>[2]</b>	<b>ENSURE</b> prerequisite actions in Section 4.0 have been met.	
EVALUATOR	CUE: State that Section 4.0 actions have been met.	SAT
STANDARD:	Performer proceeds to the next step	
COMMENTS:		UNSAT

Re	v. 0	A.1-1R Page 6 of 11
<u>Step 4</u> : <b>[3]</b>	<ul> <li>OBTAIN the NuPOP for the applicable cycle AND RECORD:</li> <li>A. The WCAP number and cycle number: WCAP Cycle</li> <li>B. The Maximum Stuck Rod Worth. Table D1, (Mode 2 below nuclear heating through Mode 5): pcm</li> </ul>	CRITICAL STEP SAT UNSAT
<u>STANDARD</u> :	Performer records WCAP- <u>16880-P</u> and Cycle <u>9</u> . Performer records <u>1242</u> pcm.	
COMMENTS:		

NOTES 1) It is permissible to use a conservative RCS temperature to bound a potential plant cooldown. Remember that Mode 4 is more limiting than Mode 5.		
2) Number of immovable/untrippable rods refers to the actual number of immovable/untrippable rods, NOT the one that is assumed to be untripped from the definition of SDM		
<u>STEP 5</u> : <b>[4]</b>	<b>DETERMINE</b> the following plant conditions: A. Core average burnup:MWD/MTU ( <i>ICS computer point U7981</i> ) and check the applicable core life below as defined in NuPOP Section 8.3.	CRITICAL STEP
	Beginning of Life Middle of Life End of Life B. Number of immovable/untrippable rods:	SAT
	C. Minimum Tcold for the desired condition:°F D. RCS Boron Concentration CB:ppm	UNSAT
<u>STANDARD</u> :	Performer records the following: A. Core average burnup: <u>7500</u> MWD/MTU. From Section 8.3, Performer checks Middle of Life box. B. Number of immovable/untrippable rods: <u>0</u> C. Minimum Tcold for the desired condition: <u>160</u> °F D. RCS Boron Concentration Cb: <u>1500</u> ppm	
COMMENTS:		

Re	v. 0	A.1-1R Page 8 of 11
<u>STEP 6</u> : <b>[5]</b>	IF there are immovable/untrippable rods, THEN A. RECORD the differential Boron Worth using burnup from Step 6.2[4]A and RCS Boron Concentration from Step 6.2[4]D: Differential Boron Worth:pcm/ppm (See NuPOP Figure 6-22) B. CALCULATE the absolute value stuck rod correction $xpcm \divpcm / ppm$ (Step 6.2[4]B) (Step 6.2[3]B ) (Step 6.2[5]A) Stuck rod correction (absolute value) = ppm	SAT UNSAT
<u>STANDARD</u> :	Performer enters N/A for this step, since the Cue Sheet stated that there were NO UNTRIPPABLE RODS. If the Performer completes the calculation, the value entered will still be ZERO. $\underbrace{0}_{(\text{Step [4] B)}} \times \underbrace{1242}_{(\text{Step [3] B)}} \operatorname{pcm} \div \underbrace{\mathbf{-6.5}}_{(\text{Step [4] E)}} \operatorname{pcm/ppm}$ Stuck rod correction = $\underbrace{0}_{(\text{ppm})} \operatorname{ppm}$ .	
COMMENTS:	Performer may enter a 0 for the stuck rod correction without ooking up data since there are no additional stuck rods, and the step is CONDITIONAL (IFTHEN)	
<u>STEP 7</u> : <b>[6]</b>	<b>RECORD</b> the (M-P) <sub>SDM</sub> from NOB Sheet A-3. (M-P) <sub>SDM</sub> =ppm.	CRITICAL STEP
<u>STANDARD</u> :	Performer obtains the required value by referring to the NOB sheet A-3. records it in the procedure blank. (M-P) <sub>SDM</sub> = <b>90</b> ppm.	SAT
<u>COMMENTS</u> :		UNSAT

<u>STEP 8</u> : <b>[7]</b>	CALCULATE required RCS C <sub>B</sub>	CRITICAL STEP
	[a] DETERMINE <u>UNCORRECTED</u> Maximum Required C <sub>B</sub> , from NuPOP Table 7-4 using burnup of Step [4] A and temperature of Step [4] C:	0.1
	<u>UNCORRECTED</u> Max Required CB = ppm	SAT
<u>STANDARD</u> :	Performer obtains the required value by referring to the NuPOP Table 7-4 for 2500 MWD/MTU and 160 °F records value in the procedure blank. <u>UNCORRECTED</u> Max Required CB = <u>1563</u> ppm	UNSAT
COMMENTS:		
STEP 9 [7b]	CALCULATE required RCS Cp	CRITICAL
		GTED
<u>0121 0</u> . [10]	[b] CALCULATE the Required C <sub>B</sub>	STEP
<u>0.12. 0</u> . (10)	[b] CALCULATE the Required $C_B$ $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$	STEP
<u></u> . []	[b] CALCULATE the Required $C_B$ $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$ Required $C_B = \_\_\_\_ ppm$	STEP SAT UNSAT
<u>STANDARD</u> :	[b] CALCULATE the Required C <sub>B</sub> $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm Performer calculates the sums from Step [5], Step [6] and Step 7a, and enters the valve calculated in the Required Cb blank. $\frac{0}{(\text{Step [5]})} + \frac{90}{(\text{Step [6]})} + \frac{1563}{(\text{Step [7] [a]})}$	STEP
<u>STANDARD</u> :	[b] CALCULATE the Required C <sub>B</sub> $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm Performer calculates the sums from Step [5], Step [6] and Step 7a, and enters the valve calculated in the Required Cb blank. $\frac{0}{(\text{Step [5]})} + \frac{90}{(\text{Step [6]})} + \frac{1563}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm	STEP
STANDARD:	[b] CALCULATE the Required C <sub>B</sub> $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm Performer calculates the sums from Step [5], Step [6] and Step 7a, and enters the valve calculated in the Required Cb blank. $\frac{0}{(\text{Step [5]})} + \frac{90}{(\text{Step [6]})} + \frac{1563}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm	STEP
<u>STANDARD</u> :	[b] CALCULATE the Required C <sub>B</sub> $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm Performer calculates the sums from Step [5], Step [6] and Step 7a, and enters the valve calculated in the Required Cb blank. $\frac{0}{(\text{Step [5]})} + \frac{90}{(\text{Step [6]})} + \frac{1563}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm	STEP
<u>STANDARD</u> :	[b] CALCULATE the Required C <sub>B</sub> $\frac{1}{(\text{Step [5]})} + \frac{1}{(\text{Step [6]})} + \frac{1}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm Performer calculates the sums from Step [5], Step [6] and Step 7a, and enters the valve calculated in the Required Cb blank. $\frac{0}{(\text{Step [5]})} + \frac{90}{(\text{Step [6]})} + \frac{1563}{(\text{Step [7] [a]})}$ Required C <sub>B</sub> = ppm	STEP

Rev. 0	A.1-1R Page 10 of 11
<u>STEP 10</u> : <b>[8]</b> VERIFY That RCS $C_B$ in Step [4] D is greater than or equal to the Required $C_B$ in Step [7][b] (Acc Crit. A & B).	CRITICAL STEP
<u>STANDARD</u> : Performer determines that the acceptance criteria are <b>NOT</b> <b>MET</b> . Value in step [4] D is less than Value in Step [7][b] and reports to the Unit Supervisor.	SAT
EVALUATOR CUE: Role play as SM/Unit supervisor and acknowledge report.	UNSAT
COMMENTS:	
END OF TASK	

TIME STOP: \_\_\_\_\_

### PERFORMER CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit has tripped and will require a Unit Cooldown to 160 °F.
- 2. ICS Point U7981 indicates core average burnup is 7500 MWD/MTU.
- 3. All control rods have fully inserted into the core.
- 4. At least one reactor coolant pump will remain in operation until cooldown is complete. #2 RCP is running and is desired to remain running for the entire cooldown.
- 5. RCS boron concentration is 1500 ppm.
- 6. You are an extra Unit Operator.

#### **INITIATING CUES:**

The SM/Unit SRO has directed you to perform a Conservative SDM Hand Calculation per 1-SI-0-10 "Shutdown Margin", Section 6.2 based on the conditions stated above.

- 1. Determine the Required RCS Boron concentration.
- 2. Determine if acceptance criteria are met.
- 3. Notify SM/Unit SRO of the Required RCS Boron Concentration.

# WATTS BAR NUCLEAR PLANT A.1-1SRO

A.1-1SRO Perform Technical Review of Shutdown Margin Calculation

## WATTS BAR NUCLEAR PLANT A.1-1SRO

#### ADMINISTRATIVE JOB PERFORMANCE MEASURE

Task: Perform Technical Review of Shutdown Margin Calculation

- Alternate Path: N/A
- Facility JPM #: New

K/A Rating(s): 001A4.11 [3.5/4.1] 2.1.7 [3.7/4.4] 2.1.25 [2.8/3.1]

**Task Standard:** Performer completes a Technical Review of Shutdown Margin Calculation Conservative SDM Hand Calculation per 1-SI-0-10 Section 6.2. Determines Required RCS Boron Concentration, determines present boron concentration is inadequate for cooldown, due to multiple errors made in transposing data and performing calculations.

Preferred Evaluation Location:

Simulator X In-Plant

**<u>References</u>**: 1-SI-0-10, "Shutdown Margin", Rev. 21; NUPOP, "Nuclear Parameters and Operating Package for Watts Bar Unit 1, Cycle 9", Rev 2; NOB, "Unit 1 Nuclear Operating Book, Sheet A-3" Rev 59.

Task Number: RO-085-SI-0-10-001

APPLICABLE FOR: RO/SRO

**Preferred Evaluation Method:** 

Perform X Simulate

#### 10CFR55.45: 1, 5, 12

Validation Time: 15 min. Time Critical: No \_\_\_\_\_ Performer: Time Start: Time Finish: NAME SSN Performance Rating: SAT \_\_\_\_ UNSAT \_\_\_\_ Performance Time \_\_\_\_ Examiner: SIGNATURE NAME DATE \_\_\_\_\_ \_\_\_\_\_ COMMENTS

### **Tools/Equipment/Procedures Needed:**

Latest revision of 1-SI-0-10 NUPOP for WBN Unit 1 Cycle 9 NOB for WBN Unit 1 Ruler or straight edge. Calculator

NOTE: START THIS JPM AT A LOCATION WHERE PERFORMER HAS ACCESS TO PROCEDURES (Simulator, Main Control Room, TIC or provide performer with procedure).

## READ TO OPERATOR

#### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit has tripped and requires a cooldown to 160 °F.
- 2. ICS Point U7981 indicates core average burnup is 7500 MWD/MTU.
- 3. All control rods have fully inserted into the core.
- 4. At least one reactor coolant pump will remain in operation until cooldown is complete. #2 RCP is running and is desired to remain running for the entire cooldown.
- 5. RCS boron concentration is 1500 ppm.
- 6. You are the Unit SRO.

#### **INITIATING CUES:**

The SM has directed you to perform a technical review of the Conservative SDM Hand Calculation per 1-SI-0-10 "Shutdown Margin", Section 6.2 which was calculated based on these conditions.

<u>STEP 1</u> :	Obtain a copy of the instruction.	CAT
STANDARD:	A copy of 1-SI-0-10 has been obtained.	SAT
EXAMINER'S	CUE: Provide the Performer a copy of the completed 1-SI- 0-1, Section 6.2.	UNSAT
COMMENTS:		
NOTE Due to the an pass accepta Sections 6.3	nount of conservatism factored into this calculation, this instrunce criteria if performed in MODES 1 or 2. During MODES 1 or or 6.4.	uction may NOT 2, perform
<u>STEP 2</u> : <b>[1]</b>	<b>ENSURE</b> precautions and limitations in Section 3.0 have been reviewed.	
STANDARD:	Performer reviews Section 3.0 Precautions and Limitations.	SAT
COMMENTS:		UNSAT
<u>STEP 3</u> : <b>[2]</b>	<b>ENSURE</b> prerequisite actions in Section 4.0 have been met.	
<u>STANDARD</u> :	Performer determines that Section 4.0 is complete.	SAT
COMMENTS:		UNSAT

Re	v. 0	A.1-1SRO Page 6 of 17
<u>Step 4</u> : <b>[3]</b>	<ul> <li>OBTAIN the NuPOP for the applicable cycle AND RECORD:</li> <li>A. The WCAP number, unit, and cycle number (front cover of NuPOP):WCAP Unit Cycle</li> <li>B. The Maximum Stuck Rod Worth. Table D1, (Mode 2 below nuclear heating through Mode 5): pcm</li> </ul>	CRITICAL STEP
<u>STANDARD</u> :	Performer verifies that the information associated with A is correct. (WCAP- <u>16880-P</u> Unit <u>1</u> and Cycle <u>9</u> .) Performer determines that an incorrect value of <u>1020</u> was entered from Table D-1 and notes <u>1242</u> pcm is the correct value.	
COMMENTS:		

NOTES 1) It is permissible to use a conservative RCS temperature to bound a potential plant cooldown. Remember that Mode 4 is more limiting than Mode 5.		
2) Number of immovable/untrippable rods refers to the actual number of immovable/untrippable rods, NOT the one that is assumed to be untripped from the definition of SDM		
<u>STEP 5</u> : <b>[4]</b>	DETERMINE the following plant conditions: A. Core average burnup:MWD/MTU ( <i>ICS</i> <i>computer point U7981</i> ) and check the applicable core life below as defined in NuPOP Section 8.3. Beginning of Life Middle of Life End of Life B. Number of immovable/untrippable rods:°F	CRITICAL STEP SAT UNSAT
<u>STANDARD</u> :	<ul> <li>D. RCS Boron Concentration CB:ppm</li> <li>Performer determines the following data was entered correctly:</li> <li>A. Core average burnup: <u>7500</u>MWD/MTU.</li> <li>From Section 8.3, Performer checks Middle of Life box.</li> <li>B. Number of immovable/untrippable rods: <u>0</u></li> <li>C. Minimum Tcold for the desired condition: <u>160</u> °F</li> </ul>	
COMMENTS:	D. RCS Boron Concentration Cb: <u>1500</u> ppm	

Re	v. 0	A.1-1SRO Page 8 of 17
<u>STEP 6</u> : <b>[5]</b>	IF there are immovable/untrippable rods, THEN A. RECORD the differential Boron Worth using burnup from Step 6.2[4]A and RCS Boron Concentration from Step 6.2[4]D: Differential Boron Worth:pcm/ppm (See NuPOP Figure 6-22) B. CALCULATE the absolute value stuck rod correction × pcm ÷ pcm / ppm (Step 6.2[4]B) (Step 6.2[3]B ) (Step 6.2[5]A) Stuck rod correction (absolute value) = ppm	SAT UNSAT
<u>STANDARD</u> :	This step should have an N/A entered, since the Cue Sheet stated that there were NO UNTRIPPABLE RODS. If the Performer completes the calculation, the value entered will still be ZERO. $\frac{0}{(\text{Step 6.2[4] B)}} \times \frac{1242}{(\text{Step 6.2[3] B)}} \exp \frac{-6.5}{(\text{Step 6.2[5] A)}} \exp \frac{1242}{(\text{Step 6.2[5] A)}} \exp 1$	
COMMENTS:		

Rev. 0	
<b>RECORD</b> the $(M-P)_{SDM}$ from NOB Sheet A-3. $(M-P)_{SDM} = \ppm.$	CRITICAL STEP
Performer determines that the value entered is incorrect, in that a negative sign was entered. Performer obtains the required value by referring to the NOB sheet A-3. records it in the procedure blank.	SAT
$(M-P)_{SDM} = -90$ ppm.	UNSAT
CORRECT VALUE	
(M-P) <sub>SDM</sub> = <u><b>90</b></u> ppm.	
	<b>RECORD</b> the (M-P) <sub>SDM</sub> from NOB Sheet A-3. (M-P) <sub>SDM</sub> =ppm. Performer determines that the value entered is incorrect, in that a negative sign was entered. Performer obtains the required value by referring to the NOB sheet A-3. records it in the procedure blank. (M-P) <sub>SDM</sub> = <b>90</b> ppm. <b>CORRECT VALUE</b> (M-P) <sub>SDM</sub> = <b><u>90</u> ppm.</b>

т
SAT

Rev. 0	A.1-1SRO Page 11 of 17
STEP 9: <b>[7b] CALCULATE</b> required RCS C <sub>B</sub> <b>[b] CALCULATE</b> the Required C <sub>B</sub>	CRITICAL STEP
(Step [5]) + (Step [6]) + (Step [7] [a])	SAT
Required C <sub>B</sub> = ppm	UNSAT
$\begin{tabular}{lllllllllllllllllllllllllllllllllll$	
+90 + <u>1558</u> (Step [5])	
Required C <sub>B</sub> = <u><b>1468</b></u> ppm	
NOTE TO EVALUATOR: CORRECT VALUE	
<u>0</u> + <u>90</u> + <u>1563</u> (Step [5]) + (Step [6]) + (Step [7] [a])	
Required $C_B = \1653$ ppm	
<u>COMMENTS</u> :	

Re	v. 0	A.1-1SRO Page 12 of 17
<u>STEP 10</u> : <b>[8]</b>	<b>VERIFY</b> That RCS $C_B$ in Step [4] D is greater than or equal to the Required $C_B$ in Step [7][b] (Acc Crit. A & B).	CRITICAL STEP
<u>STANDARD</u> :	Performer determines that the acceptance criteria is <b>NOT MET</b> , which was not initially reported. Actual corrected value in step [4] D is less than Value in Step [7] [b]. Informs the SM that multiple errors were made in the calculation and that the Acceptance Criteria which was initially indicated as <b>MET</b> was <b>NOT MET</b> based on the corrected calculation.	SAT
COMMENTS:		
	END OF TASK	

TIME STOP: \_\_\_\_\_

### PERFORMER CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit has tripped and requires a cooldown to 160 °F.
- 2. ICS Point U7981 indicates core average burnup is 7500 MWD/MTU.
- 3. All control rods have fully inserted into the core.
- 4. At least one reactor coolant pump will remain in operation until cooldown is complete. RCP #2 is running and is desired to remain running for the entire cooldown.
- 5. RCS boron concentration is 1500 ppm.
- 6. You are the Unit SRO.

#### **INITIATING CUES:**

The SM has directed you to perform a technical review of the Conservative SDM Hand Calculation per 1-SI-0-10 "Shutdown Margin", Section 6.2 which was calculated based on these conditions.

Unit 1		Shutdown Margin	1-SI-0-10 Rev. 0021 Page 16 of 47	
Data	Pack	age: Page <u>/</u> of <u>4</u>	D	ate <u>5/18/0</u>
.2 Con	serva	tive SDM Hand Calculation		
Due to the a pass accept Sections 6.3	moun ance o or 6.4	t of conservatism factored into this calc criteria if performed in MODES 1 or 2. 4.	culation, this instruction During MODES 1 or 2,	may NOT perform
D	EN	SURE Precautions and Limitations in S	Section 3.0 have	Dett
R	EN	SURE Prerequisite Actions in Section	4.0 have been met.	DAH
Ø	OB RE	TAIN the NuPOP for the applicable fue	el cycle AND	DAN
	$\otimes$	The WCAP number, unit, and cycle r NuPOP):	number (front cover of	
		WCAP-16680-P Unit _1 Cycle_	9	
	B.	The Maximum Stuck Rod Worth. Appendix D Table D-1, (Mode 2 belo through Mode 5):	w nuclear heating	
		_1020 pcm		DAA
		NOTES		
<ol> <li>It is per cooldov</li> <li>Numbe immova definition</li> </ol>	missib vn. Ro r of im able/ur on of S	le to use a conservative RCS tempera emember that Mode 4 is more limiting movable/untrippable rods refers to the htrippable rods, NOT the one that is as DM	ature to bound a potenti than Mode 5. e actual number of ssumed to be untripped	al plant from the
	DE	<b>FERMINE</b> the following plant condition	IS:	
	Q	computer point U7981) and check the below as defined in NuPOP Section	e applicable core life 8.3.	
		Beginning of Life Middle of Life		
		End of Life		

WBN Unit 1	Shutdown Margin	1-SI-0-10 Rev. 0021 Page 17 of 47
Data F	Package: Page <u>2</u> of <u>4</u>	Date 5/18/
6.2 Conse	ervative SDM Hand Calculation (continu	ued)
(	Minimum T <sub>cold</sub> for the desired condition	on: <u>160</u> °F
2	RCS Boron Concentration C <sub>B</sub> : 150	D ppm
(16)	IF there are immovable/untrippable rods,	THEN
000	RECORD the differential Boron Wor Step 6.2[4]A and RCS Boron Conce 6.2[4]D:	th using burnup from intration from Step
	Differential Boron Worth: -6.4 (See NuPOP Figure 6-22)	pcm/ppm
(	$\begin{array}{c} & & \\$	uck rod correction <u>-6.4</u> pcm/ppm Step 6.2[5]A)
	Stuck rod correction (absolute value	D = d nom DAA

. .



CAUTION

It is the responsibility of Operations to ensure that dilution protection is adequate for plant conditions. Dilution protection is assured by either 1) the performance of 1-SI-62-1, Uncontrolled Boron Dilution, 2) Stopping ALL Primary Water pumps and issuing a HOLD ORDER as administrative controls, or 3) performing the calculations within this procedure and verifying that the RCS boron concentration is adequate to allow the operator time to recognize the presence of a dilution.

#### NOTE

Dilution protection calculations are NOT needed when RHR is NOT in service or when one or more RCP's will be maintained in operation along with RHR or when dilution protection will be accomplished via valve alignment or primary water pump hold order.

Q

IF dilution protection is needed via boron analysis, THEN

PERFORM Appendix A.

NA

WBN	Shutdown Margin	1-SI-0-10
Unit 1		Rev. 0021
		Page 19 of 47

Data Package: Page 4 of 4

Date <u>5/18/09</u>

6.2 Conservative SDM Hand Calculation (continued)



**OBTAIN** Technical Review of results by STA, Senior Reactor Operator or Reactor Engineer.

STA/SRO/RXE

# WATTS BAR NUCLEAR PLANT A.1-2 RO

A.1-2 RO Calculate Target Boron Cb for Load Escalation Using Appendix E of SOI-62.02

# WATTS BAR NUCLEAR PLANT A.1-2 RO

### ADMINISTRATIVE JOB PERFORMANCE MEASURE

**Task:** Calculate Target Boron Cb for Load Escalation Using Appendix E of SOI-62.02

- N/A Alternate Path:
- Facility JPM #: 3-OT-JPMADA.1-2R
- **K/A Rating(s):** G2.1.25 [2.8/3.1]
- **Task Standard:** Performer completes a calculation for Target Boron Concentration per SOI-62.02, Appendix E "Reactivity balance calculation". Target RCS Boron Concentration is determined.

#### Preferred Evaluation Location:

- Simulator X In-Plant
- References: SOI-62.02, "Boron Concentration Control", Rev. 47; NUPOP, WCAP-16880-P, "Nuclear Parameters and Operating Package for Watts Bar Unit 1, Cycle 9", Rev 2.

Task Number: RO-062-SOI-62-016 APPLICABLE FOR: RO/SRO

10CFR55.45: 1, 5, 12

Validation Time: 20	0 min. <u>Time C</u>	Critical: No			
Performer:	NAME		SSN	_ Time Start: _ Time Finish: _	
Performance Rating:	SAT UNSAT _			Performance 7	Гime
Examiner:	NAME		SIGNA	///////	DATE
	C	COMMENTS			

**Preferred Evaluation Method:** 

Perform X\_\_\_\_ Simulate \_\_\_\_\_

## **Tools/Equipment/Procedures Needed:**

Latest revision of SOI-62.02 NUPOP for WBN Unit 1 Cycle 9 NOB for WBN Unit 1 Ruler or straight edge. Calculator

NOTE: START THIS JPM AT A LOCATION WHERE PERFORMER HAS ACCESS TO PROCEDURES (Simulator, Main Control Room, TIC or provide performer with procedure).

## READ TO OPERATOR

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit is operating at 75% rated thermal Power.
- 2. Core average burnup is 12000 MWD/MTU.
- 3. Control Bank "D" rods are at 190 steps.
- 4. RCS Boron Concentration is 750 ppm
- 5. Target Rod Position at 100% RTP will be 220 Steps on Control Bank "D"
- 6. Power will be raised 3% per hour.
- 7. Xenon printout from REACTINW has been performed by an STA.
- 8. You are an extra Unit Operator.

#### **INITIATING CUES:**

Using the information provided, the SM/Unit SRO has directed you to calculate Target Boron Concentration for raising power to 100% per SOI-62.02 Appendix E "Reactivity Balance Calculation"

- Determine the RCS Target Boron concentration.
- Notify SM/Unit SRO of the RCS Target Boron Concentration.

START TIME: \_\_\_\_\_

<u>STEP 1</u> :	Obtain a copy of the instruction.	CAT
<u>STANDARD</u> :	A copy of SOI-62.02 Appendix E "Reactivity Balance Calculation" has been obtained.	SAT
EXAMINER'S	CUE: Provide the Performer a copy of the instruction.	UNSAT
COMMENTS:		
NOTE 1 One an Nul	e calculation is required for each major change. Calculation is approximation of Final Target Boron $C_B$ . Rough interpolation of Pop figures is acceptable and expected.	
NOTE 2 Dilu	ution or Boration value for power change from $P_1$ % to $P_2$ % ver in the time period T with rods moving from step position $R_1$ to	
R <sub>2</sub> .	(Subscript convention: 1 = current point, 2 = target point)	
Evaluator Not of t	te. JPM Steps 2 through 6 evaluate performers completion the first page of Appendix E.	
<u>STEP 2</u> : <b>[1]</b>	<b>CALCULATE</b> target boron concentration by performing the following:	
	Obtains: Current RCS Boron $C_B$ :PPM.	SAT
current	RCS Boron Concentrations is 750 ppm.	
<u>STANDARD</u> :	Performer contacts Chem Lab for current boron concentration (Value provided on task assignment sheet.)	UNSAT
COMMENTS:		

A1-2R Page 6 of 16

Obtains: Core Burnup:MWD/MTU	
Performer determines current core burnup from task assignment sheet. <u>12000 MWD/MTU</u> . (ICS point display U7981 or Other ICS displays that indicate core burnup i.e., Xenon (Core burnup is provided on task assignment sheet).	SAT UNSAT
Obtains:Current Reactor power = P1:Marget Reactor power = P2:Marget Reactor power = P2:Marget Reactor power change: $\Delta \%$	SAT
Performer determines current reactor power and target power from information provided on assignment sheet. P1 = <u>76%</u> . P2 = <u>100%</u> . Target reactor power was given on task assignment. Performer determines total power change to be <u>24%</u> .	UNSAT
	Obtains:       Core Burnup:MWD/MTU         Performer determines current core burnup from task assignment sheet.       12000 MWD/MTU.         (ICS point display U7981 or Other ICS displays that indicate core burnup i.e., Xenon (Core burnup is provided on task assignment sheet).         Obtains:      %         Current Reactor power = P1:%         Calculates:       Total Reactor power change:A%         Performer determines current reactor power and target power from information provided on assignment sheet. P1 = 76%. P2 = 100%. Target reactor power was given on task assignment. Performer determines total power change to be 24%.

<u>STEP 5</u> :	Obtains: Rate of Reactor Power change: %/hr Number of hours to change power: hr(s)	SAT
<u>STANDARD</u> :	Performer determines rate of reactor power change from task assignment to be <u><b>3% per hour</b></u> . Performer calculates number of hours projected to reach target power as <u>8 hrs</u> .	UNSAT
COMMENTS:		
<u>STEP 6</u> :	Obtains: Current Rod Position: steps Final Rod Position: steps	SAT
<u>STANDARD</u> :	Performer determines final rod position from task assignment as <u>220 Steps</u> . Performer determines current rod position from ICS or Control Board Step Counters (Value provided on task assignment sheet). Value for current position is <u>190 steps</u> .	UNSAT
COMMENTS:		

A1-2R Page 8 of 16

CAUTION	Follow sign conventions explicitly.	
Evaluator No completion Balance.	ote. JPM Steps 7 through 11 evaluate performer's of the second page of Appendix E steps for Reactivity	
<u>STEP 7</u> : Det	<b>termines</b> Δρ <b>Power Defect:</b> From NUPOP, Figure 6-18, 19, or 20 (or from Table 7-17, 7-18, or 7-19 Must multiply value from these tables by (-1) to	CRITICAL STEP
	maintain sign convention. The figures are correct as shown).	SAT
<u>STANDARD</u> :	Performer determines the PD <sub>1</sub> for current power level is <u>-1594</u> <u>pcm</u> from Table 7-18, and determines PD <sub>2</sub> for target power level as <u>-2088 pcm</u> from Table 7-18, and enters the values in appropriate table locations. Performer then calculates $\Delta \rho$ Power Defect by subtracting algebraically PD <sub>2</sub> from PD <sub>1</sub> . The value determined is <u>494 pcm</u> .	UNSAT
	If using Performer determines the PD <sub>1</sub> for current power level is Figure 6-19 accept <b>-1570 to -1600 pcm for the 76% power</b> <b>level and</b> accept <b>-2050 to -2100 pcm for the 100% power</b> <b>level.</b> Acceptable Range is <b>450 to 530pcm.</b>	
COMMENTS	:	
STEP 8:Determines Δρ Xenon: Xenon1: From REACTW (either current conditions or projection to initial condition) pcm XE1. Xenon2: From REACTW (projected over time period T) pcm XE2. NOTE: Xenon Values must be negative. Performer than calculates $\Delta \rho$ Xenon by subtracting algebraically XE2 from XE1. -2644.7 pcm XE12508.1 pcm XE2 = -136.6 pcm $\Delta \rho$ Xenon	CRITICAL STEP SAT UNSAT	
---	----------------------------------	
<b>STANDARD:</b> Performer determines the XE <sub>1</sub> for current power level is <u>-2644.7 pcm</u> from Xenon REACTW printout, and determines XE <sub>2</sub> for target power level as <u>-2508.1 pcm</u> from the same printout, and enters the values in appropriate table locations. Performer then calculates $\Delta \rho$ Xenon by subtracting algebraically XE <sub>2</sub> from XE <sub>1</sub> . The value determined is <u>-136.6</u> <u>pcm.</u>		
<u>COMMENTS</u> :		

	A1-2R Page 10 of 16
STEP 9 Determines $\Delta \rho$ rods: Rods <sub>1,2</sub> : From NUPOP, Figure 6-24, or 25. pcm Rods <sub>1</sub> - pcm Rods <sub>2</sub> = pcm	CRITICAL STEP
(current) (Target) $\Delta \rho$ Rods	SAT
<ul> <li><u>STANDARD</u>: Performer determines the Rods<sub>1</sub> for current rod position as <u>150</u> pcm (accept 175 – 125) from NUPOP Figure 6-25, and determines Rods<sub>2</sub> for target as <u>0</u> (accept 0 – 40) pcm from the same figure, and enters the values in appropriate table locations. Performer then calculates Δρ Rods by subtracting algebraically Rods<sub>2</sub> from Rods<sub>1</sub>. The value determined is <u>150</u> pcm. Acceptable Range is 85 to 175 pcm.</li> <li>Performer may adjust values based on interpretation of NUPOP Figure 6-25. Values entered that are within the stated acceptable range may be used.</li> </ul>	UNSAT
COMMENTS:	

A1-2R Page 11 of 16

<u>STEP 10</u> : <b>Determines</b> ρ <b>boron</b> <sub>1</sub> : Current RCS Boron X 1000 ÷ Inverse Boron Worth NUPOP, Figure 6-21).	CRITICAL STEP
$\underline{\qquad } Boron X ( \underline{1000} \div \underline{\qquad } pcm/\%\Delta\rho) = \underline{\qquad } pcm \\ (current) \qquad \qquad \rho BORON_1$	SAT
$ \begin{array}{llllllllllllllllllllllllllllllllllll$	UNSAT
Performer must adjust value based on interpretation of NUPOP Figure 6-21. Values entered that are within the stated acceptable range may be used.	
<u>COMMENTS</u> :	



	A1-2R Page 13 of 16
<u>STEP 12</u> : (-4510) pcm ρ BORON <sub>2</sub> X (- <u>159</u> ppm/%Δρ Inverse Boron Worth $\div$ <u>1000</u> pcm/%Δρ) = <u><b>717</b></u> ppm	CRITICAL STEP
( <u>-4635</u> ) pcm ρ BORON <sub>2</sub> X (- <u>159</u> ppm/%Δρ Inverse Boron Worth ÷ <u>1000</u> pcm/%Δρ) = <u><b>736</b></u> ppm	SAT
( <u>-4498</u> ) pcm $\rho$ BORON <sub>2</sub> X (- <u>159</u> ppm/%Δρ Inverse Boron Worth ÷ <u>1000</u> pcm/%Δρ) = <u><b>715</b></u> ppm	
$\begin{tabular}{lllllllllllllllllllllllllllllllllll$	UNSAT
COMMENTS:	

		A1-2R Page 14 of 16
<u>STEP 13</u> :	<b>NOTIFY</b> SM/Unit SRO of RCS Target Boron Concentration calculated.	
EVALUATOR	CUE: Role play as SM/Unit supervisor and acknowledge report. Acknowledge request for independent verification, State that this Admin JPM has been completed. We will stop here.	SAT
<u>STANDARD</u> :	Performer informs the SM/Unit Supervisor of the Target RCS boron concentration that was calculated.	0NSA1
COMMENTS:		
	END OF TASK	

TIME STOP: \_\_\_\_\_

## PERFORMER CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

## **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit is operating at 76% rated thermal Power.
- 2. Core average burnup is 12000 MWD/MTU.
- 3. Control Bank "D" rods are at 190 steps.
- 4. RCS Boron Concentration is 750 ppm
- 5. Target Rod Position at 100% RTP will be 220 Steps on Control Bank "D"
- 6. Power will be raised 3% per hour.
- 7. Xenon printout from REACTINW has been performed by an STA.
- 8. You are an extra Unit Operator.

## **INITIATING CUES:**

Using the information provided, the SM/Unit SRO has directed you to calculate Target Boron Concentration for raising power to 100% per SOI-62.02 Appendix E "Reactivity Balance Calculation"

• Determine the RCS Target Boron concentration.

Notify SM/Unit SRO of the RCS Target Boron Concentration

#### XENON CALCULATION WATTS BAR UNIT 1 CYCLE 9 MOL NIX XENON DATA

				XE	DEL XE
TIME	POWER	XE	I	WORTH	WORTH
(HRS)	(%)	(% EQ)	(% EQ)	(PCM)	(PCM)
.0	76.0	91.2	76.0	-2644.7	.0
1.0	79.0	90.8	76.3	-2634.6	10.1
2.0	82.0	90.2	76.9	-2618.1	16.5
3.0	85.0	89.6	77.7	-2598.2	19.9
4.0	88.0	88.8	78.7	-2577.1	21.1
5.0	91.0	88.1	79.9	-2556.5	20.6
6.0	94.0	87.5	81.3	-2537.7	18.8
7.0	97.0	86.9	82.9	-2521.3	16.4
8.0	100.0	86.5	84.6	-2508.1	13.2

# WATTS BAR NUCLEAR PLANT A.1-2 SRO

A.1-2 SRO Perform Independent Verification of Appendix E of SOI-62.02, REACTIVITY BALANCE CALCULATION

## WATTS BAR NUCLEAR PLANT A.1-2 SRO

## ADMINISTRATIVE JOB PERFORMANCE MEASURE

- <u>Task:</u> Perform Independent Verification of Appendix E of SOI-62.02, REACTIVITY BALANCE CALCULATION
- Alternate Path: N/A
- Facility JPM #: 3-OT-JPMADA.1-5
- K/A Rating(s): G2.1.25 [2.8/3.1]
- **Task Standard:** Performer completes an independent verification of the SOI-62.02, Appendix E "Reactivity balance calculation". Target RCS Boron Concentration is corrected based upon errors found. Performer notifies SM of the results.

Preferred Evaluation Location:

**Preferred Evaluation Method:** 

Perform X Simulate

Simulator X In-Plant

**References:** SOI-62.02, "Boron Concentration Control", Rev. 47; NUPOP, WCAP-16880-P, "Nuclear Parameters and Operating Package for Watts Bar Unit 1, Cycle 9", Rev 2.

Task Number: RO-062-SOI-62-016

APPLICABLE FOR: RO/SRO

<b>10CFR33.43</b> : 1, 5, 12
------------------------------

Validation Time: 20 min. Time Critica	<b>al:</b>	
Performer:NAME	Time SSN Time	Start: Finish:
Performance Rating: SAT UNSAT	Perfor	mance Time
Examiner:NAME	SIGNATURE	/DATE
СОММ	IENTS	

## **Tools/Equipment/Procedures Needed:**

Latest revision of SOI-62.02 NUPOP for WBN Unit 1 Cycle 9 NOB for WBN Unit 1 Ruler or straight edge. Calculator

NOTE: START THIS JPM AT A LOCATION WHERE PERFORMER HAS ACCESS TO PROCEDURES (Simulator, Main Control Room, TIC or provide performer with procedure).

## READ TO OPERATOR

## **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit is operating at 75% rated thermal Power.
- 2. Core average burnup is 12000 MWD/MTU.
- 3. Control Bank "D" rods are at 190 steps.
- 4. RCS Boron Concentration is 750 ppm
- 5. Target Rod Position at 100% RTP will be 220 Steps on Control Bank "D"
- 6. Power will be raised 3% per hour.
- 7. Xenon printout from REACTINW has been performed by an STA.
- 8. The Unit Operator has just completed SOI-62.02 Appendix E "Reactivity Balance Calculation" for this power change.

#### **INITIATING CUES:**

The SM/Unit SRO has directed you to perform an independent verification of SOI-62.02 Appendix E "Reactivity Balance Calculation" performed by the Unit Operator START TIME: \_\_\_\_\_

<u>STEP 1</u> :	Obtain a copy of the completed instruction.	CAT
<u>STANDARD</u> :	A copy of SOI-62.02 Appendix E "Reactivity Balance Calculation" has been obtained.	SAT
EXAMINER'S	CUE: Provide the Performer a copy of the completed instruction.	UNSAT
COMMENTS:		
NOTE 1 On an Nu NOTE 2 Dil pov R <sub>2</sub> .	e calculation is required for each major change. Calculation is approximation of Final Target Boron $C_B$ . Rough interpolation of Pop figures is acceptable and expected. ution or Boration value for power change from $P_1$ % to $P_2$ % wer in the time period T with rods moving from step position $R_1$ to (Subscript convention: 1 = current point, 2 = target point)	
Evaluator No of	te. JPM Steps 2 through 6 evaluate performers completion the first page of Appendix E.	
STEP 2: [1] CUE: If the 0 correct Conce	<b>CALCULATE</b> target boron concentration by performing the following: Obtains: Current RCS Boron $C_B$ :PPM. <b>CHEM LAB notified to confirm value that was entered is</b> t, acknowledge request, then report current RCS Boron intrations is 750 ppm.	SAT UNSAT
<u>STANDARD</u> :	in the Table associated with Step 1.	
COMMENTS:		

\*\*Italicized Cues Are To Be Used Only If JPM Performance Is Being Simulated.

A.1-2 SRO Page 6 of 19

<u>STEP 3</u> :	Obtains: Core Burnup:MWD/MTU	
<u>STANDARD</u> :	Performer ensures correct current core burnup from task assignment sheet. <u>12000 MWD/MTU</u> .	SAT
COMMENTS:		UNSAT
<u>STEP 4</u> :	Obtains:Current Reactor power = P1:%Target Reactor power = P2:%Calculates: Total Reactor power change: $\Delta$ %	SAT
<u>STANDARD</u> :	Performer ensures correct current reactor power and target power from information provided on assignment sheet. P1 = <u>76%</u> . P2 = <u>100 %</u> Target reactor power was given on task assignment. Performer ensures correct total power change to be <u>24</u> %.	UNSAT
COMMENTS:		

<u>STEP 5</u> :	Obtains: Rate of Reactor Power change: %/hr Number of hours to change power: hr(s)	SAT
<u>STANDARD</u> :	Performer ensures correct rate of reactor power change from task assignment to be <u>3 % per hour</u> . Performer ensures correct number of hours projected to reach target power as <u>8</u> hrs.	UNSAT
COMMENTS:		
<u>STEP 6</u> :	Obtains: Current Rod Position: steps Final Rod Position: steps	SAT
<u>STANDARD</u> :	Performer ensures correct final rod position from task assignment as <u>220 Steps</u> . Performer ensures correct current rod position from ICS or Control Board Step Counters (Value provided on task assignment sheet). Value for current position is <u>190 steps</u> .	UNSAT
COMMENTS:		

CAUTION	Follow sign conventions explicitly.	
Evaluator No completion Balance.	ote. JPM Steps 7 through 11 evaluate performer's of the second page of Appendix E steps for Reactivity	
<u>STEP 7</u> : Def	<b>termines</b> Δρ <b>Power Defect:</b> From NUPOP, Figure 6-18, 19, or 20 (or from Table 7-17, 7-18, or 7-19	CRITICAL STEP
	Must multiply value from these tables by (-1) to maintain sign convention. The figures are correct as shown).	SAT
STANDARD:	Performer determines the PD <sub>1</sub> for current power level is <u>-1594</u> <u>pcm</u> from Table 7-18, and determines PD <sub>2</sub> for target power level as <u>-2088 pcm</u> from Table 7-18, and enters the values in appropriate table locations. Performer then calculates $\Delta\rho$ Power Defect by subtracting algebraically PD <sub>2</sub> from PD <sub>1</sub> . The value determined is <u>494 pcm</u> .	UNSAT
	If using Performer determines the PD <sub>1</sub> for current power level is Figure 6-19 accept <b>-1570 to -1600 pcm for the 76% power</b> <b>level and</b> accept <b>-2050 to -2100 pcm for the 100% power</b> <b>level.</b> Acceptable Range is <b>450 to 530pcm.</b>	
<u>COMMENTS</u>	;	

STEP 8:Determines $\Delta \rho$ Xenon: Xenon1: From REACTW (either current conditions or projection to initial condition) pcm XE1. Xenon2: From REACTW (projected over time period T) pcm XE2. NOTE: Xenon Values must be negative. Performer than calculates $\Delta \rho$ Xenon by subtracting algebraically XE2 from XE1. $\underline{-2644.7}$ pcm XE1 $\underline{-2508.1}$ pcm XE2 = $\underline{-136.6}$ pcm $\Delta \rho$ Xenon	CRITICAL STEP
STANDARD:Performer determines the XE1 for current power level is -2644.7 pcm from Xenon REACTW printout, and determines XE2 for target power level as -2508.1 pcm from the same printout, and enters the values in appropriate table locations. 	
<u>COMMENTS</u> :	

	A.1-2 SRO Page 10 of 19
	CRITICAL STEP SAT
STANDARD:Performer determines the Rods1 for current rod position as 150 pcm (accept 175 – 125) from NUPOP Figure 6-25, and determines Rods2 for target as 0 (accept 0 – 40) pcm from the same figure, and enters the values in appropriate table locations. Performer then calculates $\Delta \rho$ Rods by subtracting algebraically Rods2 from Rods1. The value determined is 150 pcm. Acceptable Range is 85 to 175 pcm.Performer may adjust values based on interpretation of NUPOP Figure 6-25. Values entered that are within the stated acceptable range may be used.	UNSAT
COMMENTS:	

<u>STEP 10</u> : <b>Determines</b> ρ <b>boron₁:</b> Current RCS Boron X 1000 ÷ Inverse Boron Worth NUPOP, Figure 6-21).	CRITICAL STEP
$\underline{\qquad } \text{Boron X ( 1000 ÷pcm/%\Delta\rho) =pcm} (current) \qquad \qquad \rho \text{ BORON}_1$	SAT
STANDARD: Performer enters <b>750</b> ppm for current boron concentration. Performer determines the inverse boron worth is <u>-159</u> pcm/%Δρ (accept <b>158 -160</b> ) from NUPOP Figure 6-21 for the current boron concentration, and enters the values in appropriate table location. Performer then calculates ρ BORON <sub>1</sub> by multiplying RCS boron concentration by the product of 1000 pcm divided by current inverse boron worth boron worth determined from figure 6-21 for the current RCS boron concentration. ρ boron 1 value is calculated is minus <u>-4717</u> pcm.	UNSAT
Performer must adjust value based on interpretation of NUPOP Figure 6-21. Values entered that are within the stated acceptable range may be used.	
<u>COMMENTS</u> :	



\*\*Italicized Cues Are To Be Used Only If JPM Performance Is Being Simulated.

	A.1-2 SRO Page 13 of 19
<u>STEP 12</u> : (-4510) pcm ρ BORON <sub>2</sub> X (- <u>159</u> ppm/%Δρ Inverse Boron Worth ÷ <u>1000</u> pcm/%Δρ) = <b>717</b> ppm	CRITICAL STEP
( <u>-4635</u> ) pcm ρ BORON <sub>2</sub> X (- <u>159</u> ppm/%Δρ Inverse Boron Worth ÷ <u>1000</u> pcm/%Δρ) = <u><b>736</b></u> ppm	SAT
( <u>-4498</u> ) pcm ρ BORON <sub>2</sub> X (- <u>159_</u> ppm/%Δρ Inverse Boron Worth ÷ <u>1000</u> pcm/%Δρ) = <b>715</b> ppm	
$\begin{tabular}{lllllllllllllllllllllllllllllllllll$	UNSAT
COMMENTS:	

		A.1-2 SRO Page 14 of 19
<u>STEP 13</u> :	<b>NOTIFY</b> SM/Unit SRO of RCS Target Boron Concentration independently verified.	
EVALUATOR	CUE: Role play as SM/Unit supervisor and acknowledge report. Acknowledge request for independent verification, State that this Admin JPM has been completed. We will stop here.	SAT
<u>STANDARD</u> :	Performer informs the SM/Unit Supervisor of the Target RCS boron concentration that was calculated and of the errors discovered during the independent verification process.	
COMMENTS:		
	END OF TASK	

TIME STOP: \_\_\_\_\_

## PERFORMER CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

## **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The Unit is operating at 75% rated thermal Power.
- 2. Core average burnup is 12000 MWD/MTU.
- 3. Control Bank "D" rods are at 190 steps.
- 4. RCS Boron Concentration is 750 ppm
- 5. Target Rod Position at 100% RTP will be 220 Steps on Control Bank "D"
- 6. Power will be raised 3% per hour.
- 7. Xenon printout from REACTINW has been performed by an STA.
- 8. The Unit Operator has just completed SOI-62.02 Appendix E "Reactivity Balance Calculation" for this power change.

## **INITIATING CUES:**

The SM/Unit SRO has directed you to perform an independent verification of SOI-62.02 Appendix E "Reactivity Balance Calculation" performed by the Unit Operator

#### XENON CALCULATION WATTS BAR UNIT 1 CYCLE 9 MOL NIX XENON DATA

TIME (HRS)	POWER (%)	XE (% EQ)	I (% EQ)	XE WORTH (PCM)	DEL XE WORTH (PCM)	
.0	76.0	91.2	76.0	-2644.7	.0	
1.0	79.0	90.8	76.3	-2634.6	10.1	
2.0	82.0	90.2	76.9	-2618.1	16.5	
3.0	85.0	89.6	77.7	-2598.2	19.9	
4.0	88.0	88.8	78.7	-2577.1	21.1	
5.0	91.0	88.1	79.9	-2556.5	20.6	
6.0	94.0	87.5	81.3	-2537.7	18.8	
7.0	97.0	86.9	82.9	-2521.3	16.4	
8.0	100.0	86.5	84.6	-2508.1	13.2	

WBN	Boron Concentration Control	SOI-62.02
Unit 1		Rev. 0047
		Page 55 of 62

## Appendix E (Page 1 of 3) REACTIVITY BALANCE CALCULATION

## 1.0 REACTIVITY BALANCE CALCULATION

## NOTES

- One calculation is required for each major change. Calculation is an approximation of Final Target Boron C<sub>B</sub>. Rough interpolation of NuPop figures is acceptable and expected.
- Dilution or Boration value for power change from P<sub>1</sub> % to P<sub>2</sub> % power in time period T with rods moving from step position R<sub>1</sub> to R<sub>2</sub>. (Subscript convention: 1 = current point, 2 = target point)

CALCU	ATE targe	boron	concentration	by	performing	the	following:
-------	-----------	-------	---------------	----	------------	-----	------------

Initials

dat

DATA REQUIRED		DATA	Where To Get
Current RCS Boron C <sub>B</sub>	750	ppm	Chem Lab
Core Burnup	12000	MWD/MTU	ICS U7981
Current Reactor power = P1	76	%	NIS
Target Reactor power = P2	IØØ	%	As required for plant conditions
Total Reactor Power change	24	Δ%	∆ Current and final Reactor power
Rate of Reactor power change	3	%/hr	As required for plant conditions
Number of hours to change power	8	hr(s)	As required for plant conditions
Current Rod Position	190	steps	ICS or MCR Board
Final Rod Position	220	_ steps	Estimate number of rod steps required to control ∆I and rod withdrawal requirements for power change.

WBN	Boron Concentration Control	SOI-62.02
Unit 1		Rev. 0047
		Page 56 of 62

## Appendix E (Page 2 of 3)

## 1.0 REACTIVITY BALANCE CALCULATION (continued)

## CAUTION

Follow sign conventions explicitly. When using values from Table 7-17, 7-18, or 7-19, they must be corrected as indicated in below.

## REACTIVITY BALANCE

	REACTIVITY BA	LANCE	
Parameter	Where To Get	Calculation	Value
Δρ POWER DEFECT	PowerDefect 1.2: From NUPOP, Figure 6-18, 19, or 20 (or from Table 7-17, 7-18, or 7-19 Must multiply value from these tables by (-1) to maintain sign convention. The figures are correct as shown).	$\frac{-1594}{(current)} pcm PD_1 - \frac{-2088}{(Target)} pcm PD_2 = (Target)$	494 pcm Δρ POWER DEFECT
Δρ ΧΕΝΟΝ	Xenon: From REACTW (either current conditions or projection to initial condition). Xenon: From REACTW (projection over time period T). NOTE Xenon values must be negative.	NOTE: Xenon values must be negative. $- 2644.7 \text{ pcm XE}_1 - \frac{-2508.1}{(\text{current})} \text{ pcm XE}_2 = (\text{Target})$	<u>136.6</u> рст Др XENON
Δp RODS	Rods <sub>12</sub> From NUPOP, Figure 6-24 or from Figure 6-25.	$\frac{17\phi}{(current)} pcm Rods_1 - \frac{1\phi}{(Target)} pcm Rods_2 = $	<u>ι 6φ</u> pcm Δρ RODS
p BORON	Currert RCS Boron X (1000 + Inverse Boron Worth NUPOP, Figure6-21)	<u>750</u> ppm Boron X (1000 + <u>-161</u> ppm/%Δp) = (current)	-4658 pcm
494	_pcm Δρ POWER DEFECT + 136.6 pcm Δρ XENON - 160	_pcm Δp RODS + - 4658 pcm (p BORON1) =	PBORON2
	continued on next page		

WBN	Boron Concentration Control	SOI-62.02
Unit 1		Rev. 0047
		Page 57 of 62

## Appendix E (Page 3 of 3)

Date

INITIALS

## 1.0 REACTIVITY BALANCE CALCULATION (continued)

## TARGET PPM

$(-41\%7 \text{ pcm } \rho \text{ Boron}_2) \times (-161 \text{ ppm}/\%\Delta\rho \text{ Inverse Boron Worth} + 1000 \text{ pcm}/\%\Delta\rho) =$	<u>674</u> ppm
(NUPOP Figure 6-21)	Target Boron G <sub>8</sub>

NOTE	
IV is NOT required if appendix is performed by an SRO to verify data provided by Rx. Eng.	



ENSURE independently verified by SRO.

IV

## WATTS BAR NUCLEAR PLANT A.2-RO

# A.2-RO CALCULATE QPTR USING 1-SI-0-21

A.2-RO Page 2 of 18

#### **EVALUATION SHEET**

Task:	CAL	CULA	TE C	PTR	USING	1-SI-0-21
The second se						

Alternate Path: N/A

Facility JPM #: 3-OT-JPMADA.2-1

K/A Rating(s): 2.1.12 [2.9/4.0]

Task Standard: Quadrant Power Tilt Ratio has been determined per 1-SI-0-21 Section 6.1 and Attachment 1. Acceptance criteria are determined to be not met due for N-42 Upper Detector, N-44 Upper Detector and N-42 Lower Detector.

Preferred Evaluation Location:

Preferred Evaluation Method:

Perform X Simulate

Simulator X In-Plant

**References:** 1-SI-0-21 "Excore QPTR & Axial Flux Difference" Rev. 15; Nuclear Operating Book (NOB) A-2 Sheet 1 Rev. 89, Sheet 2 Rev. 88, Sheet 3 Rev. 89, Sheet 4 Rev 87.

Task Number: RO-092-SI-2-001

Validation Time: 13 min. Time Critical: No.

APLICABLE FOR: RO/SRO

10CFR55.45:

***************************************	******************				
Applicant:	Tim SSN Tim	e Start: e Finish:			
Performance Rating: SAT UNSAT	Per	ormance Time			
Examiner:	SIGNATURE	/DATE			
COMMENTS					
· · · · · · · · · · · · · · · · · · ·		· · ·			
		······································			

#### **Tools/Equipment/Procedures Needed:**

Applicant Data Sheet Latest revision of 1-SI-0-21 Attached NOB Sheets A-2 (all four PR detector channels) Calculator

NOTE: START THIS JPM AT A LOCATION WHERE PERFORMER HAS ACCESS TO PROCEDURES (Simulator, Main Control Room, TIC, etc.).

NOTE TO EVALUATOR: Hand out the Applicant Data Sheet along with the Applicant's Cue Sheet.

## **READ TO OPERATOR**



## DIRECTION TO TRAINEE:

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The unit is operating at 100% power
- 2. AFD Monitor Alarm and QPTR alarms are out of service due to card problem in the annunciator system.
- 3. 1-SI-0-21 "Excore QPTR & Axial Flux Difference SI is required to be performed every 12 hours since both QPTR alarms are inoperable.
- 4. Plant computer is not available for performing this SI.
- 5. You are a support CRO.

#### **INITIATING CUES:**

- 1. Given the data that was just obtained from each power range channel upper and lower detector currents, the Unit Supervisor directs you to perform Section 6.1 "Excore QPTR Determination" of 1-SI-0-21. M&TE will not be utilized for data measurements.
- 2. Report the results to the Unit Supervisor when 1-SI-0-21, Section 6.1 and Attachment 1 have been completed.



START TIME: \_\_\_\_\_

1955		
	STEP 1: Obtain a copy of the instruction.	SAT
	STANDARD: A copy of 1-SI-0-21 has been obtained.	
	EXAMINER'S CUE: After the performer identified correct instruction, the evaluator can provide a copy of the instruction.	UNSAT
	COMMENTS	
	<u>COMMENTS</u> .	
	NOTE TO EVALUATOR: The following steps are from Section 6.1 of 1-SI- 0-21	
Ć	<ul> <li>NOTE 1 Obtaining QPTR calculated values from the Process Computer is the preferred method to check that the QPTR is within Technical Specification limits. QPTR values are obtained from Process Computer calculated computer points for upper and lower radial flux tilt. These points are available on the "Tilting Factors" display. The report may be printed with turn on code TFREP.</li> <li>NOTE 2 Up to one inoperable excore channel can be marked N/A if</li> </ul>	
	THERMAL POWER is < 75% RTP.	
	STEP 2: [Step 1] IF performing.	
	STANDARD: Performer goes to attachment 1 and commences performance of attachment 1.	SAT
	COMMENTS:	UNSAT

	A. Pa	2-RO ige 6 of 18	
	<u>STEP 3</u> : [Step 2] <b>IF</b> the process Computer is available, <b>THEN PRINT</b> the Tilting Factors Report <b>AND/OR PERFORM</b> the QPTR calculations using Attachment 1.		
1	STANDARD: Performer goes to attachment 1 and commences performance of attachment 1.	SAT	
	COMMENTS:		

NOTE TO EVALUATOR: The following steps are from Attachment 1 of 1- SI-0-21	
NOTE 1 Determining detector currents by measuring the voltage across the detector's meter test points, using DVM, is the most accurate method for measuring QPTR and for determining the validity of a QPTR alarm.	
NOTE 2 Using detector current meter readings is another method to quickly check that QPTR is within limits. These meters are not as accurate as the DVM readings and may produce unacceptable results because: 1) the meters on the 'B' drawer may be scaled too high or (2) the meter may be unstable due to drift or noise. When unacceptable results are obtained DVM readings should be obtained, otherwise, Step [1] and [2] may be marked N/A if DVM not used.	
NOTE 3 Up to one inoperable excore channel can be marked N/A if THERMAL POWER is < 75% RTP.	
STEP 3:         [Step 1]         RECORD         DVM information:           A.         TVA M&TE ID:	
	SAT
task performance and proceeds to the next step.	UNSAT
COMMENTS:	
STEP 4: [Step 2] ENSURE require M&TE is within its current calibration.	
STANDARD: Performer determines step is N/A based on initial conditions for task performance and proceeds to the next step.	SAT
COMMENTS:	UNSAT

	CAUTION An inadvertent reactor trip may be prevented by ensuring that no power range neutron high flux rate or power range high flux channels are in the tripped condition prior to taking EACH measurement in the NIS Power Range Drawer B.					
	NOTE The following determination may be made by measuring the voltage across the 1000 ohm precision resistor in NIS power range drawer B. When using this method the Ohm's Law conversion from a millivolt measurement to a microamp measurement only requires changing the unit designator (e.g., 280 millivolts converts to 280 microamps).					
	NOTE Detector A is th LOWER detecto	NOTE Detector A is the TOP or UPPER Detector and Detector B is the BC LOWER detector on the NIS drawer B.				
	<u>STEP 4</u> : <b>[Step 3] DETE</b> excor <b>RECC</b>	<b>RMINE</b> the microamps for e detector on each NIS pov <b>DRD</b> below:	each upper and lower /er range drawer B, <b>AND</b>			
		UPPER DETECTOR	LOWER DETECTOR			
t	NIS Channel	I. Detector Current	In Detector Current			
		(microamps)	(microamps)			
	N-41A	(369)	(384)			
	N-42A	(364)	(386)			
	N-43A	(369)	(385)			
	N-44A	(371)	(386)			
	STANDARD: Performer the hando appropriat	SAT				
	NOTE TO EVALUATOR handout.	e detector currents from	UNSAT			
	COMMENTS:					

Rt and Rb (detector calibration data) changes periodically throughout the cycle. NOTE: Current values are on NOB Sheet A-2, NIS Calibration Data. NOTE TO EVALUATOR: The NOB Sheets attached to this JPM are are to be given to the Performer when the Performer refers to the NOB. The data sheets attached are the basis for the calculations in the JPM> STEP 5: [Step 4] OBTAIN and RECORD current values of Rt and Rb (volts/microamps). UPPER DETECTOR LOWER DETECTOR **NIS Channel** R<sub>t</sub> (volts/microamps) R<sub>b</sub> (volts/microamps) (0.03774)N-41A (0.03833)N-42A (0.04439)(0.04492)N-43A (0.03770)(0.03713)N-44A (0.03813)(0.04198)STANDARD: Performer obtains the detector current values from NOB SAT Sheets A-2 for the respective NIS Power Range Detectors and records them in appropriate blocks on Attachment 1 Step 4. NOTE TO EVALUATOR: Values above in ( ) are detector currents from UNSAT respective NOB Sheets A-2 which are attached to this JPM. COMMENTS:
A.2-RO Page 10 of 18

E F			
	<u>STEP 6</u> : [Step 5]	the	
		$V_{t} = I_{t} \times R_{t}$	
	,		
	ľ	$\mathbf{v}_{\mathbf{D}} = \mathbf{v}_{\mathbf{D}} \times \mathbf{v}_{\mathbf{D}}$	
[		UPPER DETECTOR LOWER DETECT	OR
	NIS Channel	V <sub>t</sub> Calib. Output V <sub>b</sub> Calib. Outpu	t
	<u>N-41A</u>	(369)(0.03/74)=13.926 $(384)(0.03833)=14.7$	<u>19</u>
}	N-42A	(364)(0.04439)=16.158 $(386)(0.04492)=17.3$	005
ł	N-43A	(309)(0.03770)=13.911 $(385)(0.03713)=14.2$	210
ł	N-44A	[(371) (0.04196)+15.575 [(366) (0.03613)=14.7	10
	<u>STANDARD</u> : Perfo multi resis appro	ormer calculates the calibrated output voltages <b>[Step</b> : plying the respective detector's current reading times ance values <b>[step 4]</b> and records the results in popriate blocks on Attachment 1 Step 5.	3] by SAT
	appr		UNSAT
	COMMENTS:		
		·	
	<u>STEP 7</u> : [Step 6]	CALCULATE average calibrated output voltage for the upper and lower detectors.	e
		UPPER Vt LOWER Vb	
	AVERAGE	(13.926+16.158+13.911+ (14.719+17.339+14	.295+
		15.575)/4 =14.893 14.718)/4 = 15.2	268
	STANDARD: Perfo deter outpu by th	pperSAT ed ult eated	
	tor tr volta Attac	UNSAT	
	COMMENTS		
6			

	A.2						
		ige 11 of 18					
<u>s</u>	STEP 8:[Step 7]CALCULATE QPTR values by dividing each detector's (upper or lower) Calibration Output Voltage by the average (upper or lower) Calibrated Output Voltage.A.QPTRt = Vt ÷ Avg Vt B.QPTRb = Vb x Avg Vb						
	UPPER LOWER						
		DETECTOR	DETECTOR				
	NIS Channel	QPTR <sub>t</sub> Value	QPTR <sub>b</sub> Value				
	N-41A	(13.926/14.893)= 0.935	(14.719/15.268)= 0.964				
	N-42A	(16.158/14.893) 1.085	(17.339/15.268)= <b>1.136</b>				
	N-43A	(13.911/14.893) 0.934	(14.295/15.268)= 0.936				
	N-44A	(15.575/14.893) <b>1.046</b>	(14.718/15.268)= 0.964				
	STANDARD: Performer calculates QPTR values by dividing the respective Calibrated Output Voltage [from step 5] by the Average Calibrated Output Voltage for each NIS channel detector [from step 6]. The results recorded in appropriate blocks on Attachment 1. Performer returns to Section 6.1 Step 7.						
N	OTE TO EVALUATOR	The following steps are f SI-0-21.	rom Section 6.1 of 1-				
<u>s</u>	STEP 9: [Step 2] <b>REVIEW</b> the Upper (A) and Lower (B) QPTR values.						
<u>s</u>	STANDARD: Performer reviews QPTR values from Attachment 1 Step 7.						
	<u>COMMENTS</u> :						



		ge 12 of 18	
	<u>STEP 10</u> : [Ste	p 3] <b>CHECK</b> ( $$ ) Acceptance Criteria.	
		<b>ACCEPTANCE CRITERIA</b> : All operable excore channels (upper and lower) indicate a QPTR $\leq$ 1.02.	SAT
		YES NO	
	<u>STANDARD</u> :	Performer determines that N-42 Upper Detector, N44 Upper Detector, and N-42A Lower Detectors exceed 1.02 QPTR. Performer then checks <b>NO</b> statement.	UNSAT
	COMMENTS:		
	<u>STEP 11</u> :	Inform the Unit Supervisor that Attachment 1 and Section 6.1 of 1-SI-0-21 has been completed and the results of the QPTR.	
A	<u>STANDARD</u> :	Performer informs the Unit Supervisor of the completion of Attachment 1 and Section 6.1 of 1-SI-0-21 and reports that	SAT
		acceptance criteria have not been satisfied. QPTR for N-42 Upper Detector is 1.114, N-44 Upper detector is 1.037 and N- 42 Lower Detector is 1.131, ALL exceeding the QPTR limit of 1.02.	UNSAT
	EXAMINER'S	CUE: Acknowledge report as Unit Supervisor, then state We will stop here.	
	COMMENTS:		
		END OF TASK	<u> </u>
		<b>D</b> •	

# APPLICANT CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

# DIRECTION TO TRAINEE:

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. The unit is operating at 100% power
- 2. AFD Monitor Alarm and QPTR alarms are out of service due to card problem in the annunciator system.
- 3. 1-SI-0-21 "Excore QPTR & Axial Flux Difference is required to be performed every 12 hours since both QPTR alarms are inoperable.
- 4. Plant computer is not available for performing this Surveillance Instruction.
- 5. You are a support CRO.

#### **INITIATING CUES:**

- 1. Given the data that was just obtained from each power range channel upper and lower detector currents, the Unit Supervisor directs you to perform Section 6.1 "Excore QPTR Determination" of 1-SI-0-21. M&TE will not be utilized for data measurements.
- 2. Report the results to the Unit Supervisor when 1-SI-0-21, Section 6.1 and Attachment 1 have been completed.





# APPLICANT DATA SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

The following microampere readings were taken from the Power Range NIS detectors:

	UPPER DETECTOR	LOWER DETECTOR
NIS Channel	I <sub>t</sub> Detector Current (microamps)	I <sub>b</sub> Detector Current (microamps)
N-41A	369	384
N-42A	364	386
N-43A	369	385
N-44A	371	386





WBN		NUCLEAR (	OPERATING	NOB	Sheet A-2				
1		BOC		Rev	Revision 90				
	( NO		OB)	Page	e 1 of 5				
		NTS CALTER	ATTON DATA						
	N-41 DOWER RANGE DETECTOR CALTERATION DATA								
	A AL TOWER MARCE BELECION CALIFICATION DATA								
Q <sub>REF</sub> = 100% RTP 1-SI-92-3 / 3/3/09									
				Date	-				
PRESTARTUP ALIGNM.  INCORE-EXCORE X CAL.  SINGLE POINT ALIGNM.					IT ALIGNM. 🗆				
NC305 LOW POWER TRIP NC306 HIGH POWER TRIP			TRIP						
0 - 120%	FULL POWER	0 - 10 Vdc	0 - 120%	FULL POWER	0 - 10 Vdc				
25%	TRIP	2.083 Vdc	105%	TRIP	8.750 Vdc				
23%	RESET	1.917 Vdc	103%	RESET	8.583 Vdc				
TOP (A)	DETECTOR	N = 17.5(	03 %/VOLT	BOTTOM (B	) DETECTOR				
$R_{T} = 0.03774 V/\mu A$				$R_{B} = 0.0$	3833 V7µA				
$b_{T} = +1.$	433 μΑ/8Δφ	<i>C</i> -	1 0	$b_{B} = -1$	.57 μΑ/%Δφ				
I <sup>#</sup> <sub>T</sub> = 220.79 μA		- 5	1.0	I <sup>#</sup> <sub>B</sub> = 217	.43 μA				
NI301 DWR B TOP (A) DETECTOR NI302 DWR B BOTTOM (B) DETECTOR				) DETECTOR					
% FULL POWER	Desired	Desired	% FULL POWER	Desired	Desired				
	(mVdc)	(µA)		(mVdc)	(µA)				
08	0	0	0%	0	Û				
30%	66.24	66.24	30%	65.23	65.23				
60%	132.47	132.47	60%	130.46	130.46				
90%	198.71	198.71	90%	195.69	195.69				
120%	264.95	264.95	120%	260.92	260.92				
DESTRED	%Δ FLUX	TOP (A)	DESIRED	δΔ FLUX	BOTTOM (B)				
1-NI	-41C	DETECTOR	1-N1	I-41C	DETECTOR				
		(mVdc)			(mVdc)				
+ 30	).0	263.78	+3	0.0	170.33				
(	).0	220.79		0.0	217.43				
-3(	).0	177.80	-3	0.0	264.53				
NOTE									
NUIL: N	- NIG Cali	mputer AFD C bration (i o	aupration F	actor = K0554					
h	= Slopee o	f Current vo	· CONVEISION	/ ractors					
Ĭ#	= Full Pow	er Calibrati	on Currente-	at $\Delta \phi = 0.0$					
- n	(i.e. In	tercepts)	on currenco	ас <u>ш</u> ф — 0.08					
G	= Eagle-21	Scal Flux C	alib						

WBN		NUCLEAR	OPERATING	NOB S	Sheet A-2			
1		BC	OK	Rev	Revision 89			
	(NOB) Page 2 of		e 2 of 5					
[]		NTS CALTER	ATTON DATA					
	N-42 POWER	RANGE DETE	CTOR CALIER	ATION DATA				
	A 12 FOULA ARAGE DEFICION CALIBRATION DATA							
	$Q_{ppp} = 1009$	RTP	1-SI-92-3	/ 3/3/09				
	PREF			Date				
PRESTARTUP	ALIGNM. 🗆	INCORE-EXCO	DRE X CAL. 🔳	SINGLE POIN	T ALIGNM. 🗆			
NC305	5 LOW POWER 1	TRIP	NC3	6 HIGH POWER	TRIP			
0 - 120% F	ULL POWER	0 - 10 Vdc	0 - 120%	FULL POWER	0 - 10 Vdc			
25%	TRIP	2.083 Vdc	105%	TRIP	8.750 Vdc			
23%	RESET	1.917 Vdc	103%	RESET	8.583 Vdc			
TOP (A) I	DETECTOR			BOTTOM (B)	DETECTOR			
		N = 16.9	57 %/VOLT	<u> </u>	1/02 +1/ -			
$K_{\rm T} = 0.04439  \text{V/}\mu\text{A}$				$r_{g} = 0.04$	309 μη (CAL			
$   \mu_{\rm T} = \pm 1.3 $ $   \tau^{\pm} = 107 $	$D_{\rm T} = \pm 1.333  \mu {\rm A}/{\rm s} \Delta \phi$		1.8	$\frac{\nu_{B} = -1}{\tau^{\#} - 105}$	<u>52 μλ</u>			
$1_{\pm} = 107.72 \ \mu A$				$1_3 = 100$	• 24 µA			
NI301 DWF	(B TOP (A) D	DETECTOR	NIBOZ DWE	K B BOTTOM (B)	DETECTOR			
% FULL POWER	Desired	Desired	% FULL POWER	Desired	Desired			
	(mVdc)	(µA)		(mVdc)	(µA)			
0%	0	0	0%	0	0			
30%	56.32	56.32	30%	55.66	55.66			
60%	112.63	112.63	60%	111.31	111.31			
90%	168.95	168.95	90%	166.97	166.97			
120%	225.26	225.26	120%	222.62	222.62			
DESIRED %	έΔ FLUX	TOP (A)	DESIRED	% Δ FLUX	BOTTOM (B)			
1-NI-	-42C	DETECTOR	1-NI-42C		DETECTOR			
	0	227 71	£.1	0 0	111VQC)			
0.2.7		187 72		0.0	196 50			
- 30	-30.0			0.0	224 79			
		1 4 1 1 1 1 1 1	, , , , , , , , , , , , , , , , , , ,		444.19			
1								
NOTE: N =	= Plant Co	mputer AFD C	alibration F	actor = K0552				
NOTE: N = R =	= Plant Co = NIS Cali	mputer AFD C bration (i.e	alibration F . Conversion	actor = K0552 ) Factors	<u>,</u>			
NOTE: N = R = b =	= Plant Co = NIS Cali = Slopes o	mputer AFD C bration (i.e f Current ve	alibration F . Conversion rsus $\Delta \phi$	actor = K0552 ) Factors				
NOTE: N = R = b = I# =	= Plant Co = NIS Cali = Slopes o = Full Pow	mputer AFD C bration (i.e f Current ve er Calibrati	alibration F . Conversion rsus Δφ on Currents	actor = K0552 ) Factors at Δφ = 0.0%				
NOTE: N = R = b = I# =	= Plant Co = NIS Cali = Slopes o = Full Pow (i.e. In	mputer AFD C bration (i.e f Current ve er Calibrati tercepts)	alibration F . Conversion rsus Δφ on Currents	actor = K0552 ) Factors at $\Delta \phi$ = 0.0%	2			

WBN 1		NUCLEAR OPERATING NOI BOOK Re (NOB) Pa		NOB Rev Pag	<b>)B Sheet A-2</b> Revision 90 Page 3 of 5	
	N-43 POWER $Q_{REF} = 100$	NIS CALIBR R RANGE DETE % RTP	ATION DATA CTOR CALIBRA 1-SI-92-3	ATION DATA		
				Date	•	
PRESTART	UP ALIGNM. 🗆	INCORE-EXCO	RE X CAL. 🔳	SINGLE POIN	IT ALIGNM. 🗆	
NC	305 LOW POWER	TRIP	NC30	6 HIGH POWER	TRIP	
0 - 120%	FULL POWER	0 - 10 Vdc	0 - 120% F	ULL POWER	0 - 10 Vdc	
25%	TRIP	2.083 Vdc	105%	TRIP	8.750 Vdc	
2.3%	RESET	1.917 Vdc	103%	RESET	8.583 Vdc	
TOP (A) DETECTOR $R_{\rm T} = 0.03770  V/\mu A$		N = 16.96	58 %/VOLT .	$R_{\rm B} = 0.0$	3713 V/μA	
$\frac{b_{T} = +1.539 \ \mu A/ \& \Delta \phi}{I_{T}^{*} = 221.06 \ \mu A}$		- G =	1.8 -	$b_{\rm B} = -1.$ $I^{*}_{\rm B} = 224$	613 μΑ/&Δφ .46 μΑ	
NI301	DWR B TOP (A) I	DETECTOR	NI302 DWR	B BOTTOM (B	) DETECTOR	
FULL POWER	Desired (mVdc)	Desired (uA)	% FULL POWER	Desired (mVdc)	Desired (µA)	
0%	0	0	0%	0	0	
30%	66.32	66.32	30%	67.34	67.34	
60%	132.64	132.64	60%	134.68	134.68	
90%	198.95	198.95	90%	202.01	202.01	
120%	265.27	265.27	120%	269.35	269.35	
DESIRE 1-1	D % ∆ FLUX NI-43C	TOP (A) DETECTOR (mVdc)	DESIRED %∆ FLUX 1-NI-43C		BOTTOM (B) DETECTOR (mVdc)	
+	30.0	267.23	+30	.0	176.07	
	0.0	221.06	0	.0	224.46	
-30.0 NOTE: N = Plant Composition R = NIS California B = Slopes of I# = Full Pow (i.e. In G = Eagle-21)		1/4.89 mputer AFD C.	-30 alibration Fa	tor = K0551	272.85	
		bration (i.e of Current ve ver Calibration tercepts) Scal Flux C	. Conversion rsus Δ <b>φ</b> on Currents a alib	) Factors t $\Delta \phi$ = 0.0%		

WBN 1		NUCLEAR OPERATING BOOK (NOB)		<b>NOB</b> Rev Pag	NOB Sheet A-2 Revision 88 Page 4 of 5	
NIS CALIBRATION DATA N-44 POWER RANGE DETECTOR CALIBRATION DATA						
	Q <sub>REF</sub> = 100% RTP <u>1-SI-92-3 / 3/3/09</u> Date					
PRESTARTUP ALIGNM. 🗆 INCORE-EXCORE X CAL. 🖿 SINGLE POINT ALIGNM. 🗆					NT ALIGNM. 🗆	
NC30	5 LOW POWER T	RIP	NC3	6 HIGH POWER	TRIP	
0 - 120% E	FULL POWER	0 - 10 Vdc	0 - 120%	FULL POWER	0 - 10 Vdc	
25%	TRIP	2.083 Vdc	105%	TRIP	8.750 Vdc	
23%	RESET	1.917 Vdc	103%	RESET	8.583 Vdc	
<b>TOP (A)</b> $R_{T} = 0.04$	DETECTOR	N = 17.5	4 %/VOLT	BOTTOM (B $R_B = 0.0$	) <b>DETECTOR</b> 3813 V/μΑ	
$b_{\rm T} = +1.$	$b_{T} = +1.347 \ \mu A / 8 \Delta \phi$		• •	$b_{\rm B} = -1$	.507 μA/%Δ <b>φ</b>	
$1_{T}^{*} = 198$	$I_{T}^{*} = 198.53 \ \mu A$		1.8	$I_{B}^{*} = 218$	3.57 μA	
NI301 DWR B TOP (A) DETECTOR NI302 DWR B BOTTOM (B) DETECTOR			) DETECTOR			
% FULL POWER	Desired (mVdc)	Desired (µA)	% FULL POWER	Desired (mVdc)	Desired (µA)	
0%	0	0	08	0	0	
30%	59.56	59.56	30%	65.57	65.57	
60%	119.12	119.12	60%	131.14	131.14	
90%	178.68	178.68	90%	196.71	196.71	
120%	238.24	238.24	120%	262.28	262.28	
DESIRED 1-NI	≹Δ FLOX -44C	TOP (A) DETECTOR (mVdc)	DESIRED 1-N1	& Δ FLUX -44C	BOTTOM (B) DETECTOR (mVdc)	
+30	).0	238.94	+3	0.0	173.36	
0	0.0	198.53		0.0	218.57	
-30	).0	158.12	-3	0.0	263.78	
NOTE: N = Plant Com R = NIS Calib b = Slopes of I# = Full Powe (i.e. Int G = Eagle-21		mputer AFD C bration (i.e f Current ve er Calibrati tercepts) Scal Flux C	alibration F . Conversion rsus Δφ on Currents alib	actor = K055 ) Factors at $\Delta \phi$ = 0.0%	3	

# WATTS BAR NUCLEAR PLANT A.2-SRO

A.2-SRO Review and Approve a Disable Alarm Checklist, per OPDP-4

# WATTS BAR NUCLEAR PLANT A.2-SRO

# ADMINISTRATIVE JOB PERFORMANCE MEASURE

Task: Review and Approve a Disable Alarm Checklist, per OPDP-4

Alternate Path: N/A		
Facility JPM #: New		
K/A Rating(s): G2.2.43 [3.0/3.3]		
Task Standard:Performer identifies that the Cfilled out correctly for Annuncipackage at Step 7 as approve	PDP-4-1 Disabled Alarm Cl ator 85-F. Performer DOES d.	necklist is NOT S NOT sign
Preferred Evaluation Location:	Preferred Evaluatio	n Method:
Simulator In-Plant	Perform <u>X</u> Sir	nulate
References: . OPDP-4, "Annunciator Disablem	ent", Rev. 4.	
Task Number: SRO-055-PAI-208-001	APPLICABLE FOR: SRO	
<b>10CFR55.45</b> : 13		
Validation Time: 15 min. Time Critical	: No	
Performer:NAME	Time SSN Time	Start: Finish:
Performance Rating: SAT UNSAT	Perfor	mance Time
Examiner:NAME	SIGNATURE	/
СОММЕ	NTS	

# **Tools/Equipment/Procedures Needed:**

OPDP-4-1 Attachment 1, Disabled Alarm Checklist. GO-6, Unit Shutdown from Hot Standby to Cold Shutdown ARI-85-F, RVLIS SYS MALFUNCTION

# READ TO OPERATOR

#### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. A plant shutdown is in progress.
- 2. Mode 3 has just been entered.
- 3. The Operator-at-the-Controls has informed you that Annunciator 85-F, RVLIS SYS MALFUNCTION has been received on multiple occasions, and that OPDP-4-1 Disabled Alarm Checklist has been filled out to disable the alarm.
- 4. You are the Unit SRO.

#### **INITIATING CUES:**

Review the OPDP-4-1 Disabled Alarm Checklist for approval. Note any and all discrepancies found during your review.

START TIME: \_\_\_\_\_

<u>STEP 1</u> : <u>STANDARD</u> : <b>EXAMINER'S</b>	Obtain a copy of the completed instruction. A copy of OPDP-4-1 Attachment 1, Disabled Alarm Checklist. CUE: Provide the Performer a copy of the completed instruction.	SAT UNSAT
COMMENTS:		
<u>STEP 2</u> :	DISABLED ALARM CHECKLIST block reviewed	SAT
<u>STANDARD</u> :	Performer determines that the incorrect Panel Number is entered in the block.	LINSAT
COMMENTS:		
<u>STEP 3</u> :	ALARM LOCATION block is reviewed.	SAT
<u>STANDARD</u> : COMMENTS:	Performer determines incorrect information is entered in the Node/Mux/Pt or SER	UNSAT
<u>STEP 4</u> :	Reviews entry into 1. Description of the alarm that is being defeated.	SAT
<u>STANDARD</u> :	.Performer determines that an adequate description of the alarm function has been entered.	UNSAT
COMMENTS:		

Rev	<i>v</i> . 0	A.2-SRO Page 6 of 12
<u>STEP 4</u> :	Reviews entry into 2. Reason for disabling the alarm that is being defeated.	SAT
<u>STANDARD</u> :	.Performer determines that an <b>inaccurate description of the</b> <b>reason for disabling the alarm is entered</b> . The data entered should describe that the alarm has been deemed a nuisance.	UNSAT
COMMENTS:		
STEP 6:	Reviews entry into 3. Description of how alarm will be disabled.	SAT
<u>STANDARD</u> :	Performer determines that the description is adequate.	0/11
COMMENTS:		UNSAT
<u>STEP 7</u> :	Reviews to 4. Determine if a 10CFR50.59 Review is required.	Critical Step
<u>STANDARD</u> :	Performer determines that a <b>10CFR50.59 review is required</b> , since the alarm is NOT being disabled per GO-6.	SAT
COMMENTS:		UNSAT
<u>STEP 8</u> :	Reviews to 5. Determine if a 10CFR50.59 Review is required prior to exceeding 90 days.	SAT
<u>STANDARD</u> :	Performer determines that a 10CFR50.59 review is not required, since the alarm is NOT being for a maintenance evolution.	UNSAT
COMMENTS:		

Re	A.2-SRO Page 7 of 12	
STEP 9:	Reviews to 6. Determine if a Technical Evaluation (Form OPDP-4-5) is required.	Critical Step
<u>STANDARD</u> :	Performer determines that a <b>10CFR50.59 review is a</b> <b>Technical Evaluation (Form OPDP-4-5) is required</b> .	UNSAT
COMMENTS:		
<u>STEP 8</u> :	Performs Step 7, and determines that the form cannot be approved as presented.	<u>Critical Step</u>
<u>STANDARD</u> :	Performer states that the package cannot be signed as approved until after the errors have been corrected.	SAT
COMMENTS:		UNSAT
	END OF TASK	

TIME STOP: \_\_\_\_\_

### PERFORMER CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. A plant shutdown is in progress.
- 2. Mode 3 has just been entered.
- 3. The Operator-at-the-Controls has informed you that Annunciator 85-F, RVLIS SYS MALFUNCTION has been received on multiple occasions, and that OPDP-4-1 Disabled Alarm Checklist has been filled out to disable the alarm.
- 4. You are the Unit SRO.

#### **INITIATING CUES:**

Review the OPDP-4-1 Disabled Alarm Checklist for approval. Note any and all discrepancies found during your review.

NPG Standard	Annunciator Disablement	OPDP-4	
Department		Rev. 0004	
Procedure		Page 15 of 21	

# Attachment 1 (Page 1 of 2)

# **OPDP-4-1 - Disabled Alarm Checklist**

	DISABI	LED ALARM CHECK	LIST			
Site	DISABLED ALARM CHECKLIST		ALARM LOCA 85-F Window Nurr			_
	1-XA-55-4D Panel Number	Micr	Node/Mux/Pt or SE	R/Sensor	4	_
1.	Describe the function of this alarm (e.g. pro of an automatic trip, indication of loss of fun Provides indication of	vide indication of abn iction) Failure of	the microf	uipment fa	ailure ind	lication
2	Describe reason for disabling alarm/input. ( Not required, per 60-6	Include procedure or	WO number, if appl	cable)		-
3	Describe how this alarm/alarm input will be Defeat at the microproc	disabled USSor pur	WO 09-B1	6541	-000	_
4	is a 10CFR50 59 Review required prior to d	lisabling alarm? (Ref	er to Appendix A).		Yes	No
4.	Is a 10CFR50 59 Review required prior to d Is a 10CFR50 59 Review required prior to e maintenance)?	lisabling alarm? (Ref exceeding 90 days (al	er to Appendix A) arm disabled for		Yes	No K
4. 5. 6. Pres	Is a 10CFR50 59 Review required prior to d Is a 10CFR50.59 Review required prior to e maintenance)? Is a Technical Evaluation (Form OPDP-4-5) Appendix A). pared By:	isabling alarm? (Ref exceeding 90 days (al ) required prior to disa Date Haff Print N	er to Appendix A) arm disabled for abling alarm? (Refe www.	r to 5/15/0 Dat	Yes	
4 5. Preș	Is a 10CFR50 59 Review required prior to d Is a 10CFR50.59 Review required prior to e maintenance)? Is a Technical Evaluation (Form OPDP-4-5) Appendix A). Dared By: Approval for annunciator disablement If required, is 10CFR50 59 Review attached	isabling alarm? (Ref exceeding 90 days (al ) required prior to disa Date Haff Print N	er to Appendix A) arm disabled for abling alarm? (Refe with	r to 5/15/0 Dat Yes	Yes	
4. 5. 9 reș	Is a 10CFR50 59 Review required prior to d Is a 10CFR50.59 Review required prior to e maintenance)? Is a Technical Evaluation (Form OPDP-4-5) Appendix A). Dared By: Approval for annunciator disablement If required, is 10CFR50 59 Review attached If required, is Technical Evaluation (Form O	isabling alarm? (Ref exceeding 90 days (al ) required prior to disa Dale Haff Print N Print N 17	er to Appendix A) arm disabled for abling alarm? (Refe Man ame	Yes	Yes	
4. 5. 6. Pre;	Is a 10CFR50 59 Review required prior to d Is a 10CFR50.59 Review required prior to e maintenance)? Is a Technical Evaluation (Form OPDP-4-5) Appendix A). Dared By: Approval for annunciator disablement If required, is 10CFR50 59 Review attached If required, is Technical Evaluation (Form O If a Technical Evaluation was performed, is acceptable?	isabling alarm? (Ref exceeding 90 days (al ) required prior to disa Dale Haff Print N Print N 17 OPDP-4-5) attached? Compensatory Monit	er to Appendix A) arm disabled for abling alarm? (Refe ame	Yes	Yes	
4. 5. Preș	Is a 10CFR50 59 Review required prior to d Is a 10CFR50.59 Review required prior to d maintenance)? Is a Technical Evaluation (Form OPDP-4-5) Appendix A). Dared By: Approval for annunciator disablement If required, is 10CFR50 59 Review attached If required, is Technical Evaluation (Form O If a Technical Evaluation was performed, is acceptable? Are steps to enable the alarm provided in the	isabling alarm? (Ref exceeding 90 days (al ) required prior to disa Dale Hall Print N Print N 17 OPDP-4-5) attached? Compensatory Monit ne controlling work do	er to Appendix A) arm disabled for abling alarm? (Refe Maname	Yes	Yes	
4. 5. Preș 7	Is a 10CFR50 59 Review required prior to d Is a 10CFR50.59 Review required prior to d maintenance)? Is a Technical Evaluation (Form OPDP-4-5) Appendix A). Dared By: Approval for annunciator disablement If required, is 10CFR50 59 Review attached If required, is Technical Evaluation (Form O If a Technical Evaluation was performed, is acceptable? Are steps to enable the alarm provided in th Signature (SM/US) alarm must be returned to service by:	IIISABIING Alarm? (Ref exceeding 90 days (al ) required prior to disa Dale Haff Print N Print N 17 OPDP-4-5) attached? Compensatory Monit he controlling work do Print 1	er to Appendix A) arm disabled for abling alarm? (Reference arme	Yes	Yes	

NPG Standard	Annunciator Disablement	OPDP-4
Department		Rev. 0004
Procedure		Page 16 of 21

#### Attachment 1 (Page 2 of 2)

OPDP-4-1 -	<ul> <li>Disabled</li> </ul>	Alarm	Checklist	i
------------	------------------------------	-------	-----------	---

	DISABLED A	LARM CHECKLIST		
DISABLED	ALARM CHECKLIST	ALARM L	OCATION	
		Window	Number	
	Panel Number	Node/Mux/Pt o	r SER/Sensor	
<ol> <li>This alarm has placed on affect</li> </ol>	been disabled as described in Iter ted alarm window(s).	n 1 of this form and Disabled A	Narm Indicators h	ave been
Performed by:	Signature	Print Name	Dete	Time
/erified By:				
	Signature	Print Name	Date	Time
Prepared by:	Signatura	Print Name	Data	
	orgnature	PTINE PRATING	Date	T II T N
Reviewed & Approved by:	SM/US Signature	Print Name	Date	Time
10 This elarm has Indicator(s) as	been restored to normal and teste sociated with this alarm have been	d in accordance with Item S of removed.	this form and Dis	abled Alarm
-enormed by:	Signature	Print Name	Date	Time
/erified By:				
	Signature	Print Name	Date	Time
<ol> <li>Compensator Monitoring re-</li> </ol>	y Monitoring of this alarm is termin quired.	ated and Unit Supervisor notif	ed. N/A if no Con	npensatory
	Signature	Print Name	Date	Time

# 85-F

Microprocesso	r TRAIN-/	4		RVLIS SY: MALFUNCTI	S ON
NOTE 1	The mo detecte diagnos	st probable cause of alarm d by the microprocessor du stics checks.	would be uring syste	from errors em internal	]
NOTE 2	During not req	plant shutdown, after enter uired, this alarm may be dis	ing Mode sabled (Se	4 when RVLIS is ee GO-6).	
Probable					
Cause:	1.	Microprocessor system e	rror(s) det	ected	
	2. 3.	Loss of A Train RVLIS S) 1-BKR-235-2/47D open C Board 1-L supplying 1-R-1	STEM Po N 120 VA 148	wer Supply, Break C Vital Instrument	er board 1-1 er Power
	4.	Fuse Blown 120 VAC Vita 1-FU-235-47A/ 47B	al Instrume	ent Power Board 1	-I,
	5.	Transmitter delta-p overa with RCS below 250°F	anged due	to four RCPs in s	ervice
Corrective					
Action:	[1]	CHECK other train for op	erability (*	124-E).	
	[2]	DISPATCH Operator to c	heck pow	er supplies at 125	Vital
	[3]	IF alarm continues. THEN	N		
	L-1	NOTIFY MIG to initiate co	orrective a	ctions.	
References:	3D2	0465 Series			
	1-48	5W708-1			
	1-43 GO-	0W1023-5 6			
	GO	-			
		Ī	WBN	Page 35 of 50	ARI-81-87 Rev 30

SOURCE

Microprocessor TRAIN-A

WBN	Unit Shutdown From Hot Standby To	GO-6
Unit 1	Cold Shutdown	Rev. 0040
		Page 40 of 90

Date\_\_\_\_

INITIALS

5.5 Unit Cooldown to Between 170 and 180°F

#### CAUTION

Adequate heat removal via natural circulation requires the RCS be pressurized. Both Trains of RHR must be maintained operable whenever the RCS is open to containment atmosphere.<sup>21</sup>

 CONTINUE RCS cooldown to between 170 and 180°F while maintaining Pzr pressure between 330 and 350 psig by performing the following:

#### NOTE

Shutdown margin calculations shall be calculated using Xenon Free conditions. Emergency cooldowns may take credit for Xenon.<sup>4</sup>

- [1.1] ENSURE RCS C<sub>B</sub> is acceptable for continuing RCS cooldown by performing the following (N/A if RCS C<sub>B</sub> is adequate for a temperature of 200.1°F):
  - A. RUN the REACT shutdown margin program to determine boron requirements for 200.1°F, AND

ATTACH a copy of the results to this procedure.

B. BORATE the RCS to the applicable C<sub>B</sub> target USING desired method from Appendix E to meet or exceed the required RCS C<sub>B</sub> calculated in 5.5[1.1]A above (as a minimum).

#### NOTE

Calculated C<sub>B</sub> may be used in lieu of sample for Emergency cooldowns.

- C. ENSURE RCS and Pzr C<sub>B</sub> are acceptable by Chemistry sample or calculated C<sub>B</sub>.
- [1.2] INITIATE applicable Sections of 1-SI-68-44. AND

ACCESS ICS screens HC and HCRGRPH to monitor RCS and Pzr Temperature/Pressure Limits.

# WATTS BAR NUCLEAR PLANT A.3-SRO

A.3-SRO Authorize a Radioactive Liquid Release

# WATTS BAR NUCLEAR PLANT A.3-SRO

### ADMINISTRATIVE JOB PERFORMANCE MEASURE

Task: Authorize a Radioactive Liquid Release

- **Alternate Path:** N/A
- Facility JPM #: New
- K/A Rating(s): G2.3.6 [2.0/3.8]
- Task Standard: Performer identifies that the release permit is for the wrong tank/release point, and the voltage setpoint for 0-RE-90-122 is not within the 0.101VDC limit established in 0-ODI-90-1, Section 6.1, Step 15. Performer DOES NOT sign package as approved.

Preferred Evaluation Location:	Preferred Evaluation Method:
Simulator In-Plant	Perform X Simulate
References: 0-ODI-90-1 Liquid Radwaste T	ank Release, Rev. 31
Task Number: SRO-077-SOI-77-001	APPLICABLE FOR: SRO
<b>10CFR55.45</b> : 9	
Validation Time: 15 min. Time Critic	al: No
Performer:NAME	Time Start: SSN Time Finish:
Performance Rating: SAT UNSAT	Performance Time
Examiner:	
NAME ====================================	
COMM	IENTS
<u> </u>	

# **Tools/Equipment/Procedures Needed:**

Marked up copy of 0-ODI-90-1 Liquid Radwaste Tank Release, Rev. 31. Batch Liquid Permit, Dated 3-18-09 Monitor Tank Sample Report DKB600





# READ TO OPERATOR

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. A release of the Monitor Tank is scheduled for this shift.
- 2. Chemistry has prepared a 0-ODI-90-1 Liquid Radwaste Tank Release Package for the release.
- 3. You are the Unit SRO.
- 4. The DATES on the documentation are CORRECT.

#### **INITIATING CUES:**

Review the 0-ODI-90-1 package for release approval. Note any and all discrepancies found during your review.



# START TIME: \_\_\_\_\_

6.968	· · · · · · · · · · · · · · · · · · ·		
	<u>STEP 1</u> : <u>STANDARD</u> :	Obtain a copy of the completed instruction. Marked up copy of the Release Package including 0-ODI-90-1 "Liquid Radwaste Tank Release" is acquired by the performer.	SAT
	EXAMINER'S	CUE: Provide the Performer a copy of the completed instruction.	UNSAT
	COMMENTS:		
	<u>STEP 2</u> :	Performer reviews package for correct tank to be released.	SAT
	STANDARD:	<b>Error</b> - The Batch Liquid Effluent Permit is for the <b>Cask Decon</b> <b>Collector Tank, NOT</b> the <b>Monitor Tank</b> as described in the 0-	
	COMMENTS:	ODI-90-1 Appendix A Pre-Release Permit Data	UNSAT
	<u>STEP 3</u> :	Performer reviews package to verify radioanalysis values are less than the limits provided on the Batch Liquid Effluent Permit.	SAT
	<u>STANDARD</u> :	Performer determines that all values are less than limits (III. RADIOANALYSIS - LIQUID).	UNSAT
	COMMENTS:		



			A.3-SRO Page 6 of 20
Â	<u>STEP 4</u> :	Performer reviews package to verify the EXP. RESPONSE VALUE is less than the 0-RE-90-122 SETPOINT.	SAT
	STANDARD:	Performer determines the EXP. RESPONSE VALUE is less than the 0-RE-90-122 SETPOINT given in IV. RADIATION MONITOR(S) section of the Batch Liquid Effluent Permit.	UNSAT
	COMMENTS:		
	<u>STEP 5</u> :	Performer reviews package to verify the volume, flow, and dilution values are within limits.	SAT
	STANDARD:	Performer determines the volume, flow, and dilution values are within limits given in V. AUTHORIZATION section of the Batch Liquid Effluent Permit.	UNSAT
	COMMENTS:		
	<b>)</b>		
1	STEP 6:	Performer reviews package verify the radiation monitor voltage is within limits.	<u>Critical Step</u> SAT
	<u>STANDARD</u> :	<b>Error</b> - The 0-RE-90-122 Setpoint voltage of <u>5.84</u> Vdc recorded on 0-ODI-90-1, Appendix A is more than <u>0.101</u> Vdc higher than the setpoint of <u>5.262</u> Vdc provided in the Batch Liquid Effluent Permit.	UNSAT
	COMMENTS:		



		A.3-SRO Page 7 of 20
<u>STEP 7</u> :	Performer reviews 0-ODI-90-1 for correct step sign-off.	SAT
STANDARD:	<b>Error</b> - The 0-RE-90-122 Setpoint voltage of <u>5.84</u> Vdc recorded on 0-ODI-90-1, Appendix A is more than <u>0.101</u> Vdc higher than the setpoint of <u>5.262</u> Vdc provided in the Batch Liquid Effluent Permit. Step 15 of Section 6.1 should have been N/A, and Steps 16 and 17 should have been performed.	UNSAT
COMMENTS:		
<u>STEP 8</u> :	Performer determines that the package cannot be approved as written	<u>Critical Step</u>
EVALUATOR	CUE: When the two errors have been identified and the performer addresses the fact that the package cannot be approved with these errors state "We will stop here"	SAT
STANDARD:	Performer states that the package cannot be signed as approved until after the errors have been corrected.	UNSAT
	END OF TASK	

TIME STOP: \_\_\_\_\_



# PERFORMER CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

# **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### **INITIAL CONDITIONS:**

- 1. A release of the Monitor Tank is scheduled for this shift.
- 2. Chemistry has prepared a 0-ODI-90-1 Liquid Radwaste Tank Release Package for the release.
- 3. You are the Unit SRO.

## **INITIATING CUES:**

Review the 0-ODI-90-1 package for release approval. Note any and all discrepancies found during your review.





SURVEILLANCE TASK SHEET (STS)							
Work Order	N/A			Page of			
Si Kev	N/A		· -3+				
Procedure No.	0-001-00-1			· ·			
Titte	RW Rolesse						
Perf Section	Chemistry(CEM)		N/A	N/A	N/A		
Test Reason	Conditional Performs	ance		Authorization to Beoin: SBO	Date	Time	
Data Sheets	N/A	3106			Dute	i inte	
Due	N/A		··				
Extension	N/A			1	3/11/69	ches	
Max, Extension	N/A			· · · ·	Start Date	Time	
Frequency	Conditional						
EQ	N/A						
ASME XI	N/A						
APP Mode	1234567			j c	Completion Date	Time	
Performance Mode	1234567						
Operational	N/A						
Condition							
Dry Cask Storage	∐ Yes xNo						
Subsequent	NA						
instruction	Conditional Perform:	ance					
		<u> </u>	T				
Mama	Test Performer's	Initial	Fortion	Was this a complete or partial			
	Signature	inmai	Section	(Evoloin "Partial" in Romarka)	Complete 🗍	Portial	
AAKE NO HOTCH ( SOU	KAC-		CHEM	Miere all Toch Spec/Tech Red (			
		-		ISESI CoC/ODCM/Fire			
				Protection			
······································		1	1	Reg. acceptance criteria	Yes No	N/A E	
				satisfied?			
		1		Were all other acceptance			
				criteria satisfied?	Yes No	N/A [	
	<u> </u>			If all Tech Spec/Tech Req./ISFSI			
	ļ		<u> </u>	CoC/ODCM/Fire Protection Req.			
				were not satisfied, was an LCO/			
				(Evaluate in Demodel)	Maa bin	N/6 F	
				(Explain in Remarks)		N/A L	
	+		+	Alert Scheduling Required			
				Filer Obredbing Reduited			
	<u> </u>		[·				
	· · · · · · · · · · · · · · · · · · ·					Date	
		1	+				
				Acceptance Criterla Review: SRO	Date	Time	
				(ASME XI SIs require review within	t		
				96 hours)			
			<u> </u>	· · · · · · · · · · · · · · · · · · ·		•	
			+	Independent Reviewe	er	Date	
			<u> </u>	4			
			<u> </u>	ANII (If required)		Date	
	.1			Copy of STS sent to Scheduling	1		
Remark:					Initials	Date	
				Section	No.	Dur	
1				I	Men	Hrs	



Tennessee Valley A Watts Bar Nuclear	uthority Plant		90034.010.007 Unit # 1
	BATCH LIQU	ID EFFLUENT PERMIT	Allocation 100.
I. REQUEST			
X NORMAL UNPLANNED	RELEASE PO CASK DECON	INT COLLECTOR TANK	ESTIMATED START: 18-mar-2009 16:00:00
RELEASE VOLUME (ES 1.5190E+04 GAL	TIM.)	1	ESTIMATED STOP: 18-mar-2009 17:48:30
DILUTION FLOW AVAI 2.0000E+04 GPM	L. DISCHARGE COOLING TO	POINT WER BLOWDOWN	
II. SAMPLE IDENTIF	ICATION		
NUMBER 71 CONFIGURATION FILE	COLLECTION 06-mar-200 NAME: CAS_SAM:0	DATE/TIME 9 02:38:00 90306_0434_C.CNF	ANALYSIS DATE/TIME 06-mar-2009 02:51:23
III. RADIOANALYSIS	- LIQUID		
ECL FRACTION SUM 0.67 < 10.00 DIS. GAS SUM 0.00E+00uCi/ml < 2	CUM. T 3.88E- CUM. T 2.0E-04 3.88E-	OT-BODY DOSE(Q) 03 mrem < 1.50 OT-BODY DOSE(A) 03 mrem < 3.00	CUM. ORGAN DOSE(Q) 3.89E-03 mrem < 5.00 CUM. ORGAN DOSE(A) 3.89E-03 mrem < 10.00
IV. RADIATION MONI	TOR (S)	~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~ ~	
NUMBER 0-RE-90-122	SETPOINT 1.43E+04 CPM 0.00E+00 CPM	EFFECTIVE GAIN 2.27E-09 uCi/ml/ 0.00E+00 uCi/ml/	EXP. RESPONSE CPM 7.17E+03 CPM CPM 0.00E+00 CPM
V. AUTHORIZATION			*********
MAX. VOLUME 1.5190E+04 GAL	MAX. WASTE 7.6896E+0	FLOW 2 GPM	MIN. DILUTION FLOW 2.0000E+04 GPM
The above-named s the Offshte Dose of flow rates specifi	source has been s Calculation Manua .ed. [17]09 (000)	ampled and analyzed 1. Release is autho	and is in compliance w prized for the volume an
Performed/by / I	ate Time	Review and Approv	al (Unit SRO) / Date T
The volta	ige for radiation	monitor	

0-RE-90-122 should be set to: 5.262 (Volts)



Tennessee Valley Authority page 1 of 2 Watts Bar Nuclear Plant Liquid Radioactive Waste Release Permit 90034.010.007.L Pre-Release Supplementary Data PART I: PRE-RELEASE DATA -------RELEASE POINT (10): CASK DECON COLLECTOR TANK DISCHARGE POINT (1): COOLING TOWER BLOWDOWN DISCHARGE POINT (1): COOLING TOWER BLOWDOWN Dilution Stream (1): ERCW Permit Issued: 17-mar-2009 09:59:10 Release Type: Batch Waste Tank Volume: 1.5190E+04 GAL Recirc. Rate: 0.0000E+00 GPM Recirc. Start: Min Recirc Time: 0 MIN Sample After: Agitator Used: Rad Monitor: (1 ) 0-RE-90-122 Rad Monitor Bckgrnd: 6.2100E+03 CPM Estim. Dilution Flow: 2.0000E+04 GPM Estim. Dilution Vol.: 2.1700E+06 GAL Dilution Factor (Act): 1.4386E+02 Estim. Waste Flow: 1.4000E+02 GPM Estim. Waste Vol.: 1.5190E+04 GAL Estim. Duration: 108.50 MIN Estim. Release Start: 18-mar-2009 16:00:00 Estim. Release End: 18-mar-2009 17:48:30 \_\_\_\_\_ PART II: PRE-RELEASE CALCULATIONS Sample Entry # : 71 Sample time: 06-mar-2009 02:38:00 Sampled by: DJH Configuration File Name: CAS SAM:090306 0434 C.CNF Total Waste Activity:5.5036E+00 CuriesTotal Waste Conc:9.5715E-02 uCi/mlTotal Waste Conc/ECL:9.6033E+01Total Monit Conc:2.1851E-06 uCi/mlDilution Allocation:7.0000E-01Concurrent Releases:1Min Dilution Flow:3.6413E+03 GPMMax Waste Flow:7.6896E+02 GPM Dilution Strm Sample: Dilution Conc/ECL: 6.6756E-01 0 Max Monitor Setpoint: 4.3702E-06 uCi/ml Flag: 1.4343E+04 CPM Rqrd Dilution Fct: 1.9207E+01 Flags: C-Release Curies > Local Limit F-Waste Flow > Max Allowable R-Expected Response > Max Setpoint F-Dilution Flow < Min Allowable A-Setpoint Adjustment Factor < 1.0

Tennessee Valley Authority page 2 of 2 Watts Bar Nuclear Plant									
Liquid Radioactive Waste Release Permit 90034.010.007.L Pre-Release Supplementary Data									
ISOTOPIC IDENTIFICATION - Unit 1									
: Pre-Dilut.: Pre-Dilut.: Pre-Dilut.: Post : Measured : Measured : Measured : Dilution Isotope : uCi/ml : Conc/ECL : Conc/Total: uCi/ml	: Post : Estimated : Dilution : Curies : Conc/ECL : Released								
CO-60 P: 7.31E-07 : 2.44E-01 : 7.64E-06 : 5.08E-09 FE-55 O: 2.27E-06 : 2.27E-02 : 2.37E-05 : 1.58E-08 H-3 O: 9.57E-02 : 9.57E+01 : 1.00E+00 : 6.65E-04 SB-125 P: 1.45E-06 : 4.85E-02 : 1.52E-05 : 1.01E-08 SR-89 O: 6.23E-08 : 7.79E-03 : 6.51E-07 : 4.33E-10	: 1.69E-03 : 4.20E-05 : 1.58E-04 : 1.31E-04 : 6.65E-01 : 5.50E+00 : 3.37E-04 : 8.36E-05 : 5.41E-05 : 3.58E-06								
Totals : 9.57E-02 : 9.60E+01 : : 6.65E-04	: 6.68E-01 : 5.50E+00								

. .

\*\*\*\*\*\*\*\*\*\*\*\*\* 17-MAR-2009 09:56:40.68 TENNESSEE VALLEY AUTHORITY WATTS BAR NUCLEAR PLANT \*\*\*\*\*\*\* SAMPLE TITLE : 0-ODI-90-1 MONITOR TANK : DKB600: [TVA.SAMPLE.CHEM.NEW] 090306 0434 C.CNF;1 FILE IDENT \* OPERATOR SAMPLE ID : 090306 0434 C : DJHUTCHISON SAMPLE TIME : 6-MAR-2009 02:38: \* SAMPLE GEOMETRY : LM1K \* SHELF HEIGHT : 0 \* EFFICIENCY FILE : LM1K0 \* SAMPLE QUANTITY : 1.00000E+03 ML SAMPLE TYPE : 1L LIO. MARIN. ACQ DATE & TIME : 6-MAR-2009 02:51: \* DEADTIME (%) : 0.0% \* SENSITIVITY PRESET LIVE TIME : 0 00:15:00 : 4.00000 ELASPED REAL TIME : 0 00:15:00 \* GAUSSIAN SEN : 10.00000 ELAPSED LIVE TIME : 0 00:15:00 \* NBR ITERATIONS : 10 DETECTOR : DET #4, GSS-3850 \* LIBRARY : LIQUID : 14-APR-2003 08:32 \* EFFIC CERT DATE EFFIC CAL DATE : 14-APR-2003 08:32 DCAL DATE & TIME : 5-MAR-2009 20:47: \* ENERGY TOLER : 1.25 \* HALF LIFE RATIO KEV/CHAN : 5.00794E-01 : 8.00000 : -1.48231E-01 keV \* ABUNDANCE LIMIT OFFSET : 80.0% \* CORRECTION FACTOR : 1.00000E+00 Q COEFFICIENT : -3.28672E-07 \* PEAK END CHAN PEAK START CHAN : 140 : 4096 \*\*\*\*\*\*\* ANALYSES : PEAK V16.9 NID V3.3 MINACT V2.8 WTMEAN/KEY V1.8

COUNTED ON : LION COLLECTED BY : COUNTED BY : DJHUTCHISON REVIEWED BY : COMMENTS :

Post-NID Peak Search Report

\*\*\*\*\*

It	Energy	Area	Bkgnd	FWHM	Channel	Left	Pw	%Err	Fit	Nuclides
0	81.53	30	59	1.00	163.11	158	9	48.9		XE-133
0	176.59	90	105	1.04	353.00	348	11	24.4		SB-125
0	381.29	19	26	0.67	762.05	757	9	54.1		SB-125
0	428.01	205	63	1.35	855.44	847	16	11.2		SB-125
0	463.48	78	22	1.34	926.35	920	11	16.2		SB-125
0	510.59	74	20	3.35	1020.54	1013	16	17.9		ANNIL
0	600.56	110	18	1.81	1200.45	1192	13	12.3		SB-125
0	636.07	70	7	1.46	1271.49	1265	14	14.4		SB-125
0	810.82	180	22	1.79	1621.08	1613	14	9.2		CO-58
0	1173.03	147	3	2.01	2346.25	2338	14	8.7		CO-60
0	1332.19	114	2	2.22	2665.12	2659	11	9.8		CO-60

Nuclide Line Activity Report Sample ID : 090306 0434 C

- - - -

Nuclide Type: AP

Nuclide CO-58	Energy 810.76 863.94 1674.00	<b>%Abn</b> 99.40* 0.74 0.54	۲ ۶Eff 8.330E-01 7.882E-01 4.519E-01	Jncorrected uCi/ML 6.521E-07 Line Line	Decay Corr uCi/ML 6.522E-07 Not Found Not Found	1-Sigma %Error 9.23	Status OK Absent Absent
	Final Mean	for 1	Valid Peaks	= 6.522E-0	07+/- 6.0218	2-08 ( S	€.23%)
CO-60	1173.22 1332.49	100.00* 100.00	6.044E-01 5.426E-01	7.310E-07 6.285E-07	7.310E-07 6.285E-07	8.66 9.79	OK OK
	Final Mean	for 2	Valid Peaks	= 7.310E-0	07+/- 6.3291	3-08 ( 8	3.66%)

Nuclide Type: FP

11001400	1100. 11						
				Uncorrected	Decay Corr	1-Sigma	
Nuclide	Energy	%Abn	%Eff	uCi/ML	uCi/ML	%Error	Status
SB-125	176.33	6.89	2.679E+00	1.465E-06	1.465E-06	24.39	OK
	380.43	1.50	1.591E+00	2.390E-06	2.390E-06	54.12	OK
	427.89	29.33*	1.443E+00	1.454E-06	1.454E-06	11.17	OK
	463.38	10.35	1.349E+00	1.678E-06	1.678E-06	16.24	OK
	600.56	17.80	1.080E+00	1.714E-06	1.714E-06	12.25	OK
	606.64	5.02	1.071E+00	Lin	e Not Found		Absent
	635.89	11.32	1.028E+00	1.806E-06	1.806E-06	14.39	OK
	671.41	1.81	9.812E-01	Lin	e Not Found		Absent
	Final Mean	for 6	Valid Peaks	s = 1.454E-	06+/- 1.625	E-07 ( 11	17%)

Nuclide Type: FG Uncorrected Decay Corr 1-Sigma %Abn %Eff uCi/ML uCi/ML %Error Status 37.32\* 1.793E+00 1.364E-07 1.366E-07 48.89 OK Nuclide Energy XE-133 81.00 Final Mean for 1 Valid Peaks = 1.366E-07+/- 6.680E-08 (48.89%)

Nuclide Type: OTHER Uncorrected Decay Corr 1-Sigma %Abn %Eff uCi/ML uCi/ML %Error Status Nuclide Energy 0.00\* 1.241E+00 0.000E+00 0.000E+00 0.00 ANNIL 511.00 OK Final Mean for 1 Valid Peaks = 0.000E+00+/-0.000E+00 ( 0.00%)

Flag: "\*" = Keyline

Unidentified Energy Lines Sample ID : 090306\_0434\_C Page : 3 Acquisition date : 6-MAR-2009 02:51:23

None

.

Flags: "T" = Tentatively associated
Rejected	Report				Page: 4
Sample I	D : 090306	_0434_C		Acqui	isition date : 6-MAR-2009 02:51:23
		Half-Life			Activity 1-Sigma
Nuclide	Half-life	Ratio	Energy a	Abund	(uCi/ML) %Error Rejected by
I-131	8.04D	0.00	80.18	2.62	Not Found Abun.
			284.29	б.05	Not Found
			364.48*	81.20	Not Found
			636.97	7.26	2.823E-06 14.39
	_		722.89	1.08	Not Found
	¥	Abundances	Found =	7.39	
I-132	2.30H	0.15	262.70	1.44	Not Found Abun.
			505.90	5.03	Not Found
			522.65	16.10	Not Found
			630.20	13.70	Not Found
			650.60	2.66	Not Found
			667.69*	98.70	Not Found
			671.60	5.23	Not Found
			727.00	5.33	Not Found
			//2.61	76.20	Not Found
			809.80 954 55	19 10	1.278E-05 9.23
			1136 00	2 96	Not Found
			1295.30	1.97	Not Found
			1372.10	2.47	Not Found
			1398.60	7.11	Not Found
	¥	Abundances	Found =	2.14	(Abn. Limit = 75.00%)
TE-134	41.80M	0,50	180.89	18.00	Not Found Abun
			201.24	8.70	Not Found
			210.47	21.90	Not Found
			277.95	21.30	Not Found
			435.06	18.60	Not Found
			460.99	10.80	Not Found
			464.64	5.10	4.814E-06 16.24
			565.99	18.90	Not Found
			636.26	1.71	1.687E-05 14.39
			565.85	1.20	Not Found
			712.97	4.40	NOE Found
			767 20*	30 00	Not Found
			844 06	1 20	Not Found
*			925.55	1.65	Not Found
	8	Abundances	Found =	3.83	
CS-136	13,160	0 00	86.29	6 30	Not Found Abun
	10.100	0.00	153.22	7,46	Not Found
			163.89	4.61	Not Found
			176.55	13.56	7.453E-07 24.39
			273.65	12.66	Not Found
			340.57	48.50	Not Found
			818.50*	99.70	Not Found
			1048.07	79.60	Not Found
			1235.34	19.70	Not Found
	ક	Abundances	Found =	4.64	

•

Rejected Sample I	Report (co D : 090306	ontinued) _0434_C		Acqui	isition o	date :	6-MAI	Page 2009 02	≥: 5 :51:23
Nuclide CS-138	Half-life 32.20M	Half-Life Ratio 0.65 Abundances	Energy 8 138.10 227.76 408.98 462.79 546.94 871.80 1009.78 1147.22 1343.59 1435.86* Found =	Abund 1.49 1.51 4.66 30.70 10.80 5.11 29.80 1.24 1.14 76.30 18.86	Activ: (uCi/N Not Not 8.822E Not Not Not Not Not	ity 1-3 ML) % Found Found Found Found Found Found Found Found Found	Sigma Error  5.24    	Rejected Abun.	Ъγ
PM-148M	41.30D *	0.00 Abundances	98.48 189.63 288.11 311.63 414.07 432.78 501.26 550.27* 599.74 611.26 629.97 725.70 915.33 1013.81 Found =	2.47 1.10 12.56 3.92 18.66 5.35 6.75 94.90 12.54 5.48 89.00 32.80 17.17 20.30 3.88	Not Not Not Not Not 2.430E Not Not Not Not Not	Found Found Found Found Found Found Found Found Found Found Found Found	2.25	Abun.	
RA-228	5.75¥ \$	0.00 Abundances	99.45 129.08 209.28 270.23 327.64 409.51 463.00 755.18 772.17 794.70 835.50 911.07* 969.11 1459.30 1495.80 1588.00 1630.40 Found =	$\begin{array}{c} 1.30\\ 2.80\\ 4.40\\ 3.60\\ 2.13\\ 4.40\\ 1.05\\ 1.55\\ 4.60\\ 1.75\\ 27.70\\ 16.60\\ 1.00\\ 1.00\\ 3.50\\ 1.86\\ 5.34 \end{array}$	Not Not Not Not 3.944E Not Not Not Not Not Not Not Not	Found Found Found Found Found Found Found Found Found Found Found Found Found Found Found	6.24	Abun.	

Flag: "\*" = Keyline



Interference Report Sample ID : 090306\_0434\_C

No interference correction performed

Summary Sample I	of Nuclide D : 090306_	Activit 0434_C	У	Acquisitio	n date : 6-MAR	Page : 7 -2009 02:51:23
Total n Number Number	umber of li of unidenti of lines te	nes in fied li entative	spectrum nes ly identifie	11 0 d by NID 11	100.00%	
Nuclide	Туре : АР					
Nuclide CO-58 CO-60	Hlife 70.80D 5.27Y	Decay 1.00 1.00	Wtd Mean Uncorrected uCi/ML 6.521E-07 7.310E-07	Wtd Mean Decay Corr uCi/ML 6.522E-07 7.310E-07	Decay Corr 1-Sigma Error 0.602E-07 0.633E-07	1-Sigma %Error Flags 9.23 8.66
	Total Acti	vity :	1.383E-06	1.383E-06		
Nuclide	Type : FP		Wtd Mean Uncorrected	Wtd Mean Decay Corr	Decay Corr	1-Sigma
Nuclide SB-125	Hlife 2.77Y	Decay 1.00	uC1/ML 1.454E-06	uCi/ML 1.454E-06	1-Sigma Error 0.162E-06	%Error Flags 11.17
	Total Acti	vity :	1.454E-06	1.454E-06		
Nuclide	Type : FG		Wtd Mean	Wtd Mean		
Nuclide XE-133	Hlife 5.24D	Decay 1.00	Uncorrected uCi/ML 1.364E-07	Decay Corr uCi/ML 1.366E-07	Decay Corr 1-Sigma Error 0.668E-07	1-Sigma %Error Flags 48.89
	Total Acti	ivity :	1.364E-07	1.366E-07		
Nuclide	Туре : ОТНІ	ER	Wtd Mean	Wtd Mean	Decay Corr	1-Sigma
Nuclide ANNIL	Hlife 100.00D	Decay 1.00	uCi/ML 0.000E+00	uCi/ML 0.000E+00	1-Sigma Error 0.000E+00	%Error Flags 0.00
	Total Act	ivity :	0.000E+00	0.000E+00		
Grand	l Total Act:	ivity :	2.974E-06	2.974E-06		
Flags: "	'K" = Keylin 'E" = Manual	ne not f lly edit	ound ed	"M" = Manua "A" = Nucli	lly accepted de specific ab	n. limit

Maximum Permissible Concentration ReportPage : 8Sample ID : 090306\_0434\_CAcquisition date : 6-MAR-2009 02:51:23

Nuclide	Activity (uCi/ML)	1-Sigma % Error	MPC (uCi/ML)	Fractional MPC
CO-58	6.522E-07	9.2	9E-05	7.247E-03
CO-60	7.310E-07	8.7	3E-05	2.437E-02
SB-125	1.454E-06	11.2	1E-04	1.454E-02
XE-133	1.366E-07	48.9	- 0 -	- 0 -
ANNIL	0.000E+00	0.0	- 0 -	- 0 -
Totals:	2.974E-06			4.615E-02

.

A.4-RO Respond To Medical Emergency

#### **EVALUATION SHEET**

|--|

Alternate Path: N/A

Facility JPM #: 3-0T-JPMADA.4-1

K/A Rating(s): 2.4.39 [3.3/3.1]

<u>Task Standard:</u> Performer performs actions of Appendix A of EPIP-10, "Medical Emergency Response".

Preferred Evaluation Location:	Preferred Ev	aluation Method:			
Simulator X In-Plant	Perform X	Simulate			
References: EPIP-10, "Medical Emergency R	esponse", Rev. 20.				
Task Number: RO-100-SOI-100-011	APPLICABLE FOR:	RO/SRO			
10CFR55.45: 11					
Validation Time: 10 min. Time Critical: No					
Applicant:		Time Start:			
Performance Rating: SAT UNSAT		Performance Time			
Examiner:	SIGNATU	/ JRE DATE			
COMMENTS					

### SIMULATOR OPERATOR INSTRUCTIONS:

This JPM may be performed either on the simulator or in another location. If performed on the simulator refer to the following.

- 1. Initialize to any IC.
- 2. Acknowledge all alarms.
- 3. Freeze simulator for duration of task performance.
- 5. NOTE: This JPM may be performed using a console booth instructor who acts as personnel outside the main control room. Cues may be made by him as indicated by the JPM.

## SIMULATOR OPERATOR INSTRUCTIONS:

When directed by the evaluator, place phone call to the "Horseshoe" to initiate the medical emergency:

Call the "Horseshoe" and state the following:

### "I want to report a medical emergency."

### **Tools/Equipment/Procedures Needed:**

Latest revision of EPIP-10

NOTE: START THIS JPM AT A LOCATION WHERE PERFORMER HAS ACCESS TO PROCEDURES (Simulator, Main Control Room, TIC or provide performer with procedure).

## READ TO OPERATOR

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

You are the Control Room Operator (CRO) on shift.

You have received a telephone call reporting an onsite medical emergency.

#### **INITIATING CUES:**

• Respond to the medical emergency in accordance with EPIP-10.

START TIME: \_\_\_\_\_

<u>STEP 1</u> :	Obtain a copy of the instruction.	S A T
STANDARD:	A copy of EPIP-10 has been obtained.	SAT
EXAMINER'S	CUE: After the performer locates and obtains correct instruction, the evaluator can provide a copy of the instruction.	UNSAT
COMMENTS:		
NOT	E TO EVALUATOR: The following steps are from EPIP-10, App	pendix A
STEP 2: [Step	A] Obtain NAME of caller.	
STANDARD:	CRO requests name of caller and records on Appendix A.	SAT
CUE:	State to the performer that your name is John Doe.	
COMMENTS:		UNSAT
STEP 3: [Step	B] LOCATION of caller.	
<u>STANDARD</u> :	Performer requests the location of the caller and records on Appendix A.	SAT
CUE:	<i>State to the performer that you are just south of the station air compressors on elevation 708' in the Turbine Building.</i>	UNSAT
COMMENTS:		

		A.4 RO Page 7 of 12
STEP 4: [Step	o C] Type of Medical Emergency.	
STANDARD:	Performer requests the type of Medical Emergency and records on Appendix A.	SAT
CUE:	State to the performer that you found a male victim lying on the floor unconscious. The victim has a heartbeat and is breathing.	UNSAT
COMMENTS:		
STEP 5: [Step	DD] Number of personnel Involved.	
STANDARD:	Performer requests how many people involved and records on Appendix A.	SAT
CUE:	State to the performer: "No other individuals are involved".	UNSAT
COMMENTS:		
<u>STEP 6</u> : [Step	o E] Immediate Area Hazards (Radiological, Safety).	
<u>STANDARD</u> :	Requests if immediate hazards exist and records on Appendix A.	SAT
CUE:	State to the performer: "No hazards exist in the area".	UNSAT
COMMENTS:		

		A.4 RO Page 8 of 12		
<u>STEP 7</u> : [Step				
STANDARD:	Request the telephone number of the caller and records on Appendix A.	SAT		
CUE:	<i>State to the performer that the phone number of the phone you are calling from is 5555.</i>	UNSAT		
COMMENTS:				
NOTE TO EVALUATOR: The sequence of actions to initiate the Fire Alarm is taken AOI-30.1, Step 1. These steps appear as un-numbered steps.				
<u>STEP 8</u> : INIT	IATE the fire alarm.			
STANDARD: Performer describes how to initiate the Fire Alarm.				
EXAMINER'S				
COMMENTS:				
STEP 9: RES	ET the fire alarm.			
STANDARD:				
EXAMINER'S	CUE:			
COMMENTS:				

		A.4 RO Page 9 of 12
<u>STEP 10</u> : [Ste	ep G] ALERT and DISPATCH MERT PERSONNEL	
STANDARD:	Performer alerts and dispatches MERT personnel using a plant radio set to Channel 3.	SAT
CUE:	As MERT personnel, acknowledge performer's communication.	UNSAT
COMMENTS:		
<u>STEP 11</u> : [Ste		
	"ATTENTION ALL SITE PERSONNEL." "ATTENTION ALL SITE PERSONNEL."	
	"A MEDICAL emergency has been reported. The MERT is to ACTIVATE and RESPOND to the following LOCATION:	
<u>STANDARD</u> :	Performer makes public address announcement and has MERT respond to Turbine Building elevation 708', just south of the station air compressors.	
EXAMINER'S	CUE: DO NOT allow performer to actually perform this announcement. Ensure it is simulated.	
COMMENTS:		

		. age . e e =
<u>Step 12</u> : INI	TIATE the fire alarm.	
STANDARD:		
EXAMINER'S		
COMMENTS:		
<u>STEP 13</u> : [Ste	ep I] CONFIRM that the Shift Manager (SM) has been notified.	
<u>STANDARD</u> :	Performer ensures the SM has been notified. (may make phone call or announce to the control crew that a medical emergency is in progress)	
**CUE:	Acknowledge report as Shift Manager.	
COMMENTS:		

		A.4 RO Page 11 of 12
<u>STEP 11</u> : [Ste	ep J] CONFIRM that the Fire Protection Section Duty Shift Supervisor (Fire Brigade Leader) was notified by: Radio or Telephone (extension 3311 or 3355) or Pocket Pager 40566	SAT
<u>Standard</u> : Examiner's	Performer ensures the Fire Protection Section Duty Shift Supervisor was notified by radio, telephone, or pocket pager. <b>CUE: Do NOT allow performer to actually perform this</b>	UNSAT
	notification. Ensure it is simulated.	
CUE:	Acknowledge report as Fire Protection Section Duty Shift Supervisor.	
COMMENTS:		
<u>STEP 12</u> : [Ste	ep K] CONFIRM/COORDINATE MERT response (via radio or phone) until Incident Commander assumes control.	
<u>STANDARD</u> :	Performer confirms/coordinate the MERT response until the Incident Commander assumes control.	
CUE:	As Incident Commander, notify the performer that you have assumed control of the emergency. We will stop here.	
COMMENTS:		
	END OF TASK	

TIME STOP: \_\_\_\_\_

### APPLICANT CUE SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the administrative task to be performed. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### **INITIAL CONDITIONS:**

You are the Control Room Operator (CRO) on shift.

You have received a telephone call reporting an onsite medical emergency.

### **INITIATING CUES:**

• Respond to the medical emergency in accordance with EPIP-10.

# D.1-SRO CLASSIFY THE EVENT PER THE REP (HIGH RCS ACTIVITY, SGTR AND FAULTED SG)

## **EVALUATION SHEET**

Task: Classify the Event per the REP (HIGH RCS ACTIVITY, SGTR AND FAULTED SG)

Alternate Path:	N/A				
Facility JPM #:	3-OT-JPMS081A				
K/A Rating(s):	2.1.14 [2.5/3.3] 035A2.01 [4.5/4.6	2.4.30 [2.2/3.	6] 2.4.	38 [2.2/4.0	
<u>Task Standard:</u>	The event is classi Any Two Barriers made per EPIP-5.	fied as a GEN and Potential	IERAL EMER Loss of Thir	GENCY based d Barrier" Not	on "Loss of ifications are
Preferred Evaluati	ion Location:		Preferred Ev	aluation Meth	<u>od:</u>
Simulator <u>X</u>	In-Plant This JPM will be s	imulated.	Perfor	m <u>X</u>	
<u>References</u> : EF "GEN	PIP-1 "Emergency Pla ERAL EMERGENC	an Classificatio Y", Rev. 37	on Flowpath",	Rev. 30; EPIP	-5
Task Number:	SRO-113-EPIP-	-001	APPLICABLE	FOR: SRO	
10CFR55.45: 11, 1	2				
Validation Time:	<u>26 min. <b>Time</b></u>	Critical: Yes			
Applicant:	NAME		SSN	Time Start: _ Time Finish: _	
Performance Rating:	SAT UNSAT _			Performance T	ime
Examiner:					_/
	NAME	_ =========================	SIGNATU	RE ====================================	DATE
		COMMENTS			

EVALUATOR INFORMATION SHEET

### SIMULATOR SETUP INSTRUCTIONS:

NONE: THIS JPM IS SIMULATED and the simulator will not be used to reflect the conditions.

#### **REQUIRED MATERIALS:**

EPIP-1 and EPIP-5

### **SPECIALCONSIDERATIONS:**

### TO PRESERVE EXAM SECURITY:

- DO NOT allow actual call to ODS. If a call is made, ensure call is to simulator instructor
- UNDER NO CIRCUMSTANCES IS THE PERFORMER TO OPERATE THE FAX IN THE "ODS" or "ODS DRILL" MODES.

#### **Tools/Equipment/Procedures Needed:**

Ensure clean copy of EPIP-5 in all copies of Emergency Instructions on the Simulator Floor and in the file drawer of Unit Supervisor's desk.

#### **SIMULATOR OPERATOR INSTRUCTIONS:**

- 1. Obtain copy of EPIP-5 to facilitate role plays for contacts made by the performer.
- 2. Performer must use NRC ring down phone.

# READ TO OPERATOR

#### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

#### THE CURRENT SIMULATOR CONDITIONS ARE NOT REPRESENTATIVE OF THIS JPM.

#### **INITIAL CONDITIONS:**

- 1. The unit was at 90% RTP when the crew manually initiated a Reactor Trip and Safety Injection due to a SGTR on SG #1 of greater than 140 gpm.
- 2. The crew has entered E-3, Steam Generator Tube Rupture.
- 3. Subsequently, a Safety Valve on SG #1 OPENED and FAILED to RECLOSE and the crew transitioned to E-2, Faulted Steam Generator.
- 4. Currently, the Status Trees are GREEN except for FR-H.5, Steam Generator Low Level, which is YELLOW due to level in SG #1 at 50% wide range.
- 5. Chem Lab reports RCS activity is 340 uCi/gram dose equivalent I-131.
- 6. Wind is from 90 degrees, at 8 mph.
- 7. You are the SM/SRO

#### **INITIATING CUES:**

- 1. The Unit Supervisor has informed you of the above conditions.
- 2. The operators are taking actions per the emergency instructions (currently in E-3 and transitioning from E-2 and will be transitioning to ES-3.1).
- 3. You are to make the initial classification of the event per the REP EPIPs and make required initial notifications.
- 4. Portions of this JPM are time critical.

# START TIME: \_\_\_\_\_

<u>STEP 1</u> :	Refers to EPIP-1 to determine level of event.	
<u>STANDARD</u> :	Performer refers to EPIP-1 and declares a GENERAL EMERGENCY based on "Loss Of Three Barriers" (1.1.2 Loss, 1.2.3 Loss, 1.3.4 Loss). This must be completed within <b>15 minutes</b> of task assignment.	SAT
	This step is critical to ensure proper activation of TVA resources for event in progress.	UNSAT
COMMENTS:	RECORD time that declaration was made:	
<u>STEP 2</u> :	Implements EPIP-5, GENERAL EMERGENCY	CAT
<u>STANDARD</u> :	EPIP-5, GENERAL EMERGENCY, is implemented.	SAT
COMMENTS:		UNSAT

NOTE 1 S	Steps not required to be performed may be marked N/A.	
	NLO	
NOTE 2 S Operator	Steps with with in the margin may be performed by Non-Lic phone talker.	ensed
<u>STEP 3</u> :	<b>[STEP 1]</b> Upon determining that existing conditions are classified as a GENERAL EMERGENCY according to EPIP-1 (independent evaluations by crew members may be beneficial), the SED, or designee, will:	CRITICAL STEP
<u>STANDAI</u>	<u>RD</u> :	
**(	CUE:	UNSAT
	ITS:	
NOTE 1	IF ongoing onsite Security events may present risk to the emergenders, THEN CONSULT with Security to determine if s dangerous to the life and health of emergency responders.	ergency lite access is
NOTE 2 IF ongoing events makes activating EPS and site access dangerous to the life and health of emergency responders, THEN the STAGING AREA button on the EPS terminal should be used INSTEAD of the EMERGENCY button. This will direct off-site personnel to Training Center Classroom 19 (LNC). Responders within the Protected Area will monitor Plant Announcements and report to the TSC or OSC as conditions permit.		
NOTE 3	The Emergency Paging System (EPS) provides a printed repo minutes during the 90 minutes duration after activation. Printe available in the TSC, OSC and the MCR	rt every 10 outs are
NOTE	4 When initiating Appendix A or C ensure that only the applica which the classification is declared are documented. Example the fission product barrier matrix, document three digits inclu L(1.1.1 P, 1.2.2 L, & 1.3.2 L) When initiating Appendix D only the EAL(s) need to be listed.	able EAL(s) for e: When using Iding P or he additional

٦

Т

<u>STEP 4</u> :	<ul> <li>[STEP 1] IF the onsite emergency centers are <u>not</u> staffed, THEN DIRECT Shift Personnel to activate the Emergency Paging System (EPS) to staff the TSC and Operations Support Center (OSC). Shift Personnel should confirm activation and provide the 20 minute printed report to the SM for review.</li> <li>A IF the EPS system fails, call the ODS, ringdown or (5- 751-1700) and have him activate the EPS.</li> <li>B IF the above methods of activating the EPS fail, Shift Personnel must use the Radiological Emergency Response Call Lists to staff the TSC and OSC. This list is located in the EPS Manual near the terminal.</li> </ul>	CRITICAL STEP
<u>STANDARD</u> :	Performer directs the NLO to perform Step 1 to activate the emergency paging system (EPS) to staff the TSC and Operations Support Center (OSC) or EPS is activated in the control room. This step is critical to ensure proper activation of TVA resources for event in progress.	
**CUE:	After the NLO is notified, acknowledge the request to activate the Emergency Paging System.	
COMMENTS:		

<u>STEP 5</u> :	<b>[STEP 2] IF</b> the TSC has <u>not</u> been activated, <b>THEN</b> <b>a. INITIATE</b> Appendix A and B, Initial Notification Information for GENERAL EMERGENCY and Protective Action Recommendations.	CRITICAL STEP
<u>STANDARD</u> :	Appendix A is accurately completed with Appendix B <u>RECOMMENDATION 2 SELECTED.</u> Performer notifies the ODS, and then assigns the NLO to FAX Appendix A to the ODS.	SAT UNSAT
NOTE TO EV		
COMMENTS:		
<b>NOTE</b> ODS should be notified within 5 minutes after declaration of the event.		

<u>STEP 6</u> :	<b>b. NOTIFY</b> 1700 or 5-7	the ODS direct by ODS Ringdown or 5-751- 751-2495	CRITICAL STEP
	1) PROVID	E the information from Appendices A and B.	SAT
<u>STANDARD</u> :	Appendix A <b>RECOMM</b>	A is accurately completed with Appendix B	UNSAT
	The ODS is Appendix A <b>minutes</b> of	s notified and provided the information on A. This notification must be made within <b>5</b> f event declaration.	
	Performer FAX Apper	notifies the ODS, and then assigns the NLO to ndix A to the ODS.	
EVALUATOR NOTE: TO PRESERVE EXAM SECURITY, DO NOT allow actual call to ODS. If a call is made, ensure call is to simulator instructor			
NOTE TO EV	ALUATOR:	TO PRESERVE EXAM SECURITY, UNDER NO CIRCUMSTANCES IS THE PERFORMER TO OPERATE THE FAX IN THE "ODS" or "ODS DRILL" MODES.	
**CUE:	EVALUA and repe	<i>TOR (or Booth Operator) Role play as the ODS</i> <i>eat back the report.</i>	
COMMENTS:	RECORD ti	me that ODS was notified:	

<u>STEP 7</u> :	<b>c. IF</b> the ODS cannot be contacted within <u>10 minutes</u> , then <b>NOTIFY</b> Rhea County, Meigs County, McMinn County, and the Tennessee Emergency Management Agency (TEMA) of the classification USING the contact information in Appendix E.	SAT UNSAT
<u>STANDARD</u> :	The ODS is notified and provided the information on Appendix A. This notification must be made within <b>5 minutes</b> of event declaration. The conditions of this step are not met, so the step is N/A.	
COMMENTS:		

<u>STEP 8</u> :	<b>d</b> ANNOUNCE to the crew: "A GENERAL EMERGENCY is being declared based on Primary Coolant Activity Level, SGTR on SG #1/Faulted SG #1 Outside Containment. I will be the Site Emergency Director."	CRITICAL STEP
<u>STANDARD</u> :	NDARD: The above announcement is made to the crew. Wording describing the event may vary. Step is critical to alert crew to the declaration of the GENERAL EMERGENCY and provide for tracking personnel.	
**CUE:	After the crew is notified, acknowledge the report.	
COMMENTS:		
<u>STEP 9</u> :	e. TRACK dispatched personnel by name, and PERFORM one of the following.	SAT
	FOSC is not staffed, <b>THEN INFORM</b> Rotating Maintenance Organization Supervisor of names for team tracking.	SAT
	WHEN OSC is staffed, THEN INFORM OSC manager of names for team tracking.	UNSAT
<u>STANDARD</u> :	Performer addresses the fact that the OSC has not been staffed and that until it is, dispatched personnel will be provided to the RMOS for team tracking.	
**CUE:	If the Rotating Maintenance Organization Supervisor is contacted, acknowledge the report.	
COMMENTS:		

<u>STEP 10</u> :	f. GO TO Step 5.	
<u>STANDARD</u> :	Performer advances to Step 5.	SAT
COMMENTS:		UNSAT
<u>STEP 10</u> :	[Step 5] ANNOUNCE to the plant: "ATTENTION ALL SITE PERSONNEL. ATTENTION ALL SITE PERSONNEL. A GENERAL EMERGENCY has been declared based on " (Repeat)	SAT
<u>STANDARD</u> :	Performer provides NLO with the following information in order to make the Plant announcement :	UNSAT
	"ATTENTION ALL SITE PERSONNEL. ATTENTION ALL SITE PERSONNEL. A GENERAL EMERGENCY has been declared based on Primary Coolant Activity Level, SGTR on SG #1/Faulted SG #1 Outside Containment." (Repeat)	
COMMENTS:		

CAUTION	If there is any possibility of a radiological release, A severe weather condition (such as a Tornado) or security adversary attack, HOLD assembly and accountability actions until these conditions have been resolved. Do not send personnel into areas of unknown radiological conditions or security risk without first contacting Radiological Control (RADCON) or Security.		
NOTE 1	The following action is N/A if assembly and accountability action already been initiated.	ns have	
NOTE 2	EPIP-8, Personnel Accountability and Evacuation, Appendix D i Security actions and Radiation Protection actions (as necessary	nitiates Site /).	
<u>STEP 11 :</u>	<b>[STEP 6] INITIATE</b> EPIP-8, Personnel Accountability and Evacuation	CRITICAL STEP	
<u>STANDARD</u>	The performer determines that assembly and accountability should be performed and assigns Steps 6 to the NLO for completion.	SAT	
	This step is critical in that specific guidance is given with regard to assembly & accountability.	UNSAT	
<u>COMMENTS</u>	<u>&gt;:</u>		

<u>STEP 12</u> :	[STEP 7] CONTACT Radiation Protection (x7865), and PROVIDE the following:	CRITICAL STEP
	a. ANNOUNCE "We are in a GENERAL EMERGENCY." (Repeat)	SAT
	<b>b. DIRECT</b> Radiation Protection to IMPLEMENT EPIP-14, Radiological Control Response, and CECC EPIP-9, Emergency Environmental Radiological Monitoring Procedures.	UNSAT
	<b>c. EVALUATE</b> the need to implement EPIP-13, Initial Dose Assessment for Radiological Emergencies, for a dose projection if radioactivity is being released through normal plant release paths.	
STANDARD:	The performer assigns completion of this step to the NLO.	
	This step is critical to ensure Radiation Protection implements the proper procedures in response to the GENERAL EMERGENCY.	
COMMENTS:		

<u>STEP 13:</u>	<b>[STEP 8] IF</b> there are personnel injuries, <b>IMPLEMENT</b> WBN EPIP-10, "Medical Emergency Response."	SAT	
STANDARD:	Performer determines that it is <b>NOT</b> necessary to implement EPIP-10.		
**CUE:	Inform the performer that there are NO personnel injuries.	UNSAT	
COMMENTS:			
<u>STEP 14:</u>	<b>[STEP 9] CONTACT</b> Site Security (x8464 or x8495), and REQUEST Security to IMPLEMENT EPIP-11, Security and Access Control.	CRITICAL STEP	
STANDARD:	The performer assigns completion of this step to the NLO.	SAT	
	This step is critical to ensure Radiation Protection implements the proper procedures in response to the GENERAL EMERGENCY.	UNSAT	
COMMENTS:			

<u>STEP 15:</u>	<ul> <li>[STEP 10] INFORM TVA Management by PERFORMING the following:</li> <li>NOTIFY Duty Plant Manager in accordance with SPP-3.5.</li> <li>PROVIDE Duty Plant Manager GENERAL EMERGENCY information from one of the following (as applicable).</li> <li>The information recorded on Appendix A, Initial Notification form for GENERAL EMERGENCY, or</li> <li>The information recorded on Appendix C, Initial Classification form for GENERAL EMERGENCY.</li> </ul>	CRITICAL STEP		
STANDARD:	Duty Plant Manager is provided the Appendix A information.			
	This step is critical as it alerts plant management to REP activation.			
**CUE:	(Booth Operator) Role play as the Duty Plant Manager and acknowledge the report.			
COMMENTS:				
<b>NOTE:</b> The following step is not applicable if the state was contacted directly.				
<u>STEP 16:</u>	<b>[STEP 11] CONFIRM</b> with the ODS or CECC that the State of Tennessee has been notified.			
STANDARD:	ODS is contacted to confirm that the State of Tennessee has been notified of REP activation.	SAT		
**CUE:	(Booth Operator) Role play as the ODS and report that the State of Tennessee has been Notified of REP Activation at Watt Bar Nuclear Plant.	UNSAT		
COMMENTS:				
<b>NOTE:</b> NRC notification should be made as soon as practicable <b>but within one hour</b> of <b>GENERAL EMERGENCY</b> declaration. Whenever NRC requests, a qualified person must be provided for a continuous update to NRC Operations Center.				

EVALUATOR	NOTE: DO NOT allow actual call to NRC. Ensure call is to simulator instructor.	
<u>STEP 22:</u>	[STEP 12] NOTIFY the NRC, using designated NRC phone (ENS), of plan activation. The following commercial numbers are for the NRC Operations Center. 9-1-301-816-5100 (MAIN) 9-1-301-951-0550 (BACKUP) 9-1-301-816-5151 (FAX)	CRITICAL STEP
<u>STANDARD</u> :	The performer assigns completion of this step to the NLO. This step is critical as it alerts NRC to REP activation.	UNSAT
EVALUATOR	NOTE: DO NOT allow actual call to NRC. Ensure call is to simulator instructor.	
**CUE:	(Booth Operator) Role play the NRC and acknowledge the report.	
COMMENTS:		

<u>STEP 23:</u>	<ul> <li>[STEP 13] NOTIFY the NRC Resident Inspector (x1776) and PROVIDE one of the following (as applicable).</li> <li>The information recorded on Appendix A , or</li> <li>The information recorded on Appendix C.</li> </ul>	CRITICAL STEP
STANDARD:	The NRC Resident Inspector is provided Appendix A information.	UNSAT
	This step is critical as it alerts NRC to REP activation.	
EVALUATOR NOTE: <b>DO NOT allow actual call to NRC Resident.</b> Ensure call is to simulator instructor.		
**CUE: (Booth Operator) Role play the NRC Resident and acknowledge the report.		
EVALUATOR NOTE: Give the following cue to performer when the performer completes the call to the NRC Resident Inspector:		
**CUE:	Role play and report that the TSC is staffed, and that the SED will be coming to the control room for a turnover of SED duties. We will stop here.	
COMMENTS:		
	END OF TASK	

TIME STOP: \_\_\_\_\_

### PERFORMER HANDOUT SHEET (TO BE RETURNED TO EXAMINER UPON COMPLETION OF TASK)

### **DIRECTION TO TRAINEE:**

I will explain the initial conditions, and state the task to be performed. All control room steps shall be performed for this JPM, including any required communications. I will provide initiating cues and reports on other actions when directed by you. Ensure you indicate to me when you understand your assigned task. To indicate that you have completed your assigned task return the handout sheet I provided you.

### THE CURRENT SIMULATOR CONDITIONS ARE NOT REPRESENTATIVE OF THIS JPM.

### **INITIAL CONDITIONS:**

- 1. The unit was at 90% RTP when the crew manually initiated a Reactor Trip and Safety Injection due to a SGTR on SG #1 of greater than 140 gpm.
- 2. The crew has entered E-3, Steam Generator Tube Rupture.
- 3. Subsequently, a Safety Valve on SG #1 OPENED and FAILED to RECLOSE and the crew transitioned to E-2, Faulted Steam Generator.
- 4. Currently, the Status Trees are GREEN except for FR-H.5, Steam Generator Low Level, which is YELLOW due to level in SG #1 at 50% wide range.
- 5. Chem Lab reports RCS activity is 340 uCi/gram dose equivalent I-131.
- 6. Wind is from 90 degrees, at 8 mph.
- 7. You are the SM/SRO

### **INITIATING CUES:**

The Unit Supervisor has informed you of the above conditions.

The operators are taking actions per the emergency instructions (currently in E-3 and transitioning from E-2 and will be transitioning to ES-3.1).

You are to make the initial classification of the event per the REP EPIPs and make required initial notifications.

Portions of this JPM are time critical.