

Dominion Energy Kewaunee, Inc.  
N490 Hwy 42, Kewaunee, WI 54216  
Web Address: www.dom.com



OCT 06 2009

ATTN: Document Control Desk  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Serial No. 09-600  
LIC/NW/RO  
Docket No.: 50-305  
License No.: DPR-43

**DOMINION ENERGY KEWAUNEE, INC.**  
**KEWAUNEE POWER STATION**  
**CYCLE 30 CORE OPERATING LIMITS REPORT**

Pursuant to Kewaunee Power Station (KPS) Technical Specification (TS) 6.9.a.4.D, enclosed is a copy of the KPS Technical Requirements Manual Section 2.1, Kewaunee Power Station Core Operating Limits Report Cycle 30, Revision 0.

If you have questions or require additional information, please feel free to contact Mr. Jack Gadzala at 920-388-8604.

Very truly yours,

A handwritten signature in black ink, appearing to read "m. j. wilson".

Michael J. Wilson  
Director Safety and Licensing  
Kewaunee Power Station

Commitments made by this letter: NONE

Enclosure

1. KPS Technical Requirements Manual Section 2.1, Kewaunee Power Station Core Operating Limits Report Cycle 30, Revision 0.

ADD  
KRR

cc: Regional Administrator, Region III  
U. S. Nuclear Regulatory Commission  
2443 Warrenville Road  
Suite 210  
Lisle, IL 60532-4352

Mr. P. S. Tam  
Sr. Project Manager  
U.S. Nuclear Regulatory Commission  
One White Flint North, Mail Stop O8-H4A  
11555 Rockville Pike  
Rockville, MD 20852-2738

NRC Senior Resident Inspector  
Kewaunee Power Station

TRM 2.1

Kewaunee Power Station

**CORE OPERATING LIMITS REPORT  
(COLR)**

CYCLE 30

REVISION 0

Approved

  
FSRC Chairman

9/8/09  
Date

09-065  
Mtg.#

## **Table of Contents**

<b><u>Section</u></b>	<b><u>Title</u></b>	<b><u>Page</u></b>
1.0	INTRODUCTION .....	1
2.0	OPERATING LIMITS .....	2
2.1	Reactor Core Safety Limits .....	2
2.2	Shutdown Margin (SDM) .....	2
2.3	Moderator Temperature Coefficient .....	2
2.4	Shutdown Bank Insertion Limit .....	2
2.5	Control Bank Insertion Limits .....	2
2.6	Nuclear Heat Flux Hot Channel Limits ( $F_Q^N(Z)$ ) .....	3
2.7	Nuclear Enthalpy Rise Hot Channel Factor ( $F_{\Delta H}^N$ ) .....	4
2.8	Axial Flux Difference (AFD) .....	4
2.9	Overtemperature $\Delta T$ Setpoint .....	4
2.10	Overpower $\Delta T$ Setpoint .....	5
2.11	RCS Pressure, Temperature, and Flow Departure From Nucleate Boiling (DNB) Limits .....	5
2.12	Refueling Boron Concentration .....	5
3.0	REFERENCES .....	6

## List of Figures

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1.	Reactor Core Safety Limits Curve (1772 MWt).....	8
2.	Required Shutdown Reactivity vs. Boron Concentration .....	9
3.	Hot Channel Factor Normalized Operating Envelope (K(z)) .....	10
4.	Control Bank Insertion Limits .....	11
5.	N(Z) Values (Top and Bottom 9% excluded) .....	12
6.	Penalty Factor, $F_p$ , for FQN(Z) .....	14
7.	Axial Flux Difference Target Band .....	15

## **CORE OPERATING LIMITS REPORT CYCLE 30**

### **1.0 INTRODUCTION**

This Core Operating Limits Report (COLR) for Kewaunee Unit 1 Cycle 30 has been prepared in accordance with the requirements of Kewaunee Technical Specification 6.9.a.4.

A cross reference between the COLR section and the KPS Technical Specifications affected by this report is given below:

COLR Section	KPS Technical Specification	Description
2.1	2.1	Reactor Core Safety Limit
2.2	3.10.a	Shutdown Margin
2.3	3.1.f.3	Moderator Temperature Coefficient (MTC)
2.4	3.10.d.1	Shutdown Bank Insertion Limits
2.5	3.10.d.2	Control Bank Insertion Limits
2.6	3.10.b.1.A 3.10.b.5 3.10.b.6.C.i	Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ )
2.7	3.10.b.1.B	Nuclear Enthalpy Rise Hot Channel Factor Limits ( $F_{\Delta H}^N$ )
2.8	3.10.b.8	Axial Flux Difference (AFD) Target Band
2.9	2.3.a.3.A	Overtemperature $\Delta T$ Setpoint
2.10	2.3.a.3.B	Overpower $\Delta T$ Setpoint
2.11	3.10.k 3.10.l 3.10.m.1	RCS Pressure, Temperature and Flow Departure from Nucleate Boiling (DNB) Limits
2.12	3.8.a.5	Refueling Boron Concentration
Figure 1	2.1	Reactor Core Safety Limits (1772 MWt)
Figure 2	3.10.a	Required Shutdown Margin
Figure 3		K(Z) Normalized Operating Envelope
Figure 4	3.10.d.2	Control Bank Insertion Limits
Figure 5		N(Z) Values (Top and Bottom 9% excluded)
Figure 6		Penalty Factor, $F_p$ , for $F_Q^N(Z)$
Figure 7	3.10.b.8.A	Axial Flux Difference Envelope

## **CORE OPERATING LIMITS REPORT CYCLE 30**

---

### **2.0 OPERATING LIMITS**

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the following subsections. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.9.a.4.

#### **2.1 Reactor Core Safety Limits** (TS 2.1.a)

The combination of rated power level, coolant pressure, and coolant temperature shall not exceed the limits shown in COLR Figure 1 (1772 MWt). The safety limit is exceeded if the point defined by the combination of Reactor Coolant System average temperature and power level is at any time above the appropriate pressure line.

#### **2.2 Shutdown Margin** (TS 3.10.a)

When the reactor is subcritical prior to reactor startup, the SHUTDOWN margin shall be at least that shown in COLR Figure 2.

#### **2.3 Moderator Temperature Coefficient** (TS 3.1.f.3)

2.3.1 When the reactor is critical and  $\leq 60\%$  of RATED POWER, the moderator temperature coefficient shall be  $\leq 5.0$  pcm/ $^{\circ}$ F, except during LOW POWER PHYSICS TESTING. When the reactor is  $> 60\%$  RATED POWER, the moderator temperature coefficient shall be zero or negative.

2.3.2 The reactor will have a moderator temperature coefficient no less negative than  $-8$  pcm/ $^{\circ}$ F for 95% of the cycle time at full power.

#### **2.4 Shutdown Bank Insertion Limits** (TS 3.10.d.1)

The shutdown rods shall be fully withdrawn (229 steps) when the reactor is critical or approaching criticality.

#### **2.5 Control Bank Insertion Limits** (TS 3.10.d.2)

The control rod banks shall be limited in physical insertion as shown in COLR Figure 4.

## **CORE OPERATING LIMITS REPORT CYCLE 30**

---

### **2.6 Nuclear Heat Flux Hot Channel Factor ( $F_Q^N(Z)$ ) (TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i)**

#### 2.6.1 $F_Q^N(Z)$ Limits for Fuel

$$F_Q^N(Z) * 1.03 * 1.05 \leq \frac{CFQ}{P} * K(Z) \text{ for } P > 0.5 \quad [422 \text{ V+}]$$

$$F_Q^N(Z) * 1.03 * 1.05 \leq \frac{CFQ}{0.5} * K(Z) \text{ for } P \leq 0.5 \quad [422 \text{ V+}]$$

Where:

- P is the fraction of full power at which the core is OPERATING
- K(Z) is the function given in Figure 3
- Z is the core height location for the FQ of interest
- CFQ = 2.50

2.6.2 The measured  $F_Q^N(Z)$  hot channel factors under equilibrium conditions shall satisfy the following relationship for the central axial 80% of the core for fuel:

$$F_Q^N(Z) * 1.03 * 1.05 * N(Z) * F_p \leq \frac{CFQ}{P} * K(Z) \quad [422 \text{ V+}]$$

Where:

- P is the fraction of full power at which the core is OPERATING
- K(Z) is the function given in Figure 3
- Z is the core height location for the FQ of interest
- CFQ equals 2.50
- F<sub>p</sub> is the penalty factor described in 3.6.3
- N(Z) is a cycle-specific non-equilibrium multiplier on  $F_Q^N(Z)$  to account for power distribution transients during normal operation, provided in Figure 5.
- $F_Q^N(Z)$  is a measured FQ distribution obtained during the target flux determination

*The N(z) decks are generated for normal operation flux maps that are typically taken at full power, ARO. Additional N(z) decks may be generated, if necessary, consistent with the methodology described in Reference 1.*

- 2.6.3 The penalty factor of 1.0 shall be used for TS 3.10.b.6.A and TS 3.10.b.6.B.
- The penalty factor provided in COLR Figure 6 shall be used for TS 3.10.b.6.C.i.
- The penalty factor for all burnups outside the range of Figure 6 shall be 1.02.



## **CORE OPERATING LIMITS REPORT CYCLE 30**

### **2.7 Nuclear Enthalpy Rise Hot Channel Factor Limits ( $F_{\Delta H}^N$ ) (TS 3.10.b.1.B)**

$$F_{\Delta H}^N * 1.04 \leq CFDH * [1 + PFDH(1 - P)] \quad [422 \text{ V+}]$$

Where:

P is the fraction of full power at which the core is OPERATING  
CFDH = 1.70  
PFDH = 0.3

### **2.8 Axial Flux Difference (AFD) Target Band (TS 3.10.b.8)**

The Axial Flux Difference (AFD) acceptable operation limits are provided in COLR Figure 7.

### **2.9 Overtemperature $\Delta T$ Setpoint (TS 2.3.a.3.A)**

$$\Delta T \leq \Delta T_0 * \left[ K_1 - K_2 * (T - T') * \frac{1 + \tau_1 s}{1 + \tau_2 s} + K_3 * (P - P') - f_1(\Delta I) \right]$$

$\Delta T_0$  = Indicated  $\Delta T$  at RATED POWER, %

T = Average temperature, °F

T' ≤ 573.0 °F

P = Pressurizer Pressure, psig

P' = 2235 psig

K<sub>1</sub> ≤ 1.195

K<sub>2</sub> = 0.015/°F

K<sub>3</sub> = 0.00072/psig

$\tau_1$  ≥ 30 seconds

$\tau_2$  ≤ 4 seconds

$f_1(\Delta I)$  = An even function of the indicated difference between top and bottom detectors of the power range nuclear ion chambers. Selected gains are based on measured instrument response during plant startup tests, where qt and qb are the percent power in the top and bottom halves of the core respectively and qt + qb is total core power in percent RATED POWER, such that

(a) For qt - qb within -15, +6 %,  $f_1(\Delta I) = 0$

(b) For each percent that the magnitude of qt - qb exceeds +6%, the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 1.51% of RATED POWER.

(c) For each percent that the magnitude of qt - qb exceeds -15%, the  $\Delta T$  trip setpoint shall be automatically reduced by an equivalent of 3.78% of RATED POWER.

## **CORE OPERATING LIMITS REPORT CYCLE 30**

### **2.10 Overpower $\Delta T$ Setpoint** (TS 2.3.a.3.B)

$$\Delta T \leq \Delta T_0 * \left[ K_4 - K_5 * \frac{\tau_3 s}{\tau_3 s + 1} * T - K_6 * (T - T') - f_2(\Delta I) \right]$$

- $\Delta T_0$  = Indicated  $\Delta T$  at RATED POWER, %  
 $T$  = Average temperature, °F  
 $T'$  ≤ 573.0 °F  
 $K_4$  ≤ 1.095  
 $K_5$  ≥ 0.0275/°F for increasing T  
           ≥ 0 for decreasing T  
 $K_6$  ≥ 0.00103/°F for  $T > T'$   
           ≥ 0 for  $T < T'$   
 $\tau_3$  ≥ 10 seconds  
 $f_2(\Delta I)$  = 0 for all  $\Delta I$

### **2.11 RCS Pressure, Temperature and Flow Departure from Nucleate Boiling (DNB) Limits** (TS 3.10.k, 3.10.l, and 3.10.m.1)

- 2.11.1 During steady state power operation,  $T_{avg}$  shall be < 576.7 °F for control board indication or < 576.5 °F for computer indication.  
 2.11.2 During steady state power operation, pressurizer pressure shall be > 2217 psig for control board indication or > 2219 psig for computer indication.  
 2.11.3 During steady state power operation, reactor coolant total flow rate shall be ≥ 186,000 gpm.

### **2.12 Refueling Boron Concentration** (TS 3.8.a.5)

When there is fuel in the reactor, a minimum boron concentration of 2500 ppm and a shutdown margin of ≥ 5%  $\Delta k/k$  shall be maintained in the Reactor Coolant System during reactor vessel head removal or while loading and unloading fuel from the reactor.

### **CORE OPERATING LIMITS REPORT CYCLE 30**

---

#### **3.0 References**

1. Topical Report DOM-NAF-5-A, "Application of Dominion Nuclear Core Design and Safety Analysis Methods to the Kewaunee Power Station (KPS)," dated July, 2006.

Methodology for:

TS 2.1 – Reactor Core Safety Limits;  
TS 3.10.a – Shutdown Margin;  
TS 3.1.f.3 – Moderator Temperature Coefficient;  
TS 3.10.d.1 – Shutdown Bank Insertion Limits;  
TS 3.10.d.2 – Control Bank Insertion Limits;  
TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i – Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ );  
TS 3.10.b.1.B Nuclear Enthalpy Rise Hot Channel Factor Limits ( $F_{\Delta H}^N$ );  
TS 3.10.b.8 – Axial Flux Difference (AFD) Target Band;  
TS 3.10.k, 3.10.l and 3.10.m.1 – RCS Pressure, Temperature and Flow Departure from Nucleate Boiling (DNB) Limits;  
TS 3.8.a.5 – Refueling Boron Concentration

2. Kewaunee Nuclear Power Plant – Review for Kewaunee Reload Safety Evaluation Methods Topical Report WPSRSEM-NP-A, Revision 3 (TAC No. MB0306) dated September 10, 2001.

Methodology for:

TS 3.10.a – Shutdown Margin

3. S.M. Bajorek, et al., WCAP-12945-P-A (Proprietary), Westinghouse Code Qualification Document for Best-Estimate Loss-of-Coolant Accident Analysis, Volume 1, Rev. 2, and Volume II-V, Rev. 1 March 1998.

Methodology for:

TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i – Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ )  
TS 3.10.b.1.B Nuclear Enthalpy Rise Hot Channel Factor Limits ( $F_{\Delta H}^N$ );

4. N. Lee, et al., "Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code," WCAP-10054-P-A, dated August 1985.

Methodology for:

TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i – Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ )

5. C. M. Thompson, et al., "Addendum to the Westinghouse Small Break ECCS Evaluation Model Using the NOTRUMP Code: Safety Injection into the Broken Loop and the COSI Condensation Model," WCAP-10054-P-A, Addendum 2, Revision 1, dated July 1997.

Methodology for:

TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i – Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ )

**CORE OPERATING LIMITS REPORT CYCLE 30**

---

6. WCAP-9272-P-A, "Westinghouse Reload Safety Evaluation Methodology," July 1985.  
(Westinghouse Proprietary)

Methodology for:

TS 2.1 – Reactor Core Safety Limits;  
TS 3.1.f.3 – Moderator Temperature Coefficient;

7. WCAP-8745-P-A, Design Bases for the Thermal Overtemperature  $\Delta T$  and Thermal Overpower  $\Delta T$  trip functions, September 1986.

Methodology for:

TS 2.3.a.3.A – Overtemperature  $\Delta T$  Setpoint;  
TS 2.3.a.3.B – Overpower  $\Delta T$  Setpoint

8. S. I. Dederer, et al., WCAP-14449-P-A, Application of Best Estimate Large-Break LOCA Methodology to Westinghouse POWs with Upper Plenum Injection, Rev. 1, October 1999.

Methodology for:

TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i – Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ )  
TS 3.10.b.1.B Nuclear Enthalpy Rise Hot Channel Factor Limits ( $F_{\Delta H}^N$ );

9. WCAP-12610-P-A, "VANTAGE+ Fuel Assembly Reference Core Report," April 1995.  
(Westinghouse Proprietary)

Methodology for:

TS 3.10.b.1.A, 3.10.b.5, and 3.10.b.6.C.i – Heat Flux Hot Channel Factor Limits ( $F_Q^N(Z)$ )

10. CENP-397-P-A, "Improved Flow Measurement Accuracy Using Cross Flow Ultrasonic Flow Measurement Technology," Rev. 1, May 2000.


Methodology for:

TS 2.3.a.3.A – Overtemperature  $\Delta T$  Setpoint;  
TS 2.3.a.3.B – Overpower  $\Delta T$  Setpoint

**CORE OPERATING LIMITS REPORT CYCLE 30**

**Figure 1**


**Reactor Core Safety Limits Curve (1772 Mwt)  
(Cores Containing 422V+ fuel)  
(TS 2.1.a)**



**CORE OPERATING LIMITS REPORT CYCLE 30**

---


**Figure 2**  
**Required Shutdown Reactivity vs. Boron Concentration**  
(TS 3.10.a)



**CORE OPERATING LIMITS REPORT CYCLE 30**


---

**Figure 3**  
**Hot Channel Factor Normalized Operating Envelope ( $K(Z)$ )**



**CORE OPERATING LIMITS REPORT CYCLE 30**

**Figure 4**  
**Control Bank Insertion Limits**  
(TS 3.10.d.2)



Note: The Rod Bank Insertion Limits are based on a control bank tip-to-tip distance of 126 steps.



**CORE OPERATING LIMITS REPORT CYCLE 30**

---

**Figure 5**

**N(Z) Values <sup>1</sup>**

NODE	HEIGHT (FEET)	0 to 1000 MWD/MTU	1000 to 3000 MWD/MTU	3000 to 5000 MWD/MTU	5000 to 7000 MWD/MTU	7000 to 9000 MWD/MTU	9000 to XXXXX MWD/MTU	XXXXX to EOC MWD/MTU
Top								
6	11.0							
7	10.8							
8	10.6							
9	10.4							
10	10.2							
11	10.0							
12	9.8							
13	9.6							
14	9.4							
15	9.2							
16	9.0							
17	8.8							
18	8.6							
19	8.4							
20	8.2							
21	8.0							
22	7.8							
23	7.6							
24	7.4							
25	7.2							
26	7.0							
27	6.8							
28	6.6							
29	6.4							
30	6.2							
31	6.0							
32	5.8							
33	5.6							
34	5.4							
35	5.2							
36	5.0							
37	4.8							
38	4.6							
39	4.4							
40	4.2							
41	4.0							
42	3.8							
43	3.6							
44	3.4							
45	3.2							
46	3.0							
47	2.8							
48	2.6							
49	2.4							
50	2.2							

The N(z) data will be provided  
following shutdown of Cycle 29.

Cycle                      Specific                      N(Z) Data

**CORE OPERATING LIMITS REPORT CYCLE 30**

---

**Figure 5 (continued)**

**N(Z) Values <sup>1</sup>**

NODE	HEIGHT (FEET)	0 to 1000 MWD/MTU	1000 to 3000 MWD/MTU	3000 to 5000 MWD/MTU	5000 to 7000 MWD/MTU	7000 to 9000 MWD/MTU	9000 to XXXXX MWD/MTU	XXXXX to EOC MWD/MTU
51	2.0							
52	1.8							
53	1.6							
54	1.4							
55	1.2							
56	1.0							
Bottom								

1) Excludes top and bottom 9%

*These decks were generated for normal operation flux maps that are typically taken at full power ARO. Additional N(z) decks may be generated, if necessary, consistent with the methodology described in Reference 1.*

**CORE OPERATING LIMITS REPORT CYCLE 30**

---

**Figure 6**  
**Penalty Factor,  $F_p$ , for FQN(Z)**


<b>Cycle Burnup (MWD/MTU)</b>	<b>Penalty Factor <math>F_p</math></b>
150	1.02
18,700	1.02

Note: Linear interpolation is adequate for intermediate cycle burnups.

All cycle burnups outside the range of the table shall use a penalty factor,  $F_p$ , of 1.02. Refer to TS 3.10.b.6.C.i.

**CORE OPERATING LIMITS REPORT CYCLE 30**

**Figure 7**  
**Axial Flux Difference Target Band**  
(3.10.b.8.A)



Note: This figure represents the Relaxed Power Distribution Control (RPDC) band used in safety analyses; it may be administratively tightened depending on in-core flux map results. Refer to Figure RD 11.4.1 of the Reactor Data Manual.