UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
SAM NUNN ATLANTA FEDERAL CENTER
61 FORSYTH STREET, SW, SUITE 23T85
ATLANTA, GEORGIA 30303-8931

October 13, 2009

Florida Power and Light Company
ATTN: Mr. Mano Nazar, Senior Vice President
Nuclear and Chief Nuclear Officer
P.O. Box 14000
Juno Beach, FL 33408-0420

SUBJECT: NOTIFICATION OF TRIENNIAL FIRE PROTECTION BASELINE INSPECTION AT THE TURKEY POINT NUCLEAR PLANT WHILE TRANSITION TO 10 CFR PART 50.48(c) IS IN PROGRESS (NRC INSPECTION REPORT 05000250/2010007 AND 05000251/2010007)

Dear Mr. Nazar:

The purpose of this letter is to notify you that the U.S. Nuclear Regulatory Commission (NRC) Region II staff will conduct a triennial fire protection baseline inspection at the Turkey Point Nuclear Plant, Units 3 and 4 in January and February of 2010. The inspection team will be led by Mr. Norman Merriweather, Senior Reactor Inspector, of the NRC Region II Office. The team will be composed of personnel from the NRC Region II Office. The inspection will be conducted in accordance with Inspection Procedure 71111.05TTP, the NRC's baseline fire protection inspection procedure for plants in the process of implementing 10 CFR 50.48(c), National Fire Protection Association Standard (NFPA) 805, 2001 Edition. The inspection guidance is different from the regular triennial inspections in that the inspectors will concentrate on the fire protection program infrastructure and the adequacy of compensatory measures implemented for identified departures from code requirements. The inspectors will not routinely inspect for or evaluate circuit related issues.

On October 6, 2009, during a telephone conversation, between Ms. Olge Hanek, Licensing Engineer, and Mr. Merriweather, our respective staffs confirmed arrangements for a three-day information gathering onsite visit and a two-week onsite inspection. The schedule for the inspection is as follows:

- Information gathering visit: January 5 - 7, 2010
- Week 1 of onsite inspection: January 25 - 29, 2010
- Week 2 of onsite inspection: February 8 - 12, 2010

The purposes of the information gathering visit are to obtain information and documentation needed to support the inspection, and to become familiar with the Turkey Point Nuclear Plant fire protection program, fire protection features, post-fire shutdown capabilities and plant layout. The types of documents the team will be interested in reviewing, and possibly obtaining, are listed in the Enclosure.

Please contact Mr. Merriweather prior to preparing copies of the materials listed in the Enclosure if questions arise. The inspection team will try to minimize your administrative burden by specifically identifying those documents required for inspection preparation.

During the information gathering visit, the team will also discuss the following inspection support administrative details: office space; specific documents to be made available to the team in its office space; arrangements for reactor site access (including radiation protection training, security, safety and fitness for duty requirements); and the availability of knowledgeable plant engineering and licensing organization personnel to serve as points of contact during the inspection.

We request that during the inspection weeks you ensure that copies of analyses, evaluations or documentation regarding the implementation and maintenance of the Turkey Point Nuclear Plant fire protection program, including post-fire safe shutdown capability, be readily accessible to the team for its review. Of specific interest are those documents which establish that your fire protection program satisfies NRC regulatory requirements and conforms to applicable NRC and industry fire protection guidance. Also, personnel should be available at the site during the inspection who are knowledgeable regarding those plant systems required to achieve and maintain safe shutdown conditions from inside and outside the control room (including the electrical aspects of the relevant post-fire safe shutdown analyses), reactor plant fire protection systems and features, and the Turkey Point Nuclear Plant fire protection program and its implementation.

Your cooperation and support during this inspection will be appreciated. If you have questions concerning this inspection, or the inspection team's information or logistical needs, please contact Mr. Merriweather at (404) 562-4627, or me at (404) 562-4530.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at http://www.nrc.gov/reading-rm/adams.html (the Public Electronic Reading Room).

Sincerely,

/RA/

Rebecca L. Nease, Chief
Engineering Branch 2
Division of Reactor Safety

Docket Nos.: 50-250, 50-251
License Nos.: DPR-31, DPR-41

Enclosure: Triennial Fire Protection Inspection Support Documentation

cc w/encl: (See page 3)

cc w/encl:
Alison Brown
Nuclear Licensing
Florida Power & Light Company
Electronic Mail Distribution

McHenry Cornell
Director
Licensing and Performance Improvement
Florida Power & Light Company
Electronic Mail Distribution

Michael Kiley
Site Vice President
Turkey Point Nuclear Plant
Florida Power and Light Company
Electronic Mail Distribution

Niel Batista
Emergency Management Coordinator
Department of Emergency Management
and Homeland Security
Electronic Mail Distribution

Paul Rubin
(Acting) Plant General Manager
Turkey Point Nuclear Plant
Florida Power and Light Company
Electronic Mail Distribution

Abdy Khanpour
Vice President
Engineering Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mark E. Warner
Vice President, Nuclear Operations
South Region
Florida Power & Light Company
Electronic Mail Distribution

Mitch S. Ross
Vice President and Associate General
Counsel
Florida Power & Light Company
Electronic Mail Distribution

Marjan Mashhadi
Senior Attorney
Florida Power & Light Company
Electronic Mail Distribution

William A. Passetti
Chief
Florida Bureau of Radiation Control
Department of Health
Electronic Mail Distribution

Ruben D. Almaguer
Director
Division of Emergency Preparedness
Department of Community Affairs
Electronic Mail Distribution

Richard L. Anderson
Vice President
Nuclear Plant Support
Florida Power & Light Company
Electronic Mail Distribution

Senior Resident Inspector
Turkey Point Nuclear Generating Station
U.S. Nuclear Regulatory Commission
9760 SW 344th St.
Florida City, FL 33035

Attorney General
Department of Legal Affairs
The Capitol PL-01
Tallahassee, FL 32399-1050

Mike A. Shehadeh, P.E.
City Manager
City of Homestead
Electronic Mail Distribution

County Manager of Miami-Dade County
111 NW 1st Street, 29th Floor
Miami, FL 33128

Rajiv S. Kundalkar
Vice President - Fleet Organizational
Support
Nuclear Technical Services
Florida Power & Light Company
Electronic Mail Distribution

Letter to Mano Nazar from Rebecca L. Nease dated October 13, 2009.

SUBJECT: NOTIFICATION OF TRIENNIAL FIRE PROTECTION BASELINE INSPECTION AT THE TURKEY POINT NUCLEAR PLANT WHILE TRANSITION TO 10 CFR PART 50.48(c) IS IN PROGRESS (NRC INSPECTION REPORT 05000250/2010007 AND 05000251/2010007

Distribution w/encl:
RIDSNRRDIRS
PUBLIC
RidsNrrPMTurkeyPoint Resource

(*) – see previous page for concurrences

☐ PUBLICLY AVAILABLE ☐ NON-PUBLICLY AVAILABLE ☐ SENSITIVE ☐ NON-SENSITIVE

ADAMS: ☐ Yes ACCESSION NUMBER:_____ ☐ SUNSI REVIEW COMPLETE

OFFICE	RII:DRS	RII:DRS	RII:DRS				
SIGNATURE	*RA	RA*	RA				
NAME	MERRIWEATHER	SYKES	NEASE				
DATE	10/12/2009	10/13/2009	10/13/2009	10/ /2009	10/ /2009	10/ /2009	10/ /2009
E-MAIL COPY?	YES NO	YES N	YES NO	YES NO	YES NO	YES NO	YES NO

OFFICIAL RECORD COPY DOCUMENT NAME: S:\DRS\ENG BRANCH 2\FIRE PROTECTION\NOTIFICATION LETTER\TP 2010-007 TFPI NOTIFICATION LETTER.DOC

Triennial Fire Protection Inspection Support Documentation

Note: This is a broad list of the documents the NRC inspection team may be interested in reviewing, and possibly obtaining, during the information gathering site visit. The current version of these documents is expected unless specified otherwise. Electronic media is preferred, if readily available. (The preferred file format on CD-ROM or DVD-ROM is ".pdf"). The CD/DVD-ROM should be indexed, hyperlinked, readable, and searchable to facilitate ease of use. Please provide 5 copies of each CD/DVD-ROM submitted.) Information in "lists" should contain enough information to be easily understood by someone who has knowledge of the technology. The lead inspector will discuss specific information needs with the licensee staff and may request additional documents or electronic information.

1. The Fire Protection Program document and the Fire Hazards Analysis.

2. The Fire Protection Program implementing procedures (e.g., administrative controls, surveillance testing, fire brigade).

3. The fire brigade training program document and the pre-fire plans for the selected fire areas/zones (to be determined during information gathering visit).

4. The post-fire safe shutdown analysis, including system and separation analyses.

5. The alternative shutdown analysis.

6. Piping and instrumentation (flow) diagrams for the fire suppression systems.

7. Piping and instrumentation (flow) diagrams for the systems and components used to achieve and maintain hot standby, and cold shutdown, for fires involving shutdown from the control room.

8. Piping and instrumentation (flow) diagrams for the systems and components used to achieve and maintain hot standby, and cold shutdown, for fires in areas requiring alternative or dedicated shutdown capability.

9. Plant layout and equipment drawings which identify the physical plant locations of hot standby and cold shutdown equipment.

10. Plant layout drawings which identify plant fire area and/or fire zone delineation, areas protected by automatic fire suppression and detection, and the locations of fire protection equipment for the selected fire areas/zones (to be determined during information gathering visit).

11. Plant layout drawings which identify the general location of the post-fire emergency lighting units.

12. Plant operating procedures used to, and describing shutdown from inside the control room with a postulated fire occurring in any plant area outside the control room.

13. Plant operating procedures used to implement the alternative shutdown capability from outside the control room with a fire in either the control or cable spreading room (or any other alternative shutdown area).

14. Maintenance and surveillance testing procedures for alternative shutdown capability (including Appendix R emergency lights and communication systems) fire barriers, detectors, fire pumps and fire suppression systems.

15. Calculations and/or justifications that verify fuse/breaker coordination for the selected fire areas/zones (to be determined during information gathering visit) that are fed off the same electrical buses as components in the protected train. Also, a list of the maintenance procedures used to routinely verify fuse/breaker coordination in accordance with the post-fire safe shutdown coordination analysis.

16. A list of the significant fire protection and post-fire safe shutdown design change descriptions (including their associated 10 CFR 50.59 evaluations) and Generic Letter (GL) 86-10 evaluations.

17. A list of the protection methodologies (as identified in 10 CFR Part 50, Appendix R, Section III.G) used to achieve regulatory compliance for the selected fire areas/zones (to be determined during information gathering visit). That is, please specify whether 3-hour rated fire barriers (Section III.G.2.a), 20-foot separation along with detection and suppression (Section III.G.2.b), 1-hour rated fire barriers with detection and suppression (Section III.G.2.c), or alternative shutdown capability (Section III.G.3) is used for the selected fire areas/zones.

18. Procedures or instructions that govern the implementation of plant modifications, temporary modifications, maintenance, and special operations, and their impact on fire protection.

19. Organization chart(s) of site personnel down to the level of the fire protection staff.

20. Procedures or instructions that control the configuration of the fire protection program, features, and post-fire safe shutdown methodology and system design.

21. A list of applicable codes and standards related to the design of plant fire protection features and evaluations of code deviations (i.e., a listing of the NFPA code editions committed to (Code of Record)).

22. The three most recent fire protection QA audits and/or fire protection self-assessments.

23. A list of open and closed fire protection problem identification and resolution reports [also known as action reports/condition reports/problem investigation reports/NCRs/EARs] associated with fire protection or Appendix R safe shutdown for the past three years.

24. A list of plant fire protection licensing basis documents (i.e., a list of the SERs and change evaluations which form the licensing basis for the facility's post-fire safe shutdown configuration).

25. A list of fire protection or Appendix R calculations,

26. A list of fire impairments identified during the previous year.

27. A list of abbreviations/designators for plant systems.