

## PMSTPCOL PEmails

---

**From:** Eudy, Michael  
**Sent:** Friday, October 16, 2009 10:49 AM  
**To:** Chappell, Coley  
**Cc:** STPCOL  
**Subject:** STP Draft Chp 18 RAI 3867  
**Attachments:** RAI 3867.doc

**Importance:** High

Coley,

Please review attached RAI and let me know if you want to have a meeting or to issue it. I plan on moving it forward for processing it by c.o.b. 10/22. Thanks.

Michael A. Eudy - Project Manager  
U.S. Nuclear Regulatory Commission  
NRO/DNRL/NGE1&2  
301-415-3104

**Hearing Identifier:** SouthTexas34Public\_EX  
**Email Number:** 1763

**Mail Envelope Properties** (9E28710E0B702149AEC663972863644016F01A88)

**Subject:** STP Draft Chp 18 RAI 3867  
**Sent Date:** 10/16/2009 10:49:21 AM  
**Received Date:** 10/16/2009 10:49:23 AM  
**From:** Eudy, Michael

**Created By:** Michael.Eudy@nrc.gov

**Recipients:**  
"STPCOL" <STP.COL@nrc.gov>  
Tracking Status: None  
"Chappell, Coley" <ccchappell@STPEGS.COM>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	302	10/16/2009 10:49:23 AM
RAI 3867.doc	30202	

**Options**  
**Priority:** High  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

Request for Additional Information No. 3867 Revision 3

South Texas Project Units 3 and 4  
South Texas Project Nuclear Operating Co  
Docket No. 52-012 and 52-013  
SRP Section: 18 - Human Factors Engineering  
Application Section: FSAR section 18.4.2.1

QUESTIONS for Operating Licensing and Human Performance Branch (AP1000/EPR Projects) (COLP)

18-\*\*\*

FSAR section 18.4.2.1(3) states:

"The use of a separate set of on-screen control VDUs for safety system control and monitoring and separate on-screen control VDUs for non-safety system control and monitoring; the operation of these two sets of VDUs is entirely independent of the plant computer functions."

The second half of this sentence appears to be incorrect. In the proposed STP 3 & 4 design, there are no non-safety VDUs that are independent of the Plant Computer Function. Deletion of 18.4.2.4 (2) confirms this assessment but contradicts with the statements made in 18.4.2.1 (3).

The staff requests for the applicant to clarify/correct section 18.4.2.1(3) accordingly.