

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S ADVISORY
COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
566th Meeting

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, October 8, 2009

Work Order No.: NRC-3134

Pages 1-322

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARD

5 (ACRS)

6 + + + + +

7 566th MEETING

8 + + + + +

9 THURSDAY, OCTOBER 8, 2009

10 + + + + +

11 ROCKVILLE, MARYLAND

12 + + + + +

13 The Committee convened at the Nuclear
14 Regulatory Commission, Two White Flint North, Room
15 T2B3, 11545 Rockville Pike, at 8:30 a.m., Dr. Mario
16 Bonaca, Chairman, presiding.

17 COMMITTEE MEMBERS PRESENT:

18 MARIO V. BONACA, Chair

19 SAID ABDEL-KHALIK, Vice Chair

20 J. SAM ARMIJO, Member-at-Large

21 GEORGE E. APOSTOLAKIS

22 SANJOY BANERJEE

23 DENNIS C. BLEY

24 CHARLES H. BROWN, JR.

25 MICHAEL CORRADINI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 COMMITTEE MEMBERS PRESENT: (cont)

2 OTTO L. MAYNARD

3 DANA A. POWERS

4 HAROLD B. RAY

5 MICHAEL T. RYAN

6 WILLIAM J. SHACK

7 JOHN D. SIEBER

8 JOHN W. STETKAR

9
10 NRC STAFF PRESENT:

11 SAM DURAISWAMY, Designated Federal Official

12 TOM KEVERN

13 AMY CUBBAGE

14 MARK McBRIDE

15 WEIJUN WANG

16 TOM SCARBROUGH

17 LARRY WHEELER

18 NEIL RAY

19 GEORGE GEORGIEV

20 JERRY WILSON

21 SAMSON LEE

22 GLENN MEYER

23 DAVE PELTON

24 EMMA WONG

25 DAVID BEAULIEU

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 NRC STAFF PRESENT: (cont)

2 TIM MCGINTY

3 CHRISTOPHER BOYD

4 TIM LUPOLD

5 LOUISE LUND

6 HANS ASHER

7 TIM O'HARA

8 KAMAL MANOLY

9

10 ALSO PRESENT:

11 MARVIN SMITH

12 GINA BORSH

13 GEOFF QUINN

14 DOUG KEMP

15 JOHN KRAIS

16 DAVE FLYTE

17 DALE ROTH

18 DAN MILLER

19 CHRIS HOFFMAN

20 MIKE GALLAGHER

21 JOHN O'ROURKE

22 CLARENCE MILLER

23 PETE TAMBURRO

24 STAN TANG

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

I-N-D-E-X

<u>Opening Remarks by the ACRS Chairman</u>	6
<u>Combined License Application for North Anna, Unit 3</u>	
Marvin Smith (Applicant)	10
Tom Kevern (NRC)	13
2.4 Hydrology	
Gina Borsh (Applicant)	29
Mark McBride (NRC)	37
2.5 Geology	
Gina Borsh (Applicant)	42
Weijun Wang (NRC)	50
Chapter 3	
Tom Scarbrough (NRC)	54
RAI Updates	
Gina Borsh (Applicant)	61
Larry Wheeler (NRC)	75
Tom Kevern (NRC)	83
<u>License Renewal Application and Final SER for the</u>	
<u>Susquehanna Steam Electric Station, Units 1 and 2</u>	
Briefing by the Applicant	
John Kraiss	95
Dave Flyte	97
Dale Roth	108
Briefing by the NRC Staff	

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

Evelyn Gettys.....120

Steam Generator Action Plan, Task 3.5

Mr. Powers.....131

Tim McGinty.....135

Dave Beaulieu.....137

Christopher Boyd.....147

Oyster Creek 3-Dimensional Drywell Analysis

Mr. Arimjo.....248

Samson Lee.....250

Mike Gallagher.....251

John O'Rourke.....256

Clarence Miller.....269

Adjourn

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:28 a.m.

CHAIR BONACA: Good morning. The meeting will now come to order. This is the first day of the 566th Meeting of the Advisory Committee on Reactor Safeguards. During today's meeting the committee will consider the following: Combined License Application for North Anna, Unit 3, Economic Simplified Boiling Water Reactor (ESBWR) and the Draft Safety Evaluation Report with Open Items; License Renewal Application and Final Safety Evaluation Report for the Susquehanna Steam Electric Station, Units 1 and 2; Steam Generator Action Plan Task 3.5, A Risk Assessment of Consequential Steam Generator Tube Ruptures, and other SGAP items; Oyster Creek 3-dimensional structural analysis of the drywell shell; Preparation of ACRS reports.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act. Mr. Sam Duraiswamy is the designated federal official for the initial portion of the meeting. We have received no written comments or requests for time to make oral statements from members of the public regarding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 today's session. There will be several people on
2 the phone bridge line to listen to the discussion
3 regarding the North Anna COL application and the
4 Susquehanna new license renewal application. To
5 preclude interruption of the meeting the phone
6 will be placed in a listening mode during the
7 presentations and committee discussions. A
8 transcript of portions of the meeting is being
9 kept and it is requested of the speakers, use one
10 of the microphones, identify themselves and speak
11 with sufficient clarity and volume so that they
12 can be readily heard.

13 I will begin with the items of current
14 interest. On behalf of the committee I would like
15 to thank everyone involved in the completed
16 construction-related work in the conference room
17 in a timely manner so as to hold our meeting in
18 this very comfortable room. There was - up to the
19 last minute we didn't know if we could have the
20 meeting here rather than in the commissioner's
21 room. So I would like to introduce John Lai.
22 Okay. A risk analyst who's on rotation to the
23 ACRS staff from the Office of New Reactors. In
24 New Reactor he was reviewing the ESBWR, the CPRA
25 and COL application for North Anna, Fermi and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 South Texas bridge project. Prior to joining NRC
2 in May 2006 he worked at Public Service Electric &
3 Gas Company as a probabilistic assessment engineer
4 since 1995. His other employment includes working
5 at PSEG Nuclear as a nuclear fuel engineer,
6 Solombra Company as a lead engineer and Brookhaven
7 National Laboratory as a research associate. He
8 has 30 years of experience working in the nuclear
9 area. He holds a BS in Nuclear Engineering from
10 Tsing Hua University in Taiwan, an MS in Nuclear
11 Engineering from the University of Cincinnati, and
12 a Ph.D. from Drexel University in Mechanical
13 Engineering. Welcome aboard.

14 (Applause)

15 CHAIR BONACA: With that we are done
16 for the introductions and I think we should move
17 to the next item on the agenda which is the
18 combined license application for North Anna, Unit
19 3, Economic Simplified Boiling Water Reactor and
20 the Draft Safety Evaluation Report with Open
21 Items. And I turn to Dr. Corradini.

22 MEMBER CORRADINI: Thank you, Mr.
23 Chairman. So today we have a presentation by the
24 staff and the applicant for the first COL of I
25 assume a few others coming down the road. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 references the ESBWR. Many of you have - either
2 are part of the subcommittee for the ESBWR or have
3 attended in a rotating fashion. I guess I want to
4 frame this. Tom Kevern will lead us off, but
5 before I turn to Tom let me just frame this. The
6 one thing that I want to put kind of as an
7 undertone here is that we're running essentially
8 two parallel efforts. One is to essentially
9 finish the design certification. We now have
10 issued a number of interim letters and the staff
11 is coming back to close out open items with
12 General Electric Hitachi. Simultaneously we have
13 started the COL. So what we're going to hear
14 today from the staff and the applicant, that is
15 Dominion, is the COL application and open items
16 and issues relative to the site at North Anna,
17 rather than generic issues relative to the ESBWR.

18 So I welcome your questions, but I will be -
19 since we have limited time I will be fairly quick
20 to point out when something's generic, and we'll
21 log it, and we'll see you in middle October or
22 middle November for our fun subcommittee meetings
23 for ESBWR. But I think we ought to stay on track
24 relative to things related to North Anna. So with
25 that I'll turn it to Tom.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KEVERN: Thank you. Good morning.
2 My name is Tom Kevern. I'm the lead project
3 manager for North Anna. With me is Janelle
4 Jessie, another North Anna project manager. On
5 behalf of the staff we appreciate the opportunity
6 to meet with the full committee this morning. We
7 have a rather full agenda you see on the slide.
8 We're going to have presentations by several of
9 the members of the staff as well as
10 representatives from Dominion. So in the interest
11 of time, rather than going through introductions
12 now I'll defer that until we're doing the
13 respective presentations and just start right in
14 with the first presentation and that is the
15 overview by Dominion. And I'd like to introduce
16 Marvin Smith who's the project director for
17 Dominion North Anna.

18 MR. SMITH: Good morning. I'm Marvin
19 Smith as Tom indicated and I'd like to - next
20 slide please, thank you. This is certainly not
21 the first time that we've been here. North Anna
22 3, our process started some time ago with the
23 filing of an early site permit application in 2003
24 as indicated here. Our ESP was issued and our COL
25 application filed on the same day in November of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2007. So as indicated earlier, the focus here
2 today is on the North Anna site and the interface
3 with ESBWR and not on the generic issues
4 associated with that. And the North Anna COL is
5 also interesting in that it is, as indicated here,
6 one that referenced an approved early site permit
7 when it was filed. So many of the siting issues
8 associated with North Anna were considered
9 previously as part of that early site permit
10 process. The draft actual supplemental EIS was
11 issued in 2008 and we submitted COLA Revision 1 in
12 December of 2008 as well. So this application has
13 been under consideration now for some time.

14 We've had several subcommittee
15 meetings and we've I think been here for four
16 different days, three different meetings with the
17 subcommittee and we certainly appreciate the
18 thorough review that you've given. So as you can
19 see this shows where we covered various chapters
20 of the COL application during those meetings.
21 North Anna Power Station currently has two
22 operating units, Units 1 and 2. Those are both
23 Westinghouse-designed PWR units. The site is
24 located in central Virginia. It's approximately
25 35 miles northwest of the city of Richmond and as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I say, it has been the subject of the early site
2 permit investigation that was already completed.
3 The North Anna Units 1 and 2 and the proposed Unit
4 3 are located on the North Anna Power Station
5 site. And Lake Anna, that's the cooling water for
6 source for Units 1 and 2. Unit 3, however, will
7 not use the lake for cooling other than as - the
8 only use of the lake for Unit 3 would be as makeup
9 water to the cooling circulating water system.
10 North Anna - Lake Anna is also not used for Unit 3
11 in any safety-related manner.

12 As shown on this slide, the proposed
13 Unit 3 is located to the west and slightly south
14 of where the Units 1 and 2 are. As you can see,
15 it's oriented in such a way that the rotating
16 turbine is not in the direction that would
17 potentially send anything towards Units 1 and 2.
18 We have a proposed cooling system that's shown in
19 the figure here. It's actually a hybrid
20 circulating water cooling system that's partially
21 wet, partially dry and we did that in order to
22 minimize the water consumption associated with the
23 operation of Unit 3. So we've been through quite
24 a lot of environmental work to look at this site,
25 again, beginning with the early site permit and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then continuing through the COL application. So
2 if there are any general questions I'd be happy to
3 address them. Thank you.

4 MR. KEVERN: Okay, thank you Marv.
5 Next I'll be doing an overview from the staff's
6 perspective. As you can see on this slide, we
7 completed the Safety Evaluation Report with open
8 items. That consists of the standard 19 chapters
9 plus the applicable appendices. That was
10 transmitted to ACRS by a memorandum from the
11 Office of New Reactors early August and it is
12 publicly available. And the ADAMS accession
13 number you see there in the slide provides access
14 to that through ADAMS on the public availability.

15 The application as Marv mentioned not
16 only incorporates by reference the DCD Revision 5
17 and also the early site permit, but also it
18 included acceptable responses to most of the
19 staff's requests for additional information that
20 were issued up to November of last year. So on
21 the schedule we had, what we call Phase I, our
22 initial review and issuance of requests for
23 additional information. That occurred from the
24 November 2007 to roughly November 2008 timeframe.
25 The Revision 1 of the application came in in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 December. That incorporated - or I'm sorry,
2 acceptable responses to the majority of those
3 RAIs. So then after that timeframe we had another
4 10 months of additional review, follow-up from the
5 original RAIs as well as the content of that
6 Revision 1 of the application.

7 The meetings that Marv mentioned, I'd
8 like to emphasize that those subcommittee meetings
9 in June, July and August were focused solely on
10 the North Anna review as just emphasis of what Dr.
11 Corradini said earlier. There are separate
12 subcommittee meetings that have been and are being
13 and will be conducted associated with the design
14 certification review, but those meetings and the
15 content of those meetings has focused solely on
16 the North Anna COL application, our evaluation,
17 the staff's evaluation of that application.

18 Significant point here at the bottom
19 of the slide. There were no significant issues
20 identified in those four days of meetings. There
21 were of course a number of questions and comments
22 from all members of the subcommittee I guess I'd
23 say, and those questions and comments were
24 addressed either during a meeting by the staff or
25 by Dominion as appropriate. In several cases we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 had written responses the staff provided to
2 clarify information and then some of the issues,
3 as Dr. Corradini alluded to, were determined to be
4 more appropriate for actual design certification
5 issues and part of the generic design rather than
6 specifically applicable to the North Anna COL
7 application. So that gives us a history and that
8 brings us up to today and today's presentation.

9 So then around to subcommittee
10 meetings and today we're going to focus on three
11 different - actually four different topics: an
12 update of the open items that the staff has at
13 this point in time. It'll be a snapshot as of
14 today. We're going to be discussing several
15 selected site characteristics that will illustrate
16 the relationship between the COL application and
17 the design certification document and the early
18 site permit. We'll discuss several selected site-
19 specific systems that will illustrate again the
20 relationship between the COL application and the
21 DCD. And then we're going to provide clarifying
22 and updated information to address several of the
23 inquiries that the subcommittee members identified
24 during the meetings in June, July and August.

25 For the technical presentation today

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're going to follow the format of first it'll be
2 Dominion speaking and addressing the content of
3 the FSAR, and then the staff speaking and
4 addressing our evaluation of that part of the
5 FSAR. And then last and not least I want to
6 reiterate what Dr. Corradini said. We appreciate
7 the opportunity to be first. So far it's been a
8 challenging experience that I hope it continues
9 this morning with no pitfalls or miscommunications
10 among us and that we're having a good meeting as
11 we move on. So that concludes the overview from
12 the staff's perspective. Any questions, comments
13 before we start the more meat of the
14 presentations?

15 All right, so moving on. I'll
16 continue to talk. The first topic we have is an
17 update of the open items. First bullet on the
18 page identifies the one significant open item we
19 have relative to the North Anna review and that is
20 the staff's evaluation of the ESBWR design
21 certification. That evaluation is not yet
22 complete, again reiterating what Dr. Corradini
23 said in his opening comments. And as we all know
24 when we are implementing the Part 52 process the
25 staff cannot finalize the North Anna safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluation until the staff has finalized the
2 evaluation for design certification. So for
3 administrative convenience - we acknowledge that
4 of course, but then for administrative convenience
5 we identify that as Open item 1-1 in Chapter 1 of
6 our Safety Evaluation Report and then cross-
7 referenced throughout the remaining 19 chapters to
8 that single open item. So that one open item is
9 the meat if you will, it's the big-ticket item and
10 you'll see it just listed once rather than
11 numerous times. And I believe that's the protocol
12 that all of the rest of the design centers are
13 going to follow. So it makes it more
14 administratively convenient than getting bogged
15 down with a multitude of open items and RAIs.

16 Moving on to the specific RAIs. The
17 staff documents and tracks our requests for
18 additional information in our electronic RAI
19 database. And what you see on the next slide is a
20 download from that database. It identifies the
21 open items, open RAIs for North Anna up to this
22 point in time. And on the slide it looks - the
23 font's a little small, but that is the best I
24 could do to get all of the RAIs listed. The ACRS
25 members have a full-size page in your handout and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the rest of the attendees, if you go to the back
2 page of your handout you'll see a full-size page
3 there listing that puts it in a more legible or a
4 more readable format.

5 I'll make a couple points. These open
6 RAIs are a snapshot at this point in time. They
7 do not reflect significant challenges and actually
8 from the staff's point of view, our perspective is
9 that all of the open RAIs are on a path toward
10 resolution. Several of the RAIs are going to be
11 addressed in the respective technical
12 presentations this morning, those associated with
13 Section 2.4 Hydrology, 2.5, 3.9, 3.11 and 9.2
14 Plant Service Water are all going to be addressed
15 in technical presentations and I want to just
16 comment on a few of the others. In SAR Section
17 5.3.2 dealing with pressure temperature limits.
18 We currently have seven open RAIs and those - the
19 sum in there is a little bit disproportionate
20 considering the total number of RAIs that are
21 open. I want to tell you why. That's because we
22 just had a recent submittal back in mid-June from
23 the applicant on this topic that is a supplement
24 to their application. Staff reviewed that just
25 recently and issued RAIs. Seven is the sum total

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you can see on that subject from the staff and
2 that pressure temperature report was something
3 that was discussed in a subcommittee meeting with
4 either Kurt or - and Kurt's copy to ACRS and
5 that's why I wanted to bring that up as a current
6 status.

7 In 13.3 Emergency Planning, FEMA,
8 external to the review that the staff does for
9 offsite emergency planning, FEMA has identified
10 multiple RAIs as part of their review that are
11 currently being addressed by the applicable
12 offsite entities with support from Dominion as a
13 result of those RAIs.

14 MEMBER CORRADINI: Are we going to get
15 back to those later today? I was looking.

16 MR. KEVERN: No, sir.

17 MEMBER CORRADINI: Okay. So let me
18 ask a question here. So, how does - what's the
19 process there? Are you guys - is the staff
20 working as kind of - I'm trying to find the right
21 word here - facilitators between FEMA and the
22 applicant to identify significance of these
23 issues, or is it basically the applicant and FEMA
24 are working this out and you're observers to the
25 process? How does that work with these?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KEVERN: Short answer is the
2 latter.

3 MEMBER CORRADINI: Okay.

4 MR. KEVERN: We're observing. You
5 recognize as -

6 MEMBER CORRADINI: So in that role,
7 are you seeing any issues there that are going to
8 be a problem, or is it a matter of clarification
9 of what - matter of clarification of what the
10 applicant is presenting and FEMA is asking?

11 MR. KEVERN: It's closer to the
12 latter, but I would not say they're insignificant.
13 I mean, it requires some work for updating,
14 clarifying content of the plans and procedures
15 that FEMA thinks appropriate for implementing
16 their emergency planning requirement. But it is -
17 in fact, I'll give Dominion an opportunity to
18 speak. As far as we know it's on schedule,
19 they're on schedule to be completed and resolved
20 by the end of this month.

21 MEMBER CORRADINI: So there's a path
22 to resolution I guess is maybe the way to ask
23 this?

24 MR. SMITH: Yes, there is.

25 MS. BORSH: Right, they're - I'm Gina

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Borsh from Dominion. There are - we've had
2 meetings with FEMA and the Commonwealth and
3 Dominion because of the RAIs obviously are really
4 associated with the Commonwealth's work and their
5 plans. So we have a path forward to answer all of
6 them and we are on schedule for completing the
7 work in October.

8 MEMBER CORRADINI: Okay, thank you.

9 MEMBER MAYNARD: Are you having to do
10 things differently from emergency planning-wise
11 for the ESBWR than you are for the other plants
12 there?

13 MS. BORSH: Generally, no. Most of
14 the questions that we got were clarification -
15 from FEMA were clarifications. Are you talking
16 about the FEMA RAIs or are you talking about
17 Dominion's plan?

18 MEMBER MAYNARD: Well yes, with FEMA,
19 yes.

20 MS. BORSH: Yes. Most of them were
21 clarifications and resolving some inconsistencies
22 between the high-level plan and the procedures.
23 But let me just check and see if our subject
24 matter expert is on the line.

25 MR. KEVERN: Let me clarify part of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that. From the staff's perspective, the way the
2 technical staff has explained it to me, let me see
3 if this answers the question, sir. As part of the
4 - the answer is no, nothing additional, but as
5 part of FEMA's looking at the new COL application,
6 they did an in-depth review of everything
7 associated with emergency planning around the
8 site. And in the process of that review they
9 found - trying to be tactful on this - they found
10 some items that were not meeting their
11 expectations that and that were not identified
12 previously during exercises or during other
13 evaluations. Because this is the first time FEMA
14 had done that level of an in-depth review of
15 everything related to offsite planning in the last
16 several decades.

17 MEMBER MAYNARD: Okay. So it's not
18 just unique to the ESBWR design. Okay.

19 MEMBER CORRADINI: Thank you. Go
20 ahead, sir.

21 MR. KEVERN: Then in 13.6 related to
22 security the staff is just in the middle of their
23 ongoing review in the security area and there are
24 multiple RAIs that have been and are being
25 generated by the staff in that security area, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 just - it lists all of those.

2 VICE CHAIR ABDEL-KHALIK: Back to the
3 FEMA interface. At the end of the day NRC is the
4 agency that approves this application.

5 MR. KEVERN: Correct.

6 VICE CHAIR ABDEL-KHALIK: So, in your
7 role as an observer of the interaction between
8 FEMA and the applicant, at the end of the day are
9 you just going to take their word that whatever
10 has been done and agreed to is acceptable to you?

11 MR. KEVERN: FEMA is the lead for
12 offsite planning from a federal oversight
13 perspective. They - FEMA provides a detailed
14 report to the NRC. NRC takes that report and that
15 information provided by FEMA as input for the
16 staff's determination of the adequacy of emergency
17 planning, and then as part of -

18 VICE CHAIR ABDEL-KHALIK: Let's go to
19 the heart of my question.

20 MR. KEVERN: What is it?

21 VICE CHAIR ABDEL-KHALIK: What level
22 of detail in terms of review does the staff add to
23 this process after FEMA issues its report?

24 MR. KEVERN: We do not re-evaluate
25 FEMA. What we do have, though, are an extensive

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 number of inspection tests analysis and acceptance
2 criteria, ITAAC, that occur after a license is
3 issued and before the plan is authorized to do
4 power operation that involve exercises with
5 extensive objectives, both onsite and offsite
6 activities. Is that sufficient or do you want
7 more detail? I have a member of the staff here,
8 but I was not -

9 VICE CHAIR ABDEL-KHALIK: I think
10 that's sufficient for the moment. Thank you.

11 MR. KEVERN: Okay. Then moving down,
12 the second to the last bullet on the previous
13 slide there, talking about Chapter 16. This is
14 the technical specifications. The staff issued
15 one multifaceted RAI that pertained to finalizing
16 the completed plant-specific detail specifications
17 and parts of that RAI are yet to be completed.
18 And this also ties back into the information and
19 the updated design certification document for
20 ESBWR. And then the last item, again, it's a
21 note, a follow-on to a previous subcommittee
22 meeting on turbine missile probability analysis.
23 The applicant recently provided a submittal, late
24 July. We provided a courtesy copy to the ACRS
25 members at their request and there were a number

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of inquiries back in the last subcommittee
2 meeting. The staff is just starting its review of
3 that topic and the, I won't say likely, maybe,
4 whatever term you want to use, RAIs pertaining to
5 that. And we'll have that process completed over
6 the next several months.

7 MEMBER STETKAR: Tom, for
8 clarification, will those RAIs be issued under the
9 COL, or is that - I thought that we were told that
10 that turbine missile analysis was folding over
11 into the DCD? Is that true, or is it actually the
12 COL applicant's responsibility now?

13 MR. KEVERN: It is the - let's see if
14 I can clarify this. It is a little confusing. It
15 is a document that was prepared by GEH. It was
16 submitted as part of a COL item in the North Anna
17 COL application and so we are reviewing it as part
18 of the COL application.

19 MEMBER CORRADINI: And the reason is
20 because of the geometrical arrangement? I guess I
21 - is it that? Because I know it was partly a
22 material - an estimation of the jet missile
23 generation and also the effect. So is it just
24 because the history of how it came to here that
25 it's not generic and back with the DCD? That's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what I'm - I think John's -

2 MEMBER STETKAR: Well, the reason I
3 ask is when we brought up the question in the
4 subcommittee meeting, several of the questions
5 that we had related to their treatment of the
6 turbine protection and control system reliability.

7 There are also materials issues and at that time
8 it was my understanding we were told, well, that's
9 going to be resolved, it's a generic design issue,
10 it's not part of the COL applicant. So we sort of
11 dropped the line of questioning at that time.

12 MR. KEVERN: Well, that may be true,
13 but it is a GEH turbine. But there is a COL item
14 identified in the COL application that this - the
15 submittal of this document addresses that COL -
16 meets that, satisfies that COL commitment. So we
17 are currently reviewing it under North Anna
18 application.

19 MEMBER STETKAR: I guess the question
20 is is GEH going to - I mean, is every COL
21 applicant going to submit precisely the same
22 document? No one responds to their commitment.

23 MEMBER CORRADINI: I guess that's a
24 process question that maybe we can address later.
25 But I mean, my thinking would be if they take it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on now and get it cleared up I would R-COLA it, go
2 back to the DCD and get cleared up generically so
3 no other applicant has to deal with it.

4 MS. CUBBAGE: This is Amy Cubbage, the
5 design cert project manager with NRL. It's not
6 planned to come into the design certification. If
7 a subsequent COL applicant chose to follow the
8 same approach as the reference COLA, then we've
9 done one review and we've completed that review.
10 If they chose to deviate from what the reference
11 COLA did then we would have to review that
12 applicant's report. And it just happens that this
13 report that's being provided by Dominion was
14 prepared by GE Hitachi, but it's not part of the
15 design certification review.

16 MEMBER CORRADINI: Amy, just for our
17 clarification. And that's because it's part of
18 the secondary system that could be different with
19 every - is that the point I guess I'm trying - I
20 think we're still trying to understand how it fell
21 where it did.

22 MS. CUBBAGE: I think we'd have to ask
23 the applicants why they chose to do this on a COL-
24 specific basis, but it was identified as a COL
25 action item in the DCD, therefore it's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 responsibility of the COL applicant.

2 MEMBER CORRADINI: Okay. Is that
3 enough for now, John?

4 MEMBER STETKAR: I guess that's enough
5 for now, yes.

6 MEMBER CORRADINI: All right, thank
7 you.

8 MR. KEVERN: All right. Sorry I
9 couldn't make that more clear. I hate to ask are
10 there other questions? That's the end of the
11 discussion I was planning on presenting on
12 requests for additional information.

13 MS. CUBBAGE: I guess what I will
14 offer, Tom, is that if there was confusion at the
15 time of the subcommittee on the scope and where
16 this review is going to take place, so the ACRS
17 didn't get to fully vet your questions on this
18 report that had recently been submitted. So you
19 know, those questions could come at the next
20 phase. You haven't seen an evaluation yet of this
21 report. And you will.

22 MEMBER STETKAR: That's correct.
23 Okay, thank you.

24 MR. KEVERN: Let me just follow on to
25 what Amy said. The next - it moves into the last

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 slide, but the next phase of our review, Phase IV,
2 is after we finish the ACRS discussions then we
3 move into the next part which is our review in the
4 final safety evaluation report with no open items.

5 So as part of that review process then we come
6 back to ACRS. So if we come back and say we have
7 no open items, you say oh wait a minute, why then
8 we're back into the second round of meetings.

9 MEMBER CORRADINI: Okay.

10 MR. KEVERN: All right, so moving
11 along, that ends the discussion on open items and
12 the next topic is Section 2.4 Hydrology. Starting
13 the technical topics. And we will have first
14 Dominion and Gina Borsh with Dominion.

15 MS. BORSH: Okay. Thanks Tom. Good
16 morning. Before we get started on 2.4 I just
17 wanted to give you a little bit of an overview of
18 how we prepared our COLA. As Tom and Marvin said,
19 we incorporated the ESBWR DCD and the ESP
20 applications SSAR by reference, so those are
21 actually part of our FSAR content. Then we
22 supplemented the information in the DCD and the
23 SSAR from the ESP application to address the
24 remaining requirements and guidance that are
25 information that's required to be in our FSAR. So

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 most of the time the supplemental information that
2 we added was added to either address a COL item
3 that was in the DCD, a COL action item that was in
4 our ESP or an ESP permit condition. And then we
5 also added some actual design information for the
6 site-specific portions of systems that are going
7 to be included in the North Anna plant. And that
8 replaced the conceptual design information that is
9 in the DCD. And then finally we had supplemental
10 information that we added for various other
11 reasons. For example, Reg Guide 1.206 may have
12 had some additional guidance on what should be in
13 our FSAR and so we added information to address
14 that guidance.

15 Chapter 2 in the FSAR is about our
16 site characteristics. And as Tom said, we've
17 selected two topics from Chapter 2 to present to
18 you today to show you what kind of site-specific
19 information is in our FSAR. 2.4 is on hydrology,
20 2.5 is geology, seismology and geotechnical
21 engineering. Then we're going to talk about
22 specific inquiries that came up from the ACRS
23 members, the subcommittee members on makeup water
24 systems, circulating water and plant service
25 water.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In Chapter 2, just to give you a
2 little background, we provided a summary of the
3 comparisons that are related to the site features.

4 We compared Unit 3 FSAR site characteristics and
5 facility design values with the corresponding DCD,
6 ESP or ESP Application SSAR values to determine
7 if, one, the Unit 3 site characteristics fall
8 within the DCD's site parameters; two, if Unit 3
9 site characteristics or facility design fall
10 within the ESP site characteristics or design
11 parameters; and three, do the Unit 3 site
12 characteristics and design values fall within the
13 SSAR site characteristics and design parameter
14 values. That's all summarized up in 2.0 of the
15 FSAR. Then we go into detail in the different
16 sections to explain further what we summarized in
17 2.0 of the FSAR.

18 So for 2.4 I'm going to give you a
19 brief overview of what is in that section of our
20 FSAR. We incorporate the SSAR Section 2.4 by
21 reference and then we supplement it with a lot of
22 information. We added to address the DCD COL
23 item. We state that the layout of Unit 3 will
24 affect a few small wetlands and the upstream
25 portions of two intermittent streams that flow

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 into Lake Anna. No other natural drainage
2 features require changes to accommodate Unit 3.
3 We also specify the design plant grade for safety-
4 related structure systems and components which is
5 at elevation 290 feet. This provides over 22 feet
6 of freeboard above the design basis flooding
7 level. Local intense precipitation is discharged
8 to Lake Anna and we've located the safety-related
9 structures systems and components at elevations
10 that are above the maximum water surface elevation
11 that would be produced by local intense
12 precipitation.

13 The water supply to the alternate heat
14 sink is above the design plant grade elevation and
15 therefore it's capable of withstanding the
16 probable maximum flood on streams and rivers
17 without loss of the ultimate heat sink safety
18 functions. To address two ESP COL items, we
19 explain that the UHS for the passive design does
20 not use safety-related underground reservoirs or
21 storage basins. The UHS is in the reactor
22 building. So even if Lake Anna were to be drained
23 due to a dam failure, no safety-related structures
24 or systems for Unit 3 would be adversely affected.
25 We state that the emergency cooling water for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Unit 3 is provided from the UHS which isn't
2 affected by ice conditions. We also go on in
3 Section 2.4 to discuss ice impacts beyond the UHS.
4

5 To address an ESP COL item regarding
6 whether Lake Anna is used for safety-related water
7 withdrawals, we've included an explanation in the
8 FSAR that the UHS for Unit 3 has water in place
9 during Unit 3 operation for safety-related cooling
10 in the event that use of the UHS is required. So
11 as Marvin said, Lake Anna is not used for safety-
12 related water withdrawals for Unit 3.

13 Another ESP COL item in Section 2.4
14 requires us to address slope embankment protection
15 for the Unit 3 intake structure. We describe the
16 location of the intake structure, including the
17 fact that the embankment for the structure is
18 protected by rip-rap to prevent local runoff from
19 eroding the structure. We also note for the ESBWR
20 design the intake structure is not safety-related.

21 To address the DCD COL item, we performed a local
22 PMP flood analysis. The maximum PMP water level
23 in the power block area is 2.8 feet below the
24 design plant grade elevation for safety-related
25 facilities. Therefore, no safety-related

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 structure is subject to static or dynamic loading
2 due to flooding as a result of design basis flood
3 events or local PMP events.

4 To address another ESP COL item which
5 deals with low water conditions in Lake Anna we
6 added information to the FSAR to describe the two
7 operating modes for the circulating water system,
8 either energy conservation mode without the dry
9 cooling tower or maximum water conservation with
10 the dry cooling tower and hybrid cooling tower
11 operating in series.

12 In Section 2.4 we also provided
13 supplemental information based on additional
14 borings, groundwater level measurements and
15 hydraulic conductivity testing that was performed.

16 Specifically, we identified one variance from the
17 SSAR which we discussed in our last ACRS
18 subcommittee meeting. In Section 2.4 we also
19 provided supplemental information about
20 groundwater supply wells, groundwater use and the
21 groundwater level monitoring program. We
22 identified a variance involving the North Anna
23 water supply well information which is also
24 discussed with the ACRS subcommittee members.

25 The estimated maximum groundwater

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 level that can occur in the power block area is 7
2 feet below the design plant grade elevation of 290
3 feet. Therefore, we determined that a permanent
4 de-watering system is not required for safe
5 operation of Unit 3 because this more than
6 satisfies the DCD requirement that the maximum
7 groundwater elevation is at least two feet below
8 the design plant grade elevation.

9 MEMBER STETKAR: You know, we've had
10 some discussion about that at the subcommittee
11 meeting. I just, again, want to make sure that
12 I've got it straight in my mind. At that time I
13 understood that the lack of a need for a de-
14 watering system was now being considered as a DCD
15 item. Is that correct? That's part of the DCD
16 review now? The reason for concern for the
17 benefit of the other members of the committee who
18 weren't there is that although the maximum
19 groundwater level is 7 feet below plant grade,
20 it's about 40 feet above the basement of several
21 of the buildings. So it's not clear why a de-
22 watering system is not required. And when we
23 asked that, we were told that - that is a DCD
24 item?

25 MEMBER CORRADINI: The only other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing that I guess I remember from the
2 subcommittee, I have it written down somewhere,
3 but - was that safety grade equipment was not -
4 everything you said I think is correct except
5 safety equipment was not in those lower levels.
6 At least that was the implication I heard.

7 MEMBER STETKAR: It's the implication,
8 but there may be RTNSS equipment in these lower
9 levels. I'm not sure. We're just not sure.

10 MR. KEVERN: Right, and that is
11 something that's going to be addressed. The
12 question is going to be addressed in a
13 subcommittee meeting associated with the design
14 certifications. Amy?

15 MS. CUBBAGE: Right. That review was
16 part of the design certification and after the
17 subcommittee meeting we confirmed with GE and with
18 the DCD that the RTNSS equipment is also protected
19 and is not in these locations.

20 MEMBER STETKAR: Okay, thanks.

21 MS. BORSH: Okay? Going on to Slide
22 17. To address a DCD COL item and an ESP permit
23 condition we describe mitigating design features
24 that have been incorporated into the ESBWR
25 designed to preclude an accidental release of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 liquid effluents. To address a DCD COL item we
2 analyzed a postulated accidental release of
3 radioactive liquid effluents to the groundwater or
4 surface water at the Unit 3 site. We demonstrated
5 that the release complies with the 10 C.F.R. 20
6 limits for release to the unrestricted areas.
7 Finally, for Section 2.4 we state that Unit 3 will
8 shut down when the water level in Lake Anna drops
9 below elevation 242 feet mean sea level.

10 MEMBER CORRADINI: That's when we're
11 in an environment - just, again, to put my memory
12 straight - that's more environmental on the Lake
13 Anna side because you use it for makeup, is that
14 correct?

15 MS. BORSH: Yes, it has nothing to do
16 with safety. That's correct.

17 MEMBER CORRADINI: That's what I
18 thought. Okay.

19 MS. BORSH: And that's it for 2.4 so
20 I'll turn it over to Don.

21 MR. KEVERN: Thanks, Gina. Mark, come
22 on up. Okay, next we will have the staff's
23 perspective on Section 2.4 and Mark McBride with
24 the staff. Mark?

25 MR. MCBRIDE: Thank you. I'm again

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Mark McBride from the Hydrologic Engineering
2 Branch. Does not seem to be working. Good
3 morning again. I'm Mark McBride from the
4 Hydrologic Engineering Branch and I'm going to be
5 presenting an overview of our Safety Evaluation
6 Report Section 2.4, Hydrologic Engineering for
7 North Anna. Now Section 2.4 covers a wide range
8 of issues related to water and is relatively
9 large. I'm not going to talk about every topic
10 that we reviewed partly because Regina Borsh has
11 already touched on some of these topics, and also
12 because many are already resolved. Instead, I'm
13 going to primarily highlight areas where we're now
14 moving forward toward resolution. The staff
15 comprehensively reviewed the early site permit
16 with regard to Section 2.4. Aside from the open
17 items I'll discuss in a moment, a few significant
18 issues were identified. The six variances noted
19 here covered minor matters such as for example a
20 correction to the coordinate system that was used
21 in the drawings.

22 Two permit conditions are relevant to
23 Section 2.4. One permit condition, 3.E(2) was
24 determined to be inapplicable to Unit 3. This
25 condition had required dry cooling rather than

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water cooling for Unit 4, but Unit 4 will not be
2 built. The other condition, 3.E(3) required
3 special engineering features to preclude
4 accidental releases of radioactive liquid waste.
5 The staff concluded that the features proposed by
6 the applicant satisfied this permit condition.

7 The NCR addresses two different kinds
8 of flooding. The first is large-scale flooding
9 resulting from watershed-scale events, and second,
10 local flooding from locally intense precipitation.

11 Watershed-scale flooding was not found to be
12 problematic. There are, however, two open items
13 associated with locally intense precipitation.
14 I'll illustrate some of the features here that
15 bear on locally intense precipitation flooding. A
16 ditch called the South Ditch drains surface runoff
17 from the steep slope located on the south and
18 southeast sides of the new plant area. On the map
19 this ditch is emphasized in orange. There's also
20 a North Ditch on the opposite side of the plant.
21 The open items are associated with two particular
22 features of the South Ditch. First, the South
23 Ditch makes an abrupt bend to the northwest just
24 before it enters the storm water management basin.
25 That'll be on the right side of the figure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Second, an access road parallels the ditch and
2 this road also acts as a dyke that separates the
3 South Ditch from the existing Unit 2 area. Some
4 minor features affecting drainage are also
5 included in this review such as for example the
6 newly added ancillary diesel building off to the
7 left.

8 The issue of most immediate interest
9 is potential flooding near the Unit 3 nuclear
10 island. HEC-RAS modeling of the runoff indicated
11 that this is unlikely to be a problem.

12 MEMBER CORRADINI: What's that?

13 MR. MCBRIDE: Pardon?

14 MEMBER CORRADINI: Whatever you just
15 said, that's a computer model?

16 MR. MCBRIDE: HEC-RAS is a computer
17 model of surface runoff.

18 MEMBER CORRADINI: Okay, thank you.

19 MR. MCBRIDE: The two open items
20 address refinements to the HEC-RAS modeling of
21 runoff elsewhere in the site and related channel
22 maintenance. The first concerns updating the
23 modeling to show that the effects of minor changes
24 such as for example the newly added ancillary
25 diesel building and also ensuring that the South

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Ditch will function as described. Three RAIs now
2 under review concern the need to maintain the
3 channels in the same condition as they are
4 represented in the modeling. The second open item
5 addresses uncertainty that modeling will overtop
6 the access road and protecting the existing units.

7 One RAI requested further information on control
8 measures proposed to prevent overtopping.

9 Open Item 2.4.12-2 pertains to
10 groundwater. The underlying concern here is that
11 the DCD requires that groundwater must be more
12 than 2 feet below plant grade. The drainage
13 ditches described previously are also expected to
14 help maintain this condition by acting as drains
15 for groundwater and the open item concerns
16 evaluating their effectiveness for that function.

17 One RAI requested further information to support
18 the conclusion that groundwater levels will be
19 below the DCD design level in the power block
20 area.

21 Open Item 2.4.13-4 concerns accidental
22 releases of radioactive liquid effluents and the
23 transport of radionuclides in groundwater. Staff
24 wants to verify that the transport analysis is a
25 bounding analysis. However, the applicant's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis did not use site-specific values for all
2 parameters and did not always use the maximum or
3 minimum value measured. An RAI has been issued
4 requesting a bounding transport analysis using the
5 maximum hydraulic activity and minimum K_d values
6 observed onsite in the analysis. Now I'd like to
7 invite any questions about hydraulic engineering
8 issues that we've presented here.

9 MEMBER CORRADINI: Questions?

10 MR. KEVERN: All right, thank you very
11 much. And the next topic moving along on the
12 agenda is Section 2.5 Geology, Seismology and
13 Geotechnical Engineering. Follow the same format.

14 We'll start with a presentation by Dominion
15 followed by the staff's perspective on that topic.

16 Gina?

17 MS. BORSH: All right. In Section 2.4
18 - I mean, I'm sorry 2.5, like in 2.4, we
19 incorporated SSAR Section 2.5 and we added
20 supplemental information. The first bullet on
21 this side explains that we collected additional
22 borings for Unit 3 beyond those obtained for the
23 ESP to further describe the site's stratigraphy.
24 To address an ESP permit condition we commit to
25 excavating weathered or fractured rock at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 foundation level for safety-related structures and
2 replacing it with lean concrete before
3 constructing the foundation. To address another
4 ESP permit condition we commit to geologically
5 mapping future excavations for safety-related
6 structures and evaluating any other perceived
7 geological features that we may encounter.

8 We go on to state that the Unit 3
9 operating basis earthquake ground motion is one-
10 third of the foundation input response vector, or
11 FIRS, and is bounded by the DCD's operating basis
12 earthquake. In the excavation backfill subsection
13 of Section 2.5.4 we describe the seismic category
14 once excavation fills and slopes. We discuss the
15 excavation methods in relation to the stability of
16 the excavation and we identify the sources and
17 quantities of the backfill that we plan to use.
18 We provide the compaction criteria for backfill
19 and we describe the QC requirements that will be
20 applied to backfill. To respond to a DCD COL item
21 and an ESP COL item we provide the shear wave
22 velocity profiles for the soil which we use to
23 perform the liquefaction analysis and the slope
24 stability analysis. So right here we just want to
25 note that the shear wave velocity profiles that we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 developed for Unit 3 are used in the slope
2 stability analysis and the liquefaction analysis
3 which are coming up in later slides. Also, the
4 only seismic Category 1 structure that will be
5 founded on compacted structural fill is the
6 firewater storage complex. The primary source of
7 the fill is the bedrock that we're going to be
8 excavating to construct the Unit 3 power block
9 because the fill will be obtained from the new
10 plant excavation. We weren't able to use measured
11 shear wave velocities for this fill so we used
12 estimates to obtain the shear wave velocity
13 profile for the analyses.

14 Section 2.5.4 includes a discussion of
15 the potential for liquefaction. We looked at the
16 material at North Anna and we determined that the
17 only material that requires analysis is the Zone
18 IIA saprolitic soil. The analysis determined that
19 the chances of liquefaction occurring in the Zone
20 IIA saprolite are extremely low. We also
21 determined that if any liquefaction were to occur
22 it would not impact the stability of any seismic
23 Category 1 structure or any seismic Category 2
24 structure.

25 In Section 2.5 we cover foundation and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 slope stability. This includes an analysis of
2 bearing capacity. We determined that the reliable
3 bearing capacity values are adequate for seismic
4 Category 1 and 2 structures and for the rad waste
5 building. We also performed a settlement analysis
6 and determined that the total and differential
7 settlement values are well within the DCD limits
8 for seismic Category 1 structures. Information
9 about the static and seismic lateral earth
10 pressures is also provided.

11 MEMBER BROWN: Let me ask a question.

12 You made a statement on the previous page
13 relative to you made estimates because you didn't
14 have any other data.

15 MS. BORSH: Yes. For the soil that
16 will be under the -

17 MEMBER BROWN: I'm an electrical guy
18 so you're going to have to talk way down to me.
19 It was something, was it the SWV profiles?

20 MS. BORSH: Sheer wave velocity.

21 MEMBER BROWN: Is that where you made
22 the estimates?

23 MS. BORSH: Yes.

24 MEMBER BROWN: Okay. You used a term
25 that I - if you made estimate where do you -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 because there wasn't any data, where do you get
2 them? Is there a standard set of stuff that
3 everybody agrees to? It may be an ignorant
4 question, but.

5 MS. BORSH: No and actually we did
6 describe it in the FSAR about how we created that
7 profile. And if you'd like we can ask our subject
8 matter expert to -

9 MEMBER BROWN: I just wanted to know
10 that there was some basis for getting there.

11 MS. BORSH: It is described in detail
12 in the FSAR.

13 MEMBER BROWN: Okay.

14 MS. BORSH: In 2.5.4.

15 MEMBER BROWN: That's all I need.

16 MS. BORSH: You're welcome. All
17 right. And then finally on Section 2.5 we
18 provided the slope stability analysis. We
19 describe the Unit 3 slopes, we discuss the impact
20 of slope instability, we provide slope
21 characteristics, we summarize the design criteria
22 and analysis and provide the boring logs. And
23 that's all I have for 2.5. Very high-level
24 summary. Yes?

25 MEMBER RYAN: Just a question that may

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tie a little bit of geotechnical engineering back
2 to hydrology. After it's all said and done, do
3 you have an idea at this point how you're going to
4 be able to identify any sources of contamination
5 with regard to, say, the first two units versus
6 the third? Have you factored, you know, the
7 factor co-located into your groundwater monitoring
8 plant.

9 MS. BORSH: Well, we've done two
10 different analyses. One analysis is just for
11 releases from Unit 3 and then we've also done an
12 analysis that - for releases from all three units
13 to make sure that we're meeting the regulatory
14 limits.

15 MEMBER RYAN: That's the compliance
16 part, but my question's not that. My question is
17 how do you know that you're monitoring in the
18 right place so that you know where stuff's coming
19 from.

20 MS. BORSH: Oh I would have to leave
21 that with the subject matter expert.

22 MR. SMITH: Units 1 and 2 are down-
23 slope, if you will, from Unit 3.

24 MEMBER RYAN: Are you going to verify
25 that after construction, that it stays the same?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I don't know your site well enough to know whether
2 it will or won't, but that's always a question to
3 put through.

4 MR. SMITH: We can get one of our
5 subject matter experts to answer that question in
6 detail, but the elevation of Unit 3 is
7 considerably higher than the elevation of Units 1
8 and 2 and it's further away from the lake. So the
9 flow of water is basically away from Unit 3
10 towards Units 1 and 2 so.

11 MEMBER RYAN: How much is that
12 elevation difference? In terms of feet?

13 MR. SMITH: It's approximately 20
14 feet.

15 MEMBER RYAN: Twenty feet? That helps
16 a lot. Okay, thanks. Actually, if you could get
17 a more complete answer that'd be helpful.

18 MEMBER CORRADINI: Why don't you log
19 that and lets get back to it.

20 MEMBER RYAN: Absolutely.

21 MEMBER CORRADINI: I'm not even sure
22 if the bridge line is allowable to talk in. I
23 guess we're having problems. They can hear but
24 they can't speak for the moment, so if you just
25 log it in we'll get back to it. Jack?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Does the construction
2 of Unit 3 and the features that you've added have
3 any negative impact on Units 1 and 2?

4 MR. SMITH: That's certainly something
5 we evaluated to be sure that it would not and Unit
6 3 is located relatively far away from Units 1 and
7 2 as well. They're not that close together.

8 MEMBER SIEBER: Could you tell me
9 briefly what kinds of things you evaluated to be
10 able to assure yourself that Units 1 and 2 will
11 not be affected by hydrology, for example?

12 MR. SMITH: The concern with a local
13 intense precipitation was evaluated for potential
14 impacts on Units 1 and 2. We just generally
15 looked at for example the orientation of the
16 turbine so that it would not potentially impact
17 Units 1 and 2.

18 MEMBER SIEBER: All right.

19 MEMBER CORRADINI: Other questions?

20 MEMBER ARMIJO: A quick one. I'm not
21 familiar with saprolite, I don't know what that
22 is, but you conclude that it will not contribute
23 to liquefaction or be a source of liquefaction.
24 What is that soil and why is - what's the basis
25 for your conclusion? Some property that you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 measure, or is that commonly known?

2 MS. BORSH: Jeff, we're going to have
3 to ask John about that. Or if he can't -

4 MEMBER CORRADINI: We'll try. I was
5 told that they can hear but they can't speak back
6 in. Try it.

7 MS. BORSH: John Davy?

8 MEMBER CORRADINI: Yes, I don't think
9 we - we've lost that.

10 MR. QUINN: Let me just say that for
11 the safety-related structures the saprolite will
12 all be removed. We're going down to the bedrock.

13 MEMBER ARMIJO: So what's the problem.
14 Liquefaction is not there.

15 MEMBER SIEBER: It measures
16 liquefaction capability in soils, right?

17 MR. QUINN: Yes, sir.

18 MR. SMITH: None of the saprolite will
19 be allowed to remain under any safety-related
20 structure.

21 MEMBER CORRADINI: All right. Let's
22 move on then to the staff's review.

23 MR. WANG: Good morning. My name is
24 Weijun Wang. I'm a geotechnical engineer at the
25 NRC. I'm going to present about safety evaluation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 2.5. The Section 2.5 about geology,
2 seismology and geotechnical engineering. Because
3 Gina Borsh from Dominion already described how the
4 applicants address all the COL items and the ESP
5 permit conditions and the variations. So I just
6 give a brief summary of staff's review. There are
7 five subsections in 2.5. Among those, the 2.5.1,
8 2.5.3 and 2.5.5 related to basic geologic and
9 seismic information, surface faulting and
10 stability of slopes. The applicant provided
11 additional site geologic and seismic information
12 and they also performed new slope stability
13 analysis using updated site data. There are no
14 outstanding issues for those three subsections.
15 Next slide, please.

16 Subsection 2.5.2 is about laboratory
17 ground motion. The applicant addressed the
18 related COL items and the ESP permit conditions.
19 They revised ground motion is above spectra based
20 on updated site subsurface profile and also there
21 are no outstanding issues. Next slide.

22 MEMBER SHACK: Just on that, wasn't
23 the original ESP done with a uniform hazard ground
24 motion response spectra? Have they now changed to
25 the performance-based?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WANG: Yes. They too seem related
2 to why they revised the TMRS and one is because we
3 have new Regulatory Guide 1.2.8. In that
4 regulatory guide the NRC gave a guideline to
5 moderate the site sediments with bounds using the
6 - we call it the TMRS which is the ground motion
7 with response spectra other than ICDE probably you
8 are familiar with that term. And another issue is
9 because - based on the new site investigation data
10 the site soil profile changed a little bit -

11 MEMBER SHACK: From ESP?

12 MR. WANG: From the ESP. Because
13 during the COL siting investigation, the applicant
14 overturned a lot of more detailed information
15 about the subsurface soils. Based on the new
16 updated information, the soil layer elevation
17 changes a little bit. So because of that they
18 conducted a new site analysis. That's why they
19 revised the TMRS. Next slide, please.

20 The subject in 2.5.4 is stability of
21 subsurface materials in the foundations. Most
22 staff RAIs and open items are related to these
23 subsections. The applicant addressed the COL
24 items by providing additional boring data. The
25 site's soil profiles subsurface materials

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 properties and stability analysis. They also
2 resolved the RAIs or open items, related the two
3 static and dynamic property of backfill soils.
4 Foundation stability analysis, coefficient of
5 fraction of the foundation interface and dynamic
6 settlement calculation of soil slopes. Next
7 slide.

8 But there are two remaining open
9 items. The first one is the applicant needed to
10 clearly describe acceptance criteria in backfill
11 soil data and needed to clearly define shield
12 density test frequency during backfill soil
13 placement. The second one is the applicant needed
14 to clearly define concrete fill properties in the
15 COL FSAR. I would like to point out those two
16 open items are minor ones because for the first
17 one the applicant needed to make some wording in
18 ITAAC for backfill more clear. There's no
19 significant issue there, just some wording about
20 acceptance criteria. The second open item, the
21 applicant provided the detailed information about
22 the concrete fill in the response to staff's RAI.
23 But we would like to see those, the specification
24 about the concrete fill property in the
25 documentation of the COL application. Because the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 concrete fill will be placed directly underneath
2 the safety-related structure foundations. So
3 that's the two open items, and as I said, both are
4 minor ones. So that's the end of my presentation.

5 Any questions?

6 MEMBER CORRADINI: Questions? Thank
7 you very much. Thank you.

8 MR. WANG: Thank you.

9 MR. KEVERN: Moving along on the
10 agenda. Next topic, we've got two topics out of
11 Chapter 3 dealing with in-service testing of pumps
12 and valves, and also environmental qualification
13 of equipment. We're going to have just a staff
14 presentation on this topic, or these two topics
15 rather, and Tom Scarbrough from the staff.

16 MR. SCARBROUGH: Good morning. My
17 name's Tom Scarbrough. I'm with the Component
18 Integrity Branch and I'll walk you through Section
19 3.9.6 and 3.11 this morning. Section 3.9.6 is the
20 functional design qualification in-service testing
21 for pumps, valves and dynamic restraints. And the
22 COL application for North Anna relies on the
23 ESBWR, DCD and the FSAR to fully describe the
24 function design, qualification and IST programs
25 for pumps, valves and dynamic restraints of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 certification items in SECY Paper 05-0197. In
2 response to a number of RAIs, Dominion and GEH
3 revised the FSAR and the DCD to be able to come up
4 with a fully integrated description of the
5 functional design and qualification and IST
6 programs for these components. And on the next
7 page I'll mention some of the changes that were
8 made.

9 We did perform an audit of the GEH
10 design and procurement specifications in July 2009
11 at Wilmington. And that was to evaluate the
12 implementation of the DCD provisions into the
13 specifications. So next slide. This is a summary
14 of some of the important aspects from my
15 perspective in Section 3.9.6 for the 3.9.6 review.

16 First, the DCD specifies that the ASME Standard
17 QME-1-2007 for functional design and qualification
18 will be used for new valves and for previously
19 qualified valves the key QME-1 aspects will be
20 implemented. So there's an oversight. Even if
21 the valves have been qualified previously they
22 have to go through the key aspects of QME-1 which
23 incorporates the lessons learned from many years
24 of motor-operated valve experience and testing
25 programs that we have. And then QME-1 was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 recently accepted in Reg Guide 1.100 Revision 3.
2 Also, the DCD specifies the valve IST program.
3 It's based on 2001 edition and up to the 2003
4 addenda of the ASME OM code. That's incorporated
5 by reference in the NRC regulations. Now the
6 North Anna FSAR supplements the DCD in several
7 areas. For example, in IST provisions it
8 incorporates and expands the discussion to be
9 consistent with OM code and describes the periodic
10 verification of design basis capability of power-
11 operated valves. There are no safety-related
12 pumps or safety-related motor-operated valves in
13 the ESBWR design. But the description in the FSAR
14 incorporates the attributes for Regulatory Issue
15 Summary 2000-03 which incorporates those lessons
16 learned that we talked about in terms of motor-
17 operated valves in terms of the importance of
18 properly qualifying those valves. Also, the FSAR
19 provides a description of the snubber IST program
20 consistent with the ASME OM code Section ISTD. So
21 that's a summary of what's in the spectrum 2.9.6.

22 Now, where we are right now with the
23 resolving, closing out the section review. We had
24 one open item which we talked about with the
25 subcommittee. It involves the implementation of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the DCD qualification and IST provisions and the
2 NRC audit results were being used to address
3 those. And we summarize those results in a
4 memorandum dated September 1. And overall we
5 found the specifications to be properly
6 incorporating the DCD provisions. We do have some
7 follow-up items such as clarifying some
8 specifications in the IST table which I'll talk
9 about in a minute. Now, GEH provided a response
10 on September 21 which resolves most of those
11 items. They indicate that the specifications will
12 be updated primarily by the end of this year. The
13 IST table clarifications are already apparent in
14 Revision 6. They've already included those. And
15 they will provide us with a schedule for the
16 qualification testing for valves and the different
17 components as they get them. From a Section 3.9.6
18 perspective, the only remaining item from the
19 audit to close out this open item was the
20 reference in the response that once the QME-1-2007
21 and second Reg Guide 1.100, that that would be
22 reviewed to determine how that would be folded
23 into the specifications. So we'll be talking to
24 Dominion about that since the reg guide is now
25 issued. Other than that, that's all we have left

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on Section 3.9.6.

2 Now for 3.11 it also is an operational
3 program. So we have the FSAR incorporates by
4 reference the DCD description of the EQ program
5 for mechanical and electrical equipment. Now, the
6 DCD description of the EQ process was accepted
7 based on NUREG-1503 which is the ABWR SER. And
8 there's also, in addition to DCD, includes ITAAC
9 which are more operational program ITAAC. There
10 are specific component ITAAC which relate to
11 qualification, but there actually is a section in
12 the Tier 1 which is an operational program ITAAC
13 for the EQ program and goes through discussing the
14 variation qualification-type testing and such for
15 this process. So that's another level that's
16 added.

17 During the audit in July we also
18 looked at EQ specifications while we were in
19 Wilmington and I'll talk with you about what we
20 found there. So we had two open items and they
21 were interlinked. The first Open Item 1 had to do
22 with the general implementation of the DCD EQ
23 provisions. The second item had more specifically
24 referencing the safety-related mechanical
25 equipment which is my area in particular. So as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we noted we summarized the results in the
2 memorandum and they resolved most of those items.

3 There were a couple of EQ items left over from
4 the audit. One of them was that the specification
5 that we reviewed was a final draft after the
6 audit. It was close to being finalized but it
7 wasn't finalized yet. So we understand that GEH
8 will be finalizing that in the near future and
9 there was one item there in the response. We
10 wanted to make sure we had the right number of
11 specs that was referenced. That would be closed
12 out and we need to work with GEH and find out,
13 make sure that's clear, but that's probably just a
14 loose end we need to deal with.

15 The other item from EQ audit was the
16 transition from the initial EQ program to the
17 fully operational EQ program. And that transition
18 phase is something that we'll be discussing with
19 Dominion, GEH, we discussed it with them. They
20 consider it to be outside their scope. They focus
21 really on the initial EQ and they expect the COL
22 applicants to pick up the transition. So with
23 that, now that we understand that transition point
24 and where it is, we'll be working with Dominion to
25 be able to make sure that's fully ascribed so we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can close out that portion of the SER. So with
2 that, that's where we are with 3.9.6 and 3.11, and
3 I'll be happy to answer any questions.

4 MEMBER CORRADINI: Questions by the
5 committee? All right, I guess not.

6 MR. KEVERN: All right, thank you Tom.

7 The reason we chose 3.9.6 and 3.11 to talk about
8 today briefly was to represent the complexity of
9 this interaction between the design certification
10 review and the COL application review. IST and
11 the equipment qualification complex combination of
12 technical design issues as well as what the staff
13 calls and what the Commission calls operational
14 programs. And this was rather a quick discussion
15 by Tom, but I hope that represents the depth of
16 the staff's review and the idea of it's not just
17 simply incorporated by reference, it's an in-depth
18 review requiring interface, even audits of GEH as
19 well as Dominion, trying to ascertain if some
20 combination of both the DCD and the FSAR
21 information is adequate to meet the regulations as
22 well as the staff's expectations and our
23 regulatory guidance. So that was the purpose of
24 3.9.6 and 3.11. I hope that at least met part of
25 your expectations in that area.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Next topic is a combination of follow-
2 up to inquiries from ACRS members at subcommittee
3 meetings as well as an update to status of RAIs in
4 the area of plant service water. So in this case
5 we're going to start off with discussion by
6 Dominion addressing all three topics and then
7 we'll have a presentation by the staff on one of
8 those topics. Gina?

9 MS. BORSH: Thanks, Tom. As Tom said,
10 one of the inquiries relates to the makeup water
11 system. Just as a background, the system is
12 designed to supply demineralized water to the
13 equipment that's listed in the DCD. It's non-
14 safety related and it consists of a
15 demineralization subsystem and the storage and
16 transfer subsystem. A question was raised
17 regarding a statement in the COL about the
18 potential for using a temporary demineralization
19 subsystem during the shutdown/refueling/startup
20 mode. Per the DCD, the makeup water system pumps
21 and demineralization subsystem are designed for
22 normal power generation capacity water
23 requirements only. It's been determined that it's
24 not cost-effective to design a permanent system to
25 handle the potential outage loads or the potential

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to handle simultaneous demands that may be
2 occurring during that mode. So during the
3 shutdown/refueling/startup mode there may be an
4 increase of plant water consumption due to
5 draining that occurred of non-contaminated systems
6 that can't be refilled with condensate-quality
7 water. The capability to use a temporary
8 condensate-quality - I'm sorry. The capability to
9 use a subsystem that's temporary will allow us to
10 assure that there's an adequate supply to
11 supplement the condensate storage tank volume and
12 also we'll be using and implementing an outage
13 makeup water usage plan that will minimize the
14 need for a temporary subsystem.

15 The next item that was an inquiry from
16 ACRS subcommittee was about the assumptions that
17 the PRA made regarding the plant-specific portion
18 of the circulating water system. The PRA model
19 for the system is described in the DCD PRA. The
20 plant-specific design of the system, for example,
21 the cooling towers, is enveloped by the DCD PRA
22 analysis.

23 MEMBER STETKAR: Can I interrupt you
24 because I can read the words here.

25 MS. BORSH: Sure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I'm curious why it's
2 enveloped by the DCD PRA because the DCD PRA does
3 not include the cooling towers at all. So it's
4 curious how the DCD PRA envelopes the design by
5 not including it.

6 MS. BORSH: Now I'll have to look at
7 my technical notes here, John. Hold on one
8 second. Rick and Gary, you probably can't speak,
9 can you? I mean, you can speak but we probably
10 can't hear you.

11 (Laughter)

12 MS. BORSH: All right.

13 MS. CUBBAGE: We may have to that to
14 the takeaway. Just a wild guess, I mean they may
15 have made some bounding assumptions.

16 MEMBER STETKAR: They are just not in
17 there at all. The cooling - the pumps are modeled
18 in excruciating detail, trash racks, screens, all
19 of that, but the cooling towers are not there. In
20 effect, the PRA assumes that the cooling towers
21 are absolutely perfect. There is no failure
22 contribution from that.

23 MS. BORSH: And what Gary said in his
24 notes to me, Gary Miller from GE, was that the
25 other - you're absolutely right John, just what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you said. He said the other failures have been
2 determined to be insignificant and that's why they
3 haven't been modeled in the PRA. He said when the
4 circulating water fault tree is quantified,
5 failure of the circulating water top event, the
6 probability is $9E^{-6}$. So it's not a significant
7 contributor to PRA. In fact -

8 MEMBER STETKAR: That might be true,
9 but including the cooling towers might increase
10 that from $9E^{-6}$ to something larger than $9E^{-6}$ and in
11 fact it would. Now, whether that new number is
12 significant or not is something that the PRA sorts
13 out internally, but the fact of the matter is the
14 cooling towers are not modeled and they would be
15 an incremental contribution to whatever that
16 current number is. I guess the question is -

17 MEMBER CORRADINI: The concern you
18 have differently, if I say it differently is not
19 that it might turn out to be incrementally small.

20 It's not modeled at all and you want to know what
21 the -

22 MEMBER STETKAR: It is not modeled at
23 all and the question is does the PRA need to be
24 updated specifically for the North Anna site
25 because the North Anna site includes this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 difference in that heat removal function as
2 compared to the DCD which does not include credit
3 for any mechanical draft cooling towers. So
4 that's the real crux of the question.

5 MS. CUBBAGE: And I guess to pursue
6 that a little further. So you're satisfied on the
7 DCD?

8 MEMBER STETKAR: I'm satisfied on the
9 DCD because the DCD does not include any
10 mechanical draft cooling towers in the circulating
11 water system. That's strictly a change for the
12 North Anna site.

13 MS. CUBBAGE: Well, it would appear we
14 don't have anyone that would be able to provide
15 any more information than what Gina did.

16 MR. KEVERN: Unfortunately we have
17 provisions to deal with, but the - whoever is -

18 MEMBER CORRADINI: We're trying to see
19 if we can get them back online to talk to us.
20 It's on the table. What did you say, Dana? I'm
21 sorry, I didn't hear you.

22 MEMBER BLEY: I am not sure an oral
23 response is adequate.

24 MEMBER CORRADINI: Keep on going.

25 MS. BORSH: Okay. Gary and Rick,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thank you for trying. Okay. All right. The last
2 two items - so we don't need to talk about PRA
3 anymore?

4 MEMBER CORRADINI: We have our own
5 open item. Keep on going.

6 MS. BORSH: Yes. Last two topics that
7 ACRS members asked about were related to the plant
8 service water system. The function of this system
9 is to reject heat from the non-safety related
10 reactor component cooling water subsystem and the
11 turbine component cooling system. It has no
12 safety-related function. It is categorized as a
13 RTNSS Level C system in the DCD. The first item
14 of interest related to the plant service water
15 system involves the cross-connect between this
16 system and the normal plant heat sink which is our
17 circulating water system. The DCD identifies the
18 PSWS and normal plant heat sink cross-connect as
19 part of the conceptual design for the system. At
20 North Anna we didn't include this cross-connect in
21 our design. The decision not to incorporate the
22 cross-connect was based on the following
23 disadvantages associated with interconnecting the
24 two systems. First, the operating conditions at
25 North Anna might have required design changes for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other systems such as the RCCW and TCCW. Also,
2 during loss of offsite power the system would have
3 had to have been realigned to maintain PSWS
4 cooling capability. The cross-connect arrangement
5 would have increased capital costs, for example,
6 significant additional underground piping would
7 have been required for the cross-connect and it
8 would have increased operating costs during
9 certain periods without any offsetting benefits.
10 Although our system design at North Anna doesn't
11 include the cross-connect that was described in
12 the DCD, the system as designed does meet the
13 performance requirement specified in the DCD for
14 cooling RCCW and TCCW.

15 MEMBER STETKAR: Gina?

16 MS. BORSH: Yes, John.

17 MEMBER STETKAR: I just wanted to make
18 sure because in the ITAAC I believe there's a
19 requirement to show the PSWS basin has enough
20 inventory to provide cooling of RCCWS. It doesn't
21 mention TCCW. Does the basin actually have enough
22 capacity to provide cooling for both RCCW and
23 TCCW? Because recognizing that TCCW is certainly
24 a non-safety related system, however, some of its
25 cooling loads will indeed remain connected after a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 normal plant trip and would indeed take heat away
2 and require flow. So I was curious whether that
3 ITAAC commitment should include both the RCCW and
4 the TCCW cooling loads, or whether it already does
5 and I missed it.

6 MS. BORSH: Yes, I'm trying to pull it
7 up now John, but Jeff, do you know offhand? Or
8 Doug, do you know the answer to that? We have
9 Doug Kemp from Bechtel here with us. I was going
10 to pull up the wording.

11 MEMBER CORRADINI: You will have to
12 come to a microphone and identify yourself,
13 please.

14 MR. KEMP: Doug Kemp. I believe as
15 far as the defined heat load for the coping period
16 of the seven days it was not specifically
17 identified. It was the RCCW heat loads for the
18 coping period as well as the diesel generator
19 cooling loads, but not specifically - again, as
20 was mentioned, you know, your TCCW loads would
21 probably be very minimal because your plant has
22 shut down.

23 MEMBER STETKAR: There's a table in
24 the DCD. It's Table 9 - if I can pull it up here
25 - Table 9.2-1 in the DCD that says during a normal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 post-trip condition RCCW has about 91 megawatts
2 and TCCW has about 21 megawatts heat loads. So
3 TCCW accounts for something on the order of about
4 20 percent of the total PSWS heat load. So it's
5 not insignificant. I don't particularly know
6 exactly what those heat loads are because they're
7 not elaborated in this table, but TCCW is not an
8 insignificant fraction of the total PSWS post-
9 trip, normal post-trip heat load.

10 MS. BORSH: But I think John what we
11 did was the interface requirement in the DCD
12 specifies the heat that has to be removed and we
13 meet that requirement. So if you have a question
14 about the heat removal that's really a DCD
15 question.

16 MEMBER STETKAR: No. In, I believe,
17 and I don't have all of my notes in front of me
18 here so I'm struggling a bit. I did make a note
19 that there was a commitment to contain enough
20 inventory of cooling water sufficient to remove
21 heat from RCCWS for the 7-day coping period. And
22 it doesn't mention TCCWS so that - the question
23 was if the heat loads are indeed correct, does the
24 7-day coping period inventory in the basin also
25 account for the additional TCCWS heat loads. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if not do you -

2 MS. BORSH: But that's really a DCD -

3 MEMBER STETKAR: That's right. And
4 there's no provision, as far as I can tell, I
5 can't find any automatic isolation or any
6 provision to shut off those heat loads under
7 certain conditions. So it seems it would require
8 a manual action if -

9 MR. KEMP: I think we're getting -

10 MS. BORSH: Mike Arcaro was saying -

11 MR. KEMP: - was just here from GEH
12 and I think the response from Mike Arcaro from GEH
13 is that no, TCCW is not included.

14 MS. BORSH: It is not included. And
15 the removal capability requirements are specified
16 in the DCD. And I'm sure that if Mike were on the
17 phone he could explain in more detail why that is.

18 MEMBER BLEY: I think the other side
19 of what John's saying is those heat loads are
20 there and unless you have provision to kill TCCW
21 the water's going to go away.

22 MR. SMITH: I guess the point would be
23 from our perspective, we're meeting the DCD
24 requirement. So I think it is more in our view a
25 question for the DCD as to what the heat load

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 requirement is that would have to be met. And
2 it's more of a generic issue.

3 MS. CUBBAGE: Okay, so we'll take that
4 over to the DC and straighten that out. I don't
5 think we're going to solve it here.

6 MEMBER STETKAR: No, I don't think we
7 are either, but you understand it though. You
8 understand -

9 MS. CUBBAGE: Yes, I understand. And
10 I do have some follow-up. We've been able to
11 relay phone messages back and forth on the PRA
12 question and that question was considered by
13 Dominion and they asked GE to consider the impact
14 of the tower and the answer is that the fan was an
15 insignificant contributor, the fan component
16 itself, and what drives the risk is the support
17 systems, and it's the same support systems for the
18 pump as it is for the fans. So if you have a loss
19 of power it's going to affect both so there's not
20 an increased risk of a loss of power to the fan
21 versus a loss of power to the whole system.

22 MEMBER CORRADINI: The support system
23 being -

24 MS. CUBBAGE: The system as far as
25 power supplies, et cetera, are driving the risk so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it was determined that there was no significant -
2 it would not have changed the PRA results to
3 include the fan components.

4 MS. BORSH: That was the last bullet
5 that Gary had given us on that slide. And you can
6 ponder that.

7 MEMBER CORRADINI: I'll still have to
8 ponder that, especially -

9 MS. CUBBAGE: Power supply was
10 mentioned.

11 MEMBER CORRADINI: Okay, fine. We're
12 still trying to get your people back online.
13 They're lost somewhere, I'm not sure.

14 MS. CUBBAGE: They were able to hear,
15 but now I'm afraid they're not even able to hear
16 because it doesn't sound like - they're dialing in
17 and out.

18 MEMBER STETKAR: That may be less
19 frustrating.

20 MS. BORSH: Thank you Amy though, that
21 was really helpful.

22 MS. CUBBAGE: Welcome.

23 MS. BORSH: So John, you still have a
24 question?

25 MEMBER STETKAR: I still have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question only because the PRA includes extensive
2 analyses of things like common cause failures of
3 pumps and fans and valves and things like that,
4 and the conclusion may be true. I guess I'd just
5 like to see it.

6 MEMBER CORRADINI: Okay. So let's
7 save it. We'll get back to it.

8 MEMBER STETKAR: That's right.

9 MEMBER CORRADINI: Okay. Gina, you're
10 up.

11 MS. BORSH: So, we don't have a cross-
12 connect and we meet the performance requirements
13 of the DCD. All right? Are we?

14 MEMBER CORRADINI: Yes, keep on going.

15 MS. BORSH: Okay. All right. The
16 last item that we had related to specific ACRS
17 members' questions involves our use of fiberglass
18 reinforced piping for the underground portion of
19 the plant service water system. We evaluated the
20 different piping material options that we had
21 before us and we determined that FRP piping is the
22 best option for several reasons including the
23 following. First, the material meets the design
24 requirements that are specified in the DCD.
25 Second, the material has certain advantages over

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other materials such as its long-term resistance
2 to internal and external corrosion and biological
3 attack. The NRC - I'm sure they'll be talking
4 about this in a couple of minutes - has issued
5 RAIs to Dominion regarding our use of FRP for the
6 application and as a result of several discussions
7 that we've had on the topic with NRC we've decided
8 for the non-safety related FRP piping that we have
9 we're going to use an ASME code case as a starting
10 point and as guidance to develop the requirements
11 that will apply to the FRP in the plant service
12 water system.

13
14 MEMBER CORRADINI: I don't - I guess
15 you have to help me. What does that mean?

16 MR. KEVERN: Perhaps we could clarify
17 that with the staff?

18 MEMBER CORRADINI: That's fine. Okay.

19 MS. BORSH: Any questions before I
20 turn it over to Tom?

21 MEMBER CORRADINI: No.

22 MS. BORSH: Okay.

23 MR. KEVERN: All right. So as a great
24 segue-way provided by Dr. Corradini we have staff
25 presentation now, an update on the plant service

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 water situation, both regarding the RAIs as well
2 as specifically on the fiberglass issue. So
3 Larry?

4 MR. WHEELER: Good morning. Larry
5 Wheeler from balance of plan plants. A recap from
6 the July subcommittee meeting. As Dominion
7 stated, service bar system is non-safety related,
8 categorized as RTNSS. Since the service bar
9 system is categorized as RTNSS, staff asked
10 questions to ensure the service bar system is
11 reliable. Since the staff used to the SERs with
12 open items we have had meetings and phone calls
13 with Dominion and Dominion has submitted revised
14 RAI responses. The staff reviewed these responses
15 and identified six open items, Items 8 through 13.

16 Open Items 8 through 12 are now resolved and now
17 considered confirmatory items. Open Item No. 8,
18 GEH revised Revision 6 of their DCD addressing the
19 Tier 1 interface requirements related to the
20 service water system. Removing the requirements,
21 BTUs appeared at seven days without active makeup
22 in addressing sufficient MPSH from the service
23 water coolers. North Anna has provided an FSAR
24 markup to be consistent with the DCD.

25 Open Item No. 9 addresses COL items

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for piping material. Aboveground service water
2 materials will be carbon steel. Materials will be
3 noted in the North Anna FSAR. The underground
4 materials are addressed in Open Item No. 13.

5 Open Item No. 10. The staff asked the
6 RAI related to the service water treatment in
7 accordance with the Maintenance Rule program. The
8 response, the service water system as initially
9 classified as highly safety significant.

10 Open Item No. 11. North Anna
11 application for the Section 9.2.1 mixed together
12 the text of the ESBWR DCD and the North Anna
13 conceptual design information and COL items. In
14 response, the application will only address the
15 CDI and COL items in the North Anna FSAR.

16 Open Item No. 12, address conceptual
17 design information related to the aux heat sink.
18 The initial plant test program that has design
19 features will minimize water hammer events are
20 tested. North Anna will revise the FSAR
21 addressing the ultimate heat sink testing,
22 including the water hammer mitigating design
23 features. Open Item No. 13 will be discussed by
24 Neil Ray.

25 MR. RAY: Good morning. My name is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Neil Ray, Acting Branch Chief of Component
2 Integrity, Performance and Testing Branch. And as
3 you heard from Larry Wheeler, I'm going to
4 specifically talk about the issue of fiberglass
5 usage in the PSWS system. Let's keep in mind that
6 we are talking about this subject because this is
7 RTNSS which is special category for the passive
8 characters. And in this case ESBWR so this is
9 RTNSS Class C.

10 When we looked into fiberglass we
11 looked into of course its environment and the
12 material compatibility of that environment and
13 under the function that it will press forward.
14 And in doing so we look back the history of
15 fiberglass in terms of usage in the nuclear power
16 plant and we found out that there are quite a few
17 operating nuclear power plants use fiberglass.
18 And some of them already gone through licensed in
19 one process, namely Palo Verde. And so that is
20 some basis for us to even consider fiberglass in
21 the RTNSS system. The applicant originally
22 suggested to use B-31/1 and non-mandatory Appendix
23 3 for usage of fiberglass. In our opinion that
24 was not enough because B-31/1 doesn't talk about
25 all the design aspects, material aspect,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 installation, all those things. So we searched
2 around and we found that back in `80s, ASME code
3 case 155-2 has been gone through NRC review,
4 extensive review, and in Reg Guide 1.84 NRC staff
5 approved that document. So here we have
6 fiberglass as RTNSS Class C which does not carry
7 any radioactive material, which is a low
8 temperature, low pressure environment and we have
9 the basis that current plants using fiberglass, we
10 have the basis that we have a code case which we
11 can depend on. So, we talk with the applicant
12 over the phone twice and tell them that under the
13 situation we would strongly suggest to you to
14 consider using the code case N-155-2.

15 MEMBER CORRADINI: So let me just -
16 since I'm not enough of a good mechanical engineer
17 on this -

18 MR. RAY: Yes.

19 MEMBER CORRADINI: What that means is
20 the code case is an enveloping protocol for the
21 use of FRP in these situations, is that really
22 what it comes down to?

23 MR. RAY: You can say that, yes.

24 MEMBER CORRADINI: Okay, fine.

25 MR. RAY: We are not and nobody is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really asking - let me make it very clear to all
2 committee members. We are not asking the
3 applicant to completely accept code case 155-2
4 with the stamping, all those things. No. We are
5 asking in terms of materials fabrication, in terms
6 of installation, inspection, to follow the
7 guidance of code case N-155-2. And in our
8 judgment, based on the response we get from the
9 applicant we will decide what to do here. So at
10 this point we have not decided that we accepted
11 this material for this usage. That will be
12 decided sometime in the future within very short
13 time. We ask the applicant to provide us how far
14 they can use this code case. And based on that
15 audit process we will decide what to do about it.

16 MEMBER SHACK: What was the intent of
17 use that the code case was considering?

18 MR. RAY: Well, as I said, because B-
19 31/1 does not talk all the details, and N-155-2,
20 it's a about 50-page document. It tells all the
21 details what to do, what not to do, how to make
22 sure the installation is good as far as not said.
23 All those information are there, so this is a
24 good starting point of using code case N-155-2.

25 MS. CUBBAGE: Neil, I think he was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 asking what application was the code case -

2 MR. RAY: Is that your question? Why
3 they are using fiberglass?

4 MEMBER SHACK: What was it intended to
5 be used for, yes.

6 MS. CUBBAGE: The code case in the
7 '80s when it was -

8 MR. RAY: Oh, okay. That was for the
9 current reactors.

10 MS. CUBBAGE: Right, but for what
11 application.

12 MR. RAY: No. Essentially for spray
13 pumps, yes, but it does talk about other buried
14 piping as well, it does. And it refers to other
15 codes when it comes to the installation, like ASTM
16 document also. So it is a pretty comprehensive
17 document I would say. As I said, it is about 50-
18 page document which tells what to do, what not to
19 do. And that's basically our starting point for
20 this consideration.

21 MEMBER ARMIJO: Does it address joints
22 between let's say pipes?

23 MR. RAY: Yes, it does.

24 MEMBER ARMIJO: Does it? And joints
25 between the fiberglass pipe and the metal pipe?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. RAY: I believe it does. George,
2 you want to add something?

3 MEMBER CORRADINI: Go to the mic,
4 identify yourself please.

5 MR. GEORGIEV: I'm George Georgiev -

6 MEMBER CORRADINI: That mic is dead.
7 We have power loss everywhere.

8 MR. GEORGIEV: Yes, my name is George
9 Georgiev. I am senior materials engineer with the
10 Component Integrity Branch. And the answer is
11 yes. Adequate guidance is provided within the
12 code case to use flange connection between the
13 metallic and non-metallic portion of the piping.

14 MEMBER SHACK: Has Dominion used this
15 in flush plant applications? Do you have
16 experience with the FRP piping? The similar
17 applications?

18 MS. BORSH: Yes. We're actually using
19 it in nuclear applications today at our existing
20 plants and we like it. I mean, we are not
21 choosing - we've chosen it because we do believe
22 it's a superior material to our other options.

23 MEMBER SIEBER: Well, Dominion's had
24 problems in the past with steel piping in service
25 water systems.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. BORSH: That's right.

2 MEMBER SIEBER: And there is some
3 experience with fiberglass pipes in the same
4 application because it's more flexible and so when
5 you backfill overtop of it it becomes oval-shaped
6 and creates some stresses inside. I don't think
7 the code case deals with that issue.

8 MS. BORSH: However, there are other
9 codes that we - and standards that we plan to
10 commit to regarding installation and construction
11 and maintenance that will prevent the problems
12 that occurred previously in the '70s regarding
13 construction.

14 MEMBER SIEBER: Yes, this is in a bio-
15 plant.

16 MS. BORSH: Right, Perry. Oh, I'm
17 sorry.

18 MEMBER SIEBER: So you know all about
19 it.

20 MS. BORSH: We've looked, yes, and
21 we've spoken directly with the Perry people that
22 have been involved.

23 MEMBER SIEBER: I feel much better.
24 Thank you.

25 MS. BORSH: You're welcome. Yes. Did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that answer your question?

2 MR. RAY: Any further questions?

3 MEMBER CORRADINI: Thank you.

4 MR. KEVERN: All right, we have
5 finished with water systems. I expected that
6 fiberglass was going to take a little longer than
7 what we had scheduled for, so the next topic we
8 have are inspections tests and analysis acceptance
9 - I'm sorry, special tests analysis and acceptance
10 criteria for specific to North Anna. I'm going to
11 provide a summary of the ITAAC for North Anna.
12 Specific to North Anna there are four categories
13 of ITAAC, the ITAAC associated with certified
14 design, with emergency planning, security and then
15 of course the site-specific structure systems and
16 components. Taking these one at a time as you see
17 here on the slide, as far as the certified design
18 is concerned in Tier 1 of the DCD for the ESBWR we
19 have all of the ITAAC applicable to the certified
20 design identified and discussed, and North Anna -
21 Dominion makes these applicable to North Anna by
22 incorporating by reference the Tier 1 in its
23 entirety. So all of these ITAAC applicable to
24 certified design now become North Anna-specific
25 ITAAC.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 In the area of emergency planning, the
2 COL application included a number - well, all of
3 the expected by the staff site-specific ITAAC. We
4 have rather specific guidance in that area for
5 ITAAC emergency planning area. Staff reviewed and
6 evaluated the ITAAC that were provided in the
7 application and we currently have two open RAIs in
8 that area, both of which are concerned with a
9 specific criteria for - in two areas. Again, not
10 significant. We're talking about specific wording
11 for criteria, but those are currently two open
12 items associated with 13.3. In the area of
13 physical security, as I said earlier, the staff's
14 review is currently ongoing and there may be RAIs
15 related to ITAAC, but it's premature to say
16 whether we will or will not have it at this point
17 in time.

18 Site-specific structure systems and
19 components. To determine the ITAAC appropriate
20 for those SSCs specific to North Anna Dominion
21 applied the same selection criteria and
22 methodology as GEH did in the certified design
23 application. Staff found that that approach and
24 criteria methodology to be acceptable and so
25 therefore we found that approach by Dominion to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 acceptable for the site-specific SSCs. As a
2 result of the applicant applying that criteria
3 methodology, they ended up with ITAAC and then the
4 three areas you see identified on the slide here,
5 the backfill under Category 1 structures, ITAAC
6 and we currently have an open RAI as Weijun talked
7 about a little while ago. For plant service water
8 we had an open RAI that has now become
9 confirmatory, just mentioned previously in the
10 plant service water presentation. And pertaining
11 to offsite power system, we went through a series
12 of discussions. We had a couple of RAIs, multi-
13 part RAIs both with the design certification
14 applicant as well as Dominion for the North Anna
15 application. Identified the need for ITAAC and
16 the offsite power area. And this is relative to
17 equipment that's in the switchyard. It serves as
18 an interface between the onsite power system and
19 the transmission grid. I've had multi-part RAI in
20 that area that has been addressed by Dominion and
21 that has now moved in the confirmatory status.

22 And last and definitely not least, by
23 applying this criteria methodology the applicant
24 identified and the staff agrees that there are no
25 ITAAC for any other site-specific systems. So the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 way we're going to close out to address ITAAC for
2 North Anna is going to be the same as all of the
3 other COL applications. To ensure completion of
4 ITAAC we're going to have a license condition that
5 specifically identifies that the ITAAC will be
6 satisfied before fuel load. And in addition to
7 that, the actual closure process for North Anna
8 has been a work in progress by the staff now for
9 awhile. We currently have guidance identified in
10 Reg Guide 1.2.15 and that will be applicable to
11 North Anna as well as to all of the other COL
12 holders for the closure process. Yes, sir.

13 MEMBER CORRADINI: This is the reg
14 guide that we had reviewed -

15 MR. KEVERN: That is correct, right.
16 And that's why I put it on the slide here. I know
17 ACRS has - the entire ACRS has been interested in
18 the ITAAC closure process. It's been evolving and
19 you've had interactions with the staff and in fact
20 there's a presentation tomorrow on this topic. So
21 the point I want to make here is there's nothing
22 unique about ITAAC closure for North Anna. It's
23 going to follow the generic process the staff
24 concludes here, with some help from ACRS as far as
25 the reg guide is concerned. And that's a summary

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of ITAAC specific to North Anna. Any questions?

2 MEMBER STETKAR: Yes, Tom. I almost
3 hesitate to ask this, but in the -

4 (Laughter)

5 MEMBER STETKAR: And you know what's
6 coming, don't you? In the subcommittee meeting
7 there was mention made by Dominion that they were
8 going to request the staff issue an SER on
9 closeout of the DAC. Has that discussion
10 progressed?

11 MR. KEVERN: I'd like to defer the
12 answer to that to the subject matter expert from
13 the staff, Jerry Wilson, who's going to be giving
14 the presentation tomorrow to the full committee.

15 MEMBER STETKAR: Okay, so -

16 MR. KEVERN: Maybe he'll answer that
17 now, maybe he'll answer it tomorrow.

18 MEMBER STETKAR: Okay. Well, I know
19 we're going to have a presentation tomorrow, I was
20 just curious within this specific context.

21 MR. KEVERN: What we'll try for here
22 is a short answer to that question.

23 MR. WILSON: Jerry Wilson, Office of
24 New Reactors. The short answer is on this subject
25 matter of how we're going to expose design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 acceptance criteria we sent a letter to the
2 committee and in there we stated that we're
3 developing guidance and we're going to be getting
4 back and have a meeting with the committee to go
5 over that guidance in the future. And I'll just
6 alert the committee that in the future is
7 tomorrow.

8 MEMBER STETKAR: Okay, thanks.

9 MR. KEVERN: All right, no other
10 questions? Then the last slide we'll hear from
11 the staff's perspective is a quick review of the
12 schedule. North Anna is the reference COL for the
13 ESBWR design and therefore we follow the - what
14 the staff considers a standard 6-phase review
15 process. At this point in time we've completed
16 Phase I which was the initial round of all of the
17 RAIs reviewing the initial application as well as
18 Phase II, the safety evaluation report with the
19 initial open items. And now we're nearing the
20 end of Phase III which is our interaction with you
21 folks. And that'll be - we expect that to end on
22 schedule the first of the month with the issuance
23 of the interim letter for - from ACRS. And then
24 following that the next step is Phase IV where we
25 end up with the deliverable being the safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluation report with no open items. Then to
2 address the staff's perspective on that we come
3 back to ACRS. We currently have meetings for both
4 the subcommittee and full committee scheduled for
5 October of next year. That's in the master plan
6 schedule there for North Anna. And then we finish
7 the issuance of the license scheduled on the
8 slide. And with that that concludes the staff's
9 presentation today. We have brief concluding
10 remarks from North Anna before we turn it back to
11 Dr. Corradini.

12 MS. BORSH: We just want to say thank
13 you very much for having us today. I'm sorry that
14 our subject matter experts couldn't answer your
15 questions. I know they would have been right on
16 top of it and had answers for you, so we'll follow
17 up on that as we need to. And just in conclusion,
18 we continue to work on our R-COLA. We're
19 addressing the remaining RAIs, the ones we have,
20 the ones we'll receive, and we look forward to
21 seeing you all later in the process. So thank you
22 very much.

23 MR. SMITH: That's all.

24 MEMBER CORRADINI: Questions by the
25 committee for anyone from either Dominion or

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 staff?

2 MEMBER MAYNARD: I've got just a quick
3 question. Back to the decision to eliminate the
4 cross-connect for the water systems. And that's
5 for Dominion and the staff. What kind of review
6 was done to make sure that there wasn't some other
7 credit taken for that. Sometimes when you have
8 something like that in the design, other designers
9 take a look at that and they say oh well a cross-
10 connect is there so - what kind of review was done
11 to ensure it wasn't something else credited for
12 that?

13 MS. BORSH: Internally for Dominion as
14 we prepared our packages we had GEH, the technical
15 people that had written the DCD review the
16 packages and approve it for us to agree that we
17 did not miss something that would have been buried
18 in the DCD, for example. So we got GEH
19 concurrence on doing the review. and then of
20 course we had our internal Dominion engineers
21 reviewing the package too.

22 MR. KEVERN: From the staff's
23 perspective then we look at to Dominion's
24 application to ensure it meets the design
25 specifications from the DCD as well as whatever

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the interface requirements are. For more detail
2 I've got the subject matter expert on that
3 specifically for how the cross-connect was looked
4 at or not looked at.

5 MEMBER MAYNARD: I guess my question
6 is as much a caution as anything. Sometimes
7 somebody else has taken a look at that and said
8 well that cross-connect is there so I'm going to
9 do this a little different or something like that.
10 For some of these involved there.

11 MEMBER STETKAR: It was one of the
12 reasons I focused on TCCW and RCCW and the amount
13 of water. I was a little bit less concerned when
14 there was an additional water supply out there.

15 MEMBER CORRADINI: When there was a
16 cross-connect.

17 MEMBER STETKAR: When there was a
18 cross-connect. And not seeing TCCW listed as a
19 specific heat load sort of raised that flag now
20 that the amount of water that's available is
21 strictly limited to what's in the basin.

22 MS. BORSH: Well, and the interface
23 requirement, John, does specifically say that the
24 interface requirement is necessary for supporting
25 the post 72-hour cooling function of the PSWS so -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: This is the 7-day
2 coping inventory in the PSWS basin. So it's the
3 full 7-day heat removal capability without makeup.

4 MS. BORSH: Yes. I mean, it goes on,
5 right. And that's our interface requirement,
6 you're absolutely right. So it does go on. But
7 also in the DCD GEH for us specifies the
8 performance requirements for those systems that
9 are conceptually described, this conceptual design
10 is described in the DCD. So to answer your
11 question we - GEH has determined what's the
12 minimum requirement for a particular system and
13 then we of course make sure that we meet those as
14 we implement and develop our actual design.

15 MR. KEVERN: And specific on the
16 ITAAC, that was a subject of an RAI where the
17 staff - what initially was proposed was thought to
18 be too vague. We wanted more detail to ensure
19 that that interface was met. And that was a
20 subject that Larry Wheeler had talked about
21 earlier. I've lost him so I cannot give you the
22 details of his background and his review related
23 to that ITAAC.

24 MEMBER MAYNARD: Just review emergency
25 procedures and stuff thoroughly because that might

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have got buried in something that you guys get,
2 you know, what comes from GE then you could miss
3 something like that easily in part of the
4 emergency procedures and stuff.

5 MS. BORSH: Thank you.

6 MEMBER CORRADINI: Other questions?
7 Hearing none, let me thank Dominion and the staff.

8 And at this point I guess I'd invite any comments
9 by the committee. We're going to get back to this
10 where we're going to have to draft an - well, we
11 are planning to draft an interim letter tomorrow
12 so that if I can get some comments from you now
13 verbally or in writing or after you see the first
14 draft I'd welcome it. But other than that, thank
15 you all and I'll turn it back to you, Mr.
16 Chairman.

17 VICE CHAIR ABDEL-KHALIK: I guess
18 according to the schedule we will recess till
19 10:45.

20 (Whereupon, the foregoing matter went
21 off the record at 10:23 a.m. and went back on the
22 record at 10:43 a.m.)

23 VICE CHAIR ABDEL-KHALIK: We will come
24 back into session. At this time we're scheduled
25 to look at the license renewal application final

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 SER for the Susquehanna Steam Electric Station
2 Units 1 and 2. And Dr. Shack will lead us through
3 that discussion.

4 MEMBER SHACK: Okay. Our subcommittee
5 reviewed the license renewal of the Susquehanna
6 Steam Electric Station on April 1. There were no
7 open items in the SER at that time. However, the
8 subcommittee asked for some additional information
9 on our favorite topics, medium-voltage cables, the
10 containment liner condition and SBO recovery
11 scope. The staff has also been pursuing some
12 additional information on Boral and the fatigue-
13 monitoring program and the factors used to
14 calculate environmental effects on fatigue life.
15 We'll be hearing follow-up on these issues from
16 both the licensee and the staff, and I'll now turn
17 to Sam Lee of the staff to open the discussion.

18 MR. LEE: Okay, good morning. My name
19 is Samson Lee. I'm the deputy division director
20 for Division License Renewal, NRL. Brian Holohan
21 the division director would normally be here.
22 However, he's away at an international conference.

23 And as Dr. Shack said, today the staff is going
24 to talk about two items from the subcommittee
25 meeting. One was Boral, one was metal fatigue.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And actually, the metal fatigue issue was added to
2 address some of the ACRS questions. So those are
3 the questions and we address them. And to my left
4 is Dave Pelton the branch chief in License Renewal
5 and to his left is Evelyn Gettys. She is the
6 department manager for Susquehanna for License
7 Renewal. And also I have Glenn Meyer. He is the
8 Region 1 team leader for the inspection and he
9 will be here from then till when it's time for the
10 presentation. But before that I'm going to turn
11 over the presentation to the applicant and John
12 Kraiss, the manager for Special Projects PPL is
13 going to lead the discussion.

14 MR. KRAISS: Thank you. Good morning.

15 My name is John Kraiss. I'm the manager of
16 Special Projects for PPL Susquehanna. I want to
17 thank you for the opportunity to discuss the
18 Susquehanna license renewal request. With me here
19 today are Rick Pagodin, general manager of
20 engineering for Susquehanna, Dale Roth, supervisor
21 of programs and testing, Dave Flyte, our license
22 renewal lead engineer, both of whom will be
23 speaking to later. And we also have with us our
24 subject matter experts, license renewal project
25 team including representatives from AREVA and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Structural Integrity who assisted us in our
2 license renewal application preparation. The
3 agenda for today's meeting starts with a brief
4 description of the site. Following that, Dave
5 Flyte will discuss the operating experience
6 review, the commitment process, underground
7 medium-voltage cables and station blackout
8 recovery scoping. Dave Roth will provide an
9 overview of the condition of containment and Dave
10 will conclude with the discussion on main
11 steamline flow restrictor aging management
12 evaluation.

13 Susquehanna is located in northeast
14 Pennsylvania approximately 20 miles southwest of
15 Wilkes-Barre. The plant is owned by PPL
16 Susquehanna who has a 90 percent share and the
17 Allegheny Electric cooperative with a 10 percent
18 share. The licensee and operator is PPL
19 Susquehanna, LLC. We have two BWR-4 units
20 licensed up to 3952 megawatts thermal and a
21 generator limit rating of 1300 megawatts electric.

22 General Electric was our - supplier and Bechtel
23 was our architect engineer. The ultimate heat
24 sink is provided by a spray pond. Turbine cycle
25 cooling is provided by natural gas cooling towers,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and the makeup water is pumped up from the
2 Susquehanna River.

3 A little bit of history. Our
4 operating license was issued for Unit 1 in July of
5 1982 and Unit 2 in March of 1984 for 3293
6 megawatts thermal. Our license renewal
7 application was submitted in September of 2006.
8 Our extended power uprate of 14 percent to 3952
9 megawatts thermal was approved in January of 2008
10 and our current license expires July 17, 2022 for
11 Unit 1, and March 23, 2024 for Unit 2. At this
12 time Dave Flyte will continue with the discussion
13 of our operating experience.

14 MR. FLYTE: Thank you, John. The
15 Susquehanna operating experience review was
16 performed in accordance with the guidance that's
17 in the industry guideline document NEI 95-10. As
18 recommended in that guidance we started with
19 industry information that's been pulled together
20 over the years and the EPRI tools was one of those
21 documents that we used. It's a good compilation
22 of aging effects from various industry experience
23 over a number of years. So we used that as a
24 starting point to identify potential aging effects
25 for evaluation for Susquehanna. In addition, as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 recommended by the guidance we didn't rely solely
2 on the industry information that had been
3 accumulated. We did a plant-specific operating
4 experience review. We started out with at the
5 time the application was submitted we had done a
6 5-year review plant-specific operating experience.

7 While the application was in review we continued
8 with updates to the operating experience and we
9 effectively have very close to eight and a half
10 years of operating experience reviewed plant-
11 specific. We also looked at industry operating
12 experience during that time period to make sure
13 that we had reviewed all the pertinent industry
14 operating experience since the industry guidance
15 documents had been issued, the GALL and the tools
16 and everything like that. So with that we've been
17 able to identify all potential aging effects. I
18 would just note that the plant-specific review
19 didn't turn up anything new and different than
20 what was included in the industry guidance
21 documents which I think has been pretty typical.

22 MEMBER SHACK: Can you refresh me?
23 You haven't replaced your piping. You rely on
24 mechanical - or on stress improvement and the
25 hydrogen water chemistry, that's correct, isn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it?

2 MR. FLYTE: I believe that's correct.

3 Which piping would you be referring to?

4 MEMBER SHACK: Recirc piping.

5 MR. FLYTE: Recirc piping, yes.

6 That's mechanical.

7 MEMBER SHACK: Is that mechanical
8 stress improvement or is that induction heating?

9 MEMBER ARMIJO: I think I read both.

10 MR. SWOYER: I'm Bruce Swoyer, design
11 engineering, Susquehanna. We use both. We use
12 IHSI when the units were young and then we went in
13 and did MSIP in the early '90s.

14 MEMBER SHACK: Okay. And what's the
15 level of your hydrogen addition, or is that
16 proprietary information?

17 MR. KRAIS: We currently inject about
18 95. Dan Miller will -

19 MR. MILLER: Yes, Dan Miller, site
20 chemistry. Yes, we're running 1.97 PPM feedwater
21 hydrogen. We're a moderate hydrogen injection
22 plant.

23 MEMBER SHACK: Now has that been
24 increased since you did your power up-rate or
25 that's the level you've been?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MILLER: That's the level we've
2 been able to maintain since up-rate. We've done
3 evaluations to increase it if needed.

4 MEMBER SHACK: Okay. And can you do
5 that without shine. I mean, what's the limit for
6 you? Is it just an economic limit, or?

7 MR. MILLER: Right now we're limited
8 to 2 PPM feedwater hydrogen with the increased
9 feedwater flow. So we can increase our injection
10 rate to 98 for the first level of EPU and 106 FCSM
11 for the second phase of EPU.

12 MEMBER SHACK: Okay, thank you.

13 MR. FLYTE: The next topic on our
14 agenda is the commitment process. The license
15 renewal application as amended during the
16 regulatory review process includes 60 commitments.
17 Each of these commitments has already been
18 entered into the station commitment tracking
19 process and is scheduled for completion prior to
20 the period of extended operation. Commitments are
21 assigned to individual station personnel and
22 there's also oversight on the commitment process
23 by a nuclear regulatory affairs group to ensure
24 that implementation goes as planned. And of
25 course there's an NRC inspection prior to entering

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the period of extended operation to validate that
2 that implementation has occurred.

3 Moving into the subcommittee follow-up
4 items. At the subcommittee meeting we did discuss
5 the underground medium-voltage cables. At
6 Susquehanna we have both 5kV and 15kV cables.
7 They're routed underground within the scope of
8 license renewal. The 5kV are the safety-related
9 cables and portions of those cables are routed
10 underground in duct bank. And from pass
11 inspections of manholes in those duct bank runs
12 we've never observed any submerged medium-voltage
13 cables that are safety-related. We also have 15kV
14 non-safety- related cables that are within the
15 scope of license renewal and they're included in
16 scope for the offsite power supplies and station
17 blackout recovery. Past inspections of manholes
18 in those duct banks, we have observed submerged
19 medium-voltage cables in two of the manholes. And
20 we knew that information going into license
21 renewal application, so based on that plant-
22 specific OE we did include in our original
23 submittal a commitment to implement a program that
24 was consistent with the GALL recommendations for
25 cables that could have an opportunity to be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 submerged, and that would be to periodically test
2 the underground medium-voltage cables and also to
3 inspect the manholes and pump them as needed to
4 keep the cables from exposure to standing water.
5 Although that's a license renewal commitment, we
6 have been keeping up with industry developments on
7 that and that's - those activities have already
8 been put in place so we've started those already.

9 MEMBER STETKAR: Dave, can I ask just
10 to make sure I understand the commitment. And
11 recognizing that this is a plant licensing issue
12 so it isn't necessarily unique to the license
13 renewal commitment. As far as the license renewal
14 commitment, you're only committing to the testing
15 of the cables and inspection of the manholes that
16 include - that contain the 13.8kV cables, is that
17 correct? You're not -

18 MR. FLYTE: That's correct.

19 MEMBER STETKAR: - going to be doing
20 any inspections of the manholes that contain the
21 5kV cables?

22 MR. FLYTE: For license renewal that's
23 a correct statement. However -

24 MEMBER STETKAR: What's the basis for
25 excluding the 5kV cable, 4.16kV cable?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. FLYTE: The 5kV cables are not
2 energized more than 25 percent of the time.
3 They're standby. They're ESWR chart service water
4 kind of service so they don't meet the criteria
5 for water treating that's cited in GALL so they
6 don't meet the threshold of continuously - or I
7 shouldn't say continuously, but energized more
8 than 25 percent of the time and submerged.

9 MEMBER STETKAR: So the basis for
10 exclusion is not that they might not be submerged,
11 it's that they're not energized more than 25
12 percent of the time, is that correct?

13 MR. FLYTE: That is correct.

14 MEMBER STETKAR: Okay.

15 MR. FLYTE: In addition, we've never
16 seen them submerged so -

17 MEMBER STETKAR: But that doesn't say
18 in the future they might be submerged. But it's
19 basically they're not energized more than 25
20 percent of the time.

21 MR. FLYTE: Right.

22 MEMBER STETKAR: Okay, thanks.

23 MEMBER MAYNARD: Can you just describe
24 briefly what your inspection pumping program is?
25 How often do you look or what criteria do you use

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for when you look?

2 MR. FLYTE: What we did is, I think it
3 was in 2005 we monitored four manholes that we
4 called at that time low points in these duct bank
5 runs for both the 5kV and the 15kV cables. So we
6 picked up all the duct bank runs and over a period
7 of six months we monthly looked at the water
8 accumulation in those manholes and from that we
9 established, you know, a rough infiltration rate
10 if you will of water, an inches per month type of
11 thing. Based on that we set a frequency for
12 inspection and pumping. So depending on the
13 particular manhole it varies, the frequency
14 varies.

15 MEMBER MAYNARD: Have you found that
16 it's fairly predictable, or does it vary quite a
17 bit?

18 MR. FLYTE: From manhole to manhole or
19 in general? I'm not sure I understand the
20 question.

21 MEMBER MAYNARD: Well, I'm saying you
22 based your frequency on what you'd been finding
23 and I guess my real question is based on that
24 frequency have you had to make any adjustments to
25 that frequency, or is that?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. FLYTE: We're actually in the
2 beginnings of this. The most frequent pumping
3 cycle we have is a 3-month frequency, so we've had
4 the opportunity to complete one - a second round
5 on the 3-month pumping and it was right on the
6 mark. So I have one data point that I can offer
7 you and say the first one was good news. However,
8 our PM activities have a threshold that say if
9 you're above this level it gets into the
10 corrective action process and we adjust the pump
11 down frequency and the inspection frequency.

12 MEMBER RYAN: Just a quick follow-up
13 question. Do you know if it's groundwater coming
14 up in all cases, or is it surface water coming
15 down or both?

16 MR. FLYTE: We do not have a
17 definitive answer on that.

18 MEMBER SHACK: Now are you continuing
19 to inspect those manholes associated with the 5kV
20 cables even if it's not a license renewal?

21 MR. FLYTE: Yes, yes we are. We have
22 established the PM activities for those as well
23 and those are in place too.

24 MEMBER RYAN: Again, just one follow-
25 up. Are you working toward trying to figure that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 out?

2 MR. FLYTE: We'll gain experience as
3 we go. I can't say there's any specific plan to
4 try to figure out the exact source. Right now we
5 have what's a success path to keep the cables dry.

6 If we pump it frequently enough they will stay
7 dry so we're relying on that. We're consistent
8 with recommendations in GALL and we're just
9 following that path at this point.

10 Next topic is station blackout
11 recovery scoping. Right in front of us is a
12 conceptual overview of the plant site. And you'll
13 see in kind of the center, upper center there's an
14 area that's enclosing a dotted line which is laid
15 at the fence so that's the plant site. We have
16 the - the power block is the rectangle on the
17 right hand of that fenced area called Susquehanna
18 CS. And of course we have the cooling towers to
19 the left. So just to continue with the general
20 lay of the land here.

21 Well first I'll say that the equipment
22 is built for license renewal. The transmission
23 level or high-voltage equipment is highlighted in
24 red. But to continue with the layout, on the
25 upper left we have a switchyard which is the T-10

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 230 kV switchyard. Lower left is another
2 switchyard which is a 500 kV switchyard. On the
3 far right is the Susquehanna 230 kV switchyard
4 which is located physically across the Susquehanna
5 River from the plant. To review, as you go out
6 from the plant from the power block I'll start
7 with going down the left side of the power block
8 if you will there. We go through startup
9 transformer T-20 and move toward the grid. And
10 you'll see we go into that T-10 230 kV switchyard
11 and include two circuit breakers at the T-30 kV
12 level within scope. As we look for our other
13 offsite power supply source it comes out of the
14 bottom of that power block box there. We move out
15 from transformer T-20, the other startup
16 transformer. That's tapped into a tie line
17 between the two switchyards, the 500 and the 230
18 kV switchyard. And as you can see, we go out and
19 pick up circuit breakers at the 230 kV level in
20 both of those switchyards. So we have established
21 the scoping boundary at the 230 kV breaker level
22 in the switchyards surrounding the plant.

23 MEMBER STETKAR: Dave, just out of
24 curiosity, is the breaker in the lower left
25 corner, the 221 water transformer, is that an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 active breaker or is it a disconnect?

2 MR. FLYTE: It's an active breaker.

3 MEMBER STETKAR: It's an active
4 breaker? Thanks.

5 MEMBER BROWN: The cable that goes
6 across the river, is that overhead?

7 MR. FLYTE: Yes, that's transmission
8 towers. Yes.

9 MEMBER BROWN: Okay.

10 MR. FLYTE: At this point Dale Roth
11 will continue with a discussion of the condition
12 of the containment.

13 MR. ROTH: Good morning. My name is
14 Dale Roth. I'm the supervisor of programs and
15 testing at Susquehanna. As noted earlier, the
16 nuclear steam supply system for each unit at
17 Susquehanna consists of a GE BWR-4 boiling water
18 reactor. The containment is a Mark II pressure
19 suppression design. A cross-section of the
20 containment is shown in the slide. The upper
21 chamber is the drywell, steel-lined concrete cone.
22 The lower chamber is the expression chamber.
23 It's a steel-lined concrete cylinder. The drywell
24 expression chamber is separated by a steel-lined
25 concrete diaphragm slab. During normal operation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the atmosphere is inerted with nitrogen. The
2 reinforced concrete walls of the drywell
3 expression chamber are nominally 6 feet thick.
4 They are designed as the containment's pressure-
5 retaining structure. The liner plate is one-
6 quarter inch carbon steel. It acts as a leak-
7 tight membrane.

8 Visual inspections to the liner plate
9 and concrete structure are performed in accordance
10 with the requirements of ASME Section 11.
11 Pressure testing is performed in accordance with
12 10 C.F.R. 50 Appendix J. Neither inspections nor
13 pressure testing at the station have identified
14 any significant degradation on either unit. As a
15 result, our programs are effectively managing the
16 aging of the containment.

17 MEMBER SHACK: And do you see problems
18 at all with any of your coatings? Does that
19 require continual maintenance?

20 MR. ROTH: We've seen some white
21 corrosion, surface corrosion, minor
22 discolorations, minor pitting. That's it.

23 MEMBER SIEBER: The suppression pool
24 is part of the containment boundary?

25 MR. ROTH: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: What have you done to
2 inspect the condition of the liner underneath the
3 surface of water level?

4 MR. ROTH: Every 10 years it's
5 inspected visually. We bring in divers who are
6 qualified to perform visual inspections of that
7 liner plate.

8 MEMBER SIEBER: And the conditions in
9 the suppression pool, are they - do you consider
10 them mild or aggressive with respect to corrosion?

11 MR. ROTH: We have seen some
12 corrosion, but I don't consider it aggressive.

13 MEMBER SIEBER: Well, what have you
14 seen?

15 MR. ROTH: Again, minor degrees of
16 corrosion and some minor pitting. That's all
17 that's been reported.

18 MEMBER SIEBER: Pitting of the coating
19 or the liner itself?

20 MR. ROTH: Into the coating and a
21 little bit into the liner.

22 MEMBER SIEBER: Okay, and have you
23 done any repairs?

24 MR. ROTH: We have not been required
25 to do any repairs.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Have you done anything
2 other than visual examinations?

3 MR. ROTH: Other than pressure
4 testing. Pressure testing and visual inspections.

5 MEMBER SHACK: In the submerged case,
6 are those coatings - you just repair them as
7 needed?

8 MR. ROTH: As needed, that's right.

9 MEMBER SIEBER: How do you repair a
10 submerged coating?

11 MR. ROTH: There are materials that
12 can be deployed underwater. I don't have the
13 details, but there are materials that can be
14 applied.

15 MEMBER SHACK: The diver does the
16 repair?

17 MR. ROTH: Yes, the diver does it.

18 MEMBER BROWN: Waterproof paintbrush.

19 (Laughter)

20 MEMBER SIEBER: Okay.

21 MEMBER BROWN: Can I ask one question?

22 Back on the steel liner underwater. I'm not a
23 corrosion expert, but guys down there with goggles
24 on. I mean, it's just this nice clear water or is
25 there a -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: This is the clearest
2 water you've ever seen.

3 MEMBER BROWN: Well, it just seems a
4 little bit beyond me that you can go down and do
5 an inspection for corrosion. I mean, how do you
6 even get a corrosion thickness value if you're
7 underwater? I mean, that's -

8 MR. ROTH: We do it as part of our
9 clean-out of the inspection pool. So we bring in
10 filtering equipment. We run all the water through
11 a filter medium. We do vacuuming of all the
12 material off the bottom of the expression pool so
13 the water is quite clean when they get done, and
14 then they do the inspections after they're done.

15 MEMBER POWERS: You cannot judge the
16 depth of the water by looking from the top because
17 it is so clear.

18 MEMBER MAYNARD: Do you also use
19 cameras?

20 MR. ROTH: I believe we use cameras.
21 I'm not - I know we've done visual inspections
22 using the divers.

23 MEMBER SIEBER: Relatively calm in
24 that you can - in the pressure pool?

25 MEMBER BROWN: Well, the diver's got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to sit there and wiggle his fins.

2 MEMBER SIEBER: Well yes. My question
3 is to what - some debris also comes from the
4 operation. Any other debris that's there has to
5 come from corrosion at the surface. Do you look
6 at the debris that you retrieved to try to figure
7 out where it came from?

8 MR. ROTH: We -

9 MEMBER SIEBER: If you get a lot of
10 rust.

11 MR. ROTH: We do characterize the
12 debris that we do pull out, the sludge. Some of
13 it is - it may be dropped in from above. Some of
14 it may be corrosion particles.

15 MEMBER SIEBER: Okay. I have to think
16 about that a little bit.

17 MEMBER ARMIJO: When you inert the
18 containment, do you sparge the suppression pool in
19 that, or do you just let the nitrogen just -

20 MR. ROTH: No, we just let the
21 nitrogen fill the volume.

22 MEMBER ARMIJO: Okay. So whatever
23 oxygen that would be available to cause corrosion
24 is still in the water, but there's no air.

25 MR. ROTH: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Is the oxygen content
2 of the water monitored?

3 MR. MILLER: Dan Miller, chemistry.
4 We do not monitor the dissolved oxygen level in
5 the suppression pool water.

6 MEMBER BROWN: I missed it.

7 MR. MILLER: We do not.

8 MEMBER BROWN: You don't, okay. All
9 right. That answers it.

10 MEMBER POWERS: Why would you?

11 MEMBER BROWN: If there's no oxygen,
12 you can't corrode. If you have oxygen, you can.
13 I'm not a chemist, but that's -

14 MEMBER SIEBER: Adequate oxygen,
15 potential to corrode.

16 MEMBER ARMIJO: Right, that's what I
17 asked about the sparging. That could be pretty
18 effective to strip oxygen. They don't do that.

19 MR. PELTON: This is Dave Pelton.
20 I've just got a request from the back of the room.
21 If we could move a little closer to the
22 microphones. We're having a little trouble
23 hearing. So thank you so much. This is all good
24 conversation, they want to make sure they're all
25 hearing it all.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. FLYTE: The last of the
2 subcommittee follow-up items on our agenda today
3 is the aging evaluation that was performed for the
4 main steamline flow restrictors. The aging
5 evaluation that we performed identified two
6 possible aging concerns. One is corrosion, loss
7 of material due to corrosion and the second is
8 loss of material due to erosion. Flow restrictors
9 are formed of cast austenitic stainless steel and
10 carbon steel. And in the environment of - the
11 reactor cooling environment, corrosion is an
12 applicable aging effect. So consistent with GALL
13 - and that's an aging effect for both materials,
14 the cast and the carbon steel. Consistent with
15 GALL we've credited the BWR water chemistry
16 program supplemented by a one-time inspection to
17 verify effectiveness as the aging management
18 program. Even though it is a dry steam
19 environment and not conducive to corrosion, GALL
20 would recommend that you have an aging management
21 program. The one-time inspection scope will be
22 determined by engineering evaluation. And they'll
23 ensure that all the components that are inspected
24 are most susceptible to corrosion and bound all
25 the components that are in the population being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 managed by the BWR water chemistry program.

2 The aging management evaluation for
3 erosion concluded that this is not an aging effect
4 that requires management. And it was evaluated as
5 a time-limited aging analysis and dispositioned
6 per 10 C.F.R. 54.21(c)(1)(ii) which is the option
7 for projecting for 60 years. The real bottom line
8 on the erosion is that it's in a dry steam
9 environment and the material is resistant to
10 erosion so that's the bottom line why it's not an
11 aging concern.

12 MEMBER SIEBER: Yes, the steam
13 condition is saturated and not super-heated,
14 right?

15 MR. KRAIS: Correct.

16 MEMBER SIEBER: So it's really not
17 dry. What you're really saying is it's very high-
18 quality. Content on the order of typically is
19 less than 1 percent. But to say it's dry is not
20 correct, right?

21 MR. KRAIS: Moisture content -

22 MEMBER SIEBER: Yes. Okay, thank you.

23 MEMBER SHACK: What was the design
24 decision on whether the flow restrictor is cast
25 stainless or carbon steel?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KRAIS: I am sorry, what was the
2 question?

3 MEMBER SHACK: You said the flow
4 restrictors are austenitic cast - or I mean, are
5 cast stainless steel or carbon steel?

6 MR. FLYTE: I'm sorry, the
7 clarification on that is the leading edge in the
8 venturi is cast and the -

9 MEMBER SHACK: Okay. That makes a
10 whole lot more sense. Okay.

11 VICE CHAIR ABDEL-KHALIK: And what is
12 the velocity in the flow restrictor compared to
13 the velocity in the steam line?

14 MR. FLYTE: The velocity in the steam
15 line is about 150 feet per second and in the
16 venturi it's about 600 feet per second.

17 VICE CHAIR ABDEL-KHALIK: Six hundred
18 feet per second. And at 600 feet per second you
19 had no erosion concerns?

20 MR. FLYTE: Again, going back to the
21 dry steam, it's no concern with erosion. I'm
22 sorry, I continue to call it dry steam here.

23 In summary, the Susquehanna license
24 renewal application was developed by an
25 experienced project team that was actively

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 involved extensively with the industry throughout
2 the preparation and review. And to help ensure
3 that we submit an application that complied with
4 the regulatory requirements, followed the industry
5 guidance and met current expectations. The
6 application had a thorough review by the staff and
7 the PPL project team worked aggressively with the
8 staff to understand and resolve issues as they
9 came up which resulted in an SER with no open
10 items. The bottom line for Susquehanna is that we
11 will manage aging of equipment and structures in a
12 period of extended operation.

13 MEMBER SHACK: Just looking ahead to
14 the staff's. You had 59 commitments, now you've
15 picked up one more, right?

16 MR. FLYTE: That's correct.

17 MEMBER SHACK: What's the sixtieth
18 commitment?

19 MR. FLYTE: The sixtieth is for Boral,
20 for coupon testing.

21 MEMBER ARMIJO: Just going back to the
22 containment. When you did your industry
23 experience review, did you check with other Mark
24 II - plants that had Mark II containments to see
25 if they had the same favorable experience as far

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as liner corrosion?

2 MR. FLYTE: We did not actively
3 contact individual plants. However, we looked at
4 their operating experience with everybody else's
5 and saw the absence of operating experience so in
6 that way we did.

7 MEMBER ARMIJO: I'll ask the same
8 question of the staff.

9 MEMBER SHACK: This liner, it's
10 directly on the concrete.

11 MR. ROTH: Yes, the concrete was
12 poured right up against it.

13 MEMBER SHACK: Right up against it.
14 There's no spacer or anything that was used as a
15 construction aid as we say?

16 MR. ROTH: No.

17 MEMBER MAYNARD: And the liner is more
18 of a diaphragm. It's not intended to be a
19 standalone if the concrete wasn't there?

20 MR. ROTH: That's correct. The
21 concrete is the pressure-retaining structure of
22 the liner's membrane.

23 VICE CHAIR ABDEL-KHALIK: Are there
24 studs that hold the liner to the concrete?

25 MR. ROTH: Yes, there's studs on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 back of the liner plate that are used to bond it
2 to the concrete essentially when it's poured.

3 MEMBER SIEBER: Same as a PWR large
4 dry containment.

5 MR. FLYTE: That concludes our
6 presentation for today.

7 MEMBER SHACK: Committee? Thank you
8 very much, gentlemen.

9 MS. GETTYS: Good morning. My name is
10 Evelyn Gettys and I am the safety project manager
11 for the Susquehanna Steam Electric Station Units 1
12 and 2. Today I will be discussing the staff's
13 review of Susquehanna's license renewal
14 application. Can you hear me? Okay. This is the
15 overview of the review. Section 2 is the scoping
16 and screening review. Region 1 performed the
17 license renewal Region 1 inspection. Section 3 is
18 the aging management program and review. Section
19 4 is the time-limited aging analysis, or TLAs, and
20 then the conclusion.

21 This is some background information
22 that was mostly covered by the applicant. Just go
23 on to the next slide. This slide is a recap of
24 the April 1, 2009, ACRS subcommittee meeting. The
25 Safety Evaluation Report which I will refer to as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the SER throughout the rest of the presentation
2 was issued in March 2009. The staff issued 278
3 requests for additional information with the
4 applicant making 59 commitments. There were no
5 open items and there were no confirmatory items.
6 As previously mentioned, the staff issued the SER
7 in March 2009 and at that time two plants under
8 review for license renewal had issues with Boral
9 and metal fatigue. It was decided that the staff
10 would issue RAIs on these emerging issues.
11 However, they were not able to do so until after
12 the SER meeting. Therefore, subsequent to the
13 subcommittee meeting there were additional RAIs
14 issued, five on Boral and three on metal fatigue.
15 As a result of the RAIs issued, the applicant
16 amended the LRA and included one additional
17 commitment on Boral which I will talk about in
18 more detail later in the presentation.

19 Since issuing the March 2009 SER there
20 have been no changes to Section 2 and the staff
21 concluded that the applicant scoping and screening
22 methodology is consistent with the requirements of
23 10 C.F.R. 54.4 and 10 C.F.R. 52.21(a)(1) and that
24 there were no emissions from the scope of license
25 renewal. There were no emissions from the aging

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review in accordance. Since issuing the March
2 2009 SER, there have been no changes to the
3 regional inspection and the conclusions remain as
4 the scoping of non-safety structure system
5 components and the aging management programs are
6 acceptable. Inspection results support a
7 conclusion of reasonable assurance that aging
8 effects will be managed and that the intended
9 functions will be maintained. Section 3 of the
10 SER consists of the following subsections. I do
11 not plan to cover the subsections, but we'll touch
12 on those which are of interest.

13 After the subcommittee meeting, the
14 staff requested additional information on the
15 emerging issues regarding neutron-absorbing
16 material in the spent fuel pool. In Susquehanna's
17 case it's Boral. In response to the RAIs, the
18 applicant made an additional commitment regarding
19 Boral, that in the spent fuel pool, the Boral
20 coupon testing program will be continued into the
21 period of extended operation and that the aging
22 effects will be managed through the water
23 chemistry program and the Boral coupon testing
24 program. The staff found the responses to the
25 RAIs acceptable and revised the SER. Next.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This was the staff's conclusion for
2 Section 3. Based on its review of the LRA and
3 additional information submitted as a result of
4 RAIs, the staff concluded that the effects of
5 aging will be managed so that the intended
6 function will be maintained during the period of
7 extended operations per 10 C.F.R. 54.21(a)(3).
8 This is the list of the time-limiting aging
9 analysis. Changes were made to 4.3 which covers
10 metal fatigue. In 4.3.1 which is the reactor
11 pressure vessel fatigue analysis, the staff asked
12 the applicant to address transience event, design
13 specifications and the recording of transient
14 data. The applicant responded and indicated that
15 all monitoring transient events are bounded by the
16 design specifications and that the cycle tracking
17 activities cover the entire operating history of
18 the plant. The staff found the applicant's
19 response acceptable and revised the SER. The
20 staff asked the applicant to justify the large
21 reduction in the projected 60-year cumulative
22 usage factor, or CUF values seen for some
23 locations. With relatively minor reduction in
24 cycle projections, even though some transients had
25 projected cycles higher than design cycles. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 applicant provided justification for the 60-year
2 CUF by stating that the 40-year design CUF values
3 had incorporated extra conservatism, including
4 contributions from fault condition loads directly
5 using results of bounding locations and
6 conservative design cycles. Unnecessary
7 conservatism was removed in the 60-year fatigue
8 analysis. The staff found the applicant's
9 response acceptable and revised the SER.

10 In 4.3.3 which covers the effect of
11 reactor coolant environment on fatigue life of
12 components and piping, the staff requests that the
13 applicant provide pre-1994 data to supplement the
14 data previously provided and also the
15 justification for the dissolved oxygen data
16 applicable to all NRC - excuse me, NUREG/CR/6260
17 components. The applicant provided the dissolved
18 oxygen data, described the water samples, schedule
19 schemes and the water flow routes and demonstrated
20 the applicability of the sample data to all the
21 NUREG/CR/6260 locations. The staff found the
22 applicant's response acceptable and revised the
23 SER.

24 The conclusions for Section 4 on the
25 TLAs is that based on its review of the LRA and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 additional information submitted as a result of
2 the RAIs, the staff concluded that the applicant
3 provided an adequate list of TLAs for 10 C.F.R.
4 54.3 and that the TLAs will remain valid for the
5 period of extended operation, the TLAs have been
6 projected to the end of the period of extended
7 operation, or the aging effects will be managed
8 for the period of extended operation. The staff's
9 overall conclusion for Susquehanna is that it is
10 reasonable assurance that the activities
11 authorized by the renewed license will continue to
12 be conducted in accordance with the current
13 license bases and any changes made to
14 Susquehanna's current license basis, in order to
15 comply with 10 C.F.R. 59.29(a) are in accordance
16 with the Act and the Commission's regulations.
17 That's the end. Any questions?

18 MEMBER ARMIJO: Yes, I have a couple
19 of questions, one related to the Boral. You say
20 the applicant is going to - has a coupon testing
21 program. How does the staff relate that coupon to
22 the actual condition of the Boral in the racks
23 themselves? Is there a supplementary inspection
24 of the condition of the Boral in the fuel storage
25 racks themselves? That says okay, these coupons

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are truly representative of what's going on in the
2 racks.

3 MS. GETTYS: I think Emma wants to
4 address that.

5 MEMBER ARMIJO: Or the applicant,
6 either.

7 MS. WONG: This is Emma Wong of the
8 staff. Could you repeat the question?

9 MEMBER ARMIJO: Yes. I don't fully
10 understand the coupon testing program, but I'm
11 assuming that you have some samples that are
12 periodically tested in one way or another and
13 examined or tested to see how much attenuation -
14 neutron absorption there is. But how do you know
15 that that is representative of what's actually in
16 the racks themselves? Are the - is the Boral in
17 those racks inspected as well?

18 MS. WONG: As far as I know at
19 Susquehanna they don't actually inspect the Boral
20 in the racks, they just rely on their coupon
21 testing program until they find some sort of
22 indication that there would be start of
23 degradation. Then they would put that into the
24 corrective action program and then they might look
25 into the Boral on the racks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: And how have they
2 demonstrated that that's okay, that those coupons
3 are truly representative of what's going on in the
4 racks?

5 MS. WONG: So their coupons have been
6 placed in areas of the highest neutron flux. So
7 they always put them near freshly discharged fuel
8 every time which is not usually what the racks
9 see. They shuffle around the fuel in the racks.
10 So they don't actually see the highest neutron
11 flux every time. So the coupons actually receive
12 more flux than the racks would ever actually see.
13 So that would be an indication before degradation
14 in the racks actually would happen.

15 MEMBER ARMIJO: Maybe the applicant
16 would like to comment. I'm still a little
17 confused.

18 MR. HOFFMAN: Chris Hoffman, Nuclear
19 Fuels, PPL Susquehanna. The coupons are basically
20 double-chambered. They have one dry chamber and
21 one wetted chamber. The dry chamber is
22 representative of the Boral can in its
23 manufactured condition. The wetted chamber would
24 be representative of Boral can if you add water
25 infiltration. Coupons are taken out of the fuel

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pool and analyzed on a periodic basis. So they
2 are representative of the performance of the Boral
3 in the actual pupil.

4 MEMBER ARMIJO: Just to put it to bed,
5 have you actually inspected the Boral in the racks
6 at any point? Just to make sure everything's
7 okay.

8 MS. GETTYS: I believe they've had
9 camera inspections also.

10 MR. HOFFMAN: We have not inspected
11 the Boral in the racks. We use the coupon testing
12 program as a representative sample of what is in
13 the racks.

14 MEMBER ARMIJO: Okay. That's all I
15 have for that. My second question had to do with
16 the dissolved oxygen in order to justify the
17 environmental correction factor. Is there any
18 requirement - the data that's used to - the
19 historical data, was that data required by tech
20 specs in the plant operation? Does Susquehanna
21 have to take that data even today by tech spec, or
22 is that just something they record as a routine
23 operational matter?

24 MS. GETTYS: I'm not sure if it's part
25 of the tech specs or not.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: Does Susquehanna know?

2 MS. GETTYS: I believe they're coming
3 to the mic right now.

4 MR. MILLER: If I understand the
5 question, are you asking do we take dissolved
6 oxygen measurements as part of our tech specs or
7 some -

8 MEMBER ARMIJO: Yes.

9 MR. MILLER: Okay. We measure
10 dissolved oxygen in reactor water and feedwater to
11 comply with the EPRI BWR water chemistry
12 guidelines. They are not technical specification-
13 related.

14 MEMBER ARMIJO: And your historical
15 data actually was before some of those guidelines,
16 so you were taking them for your own purposes I
17 guess?

18 MR. MILLER: Yes. The guidelines were
19 issued circa 1982 so yes, I suppose a few of those
20 could have been before the guidelines. Yes.

21 MEMBER ARMIJO: Okay. So in the
22 future you're just going to take it to be in
23 compliance with the EPRI guidelines on water
24 chemistry?

25 MR. MILLER: We are also putting in an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 administrative limit for feedwater dissolved
2 oxygen not to exceed 50 parts per billion. Now
3 that is more conservative than the current
4 guidelines.

5 MEMBER ARMIJO: Okay, thank you.

6 MEMBER SIEBER: Could you state your
7 name?

8 MR. MILLER: I'm sorry. My name is
9 Dan Miller, Station Chemistry, Susquehanna.

10 MEMBER SHACK: Do you have a minimum
11 on the oxygen content for the feedwater?

12 MR. MILLER: Yes, we have a minimum of
13 30 parts per billion.

14 MEMBER SHACK: Any further questions
15 from the committee? Thank you very much.

16 MS. GETTYS: Thank you.

17 MEMBER SHACK: We are ahead of
18 schedule, Mr. Chairman, but I'll turn it back to
19 you.

20 CHAIR BONACA: This has been a very
21 efficient presentation. Looking at the agenda we
22 have for today I think we will have to simply
23 adjourn now - I mean, recess now for lunch and
24 start again at 1:15. Okay. Let's recess until
25 1:15.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 (Whereupon, the foregoing matter went
2 off the record at 11:32 a.m. and went back on the
3 record at 1:15 p.m.)

4 CHAIR BONACA: So, let's get back into
5 session. The next item on the agenda is Steam
6 Generator Action Plan, Task 3.5, A Risk Assessment
7 of Consequential Steam Generator Tube Ruptures,
8 and other SGAP items. And Dr. Powers will take us
9 through the presentation.

10 MEMBER POWERS: This is actually under
11 the purview of our Materials, and Metallurgy, and
12 Fuels Subcommittee headed by up by Mr. Meagle, at
13 his behest in this process.

14 MEMBER SHACK: And I should point out
15 that I have a conflict of interest in this, since
16 Argonne did a substantial amount of work on some
17 elements of the steam generator program.

18 MEMBER SIEBER: Say that again.

19 MEMBER SHACK: I have a conflict of
20 interest because Argonne was involved in work on
21 the steam generator -

22 MEMBER POWERS: Understand, of course,
23 that the steam generator tubes are part of the
24 primary system pressure boundary, and rupture of
25 those steam generator tubes has been recognized

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 since PWRs came into existence as a failure of the
2 primary pressure boundary. And they are subject
3 to a great deal of scrutiny during plant
4 operation.

5 Over the years, a mechanism by which
6 steam generator tubes degrade in time has evolved.

7 I hasten to comment that rupture of a steam
8 generator tube is a design-basis accident. Plants
9 are designed to cope with such an accident. And,
10 indeed, we have such events, and the plants have
11 coped well.

12 Over the years, the mechanism that
13 leads to a steam generator rupture through
14 corrosion has evolved from a corrosion process
15 that resulted in tube wastage, to one that
16 involves cracking. Wastage, of course, is the
17 removal of material, and is relatively easily
18 detected. And the regulations were originally
19 configured to account for that wastage. Whereas,
20 the mechanism that leads to cracking would have
21 alternate ways of detection and interpretation.

22 The industry evolved, and an
23 alternative repair criterion was established based
24 on voltage of the turbine. But there was a
25 probability of detection. And, of course, that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 means that there's a probability of non-detection.

2 And, consequently, tubes that have flaws in them
3 are -- generally exist in steam generators, and
4 plants are allowed to operate.

5 This raises the question of can you
6 have accidents initiated by other means that
7 evolve into a steam generator tube rupture
8 accident? Why would we care, if that evolution
9 took place, of course, is that where the activity
10 that gets released would pass directly into either
11 auxiliary buildings, or, in some cases, directly
12 to the environment without having benefit of
13 mitigation by systems within the containment in
14 cold bypass accidents. And, typically, though
15 rare, they certainly can dominate the risk at
16 pressurized water reactors.

17 At any rate, the Staff has been
18 addressing steam generator tubes for some time
19 through an action plan. And ACRS, in a review of
20 the alternative criteria for evaluating flaws in
21 tubes, made a variety of recommendations that the
22 Staff added to their action plan, and have
23 pursued. And they pursued them sufficiently far
24 that they think that it's time to bring this
25 action plan to a close.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The closure here is different than
2 completing the research. Closure here does not
3 mean topics all come to an end, and we never look
4 at them again. And we have a report to write up,
5 and it is the definitive word on the subject, and
6 will stand for decades to come.

7 Closure, here, is a general thing,
8 which means that the research moves into the
9 regular research program, and becomes directed
10 more toward the needs of the line agency, line
11 organizations in the agency, NRO or NRR, one or
12 the other, what they need for their particular
13 activities, as opposed to a more generic research
14 looking to make sure we understand the width and
15 the breadth of this subject.

16 Staff has come to us and said gee,
17 we'd like to close this research, close this
18 action plan. Not really close the research, but
19 close the action plan. Staff came to us to
20 discuss this because based on our report some time
21 ago, the Commission actually asked us to watch the
22 action plan. And, episodically, we have over the
23 time. So, the purpose of today's discussion is
24 for the staff to describe both parts of the action
25 plan that they have not previously closed out,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 usually with our -- coming to us and discussing
2 their closure on. And, in the main, what they're
3 going to discuss is the work done on the problem
4 of induced steam generator tube rupture; that is,
5 something causes a plant to enter into an
6 accident. And that accident evolves in a
7 direction that involved ruptures in generator
8 tube, and venting of radionuclides to the outside.

9 And, again, what they're asking to do,
10 they will articulate, I'm sure, but, in general,
11 what they're asking us to do is to close these
12 items in the action plan. And where additional
13 research will be needed to support the line
14 organizations, that research will be initiated
15 based on a user need letter.

16 Okay. Are there any questions on that
17 introductory part? With that, I will ask David
18 Beaulieu to begin the presentation.

19 MR. BEAULIEU: My boss, Tim McGinty,
20 is going to be -

21 MEMBER POWERS: Oh, I'm sorry. Tim.
22 Tim is going to start. Sorry about that, Tim.

23 MR. MCGINTY: Just a couple of opening
24 remarks. First off, thank you very much, Dr.
25 Powers. Good afternoon, Mr. Chairman, and members

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of the Committee. I'm Tim McGinty, Director of
2 the Division of Policy and Rulemaking in NRR.
3 It's the division responsible for the project
4 management of the Steam Generator Action Plan.

5 First off, I'd like to thank the
6 Committee, and the Subcommittee for taking the
7 time to review the staff's work, in light of the
8 large amount of supporting documentation, and the
9 history associated with the Action Plan.

10 Today, Dave Beaulieu is the lead
11 Project Manager for the Action Plan, and he'll be
12 providing the opening staff presentation. Others
13 that we have here are Bob Palla from NRR, and from
14 Research we have Chris Boyd, and Tim Lupold, and
15 Selim Sancaktar. And, also, in the audience we
16 have various staff members who contributed to the
17 Action Plan close-out effort, particularly, Ken
18 Kowalski and Evan Murphy, that I would call to
19 your attention.

20 As I mentioned, Dave will begin with
21 the presentation providing an overview of the
22 Steam Generator Action Plan, the desired outcome
23 of this meeting, and future plans regarding steam
24 generator research activities. The staff has
25 completed all of its work on all steam generator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 action items, and has provide the close-out
2 documentation to ACRS.

3 And, as Mr. Beaulieu will explain
4 further, the desired outcome of the ACRS review is
5 a letter from ACRS that finds acceptable the
6 staff's close-out of each action plan item that
7 ACRS has not previously reviewed, and closed.

8 Following the ACRS review, the staff
9 would like to close the Steam Generator Action
10 Plan. So, with that said, I apologize also in
11 advance, because I have another commitment at 2:00
12 that I'll need to depart for, and I appreciate
13 your understanding in that regard.

14 MEMBER POWERS: Oh, no understanding
15 at all.

16 (Laughter.)

17 MR. MCGINTY: It's on pandemic. So,
18 Dave.

19 MR. BEAULIEU: Thanks, Tim. We'll
20 keep to our schedule here. I'm Dave Beaulieu,
21 Project Manager. And I'm going to start out with
22 Steam Generator Action Plan history.

23 During the NUREG-1150 severe accident
24 risk studies from 1985 to 1990, the issue of
25 consequential steam generator tube rupture was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 evaluated. What we mean by consequential tube
2 rupture, is that we mean that instead of the steam
3 generator tube rupture itself being the initiating
4 event, consequential tube ruptures refer to those
5 ruptures that may be caused as a result of another
6 initiating event, such as a very large main steam
7 line break that leads to a high differential
8 pressure across the steam generators, or severe
9 accident condition that leads to the failure of
10 steam generator tubes.

11 For severe accident-induced steam
12 generator tube ruptures, the concern was that high
13 temperature gases created during core damage
14 sequences could cause steam generator tubes to be
15 the first component in the reactor coolant
16 pressure boundary to fail, resulting in a
17 potential containment bypass, and the release of
18 large amounts of radioactive material outside
19 containment.

20 NUREG-1150 quantified the frequency of
21 this occurrence in the low ten to the minus six
22 per reactor year on the basis of expert
23 elicitation.

24 MEMBER APOSTOLAKIS: This was the
25 frequency, the initiating event, plus the -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BEAULIEU: Of?

2 MEMBER APOSTOLAKIS: The whole thing.

3 MR. BEAULIEU: Of an actual bypass.

4 MEMBER APOSTOLAKIS: A bypass, okay.

5 Yes. But did they say anything about the condition
6 or probability of the consequential failure?

7 MEMBER POWERS: In fact, it's about
8 ten to the minus two.

9 MEMBER APOSTOLAKIS: Ten to the minus
10 two.

11 MEMBER POWERS: This is a product of
12 expert elicitation, so it's actually a
13 distribution.

14 MEMBER APOSTOLAKIS: You really liked
15 Dr. Powers jumping in, didn't you?

16 MR. BEAULIEU: Yes, I like that.

17 In the early 1990s, the industry made
18 several requests for relaxation of regulatory
19 requirements regarding steam generator tube
20 integrity. A differential -- a differing
21 professional opinion was filed involving concerns
22 with these industry relaxation requests, given
23 that eddy current methods could accurately measure
24 uniform tube wall thinning as a result of general
25 corrosion, they were less reliable in detecting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and sizing cracks that occurred in Alloy 600
2 tubes, as a result of stress corrosion cracking.

3 The staff review of these requests
4 identified that granting them might substantially
5 increase a conditional probability of containment
6 bypass during core damage accidents.

7 At approximately the same time, in the
8 early 1990s, NRR, with the assistance of Research,
9 began a study of the effects of severe accident
10 conditions on tube integrity, as background
11 information on a proposed new rulemaking on tube
12 integrity. The results of this study published as
13 NUREG-1570 indicated that the risk is controlled
14 by the current tube integrity requirements to a
15 value that is low enough that no new rulemaking
16 was needed. The NUREG was not intended to address
17 DPO, necessarily, and DPO is still open at this
18 time.

19 In 2000, following the rupture of the
20 steam generator tube at Indian Point, Unit 2,
21 there was additional focus on the resolution of
22 several longstanding issues, including the DPO.
23 The DPO was referred to ACRS by the EDO for
24 resolution.

25 After extensive public meetings, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review of the issues raised in the DPO, the ACRS
2 published NUREG-1740, to present its conclusions
3 and recommendation. In particular, ACRS concluded
4 that the methodology being used to quantify the
5 risk of containment bypass under high temperature
6 challenges to steam generator tubes was not
7 technically defensible.

8 The technical staff in NRR and
9 Research jointly reviewed the text of the ACRS
10 NUREG-1740 to extract a list of issues that
11 required additional work. These tasks were
12 incorporated into a new section of the steam
13 generator action plan, which identified specific
14 staff members with lead responsibilities for each
15 task, and schedules for completing each task.

16 Most, but not all, of the steam
17 generator action plan tasks are directly related
18 to work that defined the risk associated with
19 severe accident-induced steam generator tube
20 ruptures leading to containment bypass.

21 Section 3 of the action plan also
22 included work, such as that performed under Items
23 3.1 and 3.11 of the action plan, that involve
24 design-basis events, which address the potential
25 for damage progression of multiple steam generator

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 tubes due to steam generator depressurization
2 events, such as a main steam line break, or other
3 type of secondary side design-basis accident.

4 The staff's work to address steam
5 generator action plan items involving design-basis
6 events is complete, and ACRS has reviewed and
7 endorsed the closure of these items. This was
8 based on the overall conclusion of the work, which
9 is that the dynamic loads from such design-basis
10 events are low, and do not affect the structural
11 integrity of the tubes, or lead to additional
12 leakage or ruptures beyond what will be determined
13 using differential pressure loads across the tubes
14 alone.

15 MEMBER POWERS: It is fair to say,
16 isn't it, David, that that's a generic
17 endorsement, that you still have to validate for
18 each plant that, in fact, they fit the constraints
19 that existed on that conclusion. That is, the
20 plates have to be locked, and not left easily, and
21 things like that.

22 MR. BEAULIEU: That's true.

23 MEMBER POWERS: Yes, you answered -

24 (Laughter.)

25 MR. BEAULIEU: Where does the action

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 plan stand today? The staff has completed its
2 work to close all the steam generator action plan
3 items, and a close-out document has been provided
4 to ACRS. The purpose of this meeting is for ACRS
5 to review all action plan items that ACRS has not
6 previously reviewed and closed.

7 The desired outcome. The staff
8 requests a letter from ACRS that finds acceptable
9 the staff's close-out of each steam generator
10 action plan item that ACRS has not previously
11 reviewed and closed. These items are 3.1.k, 3.4,
12 3.5, 3.10, 3.11, and 3.12.

13 So, what can you expect to hear from
14 us today? Essentially, all the items are directly
15 related to the work to define the risk associated
16 with severe accident-induced steam generator tube
17 rupture leak on containment bypass. This work
18 involved the following technical areas of
19 research, including thermal hydraulics, steam
20 generator tube material failures, reactor coolant
21 system material failures, component behavioral
22 studies, and probabilistic risk assessment.

23 The way these work together is the
24 thermal hydraulics work takes the PRA sequence
25 being evaluated and determines the fluid

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 temperatures, and pressures as a function of time.

2 These conditions are then used as inputs into the
3 reactor coolant system material failure and
4 component behavior models.

5 Finally, all the thermal hydraulic
6 information, and the material failure information
7 are logically combined into a PRA model to
8 determine the risk associated with a consequential
9 steam generator tube rupture.

10 Future activities. While the close-
11 out documents for each steam generator action plan
12 item provides a solid basis for closing the item,
13 NRR User NEED to Research is in concurrence that
14 requests specific research products to facilitate
15 the development, and review of future risk
16 assessments involving consequential steam
17 generator tube rupture events. These products
18 will build upon the analysis methods, tools, and
19 expertise developed as part of the steam generator
20 action plan.

21 The research work to address the NRC
22 User Need no longer requires the level of
23 coordination and agency focus that's required to
24 implement an action plan.

25 MEMBER APOSTOLAKIS: What does that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean?

2 MR. BEAULIEU: It's that the level of
3 review, the action plan process is a higher level
4 review. It's something that can't go away. It
5 has to be done, and it's not -- in my next few -

6 MEMBER APOSTOLAKIS: Why did you think
7 it was important for you to tell us this?

8 MR. BEAULIEU: Okay. In my next
9 statement, I'll explain that. Consequently, the
10 closure of the action plan does not preclude
11 future research activities, but we'd simply like
12 the future activities associated with a topic to
13 be coordinated with other agency tools, such as
14 User Needs. In the planning and budget process
15 means that the work going forward goes into all of
16 Research's work, and based on risk, it's budgeted
17 and prioritized consistent with all the work
18 that's on Research's plate. And we'd like to do
19 that in the future versus adding new additional
20 steam generator action plan items. We've
21 completed the work on the current items.

22 MEMBER APOSTOLAKIS: Well, I think
23 what you're saying is that the basic work has been
24 done.

25 MR. BEAULIEU: Basic work has been

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 done.

2 MEMBER APOSTOLAKIS: It's just
3 guidance how to do it on a plant-specific basis.

4 MEMBER POWERS: You can certainly
5 agree to disagree with me, but my perception is
6 that an action plan was formulated here because
7 there was a question on whether the existing
8 regulatory structure provided adequate protection
9 or not. And, therefore, reach a high priority. I
10 think that when we close this out, we're
11 essentially saying the staff has done enough work
12 now to say well, the issue of adequate protection
13 as a generic undertaking has been addressed.

14 Now, that does not mean that in
15 specific things, there will not need to be
16 additional research done in order to look at a
17 specific question that came up. But the generic
18 question of are we providing adequate protection
19 is a satisfactory answer. Is that a fair -

20 MR. MCGINTY: I don't disagree with
21 that. And we just wanted to be careful not to
22 have any kind of a misunderstanding, either with
23 the Committee, or the public, that this
24 represents, or precludes additional research, as
25 necessary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Well, I'm curious
2 about one thing. One of the items you want to
3 close, the basis for your closure is that you
4 intend to do additional work. Plus, it says it's
5 okay to close that item, but what prompts you to
6 track the tactic you're actually going to do that
7 additional work, when you don't really have the
8 funding or the approval to do it?

9 MR. BEAULIEU: We have User Need that
10 is one particular topic that Bob Palla will be
11 discussing with you today that covers the User
12 Need that's currently in concurrence. And pretty
13 thorough research has concurred on it so far, and
14 it's in the final throws of NRR management.

15 MR. MCGINTY: Right. So, I can't,
16 necessarily, say it's agreed upon and approved
17 yet, but I would also say -

18 MEMBER SIEBER: Yes. On the other
19 hand, to the legitimate sense, since these action
20 plan items came from our NUREG, the ACRS' NUREG,
21 why would we close an item when the work really
22 isn't done? What you're telling us, the work
23 isn't done, in that one item.

24 MR. BEAULIEU: I'm not sure which one.
25 We think the work is done -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: By the time you're
2 done, I'll find it.

3 MR. BEAULIEU: Okay.

4 MEMBER SIEBER: Okay.

5 MR. BEAULIEU: Yes. We think we've
6 provided sufficient basis for closing all the
7 items.

8 MEMBER SIEBER: Why don't we listen to
9 that.

10 MR. MCGINTY: All right. Fair enough.

11 MR. BEAULIEU: With that, we'll go to
12 the easiest item. This will take just a minute.
13 This is just simply an administrative item, steam
14 generator action plan item 3.11, was GSI-163.
15 ACRS has reviewed, and found acceptable, and
16 closed GSI-163. But in the staff's presentation,
17 we never mentioned that, by the way, this is also
18 Item 3.11 of the action plan. So, this proposed
19 document that Item 3.11 is closed.

20 MEMBER POWERS: We have to do that,
21 because the Commission sent us a letter to track
22 these items. So, consequentially, we've got a
23 little mechanics here, anyway.

24 MR. BEAULIEU: Okay. With that, our
25 next presenter is Chris Boyd.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BOYD: My name is Christopher
2 Boyd. I'm from the Office of Research. And I'm
3 going to talk to you about Action Plan Items 3.4A-
4 G. I don't list them. I believe you guys have a
5 record of what they are. But, basically, it's the
6 thermal hydraulics calculations, the system,
7 number of predictions, and then some of the
8 detailed 3-D predictions that go in behind that.
9 So, what I have is the unenviable job of trying to
10 explain how, after four, or maybe up to 18 hours
11 after a severe accident, we're going to predict
12 that hot leg failure occurs five or six minutes
13 prior to steam generator tube failure. And how is
14 that possible.

15 MEMBER CORRADINI: And the uncertainty
16 in that.

17 MR. BOYD: And the uncertainty. It's,
18 obviously, something we're concerned about. So,
19 this is the gist of the topic.

20 We have four NUREGs out that
21 summarize. Two of them are draft, two of them are
22 final. We have identified the action plan items,
23 and addressed them one-by-one, with specific
24 memos, that I assume you have copies of.

25 The NUREGs do a different job. They

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 look at the whole picture, and try to answer the
2 action plan items. But, in addition, they answer
3 many other questions that were uncovered, and try
4 to put a full coverage of the issue. So, we have
5 a large report on the system analysis, that tries
6 to give an idea, and maps out where the problems
7 are, where we might expect there to be a
8 probability of containment bypass, and where we
9 don't have that. And then we have some supporting
10 CFD analysis that is needed to augment some of the
11 three-dimensional details in those calculations.

12 So, I want to go over, quickly, what a
13 typical scenario is. This is something we
14 consider a fast scenario. This is where we did our
15 sensitivity studies, and I'll explain why. We
16 start with a station blackout, and we also need to
17 assume that diesel generators are going to fail.
18 And then, if we're going to challenge the tubes,
19 we also have to assume that the auxiliary
20 feedwater systems will fail. In addition to this,
21 I don't have it on the slide, we'll also have to
22 assume that the secondary side depressurizes.
23 Without all -- you need to have high dry low
24 conditions to challenge the tubes.

25 MEMBER BANERJEE: What's the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probability of all these things happening
2 together?

3 MR. BOYD: That I don't -- I won't
4 speak to that, because I may make mistake.

5 MEMBER APOSTOLAKIS: This is in
6 thermal hydraulics system.

7 MEMBER BANERJEE: I know, but we must
8 be informed by PRA viewpoint here.

9 MR. BOYD: I don't have it off the top
10 of my head.

11 MEMBER APOSTOLAKIS: It's pretty low.

12 MR. BOYD: I've asked these questions,
13 and was told that it's a very, very low
14 probability. But because of the potential
15 consequences, it's something we look at.

16 MEMBER BANERJEE: Is that sort of -

17 MR. BOYD: This would be a question
18 for our PRA group.

19 MEMBER APOSTOLAKIS: So, we are still
20 in adequate protection space, Dana. Right?

21 MEMBER POWERS: No, this is -- you are
22 automatically into severe accident space, because
23 you've had a dual failure here.

24 MEMBER CORRADINI: Then you original
25 comment, Dana, I didn't appreciate. Then why was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 adequate protection not deemed appropriate at the
2 beginning, not because of -

3 MEMBER POWERS: The action plan was
4 set up with questions of adequate protection.
5 Most of those design-basis considerations we
6 previously dealt with.

7 MEMBER CORRADINI: Oh.

8 MEMBER POWERS: The new steam
9 generator issue arose -- I think it really came up
10 full force during the course of NUREG-1150.

11 MEMBER CORRADINI: That's what I
12 thought.

13 MEMBER POWERS: And it was triggered,
14 because we know that we're looking at tubes now
15 with eddy-current technology that have cracks in
16 them. So, there's some probability that the eddy-
17 current device simply won't detect a crack which
18 is sufficiently large, that will grow over the
19 course of between inspections. And the severe
20 accident issue becomes since the steam generator
21 is now, in some sense, degraded unbeknownst to us
22 from the full-force, we raise those questions in
23 the form of recommendations in the review of this
24 overage criterion for using eddy-current. So,
25 they just folded them into the action plan.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: Okay. All right.

2 MEMBER POWERS: I mean, that's the
3 distinction.

4 MEMBER BANERJEE: But if the -- I
5 guess I'm still trying to understand, Dana, that
6 if this is a very, very low probability event,
7 does it need to be considered?

8 MEMBER POWERS: No, this is probably a
9 frequency-dominant event for many PWR units,
10 station blackout, failure of diesels. And then
11 something else happens, so I would -- I mean, it's
12 going to vary from plant to plant, but a number
13 around one times ten to the minus fifth is not -

14 MEMBER BANERJEE: One times ten to
15 what?

16 (Off mic comments.)

17 MEMBER BANERJEE: Okay.

18 MEMBER POWERS: Ten to the minus five,
19 ten to the minus six ball park is the right ball
20 park.

21 MEMBER BANERJEE: That is the right
22 ball park. Okay. In that case, I withdraw. I
23 got an answer.

24 MEMBER CORRADINI: Oh, that's high
25 enough for you?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes.

2 MEMBER CORRADINI: Okay.

3 MEMBER BANERJEE: I mean, if it was
4 ten to the minus fifteen or something -

5 MEMBER POWERS: Only in the
6 metallurgical fields do we countenance numbers on
7 the order of ten to the minus sixteen.

8 MEMBER BANERJEE: Okay.

9 MEMBER POWERS: Only when you do
10 probabilistic fracture mechanics.

11 MEMBER POWERS: That's right. That's
12 right.

13 MEMBER APOSTOLAKIS: This is a
14 necessary condition.

15 MEMBER POWERS: The unit of time in
16 probabilistic fraction mechanics is ten to the
17 minus forty-fifth.

18 MEMBER CORRADINI: I guess, I -

19 MEMBER APOSTOLAKIS: I think so, yes.

20 MEMBER CORRADINI: Not to get to the
21 number, but I guess I wanted to make sure, just to
22 follow-up with what Sanjoy was asking, so I
23 understand it properly. So, it's not a matter of
24 adequate protection at this point. This was
25 folded into the action plan, and this is what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 now being assessed.

2 MEMBER POWERS: That's right.

3 MEMBER CORRADINI: Okay.

4 MR. BOYD: Thank you. That saved me
5 from guessing at exponents. So, we start out, and
6 because we don't have auxiliary feed, of course,
7 we start losing inventory on the secondary side.
8 We also have a small reactor coolant pump seal,
9 loss of coolant accident. At some point, around
10 100 minutes, we would dry out the steam
11 generators. At this point, the primary system
12 would pressurize. We'd start cycling the
13 pressurizer relief valves. Losing inventory in
14 the primary side, at some point the inventory will
15 drop low enough that we'll lose full loop
16 circulation. We'll continue to boil off -

17 MEMBER BANERJEE: This is a question.

18 When you cycle the pressurizer relief valves,
19 would there be any significant loss of inventory
20 through that, or is it always through the loop
21 seals?

22 MR. BOYD: No, we do see significant
23 inventory going up through that at certain points
24 in the transient, yes. You're boiling off.
25 You've got some -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes, but you're not
2 getting any liquid. It's all -

3 MR. BOYD: Well, obviously, at some
4 point, there's some liquid. But as the level goes
5 down, it actually goes liquid-solid at some point.

6 MEMBER BANERJEE: So, the TMI
7 scenario.

8 MR. BOYD: Yes, so we do lose -- I
9 don't have the numbers, though, the fractions of
10 what we lose.

11 As the primary inventory continues to
12 drop, at some point, it will drop below the hot
13 leg, and we'll start getting superheated steam
14 coming off the core. At this point, there's a
15 three-dimensional natural circulation flow pattern
16 that will set up to carry energy from the core out
17 into the loop. This flow pattern has been
18 observed experimentally at one-seventh scale.

19 With continued inventory loss, we'll
20 get collapsed liquid levels down near the bottom
21 of the core. At some point, we'll start to get
22 oxidation, additional energy being dumped into the
23 system from that reaction. At some point, the
24 system oxidation power becomes an order of
25 magnitude higher than the decay power. At that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 time, we'll get a significant system heat-up, and
2 temperatures now are well beyond what the
3 structures can take. And when these temperatures
4 become absorbed in the structures, they will fail.

5 Again, I'll point out you need the
6 high-dry-low conditions to challenge the steam
7 generator tube, so we had to dry the steam
8 generator, remain at high pressure on the primary
9 side, and then also drop the pressure on the
10 secondary side, through either a leak, or a stuck-
11 open valve.

12 MEMBER CORRADINI: So, just hold right
13 there for a second. So, that's why I don't think
14 the -- I'm looking at Mr. Stetkar, where he said
15 ballpark. Somehow, I don't believe we're in the
16 five to ten to minus six ballpark with that many
17 things happening coincidentally. That is, I have
18 low-dry, I haven't depressurized the primary side.

19 I seem to remember it was a much lower
20 probability estimate to get to this point.

21 MEMBER POWERS: They're not
22 independent events.

23 MEMBER STETKAR: They're not
24 independent events. The seals are going away
25 because you have a station blackout. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 auxiliary feedwater has -

2 MEMBER CORRADINI: And I have no way
3 to open the pressurizer relief valves to
4 depressurize.

5 MEMBER POWERS: Even if you try, it
6 takes forever to depressurize that system.

7 MR. BOYD: Well, we do transients,
8 where we do open that. But, at some point, we
9 lose battery power, and then it fails closed.
10 That delays things, but it does not, ultimately,
11 get us out of the scenario.

12 MEMBER BANERJEE: How long does it
13 take to lose the battery power?

14 MR. BOYD: We've done four and eight-
15 hour battery life.

16 MEMBER STETKAR: The key for the
17 numbers, as Dana said, the keys for the numbers is
18 it depends on the plant. And the key is it's in
19 the minus five, minus six ballpark, as opposed to
20 the minus two ballpark, or the minus ten ballpark.

21 MEMBER CORRADINI: But, I'm sorry to
22 keep on dwelling on this, because I'm just --
23 historically, I've just forgotten. This is,
24 essentially, a subset of TMLB prime. Right? Of
25 that accident sequence. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: And, remember, the
2 secondary depressurization is also a consequential
3 event.

4 MEMBER CORRADINI: Is a?

5 MEMBER POWERS: Consequential event.
6 It's going to happen because the relief valves go,
7 and they fail open the whole time.

8 MEMBER SHACK: You can look on page
9 250 of NUREG-1570 to get a plot. And you will
10 find they're between ten to the minus five, and
11 ten to the minus six.

12 MEMBER BANERJEE: All right. We trust
13 you guys.

14 MEMBER SHACK: Wow, my credibility has
15 been enforced.

16 (Simultaneous speakers.)

17 MEMBER BANERJEE: I guess,
18 intuitively, it feels like a far-out event, but
19 all right.

20 MEMBER APOSTOLAKIS: It's not just any
21 NUREG.

22 MEMBER SHACK: 1570.

23 MEMBER APOSTOLAKIS: Oh, okay.

24 MEMBER SHACK: 1570 was the early -

25 MEMBER ARMIJO: The action plan.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. BOYD: I'll also point out that
2 this particular -- this is our most typical
3 scenario. Once we've piled on all of these other
4 assumptions, we get this three-dimensional natural
5 circulation flow pattern. There's also another
6 scenario that can evolve from this, and that is a
7 scenario of clearing the loop seals. And on that
8 scenario, this three-dimensional natural
9 circulation flow pattern in that particular loop
10 would be disrupted, and we would have full loop
11 circulation. And then, at that point, we don't
12 benefit from the mixing, which I'm going to
13 discuss in a minute. And the tubes are presented
14 with a much more significant challenge. And we do
15 predict tube rupture.

16 MEMBER APOSTOLAKIS: You know, you
17 have this real good picture there. Not once do
18 you tell us what's going on here. Can you use a
19 cursor maybe in the future?

20 MEMBER POWERS: You're going to have
21 to excuse the speaker. We assumed the Committee
22 was so familiar with this picture, it was
23 unnecessary to explain it.

24 MEMBER BANERJEE: It is thermal
25 hydraulics, obscure at any level.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: As we all know,
2 thermal hydraulics is such a fundamental and
3 essential, we just assumed the familiarity.

4 MR. BOYD: But what we want to get
5 from this, though, is that we've had a boil-off on
6 the secondary side. And sticking on the secondary
7 side, we've also either stuck-open a valve, or it
8 has leaked down to a low pressure. On the primary
9 side, we've also now lost all the inventory
10 through a boil-off. We've gotten water level down
11 very low in the core, and the key here is that
12 we're now going to oxidize the core. The core is
13 damaged. The power coming off the core due to
14 this oxidation reaction is very high.
15 Temperatures are going to skyrocket at this point.
16 And, basically, the system is going to fail at
17 some point. And the next slide will help us a
18 little bit with that.

19 MEMBER BANERJEE: Maybe you should
20 show them the flow patterns. Go back to the
21 previous slide. Show them the refluxing more, and
22 just explain those arrows.

23 MR. BOYD: Okay. That's a good point.
24 This is -- it's not, necessarily, like reflux
25 condensation. This is all superheated steam.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 What we have is superheated steam coming off the
2 core. And it quickly finds its way into the upper
3 part of the 30-inch hot leg, runs along the upper
4 hot leg like smoke across a ceiling, and then
5 rises vigorously into the steam generator tube
6 bundle, which forms almost a chimney effect, and
7 really draws. It actually draws twice the flow
8 into the generator as what comes across the hot
9 leg, so it's very vigorous. The heat exchange in
10 the steam generator is very good, as we would
11 expect.

12 And then, because the loop seal is
13 filled, this flow that goes up through the
14 generator gets to the outlet plenum, and must turn
15 around and come back. So, it's pushed back by the
16 chimney effect of this heated flow going into the
17 generator. So, we've got flow going around the
18 steam generator, getting to the outlet plenum, and
19 then being forced back through the tubes, mixing
20 in the inlet plenum.

21 Now, this mixing is key. This what
22 we're going to look at on the next slide. This is
23 why the tubes are a cooler temperature. And then
24 that flow is going to flow along the bottom of the
25 hot leg, and waterfall back into the vessel,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 stirring up the vessel, keeping the vessel fairly
2 well mixed, keeping circulation patterns in the
3 vessel going. So you've got that pattern going on,
4 with the addition of some steam being generated in
5 the vessel.

6 MEMBER BANERJEE: Can you also explain
7 why you consider the loop with the surge tank
8 rather than the -

9 MR. BOYD: Okay. We -- that was a
10 question I saw. We consider all the loops. In
11 the base case highest pressure case, which we
12 consider our worst case, the tubes and the hot leg
13 fail earlier in the loop with the pressurizer.
14 And that's because the pressurizer is cycling, for
15 one. That pulls an enormous amount of steam out
16 to that loop, and actually pulls it away from the
17 other loops a little bit. That's going to heat up
18 the hot leg much more significantly than the other
19 hot legs. And then it turns out with the hot leg
20 hotter, and the pressurizer always drawing a
21 little bit of additional hot steam, because it's
22 pressurizing, and then releasing, that makes the
23 flow down the hot leg hotter. Even though it's
24 the same mass flow, it's hotter, and that
25 challenges the tubes more. So, our first failures

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 are in this loop on our worst high pressure case.

2 Now, actually, when we go to a lower
3 pressure case, this loop is no longer the first
4 failure, but we're monitoring all the loops, the
5 hottest tubes in each loop, the hot leg in each
6 loop. So, we talk about the pressurizing loop
7 because in what we consider the worst case, it
8 fails first. But when I say fails first, it's not
9 much difference, really.

10 MEMBER CORRADINI: So, just to make
11 sure I understand. The heat exchange in the
12 bundle is more just heating up the steel, or
13 you're getting significant heat transfer to what
14 is now a low pressure dry system on the other
15 side?

16 MR. BOYD: No, there's not much on the
17 secondary side. We are heating up the steel.

18 MEMBER CORRADINI: Okay.

19 MR. BOYD: And the next plots will
20 help us with that. Here's the steam temperatures
21 in the system. At the very top of this plot, I
22 don't know if you have both of these plots.
23 They're on top of each other on the slide. The
24 top plot here is a core exit temperature. This is
25 a trick of PowerPoint, they're laid on top of each

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 other.

2 MEMBER APOSTOLAKIS: Where is your
3 cursor?

4 MR. BOYD: The top is the vessel, I'm
5 sorry, the core exit temperatures. And then
6 significantly below that, you'll have the hot leg
7 entrance temperatures. And significant below
8 that, you'll have the hottest tube temperature.
9 So, this becomes the issue, how come the hottest
10 tube is so much cooler than the hot leg? And then
11 below that, we'll have the average tube, and then
12 the steam generator tube return temperature. So,
13 we'll talk in a minute about why these
14 temperatures can drop like this. But let's look
15 at structure temperatures next. And this has
16 failure times imposed on it. And this becomes
17 sort of the gist of the problem.

18 So, the upper curve is the hot leg
19 inner wall temperature, structure temperature.
20 The average temperature of the hot leg is
21 obviously much cooler than this. I just picked
22 the inner wall temperatures to plot. And let's --
23 I apologize, I have to go back one minute.

24 These are -- this plot has some
25 inflection points on it that we talked about in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the earlier slides. If we look here where all the
2 curves diverge, up until that point, they were
3 sitting around the saturation temperature. Once
4 the core starts to dump out superheated steam,
5 things start to diverge at that point. You'll see
6 the core exit temperatures going up very fast.
7 You'll see the hot leg following, and everything
8 else trailing in behind.

9 This is a key point. And that's where
10 we reach peak oxidation. At that point, the power
11 coming off the core due to the oxidation reaction
12 has increased by an order of magnitude. That's
13 what you see on this plot, they look nearly
14 vertical. This is on the order of 25 degrees per
15 second.

16 VICE CHAIR ABDEL-KHALIK: Now, these
17 plots assume no operator actions.

18 MR. BOYD: I'm sorry. That's right.

19 VICE CHAIR ABDEL-KHALIK: These plots
20 assume no operator actions.

21 MR. BOYD: This particular plot. Now,
22 I would like to mention, though, that when we
23 looked at a bunch of operator actions, that,
24 ultimately, if -- let's say they stick open a
25 PORV, and then they lose battery power, and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thing sticks closed again, or there's some other
2 operator actions that we looked at. Assuming no
3 heroic activities to put water on the steam
4 generator, or things like that, we end up getting
5 to a temperature signature that looks very similar
6 to this.

7 It might be 18 hours out, instead of
8 four hours in this case, but it looks very
9 similar. Once you lose the water in the core, and
10 that oxidation reaction kicks off, and dumps all
11 that power into the system, the loop temperatures
12 look very similar to this.

13 VICE CHAIR ABDEL-KHALIK: But at these
14 core exit temperatures, the emergency operating
15 procedures would put the operation in, I guess,
16 FRC-2, and then FRC-1. And the operators will
17 find a way to get water to the primary system by
18 somehow initiating safety injection.

19 MR. BOYD: I wouldn't argue with you,
20 but these calculations are done to show what
21 happens if they don't.

22 VICE CHAIR ABDEL-KHALIK: If that's
23 the purpose.

24 MR. BOYD: Well, these -- my purpose
25 isn't to explain the risk.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: But you're assuming
2 that it happens, and you're looking at the
3 consequences.

4 MR. BOYD: I don't run many
5 calculations where they keep water in the steam
6 generator tubes, because they're boring. Nothing
7 happens. That's going to weigh itself out in
8 integrated risk assessment, but at the end of a
9 PRA event tree, where all of this stuff that has
10 happened, we know what happens, and that's what
11 the purpose of these calculations are.

12 MEMBER BANERJEE: Chris, you keep some
13 water in, because if you don't, then again, we go
14 back one more slide. If the water is not there in
15 that loop seal, the game is over.

16 MR. BOYD: That's right. There's
17 water in the loop seal. There's also water in the
18 lower downcomer. We predict this heat-up to occur
19 before the water in the lower downcomer even
20 totally evaporates. The top of the core is
21 oxidizing, starting to relocate, things along
22 these nature. So, we -- this is our best estimate
23 prediction of what happens.

24 MEMBER POWERS: Then you start to get
25 substantial steam oxidation to cladding starting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 when the water level is about a third of the core
2 height. Once it drops below the core support
3 plate, you just don't get any heat -- massive
4 amounts of heat transfer to the water. So, it
5 takes forever to steam out the lower plenum.

6 MEMBER CORRADINI: You don't lose it.

7 It's always there.

8 MEMBER POWERS: You have to really
9 relocate fuel in order to boil that dry,
10 typically.

11 MEMBER BANERJEE: It depends on how
12 much is leaking out of the pump seal, whether you
13 suck out the loop seal, I suppose.

14 MR. BOYD: Okay.

15 MEMBER ARMIJO: Just a quick question.
16 You have a leak at the pump, something -- steam
17 is coming out of that pump, but no water is coming
18 out, because the pressure is the same on both
19 sides. Is that what we're looking at?

20 MR. BOYD: The reactor coolant pump
21 seal is going to be vapor. The loop seals,
22 themselves, are eight or nine feet deep, which is
23 going to be up higher than that. The suction
24 point on the pump is not down that low, so we're
25 going to be leaking steam.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: No significant
2 depressurization in the system with that leak?
3 It's too small?

4 MR. BOYD: No, that leak is relatively
5 small. Even at the highest reactor coolant pump
6 seal leakage of 480 gpm equivalent, it's about a
7 .6 inch hole, and we have a larger bypass between
8 the upper plenum and the downcomer, just from the
9 relief nozzles in the upper downcomer. That's
10 about a two or three inch hole at the smallest,
11 and that can be up to a 10 or 15 inch hole
12 equivalent.

13 MEMBER POWERS: We're going to have to
14 move on. We're getting kind of off schedule here.

15 MR. BOYD: I'll breeze through the last
16 two slides. I only had six. This slide took two
17 hours in the Subcommittee meeting, so I expect
18 those guys -

19 So, the reactor coolant system
20 temperatures are here. Now, just say, when we do
21 the SCDAP-RELAP calculations, all we consider
22 ourselves doing is a screening calculation. We're
23 looking at the scenarios given to us, and we want
24 to see if there's a possibility that the tube
25 fails first.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We feel that we're a little bit on the
2 conservative side, because of the way we do these
3 calculations. Our hot leg failure model is a one-
4 dimensional model. We've looked at three-
5 dimensional models that show the hot leg fails
6 actually earlier than what we predict. In our
7 tube model, we use the hottest tube, and we assume
8 flaws in it right above the tube sheet at the
9 hottest location. And we also feel that we're a
10 little conservative on our hottest tube estimate.

11 So, we feel like -

12 MEMBER CORRADINI: So, you purposely
13 degrade the strength of the hottest tube.

14 MR. BOYD: That's right. We degrade
15 it to the point -- I'll show you on this plot what
16 we do. Here's a hot tube in pristine condition,
17 and it would fail at this point in time. If we
18 multiply the stress on that tube by 1-1/2, it will
19 fail up here much closer to the hot leg. If we
20 multiply that stress by two, it will fail before
21 the hot leg. Our screening criteria is to
22 multiply the stress by three. In this particular
23 plot, that puts the failure time at about just
24 under 220 minutes, so we're failing that way out
25 in front of the hot leg. And that is our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 screening criteria. That will flag that scenario
2 as a potential bypass, and will throw it off to
3 the materials guys to do a more detailed study.

4 Now, I'll just go over this quickly, I
5 hope. But the question is, how can we get all of
6 that mixing, and how can the tube temperatures
7 drop so low? And I'll just say that we have some
8 three-dimensional CFD predictions. And they've
9 been checked, or at least we looked at the one-
10 seventh scale testing, and then we've extrapolated
11 from that. This approach did very well at one-
12 seventh scale. And we believe that we're doing an
13 adequate job at these full-scale conditions.

14 I did not show a grid sensitivity
15 study. I know we had a question, but we use a
16 million cells. They're perfect cubes in the inlet
17 plenum, which was much better than we did earlier,
18 and we got the same answer. And then we also cut
19 each of those down, and we made 8 million perfect
20 cubes in the inner plenum, except right around the
21 edges. And we got to within three significant --
22 the third digit is all that changed in that
23 calculation. So, as far as the code goes, we're
24 using the best available mesh with a Reynolds
25 stress turbulence model, which has buoyancy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 effects in it, so it's not isotropic turbulence.
2 We're doing a kind of a state-of-the-art
3 computation of fluid dynamic simulation. It's not
4 largely -

5 MEMBER BANERJEE: How are you modeling
6 the tubes, again? Remind me, Chris.

7 MR. BOYD: The tubes are -- we model
8 the tubes as groups of three-by-three. Each tube
9 is -- so, we have one-ninth of the total number of
10 tubes. And we do a side study, where we model the
11 tubes in great detail with millions of cells per
12 tube. And then we use this larger tube, and we
13 verify that our larger tube gives us the same
14 pressure drop, and heat transfer characteristics
15 as the smaller tube. Of course, to get that we
16 have to boost the heat transfer and the friction.

17 MEMBER BANERJEE: Okay.

18 MR. BOYD: The key to RCFD
19 calculations is this histogram. It gives us the
20 temperature distribution. And, again, we have
21 high confidence that at least with the tools we're
22 using, we're not grid-dependent. We're using best
23 practices on the mesh and the turbulence models.
24 And this is where we pull off, on the right side
25 of this histogram, we pull off what we consider

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the hottest tube, and then we monitor that in our
2 calculations.

3 MEMBER BANERJEE: So, coming back to
4 that, the mitigation of the hottest temperature
5 due to the movement of the plume non-steady nature
6 is by how many percent? If you just took the hot
7 part, not -- without taking into account the
8 averaging effect of the plume meandering.

9 MR. BOYD: Okay. What Sanjoy is
10 talking about is that this histogram that I'm
11 showing here is actually just the hottest
12 temperatures, irregardless of location. We looked
13 at this in another way, where we focused on each
14 tube individually. And what happens is, the hot
15 plume moves off of the tube. So we looked at mass
16 average temperatures into specific tubes. And
17 what that did, that dropped the peak temperatures
18 -- on this plot we have about .625 is the peak
19 temperature, where we have a tube area that stays
20 in that range; although, it's moving. We dropped
21 that to .425 on this normalized scale.

22 Now, we've run the sensitivity
23 studies, if we look in the code, we use .5 for our
24 screening calculation. We're run the .625 in our
25 code, and that makes about a three-minute

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 difference in the failure times.

2 MEMBER BANERJEE: Does it mean that
3 you get a lot of tube failures before the hot leg?

4 I mean, to the extent that these -

5 MR. BOYD: At .625?

6 MEMBER BANERJEE: Yes.

7 MR. BOYD: No, we still -- instead of
8 having six minutes of margin between a pristine
9 tube, we now have three minutes of margin. And
10 instead of having to maximize the stress by about
11 1.6 to get failure with the hot leg, we only have
12 to do it by about 1.25. So, it does reduce the
13 margin, if you assume that higher temperature.

14 MEMBER CORRADINI: The higher
15 temperature occurs, though, when you pen the
16 plume, instead of letting the plume move around.

17 MR. BOYD: Yes.

18 MEMBER BANERJEE: Sucked and stuck.

19 MR. BOYD: What we did is, at each
20 instant in time, we just looked at the peak
21 temperatures, irregardless of where they were.
22 But that's not a best estimate, so they dropped
23 off a little bit on that.

24 So, in summary, the thermal hydraulic
25 issues have been looked at in great detail. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have a large NUREG that summarizes the system code
2 analysis. We have maps of different parameters,
3 and how they affect whether or not we have the
4 potential for bypass. And then we have supporting
5 CFD studies in NUREG-1781, 88, and NUREG-1922,
6 which further support the system code analysis.

7 We're looking into future work, as
8 needed, with the User Need that's coming over from
9 NRR. And we haven't identified the details of
10 that work, yet, but we may be studying the CE
11 plant, and maybe looking into a little bit more of
12 our uncertainties.

13 MEMBER CORRADINI: The User Need is
14 exactly what?

15 MR. BOYD: I believe the User Need is
16 going to be spoken about, Bob is going to talk
17 about it.

18 MEMBER CORRADINI: Sorry. Okay.

19 MR. BOYD: At the end here.

20 MEMBER CORRADINI: Okay.

21 MR. BOYD: I was just making the point
22 that we will continue to support the agency with
23 this work, as needed. But we have answered the
24 action plan items.

25 MEMBER BANERJEE: I guess, Chris, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 explain what Mike is questioning, it depends very
2 much on the shape in the plenum, and its depth.
3 So, if you have a plant with a shallower inlet
4 plenum, you can get a different answer, because
5 you get less mixing, and the plume can move
6 easier.

7 But going back to the uncertainty work
8 that you're talking about, this accident is ten to
9 the minus five, ten to the minus six, so there's a
10 broad range, factor of ten, I guess, or more,
11 maybe. What would be sort of interesting to know
12 is what is the probability that you would get a
13 lot of steam generator tubes failing before the
14 hot leg, in which case, you might get a bypass
15 path. Is it 10 percent, is it 5 percent, is it 1
16 percent, ten to the minus one percent?

17 MEMBER POWERS: Sanjoy, one tube
18 failing in a severe accident is a disaster.

19 MEMBER BANERJEE: Is it?

20 MEMBER POWERS: Yes.

21 MEMBER BANERJEE: Even one?

22 MEMBER POWERS: Yes.

23 MEMBER BANERJEE: All right.

24 MEMBER CORRADINI: You use -

25 MEMBER POWERS: No, you're venting

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 radionuclides directly to the outside. You go
2 through the 25 rem at the site boundary with one
3 tube.

4 MEMBER BANERJEE: Okay. But from a
5 point of view of the hot -- even if you blow one
6 tube, Dana, eventually, the hot leg is going to
7 go, too. Right? In that case. If you blow say a
8 fairly large number of tubes, I don't know what
9 that number is, the system will depressurize, and
10 the hot leg will not blow. Right? I mean, there
11 is some point at which -

12 MEMBER POWERS: You're rating bad
13 versus really bad.

14 MEMBER STETKAR: As I understand it,
15 some of the risk assessment arguments have been
16 made that even if one, or let's say a small number
17 of tubes go first, that the hot leg will shortly
18 thereafter fail, and the off-site consequences of
19 these small number of tube failures are relatively
20 small. That's what I understood from some of the
21 -

22 MEMBER POWERS: And all that's true,
23 and the question is, you're debating the prompt
24 fatalities, or not. That's all that we're
25 debating, is the prompt fatality issue.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: It is not insignificant.

2 MEMBER BANERJEE: So, the sort of
3 thing that would interest me, if I was -- well,
4 you guys have asked the question, what is the
5 probability, taking into account uncertainties,
6 that we would get fairly large number of tubes
7 failing, and the hot leg wouldn't fail? Did you
8 ask that question?

9 MEMBER ARMIJO: Chris, just a question
10 of clarification. The hottest tube moves around.
11 Right? I mean, this isn't a stable -

12 MR. BOYD: The location of the hottest
13 tube at any one time moves around, but we have
14 identified which tube, on average, is the hottest
15 tube. And that's been fairly consistent. It's
16 the location, obviously, right above the nozzle.

17 MEMBER ARMIJO: Okay. So, it's going
18 to be in that general region.

19 MR. BOYD: That's right. I've got one
20 plot where I show the -

21 MEMBER ARMIJO: Move around so much
22 that the temperature of the hottest tube could
23 change a lot.

24 MR. BOYD: The temperature of the
25 hottest tube can change a lot.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: It can.

2 MR. BOYD: I does. The plume moves
3 completely away from it. It actually sees some
4 pretty cool temperatures at some point in time.
5 And it continues to draw in that cooler fluid
6 because of the chimney effect, so it's not just
7 only drawing fluid when it's hot.

8 MR. LUPOLD: Hello. I'm Tim Lupold
9 from the Office of Research. And I have one of
10 the Corrosion Metallurgy Branches over there. And
11 I'm going to talk to you about 3.4H, which was the
12 task looking at the locations outside of the --
13 outside of the steam generator tubes in the RCS.
14 What we needed to do was to evaluate three
15 failures of these primary system components,
16 things like the surge line, the hot leg. We had
17 to evaluate other active component failures, but
18 also included under that -- when I think active, I
19 think a thousand problems, but also this included
20 bolting and manways. And we had to determine the
21 feasibility of the RCP seals leakage failure.
22 And, if necessary, conduct large-scale tests.

23 This was taken and worked in three
24 phases. Our first phase, we reviewed the methods
25 and models, identified information needed. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the key here is scoped the RCS components that
2 needed to be looked at closer.

3 In Phase II, there was 3-D model
4 developed on those selected components, utilized
5 specific detailed drawings in that phase, and
6 included operating experience.

7 Under Phase III, then we took -- we
8 calculated the RCS component failure sequence,
9 again. We did that under Phase II, but then did
10 it again in Phase III, with some improved codes
11 and modeling that was done, the RELAP and the CFD
12 that was done. And, also, expanded the database
13 for material properties.

14 Okay. Phase I workshop was held, and
15 concluded it was possible to predict some of the
16 behavior of these certain components,
17 specifically, like the manway bolts. And then
18 following the workshop, the building connections
19 were modeled to predict failure times. And then
20 we selected -- components were selected to undergo
21 additional evaluation in the Phase II analysis.

22 In Phase II, the analysis was based on
23 the Zion station. We looked at the hot legs of
24 loop 4. As Chris explained, why loop 4 was
25 selected, because of the pressurizer attached to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that, and the continual feeding of fluid into that
2 loop. Okay?

3 We had results from RELAP5 from a
4 hydraulic analysis that was used as inputs into
5 the component evaluations. Failure times due to
6 tensile and creep rupture were calculated using
7 literature, where data was available, and if it
8 wasn't available, we used extrapolated data, at
9 times. Okay?

10 Sensitivity analyses were conducted to
11 determine the variability of the predicted times.

12 And various things, like the surface heat flux
13 on the component, the conductivity, the creep
14 rate, and yield strength of the components. And,
15 also, we analyzed the stress/strain response due
16 to the impact on the PORV, power-operated relief
17 valve.

18 MEMBER RAY: A comment was
19 made earlier about power-operated relief valves,
20 and I let it go, because you said well, the
21 batteries wouldn't last. Now not all points are
22 power-operated relief valves on the primary side,
23 so I guess I'm wondering what effect that has on
24 your analysis.

25 MR. LUPOLD: Well, under our analysis,
it -- the power-operated relief valve operation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be more of an impact on the thermal
2 hydraulics calculations, and determine what the
3 temperatures of the components were. We took the
4 input from the thermal hydraulics calculations,
5 and used that for the analysis.

6 MEMBER RAY: Well, I'm not sure what
7 to take away from that.

8 MR. LUPOLD: If the PORV did not
9 operate, then you would only be controlling your
10 pressure via your safety valves.

11 MEMBER RAY: Correct.

12 MR. LUPOLD: Okay? So, you would
13 probably end up having higher pressure in your
14 system.

15 MEMBER RAY: Yes.

16 MR. LUPOLD: All right. Because
17 you're operating at that level for the safety
18 valves.

19 MEMBER RAY: It appears that way, so
20 what's the result? What impact does that have on
21 the result here, I guess is what I'm trying to
22 figure out.

23 MR. LUPOLD: It, actually, does not
24 have a major impact on the results. What really
25 drove the results in our calculations was the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 temperature spike that proceeded, and how rapid
2 that temperature spike was.

3 MEMBER RAY: Okay. I'm just -- I'm
4 trying to intuit what the effect is.

5 MEMBER SHACK: You can change absolute
6 numbers, as Chris said. Things go back and forth,
7 but, again, it's the relative failure times that's
8 always of concern here. Everything is going to
9 fail sometime, and the only question is which
10 fails first.

11 MEMBER RAY: Well, all that being
12 said, I don't want to take people's time. It's
13 just not obvious to me that -- it's obvious to me
14 that there would be a difference, like we said.
15 What effect that would have on the answers we're
16 talking about is what's harder for me to imagine.

17 MEMBER BANERJEE: Are you saying that
18 for different types of plants, there would be sort
19 of different outcomes?

20 MEMBER RAY: We don't have -

21 MR. LUPOLD: On some, yes.

22 MEMBER RAY: Yes.

23 MEMBER POWERS: Some of them don't
24 have loop seals, either.

25 MEMBER RAY: Well, that's a different

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question.

2 MEMBER BANERJEE: Well, the depth of
3 the loop seals are very different for different
4 plants. I assume you used Zion here. Right?

5 MEMBER RAY: That's what they use in
6 the Zion. Yes. I understand. I've got to pick
7 something. I just made a simple question, I'm
8 just not clear what the implications of not having
9 -

10 MR. BOYD: I can try to answer that.
11 This is Chris Boyd from Research. If we're
12 operating at the safeties, we would be at a
13 slightly higher pressure. That pressure
14 percentage-wise is not a real big deal, but you
15 would have slightly higher stress in the tubes and
16 the hot leg. This is kind of a materials issue,
17 where we're heating things up, and we're bringing
18 down the magnitude of the flow stress of the
19 materials, is a simple way that I look at it, as a
20 thermal hydraulics guy. So, as the thing heats
21 up, it continues to get weaker and weaker. At
22 some point, it will have a stress-strength ability
23 that will equal the stress that's on it. And it's
24 not much difference between the set points of the
25 power-operated relief valves, and the safeties

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from a percentage point of view. What is it, 4 or
2 5 percent, maybe, so the stress is going to go up
3 by 4 or 5 percent. So, things are going to fail
4 at a slightly lower temperature, but it's not a
5 big deal time-wise.

6 MR. LUPOLD: And that pressure,
7 actually, is through the entire RCS. It's not
8 just in the tubes, like you said. So, you have
9 that increased pressure on all your other
10 components.

11 MEMBER RAY: I mean, I should have
12 come to the Subcommittee meeting. I couldn't do
13 that, so -

14 MR. LUPOLD: Let's go on.

15 MEMBER BANERJEE: Well, one of the
16 questions which sort of arose was, when you do the
17 CFD calculations, you're actually calculating the
18 temperature field in the walls, aren't you?

19 MR. BOYD: No, we're not, not in the
20 CFD calculations.

21 MEMBER BANERJEE: Oh, you're not. So,
22 it's not coupled to the walls.

23 MR. BOYD: No. We looked at that as a
24 sensitivity, but we're doing a quasi-steady
25 calculation. And in that type of calculation, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 walls would all reach the fluid temperature. We
2 do a three-dimensional finite element analysis of
3 the temperature walls, of the walls, temperatures
4 in the walls.

5 MEMBER BANERJEE: I'm sorry. Then, I
6 didn't understand. I thought you had coupled the
7 walls. So, what you have is the wall temperature
8 sort of as a lumped parameter. Is that the way --
9 when you show metal temperature rising -

10 MR. BOYD: Those metal temperature
11 rises came from the system level code,
12 SCDAP/RELAP5. That was the one-dimensional heat
13 structure inner wall temperature on the upper hot
14 leg. We did some CFD analysis. I don't know if
15 you saw it, where we did have the walls in place.

16 And we believe there's mixed convection all the
17 way down the hot leg. We don't account for that.

18 That would put us on the conservative side. We
19 have looked at that. But, in general -

20 MEMBER BANERJEE: There will be radial
21 conduction from the -

22 MR. BOYD: There is radial conduction.
23 That's right. And the cold boundary layer falls
24 off the wall and causes mixed convection. We have
25 all of that going on. We've looked at that, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we don't use that in our calculations.

2 MEMBER BANERJEE: So, you're just
3 taking -- so, it's quite conservative. So, you're
4 just taking the top tube, if you wish, the top
5 heat structure in the SCDAP/RELAP calculation in
6 the -

7 MR. BOYD: That's right. We only
8 moved it -- it's a screening calculation. We just
9 look at the one cell closest to the vessel where
10 it's the hottest. Right.

11 MEMBER BANERJEE: Okay.

12 MR. LUPOLD: Okay. To get back on
13 track, to really answer your question, I guess, we
14 didn't look at the situation where a --

15 MEMBER RAY: I mean, you ought to
16 think about it, but if it's a material difference,
17 that's fine. I was more thinking about whether
18 operator action played any role in here, to open
19 the PORVs at a lower pressure, or something of the
20 kind, that would affect the analysis.

21 MR. LUPOLD: Well, obviously, that
22 would affect it. But the analysis that we were
23 doing, we were not assuming any operator actions.

24 MEMBER RAY: Okay.

25 MR. LUPOLD: Okay. So, the results of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Phase II are what you see on the screen right now.

2 And these were the -- kind of a timeline, where
3 relative, I don't have absolute times here, but
4 you have core uncovering, and then you would have
5 the RTD hot leg weld would fail first. Then the
6 instrument line, then the instrument line weld,
7 socket weld, and the surge line in the hot leg
8 nozzle weld, the hot leg near the reactor pressure
9 vessel, generator tube failure, and then you would
10 have the surge line bend near the hot leg. These
11 were the results from Phase II.

12 MEMBER BANERJEE: When does the metal-
13 water reaction start in the core, or metal-steam
14 react. Is that steam reaction?

15 MR. LUPOLD: Well, that would be some
16 time after the core uncovering, before you actually
17 had a failure of the RTD hot leg weld. It's that
18 reaction that's necessary in order to drive that
19 spike in temperature, in order to drive these into
20 the creep range, and then have failure.

21 MEMBER BLEY: Some of the things you
22 showed us in the Subcommittee meeting made that a
23 lot clearer, that it really does -- if the timing
24 until you get to that point is much different, it
25 really doesn't matter much, because things happen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so fast. And then the timing is pretty constant,
2 no matter how you -

3 MR. LUPOLD: Phase III, we made some
4 improvements in the thermal hydraulic modeling.
5 Refinements were made in the surge line, the hot
6 leg connections in the RELAP model, thermal
7 hydraulic calculations using RELAP were improved,
8 high-temperature materials database was expanded.

9 The enhancements actually did change the
10 calculated failure sequence. And after the
11 enhancements were made, it results in hot leg
12 failing first, as opposed to the surge line.

13 And, also, there's still suggestions
14 that the RCP seals could possibly fail prior to
15 steam generator tubes failing. And we didn't go
16 into that a lot here, but there are scenarios
17 where if you have leakage of those components,
18 they can reduce the pressure, and change the
19 failure consequence.

20 MEMBER BANERJEE: Well, what sort of
21 seals of these pumps -- the pump seals, but you
22 say they could fail. How would they fail? I mean,
23 isn't there a labyrinth in -

24 MEMBER CORRADINI: It's heat. They
25 start leaking at higher temperatures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: They leak, but when
2 you say fail, what does that mean?

3 MEMBER CORRADINI: They leak more.

4 MEMBER BANERJEE: Oh, but how much
5 more?

6 MR. LUPOLD: That's a really difficult
7 thing to answer. There was not a lot of work done
8 to try and measure this leakage on the seals.
9 This is just a possibility that, if we thought
10 necessary, there could be added work done there.

11 MEMBER CORRADINI: If memory serves
12 me, Westinghouse about 20 years ago at Triden had
13 analyzed this, and they came up with two or three
14 times the leak flow through, something on that
15 order. It's a controlled leakage letdown system,
16 so it's about three times the normal leakage
17 letdown through those. That was a guess. That
18 was an engineering guess at the time, I remember.

19 MR. LUPOLD: I had seen estimates on
20 seal leakage, 25 gallons per minute per pump, up
21 to a much, much higher value, depending on the
22 damage that progressed, and the way the
23 temperatures changed at the seals.

24 MEMBER BANERJEE: This is a steam leak
25 we're talking about. Right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. LUPOLD: Well, your fluid would
2 flash to steam as its dropping pressure across the
3 seal faces. So, you'd be flashing, you'd be
4 flashing the steam immediately. And it would be a
5 liquid flashing of steam until sometime in the
6 evolution that you had steam in your cold leg at
7 the reactor coolant pump seals.

8 Okay. So, then after this work was
9 done, an expert workshop was held to evaluate
10 these findings. And the general consensus there
11 was that yes, seal failure could possibly occur
12 sooner than previously estimated. There were no
13 changes on the challenges to the failure sequence
14 of the components. And we're not saying this will
15 happen. They're just saying there's a possibility
16 that it could happen. And if you had to make
17 anything definitive on it, you would have to do
18 some additional work.

19 So, overall conclusions, we felt we
20 accomplished the intent of what the steam
21 generator action plan item was, looked at the
22 differences in times between components outside of
23 the RCS. Again, seals could fail. And there is a
24 -- there is some follow-on work on research that's
25 being done. You've heard the User Need request

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mentioned here a couple of times.

2 VICE CHAIR ABDEL-KHALIK: What would
3 you do, and what is it that you're trying to prove
4 by doing that work, the last bullet?

5 MR. LUPOLD: The additional work?

6 VICE CHAIR ABDEL-KHALIK: Right.

7 MR. LUPOLD: Actually, what they've
8 asked us to do in the materials area was to come
9 up with some flaw distribution in the steam
10 generator tubes right now. And, also, look at --
11 and I'm not sure exactly what we need to do yet
12 for the components outside the RCS, but there's
13 talk about developing a flaw distribution which
14 could be in some of those welds. There's a lot of
15 negotiation that has to go on there yet, so I can
16 make sure I can meet what their need is.

17 But, as you know, in the steam
18 generator tubes these days, there's been a lot of
19 steam generator replacements. They're now using
20 690. The current degradation mechanism in the
21 generator is 690, is different than what it is in
22 the steam generators that have 600 mill-annealed,
23 or 600 thermally treated tubes in it. So, we are
24 basically trying to rebaseline what the flaw
25 distribution is.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIR ABDEL-KHALIK: I'm still
2 trying to put my arms around the big picture, and
3 I can't figure out what is it that you -- what
4 additional information you would get with this
5 follow-on research.

6 MEMBER CORRADINI: Asking it
7 differently, are you trying to determine margin, a
8 lack thereof, or an improvement of margin with the
9 change in material? I guess -- that's what I
10 assume.

11 MR. PALLA: I could talk about that.

12 MR. LUPOLD: Good, because I was going
13 to have to defer that, because I'm just giving
14 inputs into the other calculations that are going
15 to be done.

16 MEMBER CORRADINI: He's helping -

17 (Simultaneous speakers.)

18 MR. PALLA: I'll just cover it a
19 little bit later.

20 MEMBER ARMIJO: All right. In the
21 future -- well, first of all, in your analysis,
22 let's say at the RPV nozzle, it seems to me that's
23 going to be the hottest part. Yet, you're failing
24 -- at least at the Subcommittee, it seemed like
25 you were failing in the straight tube part. How

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 detailed is your RPV nozzle analysis? Because
2 we've got the carbon steel, which is very weak.

3 MEMBER SHACK: It's very detailed.

4 MEMBER ARMIJO: It is?

5 MEMBER SHACK: It's so mass -- I mean,
6 I went back and I checked with Shurin after the
7 Subcommittee meeting to ask. It doesn't fail very
8 far down the hot leg, but you're down there in the
9 stainless steel because the nozzle, although it's
10 a weaker material, there's just an awful lot of it
11 connected to a very large vessel.

12 MEMBER ARMIJO: And with the detail of
13 that, it's machined down quite a bit.

14 MEMBER SHACK: Right. All that is in
15 -- this is a detail finite element model that
16 includes that from, essentially, the vessel down
17 to the nozzle, down to the hot leg.

18 The other question that came up at the
19 Subcommittee meeting was, when you say "fail", is
20 this kind of -- you know. And what we did was, we
21 based the failure on, essentially, the average
22 stress thruster, so when this baby goes, it's
23 going big time.

24 MEMBER CORRADINI: You mean it's not
25 leak-before-break. I'm sorry.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: It's going bang. And
2 it will depressurize rapidly, at that point. But
3 contrary to what you might expect if you only
4 looked at the materials property, it really does
5 seem to be the hot leg that goes first.

6 MEMBER CORRADINI: And nothing on the
7 vessel head?

8 MEMBER ARMIJO: Yes. That's the other
9 question. You've got all those jay-welds and all
10 that stuff up there. Why doesn't that get hot?

11 MEMBER SIEBER: The things that fail
12 before that are just not big enough to bring the
13 pressure down.

14 MEMBER ARMIJO: That's the right
15 answer.

16 MEMBER SIEBER: That's right.

17 MEMBER BANERJEE: It's a real doomsday
18 scenario.

19 MEMBER STETKAR: Even on this slide
20 that's up there, that slide that was up there -

21 MR. LUPOLD: Do you want to go back to
22 it? Yes, the graph?

23 MEMBER STETKAR: No. The slide that -

24

25 (Simultaneous speakers.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: The third bullet down
2 there that says the RCP seals could fail prior to
3 the tubes. They have to fail in a way that's big
4 enough, also, to achieve that. It's got to be the
5 kind of worst possible failure for that -

6 MEMBER SIEBER: It's got to be more
7 than the sealed materials.

8 MEMBER STETKAR: That's right.

9 MEMBER SIEBER: I mean, that
10 structure.

11 MEMBER ARMIJO: That doesn't look very
12 likely.

13 MEMBER BANERJEE: If it fails, you
14 might clear the loop seal, in which case, it would
15 be a horror scenario.

16 MR. BOYD: We don't find that you have
17 to fail them where there's more than the seals
18 failing. There are some failure mechanisms, and I
19 don't know the basis of them, but they have some
20 different failure mechanisms for their reactor
21 coolant pumps, and we find that we need the
22 equivalent of about maybe 100 gpm per pump, which
23 is within their failure modes. In fact, the most
24 probably failure mode is 180 gpm per pump. And
25 I'm not sure exactly -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: I thought they said
2 180 wasn't enough, that you had to be -

3 MR. BOYD: 180 is enough to
4 depressurize the system. It's not enough to clear
5 the loop seal.

6 MEMBER STETKAR: For the loop seal,
7 okay.

8 MR. BOYD: It's enough to depressurize
9 the system. And we could call it saving the
10 tubes, but you take the pressure off the tubes.

11 MEMBER SIEBER: The pump seals are
12 going to be one of the last things to go, because
13 it's in the tube, so it's all -

14 MEMBER BANERJEE: If it has liquid,
15 then it will get two-phased flow through it.

16 MEMBER BLEY: In this scenario -

17 (Simultaneous speakers.)

18 MEMBER BLEY: -- to go long before we
19 get to these really bad things that are going on,
20 because you've lost all power, you've lost all
21 seal -

22 (Simultaneous speakers.)

23 MEMBER BLEY: So, they start leaking
24 pretty soon, and they -

25 MEMBER SIEBER: Within an hour, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would think.

2 MEMBER BLEY: Yes.

3 (Simultaneous speakers.)

4 MEMBER POWERS: I'm going to have to
5 intercede a little bit. The question that the
6 Committee is really addressing here is, have they
7 done enough to close out the steam generator
8 action plan. And they don't presume to have
9 solved all of the research problems here. So, in
10 order to keep us on schedule, I'd like to
11 intercede and let them go ahead, unless you have
12 questions that may strike to the heart of whether
13 they have done enough to close out the steam
14 generator action plan.

15 MEMBER CORRADINI: No.

16 MEMBER POWERS: Please continue.

17 MR. LUPOLD: Now I'll talk real
18 briefly about Action Item 3.10, to address some
19 concerns that the ACRS reported regarding our
20 understanding of stress corrosion cracking,
21 limitations of laboratory data and application of
22 those to real field situations, and issues with
23 the voltage and eddy current testing. Okay.

24 Actually, this particular item was not
25 based on a specific ACRS recommendation that came

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 out of the NUREG, and operating experience we have
2 on the plants indicates that plant practices for
3 predicting flaw initiation and growth have been
4 effective in assuring tube integrity consistent
5 with the assumptions that were used in the risk
6 analysis. And that the NRC staff, particularly
7 NRR, monitors plant operating experience through
8 the inspection process. And that there is really
9 no additional work that needed to be done for the
10 program, for the steam generator action plan on
11 this item. So, we're asking that that be closed,
12 since it actually was not part of the action plan
13 recommendation from the NUREG. Questions?

14 All right. I'm going to turn it over
15 to Bob Palla.

16 MR. PALLA: Okay. I'm Bob Palla. In
17 the interest of time, I can ask the Committee if
18 they want to hear all four of these items. I was
19 going to run through four items, three of which
20 are really covered by other actions, other items
21 in the plan.

22 MEMBER POWERS: I think, Bob, it's
23 useful for you to go through this, address some
24 things, understanding that this is stuff that's
25 coming.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PALLA: Okay. The items that I'm
2 going to discuss are -- that really is more
3 administrative than technical. The tasks that
4 we're looking at involve taking the results from
5 the thermal hydraulic and structural analyses, and
6 packaging that information for use in PRAs.

7 As I'll describe these tasks were
8 deferred, not actively worked as originally
9 intended. As part of the action plan close-out,
10 we reassessed the original intent of this work to
11 determine what additional work might be needed.
12 We believe that the work completed to-date under
13 the action plan tasks, combined with the work that
14 we intend to include in the User Need request
15 addresses the intent of the action plans, and that
16 the tasks can be closed.

17 So, the first task is 3.1.k. It's
18 called for using information developed in tasks
19 3.1.a through 3.1.j to evaluate the conditional
20 probabilities of multiple tube failures for
21 appropriate scenarios in risk assessments for
22 steam generator tube alternate repair criteria.
23 And these prior tasks involve the impact of
24 dynamic loads on tube integrity.

25 The objective of task 3.1.k was to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 calculate the leakage from existing steam
2 generator flaws under differential pressure loads
3 alone for the design-basis main steam line break,
4 and the result would be expressed in the form of a
5 probability distribution for total steam generator
6 leak rate from the population of flawed tubes.

7 The planned approach was to develop
8 the leakage distribution based on the RES
9 developed flaw distribution for flaws in the free
10 span. And this distribution is quite dated, at
11 this point, but that was the plan, is to basically
12 take that flaw distribution, combine it with
13 formulas for predicting the occurrence of bursts
14 and leaks in the associated leak areas, and then
15 run RELAP5 calculations that would provide
16 realistic flow rates through the leak areas
17 associated with the bursts and leakage.

18 This information was to be used to
19 support the resolution of GSI-163, which dealt
20 with multiple steam generator tube leakage in
21 design-basis accidents. This was Action Plan Item
22 3.11. We could also use that result in PRA.

23 The need for the calculation was
24 diminished for several reasons. First, in Tasks
25 3.1.a through 3.1.j, dealing with the dynamic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loads from a steam line break, the conclusion was
2 that these loads on the tubes were low, and did
3 not lead to additional leakage or ruptures beyond
4 what would be determined using differential
5 pressure loads alone.

6 In addition, these performance-based
7 technical specifications that have been put in
8 place at all U.S. PWRs in the last several years
9 as part of the industry initiative on steam
10 generator tube integrity, this is the NEI
11 Initiative 97-06. These measures will provide
12 reasonable assurance that the potential for one or
13 more tube ruptures, or the equivalent leakage from
14 multiple tubes under normal operating conditions,
15 or under DBAs, would be well within that which was
16 assumed in previous risk studies. And the leakage
17 from one or multiple tubes would also be limited
18 to small amounts. So, we have that confidence
19 coming from the way that these tubes are being
20 maintained now under the performance-based tech
21 spec. And, finally, most plants have installed
22 replacement steam generators with more corrosion-
23 resistant materials. And this has led to lower
24 number of flawed tubes being left in service, and
25 fewer proposals to increase the amount of leakage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that would be allowed under design-basis events.
2 So, accordingly, we concluded that the
3 calculations that were planned under 3.1.k are not
4 needed, weren't needed to close GSI-163, and that
5 this task can be closed.

6 Next task I'll be discussing is 3.4.j.

7 The task called for putting information developed
8 in Task 3.4.i into a probability distribution for
9 the rate of tube leakage during severe accident
10 sequences based on measured and regulated
11 parameters for alternate repair criteria applied
12 to flaws located in restricted places.

13 As background, Task 3.4.i provided
14 analytical predictions of flaw opening areas and
15 leak rates from axial and circumferential cracks
16 under the tube support plate during a steam line
17 break in severe accidents. And that work was
18 performed at Argonne.

19 Although, under Task 3.4.j we had
20 intended to put that information into a
21 probability distribution, that work was actually
22 done as part of Action Plan Item 3.5 that you'll
23 hear about shortly.

24 Under 3.5, the Office of Research
25 tasked Sandia and SAIC with developing a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 methodology for integrating the results of PRA
2 with results from supporting thermal hydraulic and
3 materials engineering analyses. This will be
4 discussed momentarily. SAIC developed an Excel
5 spreadsheet to compute the probability of tube
6 failure during an accident, and using the flaw
7 distribution and a pressure temperature history
8 for the accident.

9 Flaw distributions that were used
10 provided for six defect types, including
11 circumferential and axial outer diameter stress
12 corrosion cracking at the tube support plates.
13 And the Argonne models were used in this code to
14 calculate the growth of each crack during the
15 transient. So, what we conclude from this is that
16 the SAIC model can be used to assess the impact of
17 alternate assumptions, or models regarding leak
18 rates from flaws in restricted places, which was
19 the intent of this item. So, accordingly, the
20 effort performed under Task 3.5 has achieved the
21 intent of 3.4.j, and 3.4.j can be closed.

22 Next task is Task 3.4.k. This task
23 called for integrating information provided by
24 Tasks 3.4.a through 3.4.j, as well as Task 3.5 to
25 address ACRS criticisms of risk assessments for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 alternate repair criteria that go beyond the scope
2 and criteria of Generic Letter 95-05, as well as
3 criticisms dealing with other steam generator tube
4 rupture, integrity and licensing issues in the way
5 that they are dealt with.

6 ACRS concerns in this area included a
7 specific concern, as well as a broader concern
8 regarding the capability to perform defensible
9 calculations in the area of severe accident-
10 induced ruptures. The specific concern involved
11 alternate repair criteria that credit indications
12 restricted against burst.

13 The concern was specific to the South
14 Texas project, that had stainless steel drilled
15 tube support plates. And this is the only plant
16 that this design in the U.S., and, subsequently,
17 these generators were replaced. But the concern
18 was that because the tube support plates, they're
19 stainless instead of carbon, they didn't corrode.

20 The tubes were not clamped in place, or dented;
21 however, the crevices did accumulate debris, which
22 was causing the steam generator tube cracking.

23 There was a concern that in a rapid
24 depressurization event, the tube support plates
25 could move and expose the cracks. And a measure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that was taken to limit the displacement of the
2 tube support plates at that plant, several tubes
3 were expanded at various tube support plate
4 locations, which essentially locked the TSPs in
5 place.

6 Now, getting back to the concern.
7 When a flaw in this area, in the burst -- when the
8 flaw is in that area, and the burst pressure is
9 exceeded, the tube will not burst because of the
10 physical restriction of the tube support plate,
11 but the flaw will result in increased leakage.

12 The staff had calculated about a 5 gpm
13 leakage per flawed tube in that region. Now, that
14 result could have been used in a severe accident
15 assessment calculation, but there was no action
16 taken to actually do that, because these steam
17 generators were removed from service. So, that
18 addressed the specific Committee's concerns.

19 Now, the broader concerns involve
20 other steam generator tube integrity and licensing
21 issues related to flaws in the free span of the
22 tubes, and the ability to perform severe accident
23 calculations in a technically defensible manner.

24 Steam Generator Action Plan Item 3.5
25 that you'll hear about in a few minutes, was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 specifically intended to address that concern.
2 Based on results from the example applications
3 performed under Task 3.5, Office of Research
4 concluded that the contribution of induced SGTR
5 events to overall containment bypass frequency is
6 lower than, or about the same order of magnitude
7 as containment bypass frequency due to other
8 internal events. So, in light of that, RES
9 recommended that plant PRAs should continue to
10 evaluate consequential tube ruptures in the plant-
11 specific PRAs, in accordance with the ASME PRA
12 standards for PRA quality.

13 The methods and the results obtained
14 through the research activities provide insights
15 into the risk-significance of the consequential
16 steam generator tube rupture, as well as a
17 foundation from which risk implications of future
18 steam generator tube integrity and licensing
19 issues might be assessed. So, they've given us
20 some basic tools.

21 As I'm going to tell you in a few
22 minutes, we still think additional work is needed,
23 but even though more is needed, the work completed
24 under 3.5 has, effectively, achieved the result of
25 what that action plan item was intending to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 address. So, we think that 3.5.k can be closed,
2 for that reason.

3 MEMBER POWERS: You mean 3.4.k.

4 MR. PALLA: 3.4. Yes, sorry. I'm
5 going to move to 3.12.

6 MEMBER SIEBER: Now, before you start,
7 this is the item that I first complained about -

8 MR. PALLA: I figured it was.

9 MEMBER SIEBER: And what you're posing
10 is Steam Generator Action Plan Item to a future
11 not yet approved User Need to research.

12 MR. PALLA: Well, this -

13 MEMBER SIEBER: So go through -

14 MR. PALLA: I'll introduce it very
15 carefully, and explain how this action plan item
16 was actually phrased, because what the task called
17 for was reviewing the risk insights developed
18 under Task 3.5, and assessing the need to complete
19 a draft Reg Guide that was -- it was called DG-
20 1073. It was called, "Plant Specific Risk-
21 Informed Decision Making for Induced Tube
22 Rupture." So, it was basically asking us, do we
23 or don't we need additional guidance?

24 MEMBER SIEBER: That's correct.

25 MR. PALLA: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: And you haven't
2 answered that question.

3 MR. PALLA: Well, I'm going to say
4 yes, we do need additional guidance. And that's
5 what we're going to be -- that's what the User
6 Need is going to cover.

7 MEMBER SIEBER: I gathered the User
8 Need, and this may be a mistake on my part, was to
9 have Research decide extra guidance or not.

10 MR. PALLA: Well, they've given us
11 guidance that they think is -- well, they've given
12 us the method, they applied the method on an
13 example application, a number of plants. They've
14 drawn conclusions, and they think that their tools
15 are sufficient to close 3.5.

16 MEMBER SIEBER: Right.

17 MR. PALLA: Now, we look at those
18 tools and say well, will these tools be sufficient
19 for us to use in the future should we get
20 additional license amendment requests dealing with
21 alternate tube repair criteria. Can we pick them
22 up and use them, or do we need additional
23 guidance? The answer is, we think we need
24 additional guidance to make user assessments.

25 MEMBER SIEBER: And that's written

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 down.

2 MR. PALLA: That's written down. Yes,
3 absolutely.

4 MEMBER SIEBER: Okay. I withdraw my
5 comment.

6 MR. PALLA: Okay. At the time -- this
7 original Action Item 3.12 was, I guess -- and the
8 need for that guidance was identified COM-SECY-97-
9 013. At the time, the NRC staff had concluded
10 that the regulatory approach for assessing, or
11 addressing steam generator tube integrity should
12 be revised from issuing a new rule, to issuing a
13 compliance-based Generic Letter, with supporting
14 regulatory guidance. And that regulatory guidance
15 was expected to include this DG-1073. And the
16 idea was that 1073 would address how to make
17 changes to the steam generator licensing basis
18 consistent with Reg Guide 1.174.

19 Now, we didn't end up going in that
20 direction. Instead, we had a decision to endorse
21 the industry initiative, in lieu of the Generic
22 Letter. And that Reg Guide was never developed.
23 Now, when we came to looking at this action plan
24 item, and saying well, what do we do now? Do we,
25 or don't we need this guidance document that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 never developed? We did what the action plan item
2 said, is look at the insights coming out of Task
3 3.5, and determine what you need.

4 Based on that assessment, we concluded
5 that additional guidance and tools are still
6 needed to support future risk assessments of
7 induced steam generator tube rupture.

8 MEMBER SIEBER: Okay.

9 MR. PALLA: And the criteria, or kind
10 of the logic, is summarized on the sub-items
11 there. I'll just say briefly, Task 3.5, as well
12 as numerous studies performed by NRC and industry
13 over the last decade have not generically
14 dispositioned the issue of steam generator tube
15 rupture, induced steam generator tube rupture, or
16 substantially reduced the inherent uncertainties
17 in the analysis of these events.

18 Also, the work to-date, while
19 sufficient to resolve the technical concerns
20 regarding 3.5, there are certain limitations to
21 that work that restrict its usefulness in
22 supporting future risk assessments. For example,
23 the risk analyses do not account for updated flaw
24 distributions, or the results from the most recent
25 thermal hydraulic analyses. So, the flaw

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 distributions in there are probably 20 years,
2 based on generators as they were operated 20 years
3 ago. And the thermal hydraulic analyses that
4 Chris Boyd described, significant advances in
5 thermal hydraulic modeling, both CFD and systems
6 modeling at both levels, those results, the most
7 recent, at least, have not -- were not really
8 rolled into the work that you'll hear about on
9 Task 3.5. So, you've got, potentially, much
10 different flaw distributions, and flaw -- thermal
11 hydraulic forcing functions, basically, that maybe
12 not radically different, but maybe different
13 enough that actually, if you kind of put that
14 information together and turn the crank, again,
15 you might see a substantial reduction in the
16 conditional probability of tube failure.

17 Another thing that was not in there
18 was the work that Tim Lupold had mentioned about
19 the finite element analysis of the different
20 structural components in the RCS. The calls that
21 you'll hear about didn't have full advantage of
22 those times. And, if you did, you'd have somewhat
23 earlier times for some of these other RCS
24 components failing.

25 The third sub-item underneath there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that there's a PRA standard that identifies the
2 need to address induced steam generator tube
3 ruptures. This is one of the supporting
4 requirements for quality PRA. That item -- in the
5 standard, it references NUREG-1570 as one
6 acceptable approach. And we noticed in our
7 dealings with the industry that there's at least
8 two other methodologies that are out there, and
9 being used. Westinghouse has a simplified
10 methodology. It's part of their methodology for
11 simplified Level II modeling, but they've re-
12 looked at steam generator -- consequential steam
13 generator tube rupture, and have a simplified
14 approach with their own conditional probability
15 values for tube rupture. EPRI has a document that
16 they've submitted. It's several years old now,
17 but it's still -- it's newer than 1570.

18 We've not -- we know about this, but
19 we've not reviewed these methods. And one of the
20 things I'll mention with regard to the User Need,
21 is the desire to look at those methods, and to do
22 some comparisons with them.

23 And, finally, just based on anecdotal
24 information, licensees are using these models.
25 We've not really looked at them, and we're not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really sure what the peer review process, how that
2 would work with these methods. It may well be
3 that everyone looks at each other's PRAs and
4 thinks everything is rosy. And, in reality, if we
5 generated our own numbers today, maybe there would
6 be some significant differences. So, the
7 conclusions here are that we think that additional
8 guidance is needed.

9 The guidance would address acceptable
10 approaches for modeling and quantifying
11 conditional probability events, consequential
12 steam generator tube rupture events in future NRC
13 and/or licensee risk models. It would also
14 support staff assessments of the risk implications
15 of new licensee proposed alternate repair
16 criteria, if they should arise. The development
17 of the guidance is part of a User Need, and it's
18 very much far along. It's, basically, at our
19 office level for signature now. We have some
20 reformatting to do. There are no issues with
21 regard to the desire to ask for the information,
22 or the scope of the information that we've been
23 asking for. There's been a lot of back and forth
24 with our compatriots in Research, and general
25 agreements on the nature of what would be done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So, the conclusion that additional
2 guidance and tools is needed, and the decision to
3 proceed with the development of these tools meets
4 the intent of the action plan. This gets to, I
5 think, your concern. We're not trying to pull a
6 fast one, but we look at the way the item was
7 phrased, and asking for a decision, we say yes.
8 And we think we know what we want to include in
9 that User Need.

10 I didn't really plan to talk about it
11 much, so maybe I'll just say the User Need letter,
12 it covers four broad areas. CFE and system code
13 calculations for CE plants, a lot has been done
14 for Westinghouse. We think that some additional
15 calcs for Westinghouse are still needed. For
16 example, replacement generators have different
17 geometries in the lower plenum of the generator
18 that could affect the mixing in the hottest tube,
19 and some of these conditional probabilities, so we
20 may need to look at some additional Westinghouse
21 plants, or at least look at what we've assessed so
22 far, and determine if it covers the rest of the
23 Westinghouse plants. But, clearly, CE plants is an
24 area that not that much has been done. So, one of
25 the key items in that first bullet is let's expand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the scope of what we look at to go from
2 Westinghouse to now include some of the CE things.

3 One of the things that you may have
4 heard about in the context of the SOARCA code, and
5 I don't think Chris Boyd had the time to bring it
6 up, but under SOARCA they've run calculations that
7 have shown that even if you failed multiple tubes,
8 initially, if the first point of failure in this
9 consequential rupture scenario is actually tubes,
10 you can fail multiple tubes. You mentioned eight
11 tubes at the Subcommittee meeting, and even then,
12 you would have a hot leg failure shortly
13 thereafter that would basically pull the plug on
14 the pressure loads, and knock the fission product
15 inventories down to a percent, a couple of percent
16 of the Cesium and Iodine. And like Dr. Powers had
17 said, you'd exceed your 25 rem at the boundary,
18 but this wouldn't be a LERF, if you're looking at
19 the criteria for when do you have early fatality.

20 So, the subsequent failures that look to be
21 pretty robust finding for Westinghouse plants, may
22 or may not pan out for CE, so that's one of the
23 things we want to look at.

24 Also, the impact of in-core instrument
25 tube failure on consequential tube ruptures, some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 studies have been done by industry, Fauske &
2 Associates have done some looks at TMI scenario.
3 They like to study that.

4 MEMBER BLEY: Bob, at the Subcommittee
5 meeting we did hear a comment about the tubes.

6 MR. PALLA: Right.

7 MEMBER BLEY: Although, I have to say,
8 we have never seen that analysis yet.

9 MR. PALLA: Okay.

10 MEMBER BLEY: We haven't heard from
11 those folks.

12 MR. PALLA: Yes. And I knew they said
13 it there, but at this Committee today they didn't
14 mention it. But this whole idea, that even if you
15 fail the tubes first, it doesn't necessarily mean
16 that's the only failure location.

17 MEMBER SIEBER: What about B&W plants?

18 MR. PALLA: We did not have any plan
19 to look at that, thinking that there wasn't a
20 concern in that area.

21 MEMBER SIEBER: Why is there not a
22 concern?

23 MR. PALLA: I'd have to talk to
24 somebody smarter than me to find out why that has
25 never really been on the plate.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Well, you're smarter
2 than me, so that person is -

3 MR. PALLA: I think it's been looked
4 at before, but it was never flagged as a concern.
5 I don't know if it has to do with the basic
6 structure of the generators.

7 MEMBER SIEBER: There's nothing that
8 pops out to me that's obviously different, so I
9 would -- I'm curious to know why that's the case.

10 MR. PALLA: Well, maybe we ought to
11 reconsider whether we're complete enough. But, at
12 this point, there's no plan, there's no mention of
13 B&W. It's not on our radar. And I'll make a note
14 to make sure that it shouldn't be.

15 Okay. The second item, second major
16 bullet was updated flaw distributions, and
17 structural -- RCS structural analyses. Now, the
18 point of the second bullet, and the idea of
19 updating the distributions is that the flaw
20 distributions that are in the analyses done to-
21 date are quite old. A lot of generators have been
22 replaced. You have, perhaps -- you don't have the
23 same types of flaws. You may have different
24 flaws. You may have flaws induced by foreign
25 objects bouncing around in the system. But you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would expect that the situation with replacement
2 generators is quite a bit better. And if you
3 looked at those generators, you'd probably have a
4 different result than using the old distribution.

5 Similarly, the new performance-based
6 tech spec, the population of tubes that are left
7 in service with flaws is probably more favorable,
8 so our expectation is if we can develop a
9 reasonable updated flaw distribution, that's what
10 we would like to use in these updated
11 calculations.

12 Finite element analyses of RCS
13 components. This just refers to relooking at the
14 same kind of things that we looked at before, but
15 with the latest thermal hydraulic analyses, and
16 there were some, I think, weaknesses in the
17 analyses. The TH work that was provided to our
18 colleagues in Research that they used in the prior
19 analyses of the different structural components,
20 we think, for example, if you looked at the hot
21 leg, that the heat transfer coefficients in the
22 hot leg area are understated in those calcs. So,
23 if we go back and come up with -- properly account
24 for the heat transfer, it would probably increase
25 some of the margin in the time. It would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 probably result in earlier hot leg failures.

2 There was also some concern about the
3 material properties not being properly fully
4 accounted for in that area. So, the focus, I
5 think, is going to be really on the hot leg, and
6 maybe the surge line, but not the RCP seals. The
7 seals are understood to be highly uncertain.
8 There's actually a Westinghouse topical report in
9 that deals with -- it's a seal mod, they call the
10 shutdown seal that would be -- if implemented,
11 would probably drive the likelihood of a RCP seal
12 load, quite small, so the need to look at RCP
13 seals, probably not too high on the list.

14 The third major item is guidance and
15 tools for future risk assessments. And, in that
16 regard, what we're looking for is something that
17 is a bit more user-friendly, that we can use in
18 future risk assessments. We're thinking along the
19 lines of generalized event trees, improved
20 guidance on the treatment of critical operator
21 actions, things like B.5.B strategies, and how
22 they might be able to be accounted for. And
23 guidance on the probabilistic computer code that
24 was developed. The guidance that exists, so far,
25 is not in the form that somebody could actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pick it up and use it, if they wanted to use it.

2 MEMBER BLEY: Bob, a couple of things
3 came up at the Subcommittee on this, I'd like to
4 mention for those that weren't there. One is,
5 this is a personal opinion. I think the worry
6 about how difficult the PRA was, what Sandia did
7 for you folks is a little overstated, because they
8 had to learn the plant. The PRA team that knows
9 their PRA, and knows their plant would not have
10 done -- would have saved well over half the effort
11 that went into that, because they were doing an
12 awful lot of coming up to speed.

13 The other thing is, we did ask the question -

14 MR. PALLA: So, it may not be as big a
15 deal as we think, as we -

16 MEMBER BLEY: I think it might not be
17 as big a deal for them to do it.

18 MR. PALLA: Yes.

19 MEMBER BLEY: And your people who own
20 the models here, know those pretty well, too, now,
21 because we had a separate team come in and do this
22 from scratch.

23 The other point that came up was the
24 little code you mentioned, that puts together all
25 the thermal hydraulics and the structural stuff.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 It's a little disturbing to learn that your
2 experts in thermal hydraulics and fraction didn't
3 review how that was actually done inside of the
4 PRA. So, there was interaction for the PRA people
5 to learn what they had done, and what the results
6 meant, but there was never the opposite review
7 back of how it was actually implemented in the
8 PRA, and in that little CRYSTALBALL program to see
9 if everybody agreed that those results were
10 telling the right story.

11 MR. PALLA: I think that project --
12 that task never really went to completion, as it
13 was intended to go. That Sandia/SAIC activity,
14 basically, was brought to a screeching halt, and
15 never -- we never really had documentation until
16 very recently.

17 MEMBER BLEY: Okay.

18 MR. PALLA: Well, I mean, it existed,
19 but we didn't have it in-house. And had to
20 actually, after-the-fact, go and try to
21 reconstruct, and so the tool as a tool would not
22 be usable yet. So, we've made some major strides
23 towards doing that. But, yes, the QA has never
24 been done, so it's kind of like a black box. And
25 we think we know what it's doing, but we're not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sure yet, having gone through the QA process. We
2 want to make sure that the equations in there are
3 the right ones, and that you're actually doing the
4 thinking when you run that calculation. Which,
5 it's heavy on uncertainty, that's what -

6 MEMBER BANERJEE: I'm sorry. I was
7 out talking to Chris Boyd about the thermal
8 hydraulics.

9 MR. PALLA: So, we made up some time.

10 MEMBER BANERJEE: Yes, you made up
11 some time. But one of the -- so, you're not going
12 to ask them to aggregate, and put together at
13 least a first estimate of uncertainties and
14 predictions?

15 MR. PALLA: You mean the TH area?

16 MEMBER BANERJEE: Well, really the
17 impact on what is first. In some sense, if it's
18 pretty resilient, that the hot leg goes before the
19 steam generator tubes, then you've got a
20 particular outcome, which is lower in terms of
21 consequences, than if the -- a lot of steam
22 generator tubes go, and the hot leg doesn't go at
23 all. And I think there's been a fair amount of
24 assessment done of this already looking at
25 uncertainties.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PALLA: Well, I think maybe Selim
2 is probably the best person to address that.

3 MEMBER BANERJEE: I was looking at
4 your User Need for that.

5 MR. PALLA: The basic -- the
6 uncertainties really come together in that
7 probabilistic code that marries the TH results
8 with the tube flaw distributions. And in input to
9 that, also, is timing estimates for the difference
10 RCS components.

11 MEMBER BANERJEE: That was done
12 somewhere.

13 MR. PALLA: It's all done in that
14 probabilistic code, and the uncertainties are
15 ascribed to the TH, to the time of -

16 MEMBER BANERJEE: But in order to do
17 this ascribing of the uncertainties, you have to
18 have something which tells you what the
19 uncertainties are. Right? I mean, you just can't
20 pull the uncertainties out of the air.

21 MR. PALLA: Well, we've done that
22 before.

23 MEMBER BANERJEE: Yes, so -

24 (Simultaneous speakers.)

25 MEMBER BANERJEE: This is thermal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hydraulics. I would rather we did it in -

2 (Simultaneous speakers.)

3 MR. PALLA: Well, if you have the TH
4 results, you can pass the TH pressure temperature
5 histories to the people that are doing the finite
6 element analysis for let's say the hot leg.

7 MEMBER BANERJEE: Yes.

8 MR. PALLA: They go off and they run -

9

10 (Simultaneous speakers.)

11 MR. PALLA: They tell you here's the
12 flaw -- the timing distribution for when this
13 component would fail given this TH profile. And,
14 I guess, ideally, you'd have a distribution for
15 the TH, so they'd have a time and a distribution
16 of the time. That gets fed into the probabilistic
17 code, which is taking that same TH history and
18 convoluting it with the flaw distribution.

19 MEMBER BANERJEE: I understand the
20 process.

21 MR. PALLA: Okay.

22 MEMBER BANERJEE: It's generating this
23 distribution -

24 MEMBER POWERS: I'm going to, again,
25 assert myself -

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SIEBER: Okay.

2 MEMBER POWERS: I was kind of enjoying
3 watching you squirm, Bob. In order to keep on
4 schedule, I do caution you -- I think there's
5 going to be a great deal of interest in this User
6 Need once it gets completed. It might be useful
7 to send it over to us, and -

8 MR. PALLA: Actually, I think that
9 Dave had given you an ML number for it, so -

10 MEMBER POWERS: Giving me an ML number
11 is the same as hiding it in the recesses of your
12 desk.

13 MEMBER MAYNARD: Dana, we're not being
14 asked to approve all the ideas at this point.
15 Just connected to the -

16 MEMBER POWERS: Well, we simply --
17 this is more for interest and things like that.

18 MR. PALLA: Yes, but if you got
19 curious, I think you have the ML number, among
20 many other ML numbers.

21 MEMBER POWERS: Like I say, giving me
22 an ML number is the same as hiding it in the
23 recesses of a dark closet.

24 MR. PALLA: Well, then the key points
25 are on the slides.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: I'd like to go ahead
2 and move on.

3 MR. PALLA: The last item is that we
4 think that a little better documentation should be
5 done, because there's a lot of work that's been
6 finished and documented in many different places.

7 And we envision a summary document that didn't
8 reiterate all of it, but at least provided a
9 coherent roadmap, a summary document, but, yet,
10 something more than a two-pager.

11 MEMBER POWERS: Well, I think one of
12 the items that we certainly discussed at the
13 Subcommittee was exactly that. I'd like to move
14 on, and I'd like to finish up by 3:30, so we'll
15 have to move summarily.

16 MR. SANCAKTAR: My name is Selim
17 Sancaktar, and I work for the Office of Research
18 in PRA. I have minus four minutes to give this
19 presentation.

20 MEMBER POWERS: And that's an upper
21 bound, by the way.

22 MEMBER MAYNARD: The uncertainty of
23 you making it that has us worried.

24 (Laughter.)

25 MEMBER SHACK: No uncertainty.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SANCAKTAR: Well, I'll start by
2 saying that when I inherited this project about
3 less than two years ago, my understanding of the
4 objectives were the following. A lot of work was
5 done, and the project was, basically, in a sense,
6 wrapping up. The main objectives, in my
7 understanding, were develop a method to assess the
8 risk of consequential steam generator tube
9 rupture, apply -- extend and apply to CE plants,
10 external events, low-power and shutdown, and main
11 steam line breaks. And make sure that we
12 demonstrate the methods with illustrative examples
13 to more than one plant.

14 I looked at the existing pieces
15 available at that time, and that was, of course,
16 the 1570, which appeared, to me, to have consumed
17 a lot of effort, and it was a valiant effort,
18 really, if you look at the scope of it. There was
19 the EPRI study in two volumes that looked at
20 certain plants, and made some calculations,
21 actually, numerical results for PRA. There was
22 the Sandia report that Research has commissioned,
23 and it was pretty much done, at that time. So,
24 those were the main pieces that were available to
25 me. And what I'm trying to explain here is my

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 attempt to bring them together in a report that
2 you should theoretically have access to. It's a
3 145-page report, and it says, "A Risk Assessment
4 of Consequential Steam Generator Tube Ruptures",
5 not the, not the final, it says A. So, please
6 notice that it's on purpose and the title is not
7 accidental. I tried to bring things together here
8 with the available information.

9 The methods that were used previously
10 in the documents I mentioned were very detailed.
11 They tried to a detailed job, and it's a very
12 commendable task. When I was looking at it also
13 from the NRC's point of view as how we would
14 review things independently, how we would look at
15 things and try to quickly assess results, not in a
16 trivial sense, but more than just a trivial,
17 asking some RAIs or something.

18 So, is it possible to have a less
19 intrusive way of estimating the risk? Of course,
20 it has its own price. I mean, there's a price for
21 everything. The method that I suggest cannot be a
22 final method. It has to be repeated every time
23 you repeat your --as you change your PRA updates,
24 however, it's done very quickly. If you do an
25 intrusive modeling, then whenever you update your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 PRA, your results pop out, so you don't have to
2 change -- you don't have to reassess things from
3 scratch. So, there's a price for everything,
4 depends on what the main objective is.

5 We tried to reflect the current
6 understanding of the factors that lead to
7 consequential steam generator tube rupture. As
8 far as I could tell, this subject was studied over
9 like a decade, closer to 15 years, both in
10 materials aspects of it, thermal hydraulics
11 aspects of it, and the sequences that can lead to
12 it. They were really well studied, and
13 understood. It's not like people are still trying
14 to figure out what's going on.

15 The work done by materials and thermal
16 hydraulics fields were incorporated. The steam
17 generator tube flaws were studied, although, as
18 mentioned before, they were dated. However, I
19 caution you that I don't think the new steam
20 generators data, if we today we go and get new
21 flaw distributions, I don't think it will happen,
22 these things will go down, for simple reasons
23 like, I was told that the new steam generators,
24 the lowest point of the tubes is closer to the
25 bottom, so that the Westinghouse steam generators,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 newer ones, are closer to today's CE steam
2 generators. So, they suffer from the things that
3 we attribute to the CE plants, and CE steam
4 generators today. So, I don't -- I think that
5 people might be expecting too much, that somehow
6 things will be much better if we do new flaw
7 distributions. I wouldn't count on it.

8 Also, although many of the steam
9 generators are replaced, as times goes on, the
10 flaws will accumulate. So, this is not a time
11 frozen issue. You can't just say okay, I look at
12 this, I calculate some generic numbers, put them
13 aside, I'm done. It can't be done, and it's
14 obvious to me. I don't know, maybe I'm being too
15 simplistic.

16 Another point that I want to make sure
17 is, we in the NRC, we have SPAR models, which
18 underwent considerable review against the plant
19 models reviews. And they are also undergoing peer
20 reviews, as we speak. And they can certainly be
21 utilized to make our independent check against any
22 submittal that might, however complicated it is,
23 you can check independently, the essence, so we
24 can see if it passes the common sense tests.

25 I'm worried about complicated models,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 while people somehow pile up a lot of mitigative
2 operator action credits here and there. And it
3 won't be easily scrutinizable to a reviewer,
4 because it's buried in the complexity of the
5 model.

6 So, the method I tried to outline in
7 this report, and show also extensively with tables
8 and appendices is identify those sequences from
9 the existing PRAs that can challenge the steam
10 generator tubes, apply mitigation credit sequence-
11 by-sequence, just focus on the sequences, and go
12 down the list of sequences, starting with the ones
13 that have the highest core damage frequency
14 initially. So that as you go down, potentially,
15 the frequency of the starting point comes down, so
16 you can start wherever you want, basically, and
17 see if it's worth going any further, or not. And
18 then concentrate on each sequence, and apply
19 mitigation credit. What that means is you can see
20 the core damage, but then say okay, what else can
21 we do in a sense of B.5.B, et cetera, and what
22 kind of operator actions are feasible, and so on.
23 And then, another factor is the -- even if the
24 mitigation fails, still the tubes may not fail.
25 So, you can see there is a three-factor formula,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the sequence frequency times total mitigation
2 probability, times the conditional consequential
3 steam generator tube rupture probability. So, if
4 you multiply these three numbers -

5 MEMBER APOSTOLAKIS: I'm a bit
6 confused by your use of the word "mitigation."

7 MR. SANCAKTAR: Yes.

8 MEMBER APOSTOLAKIS: Probability that
9 the operators mitigate the conditions leading, you
10 mean?

11 MR. SANCAKTAR: What -

12 MEMBER APOSTOLAKIS: So, you don't
13 have a tube rupture yet.

14 MR. SANCAKTAR: Right. Right.

15 MEMBER APOSTOLAKIS: And you're doing
16 something to prevent it.

17 MR. SANCAKTAR: Yes. Absolutely.

18 MEMBER APOSTOLAKIS: And what gives
19 you that probability?

20 MR. SANCAKTAR: HRA people and the
21 PRA.

22 MEMBER APOSTOLAKIS: And do you know
23 how they do that?

24 MR. SANCAKTAR: They can do that with
25 any method of their choice that is acceptable at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 this point.

2 MEMBER APOSTOLAKIS: Come now into
3 territorial -- I don't know what -

4 MR. SANCAKTAR: You name me a
5 territory, and spend the next few hours discussing
6 the fine points of HRA.

7 MEMBER APOSTOLAKIS: So, it's not
8 mitigation. I mean, I'm confused. It's not
9 mitigation. It's prevention.

10 MR. SANCAKTAR: Okay.

11 MEMBER APOSTOLAKIS: That was easy.

12 MR. SANCAKTAR: Okay. The scope of
13 the method, does that include LERF analysis, the
14 measure of steam generator -- consequential steam
15 generator tube rupture importance in my context is
16 containment bypass frequency. Okay? That doesn't
17 mean that it's LERF. It may -- a percentage of it
18 will be LERF, but we're staying out of it at this
19 point.

20 MEMBER APOSTOLAKIS: So, Selim, what
21 you're saying is that you created the structure,
22 other people are giving you input. Is that what
23 you're saying with all this? If you need this
24 probability, you go some place and you get it.

25 MR. SANCAKTAR: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER APOSTOLAKIS: Okay.

2 MR. SANCAKTAR: So, this is intended
3 to provide a method for NRR to assess the risk,
4 and can be incorporated into a formal guidance
5 document.

6 So, again, first, we identify the
7 sequences by looking at the details of the
8 sequence, what happened in the primary, what
9 happens in the secondary, initially. And,
10 typically, as the TH analysis indicated, we are
11 worried about high-dry-low conditions. Also,
12 identify sequences by the initiating events that
13 can challenge the tubes, by just the nature of the
14 initiating events. And then, also, the method
15 should consider external events, and shutdown
16 initiators, as appropriate, because they are in
17 the scope.

18 There were mitigation credits. Given
19 that the core damage occurred, what's the
20 probability that the recovery actions to mitigate
21 the various conditions in the primary, or
22 secondary, or both. Restoration of secondary
23 cooling, RCS depressurization. Usually, lately,
24 they've been collected under B.5.B-type of
25 actions; although, many of them existed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 historically in the PRAs. If you go back in PRAs
2 in the past, you will see many situations where in
3 severe accident domain credit, whether it's
4 appropriate or not, was taken for various actions,
5 which in knowledge-based arguments now, B.5.B
6 makes it more proceduralized, and, also, dedicates
7 some improvement. So, there might be more
8 credibility to these.

9 Recovery may not be feasible in
10 certain situations. The ones that I'll really
11 call attention to are the high PGA, peak ground
12 acceleration seismic events, or maybe may control
13 in fires where loop, loss of on-site power, and
14 station blackout may occur. You have to be
15 careful about how much credit is justifiable. I
16 believe that this is one of the areas where most
17 uncertainty exists. You can easily move the
18 answers down orders of magnitude, effectively, by
19 giving a lot of credit to operator actions.

20 MEMBER APOSTOLAKIS: I must say, I'm a
21 bit confused. Are you proposing this method, or
22 somebody has already done it?

23 MR. SANCAKTAR: No, I'm proposing.

24 MEMBER APOSTOLAKIS: So, if I wanted
25 to find out how people handle this mitigation

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 action in terms of time available, is there a
2 place where I can go and find out, or you are
3 saying this is what I'm advising people to do in
4 the future?

5 MR. SANCAKTAR: I'm giving a potential
6 list of actions that are applicable to many
7 plants, although, specific plants might have other
8 ones. And then you can take credit, as much as
9 you can justify, for those actions.

10 MEMBER APOSTOLAKIS: But right now,
11 has anybody done this?

12 MR. SANCAKTAR: The numbers that I use
13 are screening values.

14 MEMBER APOSTOLAKIS: But it's only
15 you, not the -

16 MR. SANCAKTAR: Right. And the values
17 that were calculated in the past, like in the
18 Sandia report, they were basically calculated by
19 using standard techniques. So, there are tables
20 that says if you see this action, assign this
21 value. However, this is really both plant-
22 specific, and sequence-specific. Not only plant-
23 specific, but sequence-specific. So, if somebody
24 picks up that number, and just sprinkles it to
25 different sequences, it's possible to misuse it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And I'm just indicating that, as a point that I
2 think is important to consideration.

3 The -- we have CRYSTALBALL, which is a
4 Excel add-on that does, basically, simulations, as
5 we want to call it. CRYSTALBALL-based calculation
6 that takes flaw distributions, pressure and
7 temperature history, materials properties, common
8 failure types 3:32:11) RCS locations, generated
9 originally with the Sandia report. We are in the
10 process of taking it to the next level, where it
11 will be much more scrutinizable, and suitable for
12 various purposes that we see need for it.

13 I basically used four types of
14 consequential -- conditional consequential steam
15 generator tube rupture probabilities. I used
16 high-probability for sequences that are seriously
17 challenging the steam generator tubes, .4. That
18 number is basically calculated by -- in the Sandia
19 report, Table 4. Low-probability, .02,
20 negligible, .01, effectively zero unrealized .5.

21 The illustrative examples are applied
22 to a four-loop Westinghouse plant, Plant One is
23 the report on a site by itself. There is no
24 second unit to help it. Another one is two-loop
25 Westinghouse plant on a site by itself, again.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 There is no second unit to help it. And the two-
2 loop Combustion Engineering plant with multiple
3 units on the same site. Included are sequences
4 from so-called external events, such as seismic,
5 fire, internal fire, actually, and so on.

6 The calculations, or illustration
7 includes sequences not only caused by the core
8 damage, but, also initiating events, such as ATWS,
9 and loss of main feedwater. Examples of three
10 dominant sequences are given in the backup slides.

11 I don't -- I'm not going to go into it, but they
12 are contained in the slides. Here is a typical
13 output, just to give you a taste of it. This is
14 for Plant One, four-loop Westinghouse single unit.

15 The number at the lower right-hand corner -
16 again, don't take these numbers as the final proof
17 of anything. It's just an illustrative number.
18 Okay?

19 The number at the bottom on the right-
20 hand side is the percentage, if you take this
21 number and divide by this number --

22 (Simultaneous speakers.)

23 MR. SANCAKTAR: Okay. The 2.8 is 1.6
24 ten to the minus six divided by 5.8 ten to the
25 minus five, just to make sure. So, one shouldn't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 really focus on the magnitude of what is bypassed.

2 I mean, in this case, it's ten to the minus six,
3 it's approximately two times ten to the minus six,
4 but you have to see that in context of the total
5 number that we started with. So, that number
6 could have been ten to the minus seven, but if you
7 started with ten minus seven -- the core damage
8 goes to bypass, which is not terribly comforting.

9 The key insights to mention are, first
10 of all -- unfortunately, I'm not in a position to
11 say that here's a silver bullet. This issue is so
12 insignificant for all plants, we can just forget
13 about it. I cannot say that. Nor, I can say it
14 is such a big deal that we should be doing
15 something about it immediately. So, it is very
16 plant-specific. It should be considered, and
17 monitored in the plant risk assessments, and the
18 current standards already force the PRAs to
19 address this one way or the other from a LERF
20 point of view.

21 MEMBER APOSTOLAKIS: Let me understand
22 this, again, because I'm -- you're going too fast.

23 Go to the previous slide.

24 MR. SANCAKTAR: Okay.

25 MEMBER APOSTOLAKIS: This 2.8 percent,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 isn't this the conditional probability of
2 bypassing the containment given core damage?

3 MR. SANCAKTAR: Yes.

4 MEMBER APOSTOLAKIS: How is that
5 related to LERF?

6 MR. SANCAKTAR: This is an absolute
7 bound of LERF. That's to say LERF from -- LERF
8 will be a fraction of this. And, especially, for
9 steam generator tube ruptures, it's probably a
10 smaller fraction. It's probably not 50 percent,
11 but is much less than that. But I wouldn't hazard
12 a guess for it at this point.

13 MEMBER APOSTOLAKIS: So, when we're
14 bypassing the containment through the steam
15 generator tubes, you say that we have a full
16 spectrum of releases. So, if large is really a
17 smart part of it.

18 MR. SANCAKTAR: Another point to make
19 is the sequences that really dominate the bypass
20 are core damage sequences that cause thermally
21 induced steam generator, not necessarily ATWS, or
22 main steam lines as an initiating event, that also
23 the -- steam generator tube rupture.

24 Recommendation, plant PRAs should
25 address this issue in their evaluation of plant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 LERF on Level II analyses, whatever they have on a
2 plant-specific basis, referring to the existing
3 PRA standard. As I mentioned before, results are,
4 I think, it's my opinion, it's kind of obvious
5 from the numbers that results are very sensitive
6 to the degree of credit allowed for preventing and
7 mitigating the conditions, very, very sensitive.
8 So, based on that, care must be taken not to take
9 excessive credit for same actions, or other
10 recovery actions non-safety equipment, especially
11 for external events.

12 From a programmatic point of view, the
13 Task 3.5, which is a PRA task of the steam
14 generator action plan has been completed, and
15 should be closed. Thank you.

16 MEMBER STETKAR: I'd like to make just
17 one comment, briefly. I completely agree that the
18 what question has been answered here; that,
19 indeed, the work that's been done has concluded
20 that the issue of induced tube rupture needs to be
21 included in any plant-specific PRA. The second
22 sentence in the first bullet on the slide that's
23 up there now regarding how that's done, whether
24 that's done by actually integrating a model for
25 induced tube rupture within the plant-specific PRA

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that more comprehensively searches for the types
2 of conditions that could cause an induced tube
3 rupture, rather than kind of post-processing a
4 selected set of pre-quantified accident sequences.

5 That's the how. And we had quite a bit of
6 discussion in the Subcommittee meeting regarding
7 whether or not, indeed, this simplified approach
8 that's been used to examine whether or not this
9 issue is important enough to consider in the risk
10 assessment process, whether that method, indeed,
11 would be appropriate for the actual evaluation. I
12 think that question needs some more consideration
13 in the follow-on work. Just for the benefit of
14 the members that weren't at the Subcommittee
15 meeting. I view this as a question of what needs
16 to be considered. Does it need to be considered?

17 Yes, it does. How it's actually considered, the
18 implementation of the models, and the methods, is
19 something I still think needs a little bit of
20 examination. That doesn't alter the conclusion
21 regarding closeout of the action plan item.

22 MEMBER APOSTOLAKIS: So, if they
23 include it in the PRA, so what?

24 MR. PALLA: If you include it in the
25 PRA, and it's a dominant contributor, you may need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to scrutinize what you can do, let's say -

2 MEMBER APOSTOLAKIS: I think Selim
3 concluded it's not, didn't you? Is it a dominant
4 -

5 MR. PALLA: It's not a throw-away.
6 It's significant -- it's probably among the
7 dominant contributors to LERF. Now, if you looked
8 at the subsequent piping failures, it may say that
9 it's not a LERF contributor.

10 MEMBER STETKAR: George, what they
11 concluded was that as a fraction of the
12 containment bypass probability, if you allow me to
13 use probability, frequency, this issue could be as
14 large as everything else that has been previously
15 quantified. So, in other words, this could be a
16 factor of two-ish, perhaps less. But the fact of
17 the matter is, it hasn't been previously
18 quantified. So, it isn't necessarily dominant,
19 but it's big enough that you could be
20 underestimating containment bypass frequencies by
21 factors of two, perhaps. It might even be a
22 little bit larger than that. It's not a factor of
23 ten. It's not one-one-hundredth, either.

24 MEMBER APOSTOLAKIS: But, still, it's
25 within the realm of analysis in terms of actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 doing something, but would you -- suppose a
2 licensee comes in here, does everything that Selim
3 says, and finds that this is a dominant sequence
4 within the ten to the minus six domain. Now what?

5 You're not going to ask them to do anything, are
6 you?

7 MR. PALLA: Well, I think -- well,
8 what you're probably talking about is just
9 operator actions, accident management-type actions
10 that you might be able to, perhaps, do a little
11 better, more guidance.

12 MEMBER BANERJEE: Does operator
13 actions make a big difference?

14 MEMBER APOSTOLAKIS: These operator
15 actions here -- this is the weak part of the
16 analysis, is it not?

17 MR. PALLA: I don't think you're going
18 to change it that much, but you can, at least,
19 focus it.

20 MEMBER APOSTOLAKIS: My conclusion is
21 that in terms of real action, there is very little
22 that will result, but maybe I'm wrong. Maybe I'm
23 not with it. I'm sorry. I'm asking in terms of
24 real action on the part of the agency. It's one
25 thing to improve analysis. I'm all for it, but in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 terms of real action I don't see much happening
2 here.

3 MEMBER BLEY: I think that's why they
4 feel we can close these items.

5 MEMBER APOSTOLAKIS: No, I think he's
6 closing it because he believes that, from a
7 programmatic point of view, they've done enough.
8 That's fine.

9 MEMBER BLEY: This is a -

10 MEMBER APOSTOLAKIS: Yes, I have no
11 problem with that. Okay.

12 MR. BEAULIEU: The fact that it's part
13 of the PRA standard, I think is key. And the
14 industry is already required by the PRA standard
15 to account for this risk.

16 MEMBER APOSTOLAKIS: But, again, that
17 -- one thing is to account for it -

18 (Simultaneous speakers.)

19 MEMBER APOSTOLAKIS: And if you do --
20 if you find this, then what -

21 (Simultaneous speakers.)

22 MEMBER POWERS: I think they're in
23 violent agreement here. Are you done?

24 MR. BEAULIEU: We're complete.

25 MEMBER POWERS: We're complete,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 believe it or not.

2 MEMBER APOSTOLAKIS: Wow.

3 CHAIR BONACA: Okay. So, well said.

4 Let's take a break until 4:00.

5 (Whereupon, the proceedings went off
6 the record at 3:45 p.m., and resumed at 3:58
7 p.m.)

8 CHAIR BONACA: Okay. Let's get back
9 into session. The next item on the agenda is the
10 Oyster Creek 3-Dimensional Drywell Analysis.
11 Before I turn over the meeting to Dr. Shack, I
12 think Dr. Armijo has a statement.

13 MEMBER ARMIJO: Yes. Mr. Chairman, I
14 have a conflict of interest on this matter, so I
15 will just listen and learn.

16 CHAIR BONACA: Okay. With that.

17 MEMBER SHACK: During our
18 considerations of the license renewal for Oyster
19 Creek, we reviewed analyses presented by the
20 licensee, and by the Staff's contractor, Sandia
21 National Laboratory, that assessed whether the
22 drywell shell met the structural requirements for
23 the current licensing base of Oyster Creek.

24 The most challenging requirements were
25 against buckling during refueling with the dead

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 weight in the reactor cavity blotter, in the post-
2 accident case with seismic load and flooding.
3 Both the licensee's analysis, and the Sandia
4 analysis, found that the shell did meet the CLB
5 structural requirements. However, these analyses
6 did not provide a defensible estimate of the
7 actual structural margins.

8 Exelon committed to perform a 3-D
9 finite element analysis of the Oyster Creek
10 drywell showing the as-found degraded condition to
11 obtain a more realistic analysis of the actual
12 margins.

13 Exelon will be presenting the results
14 of that analysis today. We do note that the
15 licensing basis analysis remains the analysis by
16 GE that we would use during the license renewal.
17 Exelon, as I understand it, is not proposing to
18 replace that analysis. This analysis is being
19 presented for information and insight on the
20 actual capability of the shell. And I'll turn to
21 Sam Lee to open the discussion.

22 MR. LEE: Yes. My name is Samson Lee.
23 I'm the Deputy Division Director of Licensing
24 Renewal, NRR. And, to my left is Louise Lund.
25 She's the Senior Project Manager, and to her left

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is Tim O'Hara. He's the Senior Inspector from
2 Region 1. And he, actually, was fortunate enough
3 to actually physically inspect the sandbed region.

4 To his left is Allen Hiser, who is the Senior
5 Level Advisor in division license renewal. And to
6 his left is Hans Asher. He's a Senior Structural
7 Engineer. And to his left is Kamal Manoly. He's
8 the Senior Level Advisor, Division of Engineering.

9 And the staff will be making a presentation after
10 the utility's presentation.

11 Like Dr. Shack said, this is the --
12 meeting is on the 3-D analysis of the drywell
13 shell. And this is long history. Oyster Creek
14 found corrosion in the center region of the
15 drywell back in the 1980s, and they are taking
16 corrective action. And these have been one of the
17 sensitive items in the license renewal review.
18 And it draw a lot of public interest, including
19 public citizen group this day in New Jersey, and
20 other elected officials. And we find the drywell
21 acceptable. We know the ASME code, but it's a
22 commitment to perform the confirmatory analysis.

23 The utility did a 3-D finite element
24 realistic analysis, and they will talk about that
25 today. And with that, I'll turn it over to Mike

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Gallagher. He is the Senior -- he's the VP of
2 utility.

3 MR. GALLAGHER: Okay. Good afternoon.

4 I'm Mike Gallagher, and I'm the Vice President of
5 License Renewal for Exelon.

6 Our presentation is going to be a
7 summary to the Subcommittee -- that we gave to the
8 Subcommittee, so the Full Committee Members have a
9 little bit of that background. And then there's
10 some specific areas of feedback that we got from
11 your questions that we are presenting our
12 responses to.

13 But before we get into today's
14 presentation, I would like to introduce the
15 presenters to you. We have John O'Rourke, and
16 John is our Exelon Senior Project Manager in
17 license renewal, and he provided oversight for the
18 development of the Oyster Creek 3-D drywell
19 analysis. John has over 36 years of nuclear power
20 plant experience, primarily in engineering. And
21 John is also a registered Professional Engineer in
22 Pennsylvania.

23 Structural Integrity Associates is our
24 engineering contractor, that developed the Oyster
25 Creek 3-D drywell analysis. SIA are experts in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the field of structural analysis. And with us
2 today, we have Stan Tang. He also presented at
3 the Subcommittee. And Stan has over 30 years
4 experience in the areas of fatigue, fracture
5 mechanics, thermal mechanical stress analysis,
6 structural dynamics, finite element methods, and
7 software development. Stan's work covers areas in
8 the Defense and Nuclear industries. And Stan is
9 also a registered Professional Engineer in the
10 State of California.

11 Then, at the far end of the table we
12 have Dr. Clarence Miller. Dr. Miller has an
13 extensive career in the area of research and
14 design related to the strength and stability of
15 shell structures. Dr. Miller is currently an
16 independent consultant after retiring from Chicago
17 Bridge and Iron following 44 years of service.
18 Dr. Miller is also a registered Professional
19 Engineer in Illinois.

20 Dr. Miller has written over 90 papers,
21 publications, and test reports related to shell
22 stability. And Dr. Miller was the primary author
23 of ASME Code Case N-284 in 1979, and N-284-1. And
24 that's the metal containment shell buckling design
25 methods.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We used Code Case N-284-1 in the Oyster Creek 3-D
2 drywell analysis. Go to slide 2.

3 So, as I mentioned, today we'll be
4 presenting a summary of what we presented to the
5 Subcommittee on the 3-D drywell analysis. We also
6 have included our response to the feedback areas
7 we heard from you, from the Subcommittee from the
8 September 23rd meeting. And, our presentation is
9 framed -- this feedback is questions that we
10 thought we heard, and followed by our responses,
11 so we know that they're not, perhaps, the exact
12 questions that individual members had, but we
13 tried to frame it as such.

14 I will just go over background a
15 little bit, for the Full Committee Members'
16 benefit. So, if we go to slide 3. So, on January
17 18th, 2007, we met with the ACRS Subcommittee for
18 the Oyster Creek drywell license renewal - excuse
19 me - the Oyster Creek license renewal review. We
20 gave a detailed presentation on the drywell
21 corrosion issue.

22 In this presentation, we discussed how
23 the issue of water entered the sandbed, and caused
24 corrosion of the drywell shell, and how it was
25 identified in the early 1980s; how in 1992

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 extensive corrective actions were completed
2 resulting in the gaining of the access to the
3 sandbed region, removal of the sand in the
4 sandbed, and applying a three-layer epoxy coating
5 system on the drywell shell.

6 UT thickness measurements were
7 performed to verify adequate thickness, and we
8 continue taking these measurements today. We do
9 these every other refueling outage as part of our
10 ongoing aging management program. These UT
11 measurements have verified that the corrective
12 actions have been effective, and there are no
13 ongoing corrosion.

14 One of the items we presented was the
15 GE analysis of drywell thickness that we use as
16 our acceptance criteria for our ongoing UT
17 measurements. We showed the calculated thickness
18 margins, and why these calculated thickness
19 margins are conservative.

20 On February 1st, 2007, we met with the
21 ACRS Full Committee for the Oyster Creek license
22 renewal, and we presented some information as a
23 follow-up to the Subcommittee. One item was a
24 comment from the Subcommittee that said thickness
25 margins may be better understood with a modern 3-D

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 finite element model where various thickness, and
2 thickness configurations could be evaluated.

3 We agreed with the Subcommittee, and
4 committed to perform a 3-D finite element analysis
5 of the Oyster Creek drywell shell prior to the
6 period of extended operation. We completed the
7 analysis, and submitted it to the Staff on January
8 22nd, 2009.

9 It's important to note that this
10 analysis matches our commitment. The idea was to
11 quantify the margin that is currently available.
12 So, it is based on a realistic, but conservative
13 thickness input based on the data that we've
14 taken. This is in contrast to the GE analysis,
15 which was a conservative uniform thickness in the
16 sandbed region, that is the licensing basis, and
17 used as our acceptance criteria.

18 Also, on April 8th, 2009, the staff
19 issued the renewed license for Oyster Creek. So,
20 why we are here today is that in the February 8th,
21 2007 ACRS letter, you asked us for a briefing on
22 the results of the 3-D drywell analysis when they
23 became available. And that's why we're here
24 today.

25 If we go to the next slide, I'll just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do an overview of the results, and we'll get into
2 the presentation. This table shows the safety
3 factors for the base case, and two sensitivities
4 that we studied. It shows that the required
5 safety factors of 2.0 for the refueling case, and
6 1.60 for the post-accident flooding case. The
7 base case results show that there's margin above
8 the required, and the sensitivity show that for
9 rather large changes in thicknesses, or bay-wide
10 or locally, there's relatively small change in
11 safety factors.

12 So, with that, I'll turn it over to
13 John O'Rourke, and we'll get into the details of
14 our presentation.

15 MR. O'ROURKE: Thanks, Mike. This is
16 John O'Rourke from Exelon. And on Slide 5 I show,
17 which is also Figure 1.1 in the base case summary
18 report, illustrates a typical Mark-I containment
19 configuration representative of the Oyster Creek
20 drywell.

21 As I did at the Subcommittee meeting,
22 I want to point out the sandbed region, this small
23 region here, labeled as sandbed, which was part of
24 the original Oyster Creek design. This area was
25 originally filled with sand. The corrosion on the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exterior of the drywell shell was caused by water
2 that got into this area, and was held against the
3 shell by the sand. The sand was permanently
4 removed from this area in the early 1990s,
5 following analysis that justified such removal.
6 The exterior of the shell was cleaned and coated
7 with a three-layer epoxy coating to arrest the
8 corrosion. And, although there is no longer any
9 sand in this area, we continue to refer to this
10 area as the sandbed region.

11 This is the area in which we performed
12 the external ultrasonic thickness measurements.
13 This area is five foot four inches, and 15 inches
14 wide, and is divided into 10 bays equally space
15 around the circumference. Next slide.

16 MEMBER SIEBER: Before you leave that

17 -

18 MR. O'ROURKE: Sure.

19 MEMBER SIEBER: -- I do have a
20 question. The connection between the torus and
21 the drywell, you have a number of those around,
22 are 81 inch pipes. There is an expansion bellows
23 in there. Did you take into account in the
24 analysis any forces due to the mounting of the
25 torus with respect to the drywell in a seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 event? As I read your drawings from our last
2 meeting, you considered the structure of those 81-
3 inch pipes but I did not see any interactive
4 forces between that and the torus. Is that
5 correct?

6 MR. O'ROURKE: We modeled the six foot
7 six drywell vent pipes that go down to the vent
8 header, we modeled the entire 360 degree vent
9 header with vertical restraints at the point where
10 it's anchored to the structure.

11 MEMBER SIEBER: Okay. Thank you.

12 MR. GALLAGHER: Yes. And, Mr. Sieber,
13 on page -- slide 25, we'll be getting this when
14 Stan talks about the one follow-up question. It
15 shows all the areas, basically the constraint
16 points that are modeled. So, you have like the
17 star trusses, you have the -

18 MEMBER SIEBER: Thank you.

19 MR. O'ROURKE: Slide 6. I'd like to
20 provide a brief overall summary of the detailed
21 presentation of our 3-Dimensional Finite Element
22 Analysis provided to the Subcommittee, after which
23 I will go over several areas in detail based on
24 the Subcommittee's questions.

25 The model was developed using design

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drawings and documents. Shell thicknesses were
2 developed based on the ultrasonic thickness data
3 taken during the 2006 refueling outage. And I
4 will discuss this in more detail in the following
5 slides.

6 Current licensing basis inputs were
7 used, including the Code of record loads, and load
8 combinations. The Oyster Creek drywell vessel was
9 designed, fabricated, and erected in accordance
10 with the 1962 edition of ASME Section 8, with the
11 Code Cases shown in this slide. We did utilize
12 guidance from the 1980 edition of Section 3, and
13 Standard Review Plan 3.8.2 for certain areas not
14 covered by the 1962 edition of Section 8.

15 The buckling analysis was performed
16 per Section NE-3222 of the '89 edition of Section
17 3. We used a modified capacity reduction factor
18 in accordance with Code Case N-284-1, whose
19 primary author was Dr. Clarence Miller. As Mike
20 mentioned earlier, code minimum safety factors
21 have been met with margin. We performed a stress
22 evaluation, and the stresses are within code
23 allowables.

24 I will now discuss in some detail the
25 sandbed region shell thickness data that was used

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 as input to the analysis, starting with our aging
2 management monitoring program. Then I'll address
3 one of the Subcommittee questions, which will
4 provide the basis for the sandbed region
5 thicknesses, including two representative bays as
6 examples of how we developed the general bay
7 thicknesses, and the locally thinned area
8 thicknesses.

9 The Subcommittee members will recall
10 that I discussed all 10 bays in the Subcommittee
11 meeting. I'll conclude this section of the
12 presentation by addressing a second question
13 raised by the Subcommittee.

14 This slide illustrates the various
15 areas in the sandbed region that we monitor every
16 other year with ultrasonic thickness measurements
17 as part of our aging management program. It's
18 important to note, and I'll emphasize this in the
19 appropriate slides, that the general bay-wide
20 thicknesses are based on the internal grid
21 measurements, and external measurements are only
22 used to define the locally thinned area
23 thicknesses.

24 MEMBER SHACK: Why is that? Why don't
25 you use all the information?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'ROURKE: I'll be explaining that
2 as we go through the presentation.

3 MR. GALLAGHER: Yes. And, basically,
4 the short answer, Dr. Shack, is that these
5 external points were visually identified to be
6 thin areas, and then further ground down to -- so
7 we could interrogate them with UT. So, they are
8 very thin, and biased. So, we use them for like
9 local acceptance criteria, but not for determining
10 average, or any acceptance criteria based on
11 average.

12 MEMBER SHACK: Yes, but the statement
13 is made that you ground off 100 to 200 mils. I
14 mean, if it my drywell showing, somebody came up
15 to a thin area and wanted to grind off another 200
16 mils, I'd -- do you really believe that you've
17 ground off that much material?

18 MR. GALLAGHER: Yes. Well, we have --
19 the records show based on micrometer readings
20 that were taken that that was done.

21 MR. O'ROURKE: It was actually about
22 100 mils that was ground off. It sounds like a
23 lot, but in order to get proper UT measurements,
24 you need a good surface to get the probe on.

25 MR. GALLAGHER: And, of course, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 UTs were done and verified that adequate thickness
2 was still there, so it was still confirmed to be
3 adequate. But I agree -

4 MEMBER SHACK: So, you actually have
5 micrometer measurements. This is not somebody's
6 eyeball estimate on the 100 mils.

7 MR. GALLAGHER: That's correct. And
8 as John said, we have a slide on that, and how
9 those points were developed.

10 MR. O'ROURKE: And recalling that the
11 purpose of the analysis was to try to model the
12 drywell in as realistic, but still conservative
13 manner as possible. The external points become
14 very conservatively thin, and I'll discuss why
15 that was not appropriate to use those.

16 VICE CHAIR ABDEL-KHALIK: How do you
17 do micrometer measurements? Just the outside
18 surface?

19 MR. GALLAGHER: Yes. It was basically
20 the delta between a reference point and -

21 VICE CHAIR ABDEL-KHALIK: This is like
22 a depth micrometer?

23 MR. GALLAGHER: Yes. Sure. Depth
24 gauge.

25 VICE CHAIR ABDEL-KHALIK: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GALLAGHER: You're getting a delta
2 change between a reference point and where you
3 went to. But the UT measurements are the actual -
4 - confirmation of what the actual thickness is
5 after the area is prepared. And we continue to
6 monitor those points.

7 MEMBER SIEBER: But the thickness was
8 scaled since the volume was higher in the oxidized
9 region, gives a bias toward a greater amount of
10 grounding than probably actually occurred.

11 MR. GALLAGHER: But, I believe this
12 was done after the surfaces were prepared. So, in
13 other words, the corrosion products were removed,
14 and then there was some more -

15 MEMBER SIEBER: Additional grinding to
16 get you to a flat surface.

17 MR. GALLAGHER: Right.

18 MEMBER SIEBER: Okay.

19 MR. GALLAGHER: And, when you see some
20 pictures - we have a couple of pictures, you'll
21 see the -- they look like divots, almost, and
22 prepared areas.

23 MEMBER SIEBER: That's the picture I
24 have in my mind.

25 MR. GALLAGHER: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'ROURKE: And we have those, as
2 part of the presentation.

3 MR. GALLAGHER: Yes. If you want to
4 do a quick look ahead, Mr. Sieber, there's a -

5 MEMBER SIEBER: No, that's okay.

6 MR. GALLAGHER: All right.

7 MEMBER SIEBER: Thank you.

8 MR. O'ROURKE: On Slide 8, I show the
9 aging management program points that we monitor.
10 The green squares and small vertical rectangles
11 represent the 19 internal grid measurements.

12 When the sandbed problem was first
13 discovered, and before the sand was removed from
14 the sandbed region, a number of grid measurements
15 were taken around the drywell at elevation 11 foot
16 three. Nineteen of these grid locations
17 representing the lowest readings in each bay were
18 selected for continuing monitoring and trending,
19 and those are the locations that we show on this
20 chart. The large vertical rectangles in Bays 5 and
21 7 represent the trench grid readings.

22 MR. GALLAGHER: It's 17, John.

23 MR. O'ROURKE: 17, 5 and 17. And they
24 were created by removing concrete from the floor
25 inside the drywell to allow access to the interior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 drywell shell in those bays.

2 The triangles represent the external
3 point readings taken in the sandbed reading after
4 the sand was removed. The thinness points is
5 determined by visual inspection, were ground for
6 the ultrasonic thickness measurements, as we just
7 discussed. And I'll talk about that in more
8 detail in a few slides. These monitor points are
9 also trended.

10 Slide 9. Our understanding of the
11 question that came up during the September 23rd
12 meeting is about the appropriateness of using the
13 UT grid averages as the model thickness for large
14 areas within the sandbeds.

15 The 19 internal grids that we continue
16 to monitor were selected based on a series of grid
17 data taken to locate the thinnest general area.
18 The thinnest areas were then selected for ongoing
19 monitoring; therefore, the averages we used in the
20 3-D analysis are representative of the bay-wide
21 thicknesses, and are biased thin. Also, the
22 buckling wavelength of the drywell shell is large,
23 on the order of five to eight feet, which
24 indicates a bay-wide effect. Based on this, the
25 use of the average thickness over a bay, or a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 large portion of the bay is acceptable, and Dr.
2 Miller will speak on this further in just a few
3 slides.

4 On Slide 10, the original series of
5 internal grid measurements, over 500 measurements
6 were taken before the sand was removed from the
7 sandbed region. Where the thin locations were
8 identified, the areas around the location were
9 horizontally and vertically interrogated to locate
10 the thinnest locations.

11 Out of all locations measured, 19
12 locations were selected for ongoing monitoring,
13 making sure that there was at least one grid in
14 each of the 10 bays. These locations are
15 monitored every other refueling outage, as part of
16 the ongoing aging management program. And since
17 1992, these monitoring locations have indicated no
18 ongoing corrosion.

19 Based on this, we concluded that the
20 UT internal grid locations are representative of
21 the average thicknesses biased on the thin side,
22 and that they are appropriate to use as inputs to
23 the 3-D analysis to conservatively model the
24 general bay thicknesses.

25 MEMBER SHACK: Yes, but there's an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 exception. You go to the Bay 1 thickness from
2 your presentation last time, and it said the
3 internal grid readings for Bay 1 indicate near-
4 nominal shell readings. And, yet, that was -- you
5 conservatively estimated to be the same as Bay 19,
6 which is the thinnest, so is that just additional
7 conservatism that you've put in, or there really
8 is more corrosion above that 11 foot 3 level than
9 you're seeing on the internal grid?

10 MR. O'ROURKE: Well, the corrosion in
11 that bay doesn't go the whole length of the bay.
12 We did conservatively use the same thickness for
13 the whole bay, but the -- we used Bay 1 and 19,
14 and that is based on internal grid readings. And,
15 also, based on the fact that -- and the pictures
16 will show you this, that the bays looks very
17 similar in terms of their corrosion. So, some
18 engineering judgment was applied, but all of the
19 thicknesses that we used for the general bay
20 thicknesses were based on internal grid readings.

21 MEMBER SIEBER: I presume Dr. Miller
22 will tell us why average biased on the thin side
23 is just as good as, or usually as good as taking
24 the thinnest reading.

25 MR. GALLAGHER: We have a slide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'ROURKE: We have a slide right
2 after I finish talking about trench -

3 MEMBER SIEBER: Okay.

4 MR. O'ROURKE: On Slide 11, in
5 addition to the internal grid measurements,
6 trenches were excavated to characterize the extent
7 of corrosion at elevations below the drywell
8 interior floor. Two bays were selected for
9 excavations, representing bays having the least
10 and the most corrosion.

11 The trenches extend to about the
12 bottom of the sandbed region, and the UT
13 measurements taken in the trenches below Elevation
14 11 foot 3, confirm that the measurements are
15 bounded by the monitoring at 11 foot 3, which
16 supports our conclusion that the internal grid
17 measurements are appropriate to use as input to
18 conservatively model the general bay thicknesses.

19 At this point, I'll turn the
20 presentation over to Dr. Miller, to discuss the
21 use of average thickness.

22 MR. MILLER: Thank you, John. I'm
23 Clarence Miller. I'm going to discuss the use of
24 average thicknesses in the drywell analysis. A
25 circle shell subjected to compressive loads will

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 buckle in local areas with highest stresses.
2 Local buckling stresses depend on the applied
3 stress over a half-buckle wavelength, $L_{sub C}$. $L_{sub C}$
4 $sub C$ equals $3.72 \sqrt{RT}$, where R is
5 the radius of the shell, and T is the thickness of
6 the shell.

7 For the Oyster Creek drywell shell,
8 the half-buckle wavelength varies between 62
9 inches, and 89 inches. For shells with variable
10 thickness, where thickness can be averaged over a
11 distance of at least this half-buckle wavelength,
12 $L_{sub C}$.

13 The second point, where the drywell
14 shell is not sensitive to small thinned areas,
15 tests have been conducted on actually compressed
16 shells with unreinforced openings, which show
17 little reduction in the buckling strength. In the
18 diameter of the whole, D is less than $8/10$ ths
19 squared of RT . For the Oyster Creek drywell
20 shell, D varies between 13 inches, and 18 inches.
21 A hole less than 13 inches will have little effect
22 on the buckling strength. Therefore, thinned
23 areas, less than 13 inches, will have little
24 effect on the buckling strength.

25 Conclusion. The use of average

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 thicknesses for a bay as input to the 3-D analysis
2 is acceptable.

3 VICE CHAIR ABDEL-KHALIK: Is the
4 implication here that all the thinned areas are
5 less than 18 inches in diameter?

6 MR. GALLAGHER: No. I think what
7 we're trying to say here, the areas we have are
8 actually -- that we modeled are actually a 51-inch
9 circle, or an 18-inch circle. Okay? So, they're
10 bigger than these areas. And we chose big areas
11 so you could see some changes.

12 What Dr. Miller is saying is,
13 basically, you could have a hole 13-inches, and
14 that will change -- that won't change the buckling
15 strength much, at all. So, having thinned areas,
16 small thinned areas really doesn't have an effect.

17 VICE CHAIR ABDEL-KHALIK: I guess
18 we're -- okay. I understand that you have large
19 thinned areas that you modeled as thinned areas.

20 MR. GALLAGHER: Right.

21 VICE CHAIR ABDEL-KHALIK: And all the
22 discussion here pertains to the use of average
23 thickness throughout. So, the question is, the
24 areas that you sort of smeared within the rest of
25 the uniform thickness, are all those areas less

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 than 18-inches in diameter? They're not
2 necessarily holes.

3 MR. GALLAGHER: The bays are greater
4 than 18 inches.

5 VICE CHAIR ABDEL-KHALIK: I understand
6 that the bays are -- the locally thinned areas
7 that were not specifically modeled in the finite
8 element analysis as thinned areas.

9 MR. GALLAGHER: Yes.

10 VICE CHAIR ABDEL-KHALIK: Do you
11 understand my question?

12 MR. GALLAGHER: Yes. Maybe this would
13 help. We could just jump to Slide 20.

14 MR. MILLER: Yes. I was going to say,
15 things outside the 51-inch are actually modeled
16 with a thicker shell.

17 MR. GALLAGHER: Right. Just to make
18 sure we all have the same mental image, if you
19 look at Slide 20, and we're jumping ahead a little
20 bit, but I think this is important. We had shown
21 you before how we developed these local areas. We
22 think -- locally thinned areas. We think they're
23 very conservative. Basically, what we did was,
24 say in this particular case, in the inset in the
25 bottom there, we have how we modeled Bay 1. It's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 basically, there's four red points. We just
2 simply averaged them, and assigned that value to
3 an entire 51-inch circle. And what we're trying
4 to show you here is, this particular picture is
5 the -- a corner of this circle. And those points,
6 we pointed out what -- the points are the blue
7 points. Okay? And we pointed out what the actual
8 thicknesses are. So, if you can imagine, we have
9 that entire circle at 696 mils thick, but you can
10 see that that's not the way it is. Okay? We
11 conservatively modeled that way. So, if you look
12 at that first point, that 783, I mean, it's much
13 thinner than that. So, what we did was, where we
14 had some areas where we had some external points
15 that were kind of an area, we called that a thin
16 area, and conservatively modeled it to a very thin
17 value.

18 So, we did that in five bays, and
19 they're either 51-inch circles, or 18-inch
20 circles. And in the other five bays, there's none,
21 because if you look at those values, there's
22 hardly any thin points. All the points are
23 valuated based on local thickness criteria, so
24 everything is covered, as far as evaluation.

25 MR. O'ROURKE: That brings us back to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Slide 13. And I mentioned I would discuss two
2 representative bays as examples of how we
3 developed the UT thickness measurements to develop
4 both the general thickness, and the locally
5 thinned areas. Again, the general bay-wide
6 thicknesses being based on the internal grid UT
7 measurements, and the locally thinned areas being
8 based on the external point measurements.

9 This slide shows a picture of the
10 external surface of the drywell shell in Bay 19
11 taken in 2006. Bay 19 is one of the bays that had
12 experienced historical corrosion throughout most
13 of the bay, and we used -- to Dr. Shack's point,
14 even though there might be some area of nominal
15 thickness above -- at the top of the bay, we
16 modeled the whole bay as the same thickness. And
17 that thickness is based on three nominally 49-
18 point grids that we measure in this bay. We
19 average those points to come up with the thickness
20 value for the whole bay.

21 On slide 14, this shows the locally
22 thinned area that we've been discussing modeled by
23 the 51-inch circle. The model thickness of this
24 bay is the average of just the two thinnest
25 points, two thinnest external points. Again, to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be conservative, we picked just those two points
2 for the average of the entire 51-inch circle for
3 modeling purposes. And recognize that the 51-inch
4 circle is almost 20 percent of the area of the
5 entire bay.

6 VICE CHAIR ABDEL-KHALIK: Now, my
7 earlier question pertains to areas surrounding
8 that 721 mil point. Is it possible that at a
9 place like that, you would have a locally thinned
10 area that's greater than 18 inches in diameter?

11 MR. GALLAGHER: Not based on our
12 visual observation. That was like a point that we
13 interrogated, ground it down, and took a UT
14 reading. So, the area in-between all these points
15 is thicker.

16 MR. O'ROURKE: And if you look at the
17 adjacent point, page 67, very close to the 721, so
18 it is, in fact, a localized point, localized thin
19 point that we continue to do UT measurements and
20 trend. So, we're watching it, but for analysis
21 purposes, the area encompassed by the circle is an
22 area that we had evaluated in our calculations,
23 and wanted to model that as the 51-inch circle.

24 MEMBER SHACK: Okay. But you're going
25 to give me, at last, visual assurance that there's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 no groove along there that runs from the 736 to
2 the 728, to the 721.

3 MR. O'ROURKE: That's correct.

4 MEMBER SHACK: I mean, I -- just
5 looking at these things, I might be inclined to
6 draw an ellipse that encompassed those. But
7 you're telling me that, visually, if I went out
8 there and looked, I'd see that that 721 is -

9 MR. O'ROURKE: You would not see a
10 groove in the drywell.

11 MR. GALLAGHER: If you go back to
12 Slide 13, Dr. Shack, I mean, that -- this doesn't
13 show you the entire bay, but that's a visual of
14 how that particular bay looks. Now, at some point
15 at the top, it does stop. Right? So, you can see
16 like a little step change, but that's where it
17 stops. Then, basically, it's nominal thickness at
18 that point.

19 MEMBER SHACK: Well, I'm just looking
20 at this particular local area in Bay 19.

21 MR. GALLAGHER: Right.

22 MEMBER SHACK: Because the thing that
23 we can't see is your visual judgment as you're
24 making these decisions.

25 MR. GALLAGHER: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: All we see are a
2 collection of points.

3 MR. GALLAGHER: Right.

4 MR. O'ROURKE: But the visual
5 inspections are done along with -- I mean, the
6 people that go in to do the UTs, also are
7 qualified VT inspectors. And they report back,
8 and document their findings in their reports.

9 Slide 15 shows a picture of the
10 external surface of the drywell surface in Bay 1,
11 also taken in 2006. As we discussed, this is the
12 one where we monitor the seven-point grid. As you
13 can see from this picture, the visual observations
14 confirm the presence of some historical corrosion.

15 And, therefore, we conservatively estimated this
16 bay to be the same thickness as in Bay 19. And,
17 again, top to bottom. So, if you go back and look
18 at slide 13, and compare it to slide 15, you see a
19 very similar corrosion pattern.

20 VICE CHAIR ABDEL-KHALIK: Just for
21 scale, what is the size of this bead, this caulk
22 bead?

23 MR. GALLAGHER: The size of the caulk
24 bead? Pete, would you know what the size of the
25 caulk bead is, Pete Tamburro.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TAMBURRO: My name is Pete
2 Tamburro. The size of that caulk bead is between
3 one and two, at the out, three inches.

4 MR. O'ROURKE: On Slide 16, we also
5 modeled the locally thinned area in this bay,
6 represented, again, by a 51-inch circle. The
7 model thickness in this area is the average of the
8 four thinnest points encompassed within the
9 circle, again, shown in the diagram in red.

10 And in Slide 17, after looking at the
11 two examples, this pictorial of the whole drywell
12 sandbed region summarizes the thicknesses used in
13 the 3-D analysis, including the locally thinned
14 areas, which are modeled in five of the ten bays.

15 Slide 18. Our understanding of a
16 second question that came up during the September
17 23rd meeting was, why the external UT points are
18 considered bias thin? We had purposely looked
19 visually for the thinned points in the shell for
20 further evaluation, and most of them were ground
21 to permit accurate UT measurements. Therefore,
22 the -

23 MEMBER SHACK: And, again, you think
24 100 mils is a reasonable estimate for the amount
25 of grinding that went on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. O'ROURKE: That's what the records
2 tell us, yes. And that's on the next slide. We
3 did identify, as we said, the thinnest locations,
4 and were further investigated and characterized,
5 both visually, and using UT measurements. We
6 mapped over 100 external locations within the 10
7 bays.

8 The external surface of the drywell
9 was rough, as you saw in the couple of previous
10 slides, so most of the locations had to be ground
11 in order to create the sufficient flat surface to
12 allow a UT probe to be placed perpendicular to the
13 drywell shell. This resulted in small one to two
14 inch dimples, with relatively thinner local areas
15 that were subsequently measured by UT. I mentioned
16 the 100 mils removed. And, as you can also see
17 from the pictures, the area between the external
18 UT locations is thicker than the dimples that show
19 where we take the UT measurements.

20 So, based on all of this, we conclude
21 that the external UT points are bias thin, and are
22 not appropriate to use to determine the general
23 bay thicknesses. We did, however, use these
24 measurements, as I said, to define the locally
25 thinned areas thicknesses.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And, finally, going back to Slide 20,
2 so what I discussed on the previous slide is shown
3 visually here from the sandbed floor. We
4 discussed the caulk, and then there are several
5 external points that we monitor. And the inset,
6 which we had seen previously, shows the locations
7 that we show in the picture in blue. We've also
8 superimposed a 51-inch circle, and we've modeled
9 that as a thickness of 696 mils. I did mention
10 that the 51-inch circle covers about 20 percent of
11 the area of the entire bay. And, as I said, you
12 can note that the thickness between the dimples
13 shows thicker material. However, the whole area
14 has been conservatively modeled at 696.

15 At this point, I'll turn the
16 presentation over to Stan Tang of Structural
17 Integrity, who will discuss the finite element
18 model.

19 MR. TANG: Thank you, John.

20 MEMBER RAY: Before you get to that,
21 have you ever had occasion to remove and replace
22 any of the moisture seal? The moisture seal, have
23 you ever taken any of it out and replaced it for
24 any reason?

25 MR. GALLAGHER: No, we've done some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 repairs, because it's kind of like a hard --
2 repaired cracks that could occur in the moisture
3 seal.

4 MEMBER RAY: And, it's a seal against
5 moisture going where?

6 MR. GALLAGHER: This is the joint
7 where the shell and the floor is, and so a caulk -
8 - the seal was just put there just to prevent any
9 moisture getting into that crack.

10 MEMBER RAY: It would go into a crack
11 that -

12 MR. GALLAGHER: It's a poured floor of
13 like an epoxy, and poured right up to the shell.
14 And then the -- this material was put there that
15 just pulled that joint in. Because the shell is
16 more like this, it's curved a lot, so it's a
17 pretty tight joint.

18 MEMBER RAY: Yes. I just wondered,
19 this moisture seal looks like it's all very good.
20 A little surprising. I thought maybe it had been
21 replaced, or renewed, or something.

22 MR. GALLAGHER: No. In these pictures
23 here from 2006, that was installed in 1992.

24 MEMBER RAY: Oh, okay. It's not
25 original.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. GALLAGHER: No. All these repairs
2 were done in 1992. And just -

3 MEMBER RAY: And the moisture seal was
4 part of that.

5 MR. GALLAGHER: And that was part of
6 that. And just for clarity, this grinding that
7 was done was in 1992. This isn't something we've
8 done recently.

9 MEMBER RAY: Yes. No, no, no. I
10 mistook. I thought the moisture seal was part of
11 the original design.

12 MR. GALLAGHER: No. The repairs were
13 done in 1992.

14 MR. O'ROURKE: And that seal is
15 visually inspected every other outage. When we
16 get into the sandbed regions, we inspect that
17 seal. Stan.

18 MR. TANG: Thank you, John. I am
19 presenting the finite element model. In the
20 previous ACRS Subcommittee meeting, we have
21 presented in details the finite element model, and
22 the analysis results on ASME Code stress
23 evaluations, and buckling safety factors. In this
24 presentation, I will give a brief overview of the
25 finite element model, and provide responses to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 questions posed by the Subcommittee in the
2 September 23rd, 2009 meeting. Next slide, please.

3 The three-dimensional finite element
4 model was generated using ANSYS Release 8.1, and
5 analyzed using Release 11.0. ANSYS is a proven
6 general purpose finite element code accepted by
7 the nuclear industries. The drywell dimensions
8 are obtained from detailed drawings, with wall
9 thicknesses from the field measurements. The
10 material properties are obtained from the ASME
11 Code. The model has about four hundreds and six
12 thousands elements, with about hundred thousand
13 nodes.

14 To show that the mesh is small enough,
15 a mesh sensitivity study was performed with a
16 model, which has approximately one million
17 elements. It was shown that the stresses from
18 these two models do not have any significant
19 differences, confirming that the four hundred
20 thousand elements model is sufficient for
21 analysis. Next slide.

22 This slide shows the overall mass of
23 the overall mesh of the three-dimensional drywell
24 model, including all the major components of the
25 drywell.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The table in the upper right corner
2 identifies the mesh sizes in some of the major
3 components in the drywell. The local thinned
4 areas have the smallest nominal mesh size, about
5 three-quarter of an inch, because they are the
6 areas of interest. The sandbed region has the
7 next smallest nominal mesh size, about 1.5 inches.

8 The components further away from the sandbed
9 regions have increasing nominal mesh sizes. The
10 larger mesh sizes are still small, compared to the
11 overall size of the drywell.

12 The figure in the lower right corner
13 shows a close up view of the mesh in Bay 19 in the
14 sandbed region. The circle represented 51 inches
15 diameter of the local thinned area, which has the
16 smallest mesh. The area at the bottom of the
17 figure is the embedded regions with the boundary
18 conditions applied; thus, not required fine mesh.

19 VICE CHAIR ABDEL-KHALIK: I'm sorry.
20 Could you go back to Slide 20? Can you explain
21 not the low numbers, but the 1157 number?

22 MR. GALLAGHER: Yes. The 1157 is
23 towards the top of the sandbed, so that would be -
24

25 VICE CHAIR ABDEL-KHALIK: I mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what's the nominal thickness?

2 MR. GALLAGHER: 1154, so that's
3 basically nominal thickness. So, at some point,
4 the corrosion kind of blends and either changes,
5 because there was air, water, air-sand-water
6 interface, and essentially stops. And we had
7 shown pictures at the Subcommittee. I mean, I can
8 grab one if you'd like to take a look at it, but
9 it's from the original Subcommittee. So, up at the
10 top, you will see nominal thicknesses.

11 VICE CHAIR ABDEL-KHALIK: Okay. Thank
12 you.

13 (Off the record comments.)

14 MR. TANG: The top part of the figure
15 represents the mesh in the vent pipe with the mesh
16 transition from smaller mesh size to a larger mesh
17 size. Slide 24.

18 Our understanding of the Subcommittee
19 questions, or area of interest in the finite
20 element model, is to describe specifically the
21 modeling of the vent header boundary condition.
22 Will the downcomer vents buckle? Is the boundary
23 condition appropriate as to the effect on the
24 shell?

25 The chosen boundary condition is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 realistic as to the effect of the shell, and does
2 not provide added benefit to the shell analysis.
3 The vent header boundary condition modeling is
4 appropriate. The vent pipes, and the vent header
5 assembly will not buckle before the shell. All
6 these will be explained in more details in the
7 next few slides.

8 This slide shows all the boundary
9 conditions at different locations in the drywell
10 model, such as the star truss, the equipment
11 hatch, and the drywell bottom embedded regions.
12 In particular, the vertical constraints are used
13 on the vent header reinforcing flanges to simulate
14 the column supports which connected the vent
15 headers to the torus.

16 I'd like to point out, as highlighted
17 by the circle, that the vent header assembly,
18 starting from the vent pipe inside the torus, is
19 included for the only purpose of providing a
20 realistic stiffness/interaction boundary condition
21 only, as explained in the next couple of slides.

22 Detail modeling of the vent headers
23 and downcomers is included only for the realistic
24 representation of the stiffness/interaction of
25 components attached to the drywell shell. It is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 similar to the use of stiffness matrix, which is a
2 common finite element modeling technique, to model
3 the boundary conditions. The detail modeling is a
4 better representation of stiffness/interaction at
5 the end of the vent pipe outside the torus.

6 Modeling of the portion of vent pipe
7 inside the torus, the vent header, and the
8 downcomers reduces the conservatism in stress and
9 buckling results in the drywell shell, because it
10 accounts realistically, some of the loads, a small
11 percentage are transmitted to the vent header
12 assembly, as shown in the next slide. Alternate
13 approach is to model with a conservative boundary
14 condition at the vent pipe and torus interface
15 location. In most cases, this would be a free end
16 boundary condition that is allowing the end of the
17 vent pipe to move freely. Slide 27.

18 This slide summarizes how the reaction
19 forces are distributed in the flooding case.
20 About 93 percent of the total reaction forces was
21 at the embedded bottom head boundary conditions.
22 The loads going through the vent pipe to the vent
23 headers are small. About 4 percent of the total
24 reaction forces was at the vent header support
25 locations. About 3 percent was at the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 boundary conditions, such as the equipment hatch,
2 and the start truss.

3 If the stiffness of the vent header
4 assembly is not included in the model, the 4
5 percent of the reaction loads would go through the
6 drywell shell into the embedded region. These
7 results also confirmed that the modeling of the
8 stiffness/interaction due to the vent headers and
9 the downcomers assembly reduces the conservatism,
10 even if it only 4 percent in the stress/buckling
11 evaluation results of the drywell. The conclusion
12 is that majority of the loads are carried by the
13 spherical shell, that the boundary conditions are
14 appropriate, as to the effect of the shell. Slide
15 28.

16 The question, will the downcomer vent
17 buckle arise from the buckling mode shape results,
18 that the first ten buckling modes are not in the
19 drywell, but in the vent header assembly. It
20 should be emphasized that the inclusion of the
21 vent header assembly is only for the purpose of
22 providing stiffness interaction with the shell,
23 similar to the use of a stiffness matrix, as
24 described in the previous slides. Therefore, the
25 finite element results or the buckling modes need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 to be interpreted accordingly. This slide
2 provides a qualitative assessment to support that
3 interpretation of the buckling mode result, and
4 why the vent header assembly will not buckle
5 before the drywell shell.

6 The vent pipe has a radius to wall
7 thickness ratio of about 150, compared to the R
8 over T ratio of about 300 for the drywell
9 cylindrical shell, and about 400 to 600 for the
10 drywell spherical cell. The vent header has a
11 lower R over T ratio, about 110, and even a lower
12 R over T ratio for the downcomers, about 48.

13 The vent pipe has a length between the
14 stiffeners of about 85 inches. The length between
15 the stiffeners for the vent header and the
16 downcomers are shorter, about 48 inches and 75
17 inches. The drywell cylindrical shell has a
18 length between the stiffeners, about 103 inches.
19 For the drywell spherical shell, the length
20 between the stiffeners is from 235 inches to 332
21 inches, much longer than those in the vent pipes,
22 and the vent header assembly.

23 In Code Case 284-1, for cylinder, a
24 smaller R over T ratio gives a larger capacity
25 reduction factor. Also, a cylinder with a small R

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 over T ratio and a shorter length between the
2 stiffeners would have a higher buckling strength.

3 Based on the comparison of R over T
4 ratios, and the lengths between the stiffeners
5 among different components, the vent pipes and the
6 vent header assembly would have a larger safety
7 factor, and a higher buckling strength than the
8 drywell shells. Therefore, the vent pipes, or the
9 vent header assembly, will not buckle before the
10 drywell shells.

11 Now, I return the presentation to
12 John.

13 MR. O'ROURKE: Thank you, Stan.

14 Slide 29. Up to this point, all of
15 the discussion has been on the base case analysis.

16 We also performed two sensitivity cases that were
17 submitted to the NRC on January 22nd, 2009. And I
18 will summarize the results of the two sensitivity
19 analyses, and then address a question from the
20 Subcommittee.

21 The model used for the sensitivity
22 analysis is the same model used for the base case
23 analysis, with two exceptions. For sensitivity
24 case one, the thickness of the 51-inch locally
25 thinned area in Bay 1 was reduced by 100 mils,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 while keeping the general area of the bay
2 constant. For sensitivity case two, the thickness
3 of the general area in Bay 19 was reduced by 50
4 mils, while keeping the locally thinned area
5 thickness constant.

6 Slide 31 compares the results of the
7 base case with the two sensitivity cases. This is
8 a slide Mike had shown earlier. And, as you can
9 see, although the safety factors are reduced for
10 the base case, they are still well above the
11 required safety factors.

12 At the September 23rd meeting, we
13 understood one of the questions to be how the
14 selection of the 100 mil local reduction, and the
15 50 mil general reduction in the sensitivity cases
16 was related to the UT data.

17 Our response is that we wanted to
18 select reductions that we felt would bound data
19 uncertainties. As you can see from this slide,
20 the local area reduction, the 100 mil reduction
21 reduces the locally thinned area over 15 times the
22 observed external UT measurement difference. It
23 is, therefore, expected to bound data
24 uncertainties.

25 For the general bay-wide reduction and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 with the range of standard errors for the 19
2 internal grids, from plus or minus 2 mils, to plus
3 or minus 16.6 mils, the 50 mil bay-wide reduction
4 is at least three times the standard error for
5 the data used to determine general bay-wide
6 thicknesses. And is, therefore, expected to bound
7 data uncertainties.

8 Finally, although the drywell is not
9 experiencing corrosion, if we hypothesized a 2 mil
10 per year corrosion rate over the four-year
11 measurement interval, the 100 mil local, and 50
12 mil general reductions would be much greater than
13 the postulated 8 mil loss.

14 With that, I'll turn the presentation
15 back to Mike.

16 MR. GALLAGHER: Okay. So, just to
17 summarize, we had a license condition, and a
18 commitment to perform a modern 3-D analysis. We
19 believe we met that commitment to quantify the
20 margin. We quantified that margin. And, in
21 summary, this is the summary conclusions here,
22 which is normal operating conditions of -- the
23 limiting condition is refueling condition. And
24 for this condition, the current safety factor of
25 the limiting sandbed bays 3.54, which results in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 safety margin greater than the ASME Code specified
2 safety factor of 2.0.

3 And then for the emergency conditions,
4 the limiting condition is the post-accident flood
5 condition. For this condition, the current safety
6 factor for the limiting sandbed bay is 2.02, which
7 results in a safety margin greater than the ASME
8 Code minimum of 1.67.

9 And the sensitivity studies that we
10 performed show that we could have significant
11 thickness changes, either from uncertainty or
12 corrosion, and that we showed that we would have
13 rather large changes, without a significant
14 reduction in the safety margin, as we've shown in
15 our sensitivity cases.

16 That concludes our presentation, and
17 we'd see if you have any other questions we can
18 answer.

19 MEMBER SHACK: Thank you. I guess we
20 will have the Staff presentation now.

21 (Off the record comments.)

22 MR. GALLAGHER: Okay. Thank you, Dr.
23 Shack.

24 (Off the record comments.)

25 MEMBER SHACK: Louise, I understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you're going to be starting us off.

2 MS. LUND: Yes, thank you. Am I close
3 enough to the microphone? Okay. Is this close
4 enough? Okay. Thanks.

5 MEMBER SHACK: He's the problem, not
6 us.

7 MS. LUND: Who is?

8 MEMBER SHACK: Our reporter has to
9 hear everything.

10 MS. LUND: Oh, okay. Am I all right?

11 COURT REPORTER: Yes.

12 MS. LUND: Okay. Great. As you can
13 probably tell, on our slide up there right now
14 we've got Allen Hiser and Hans Asher, Kamal
15 Manoly, and Tim O'Hara. And you probably realize
16 that I'm not Allen Hiser, but I'm substituting in
17 for him during this presentation. And I think
18 that probably what you remember from the
19 Subcommittee meeting is, I was the Branch Chief
20 for much of the Oyster Creek license renewal
21 review. And, of course, next to me is Kamal
22 Manoly, who is the Branch Chief in the Division of
23 Engineering, and also participated in the review
24 of the 3-D analysis. And to his right is Hans
25 Asher, and he's a Senior Structural Engineer, and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 he was in the Division of Engineering, now is in
2 the Division of License Renewal. And, in fact,
3 Kamal Manoly is now a Senior Level Staff in the
4 Division of Engineering, and both of them are
5 structural engineers who have been with the NRC
6 for a long time, and sit on a number of our
7 Standards and Codes Committee. And all the way to
8 my right is Tim O'Hara, who joined us today from -
9 - he's the Region 1 inspector who actually had the
10 opportunity to go into the sandbed region, and
11 look at the activity, the inspection activities
12 for 2006 and 2008. So, he has quite a good
13 perspective to bring, as far as having looked
14 directly at the sandbed itself, and the sandbed
15 region of the drywell shell. So, we'll be
16 presenting that, as well.

17 And we're actually going to talk a
18 little bit about some of the areas that we talked
19 about during the Subcommittee meeting, but we're
20 going to go on to have Tim provide his
21 perspective, as well. And I think that the
22 licensee had discussed where we got to as far as
23 the drywell shell in the late '80s, the corrosion
24 that had occurred in the sandbed region, and the
25 reason for that. And, also, the remediation that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 they did at that time. In this case, especially,
2 I guess you've heard in their presentation, around
3 the 1992 time frame, in which they had ground down
4 those areas for measurements, and they also had
5 installed this coating that you saw in the
6 pictures.

7 Now, talking about -- this is, of
8 course, one of three analyses that were actually
9 performed. And we talked a little bit about the
10 GE analysis, is, of course, the analysis of
11 record, which is intended to be a conservative
12 analysis. And it remains the licensing basis.
13 And the acceptance criteria is derived from this
14 analysis.

15 We also, during the license renewal
16 review, had performed a confirmatory analysis by
17 Sandia that the ACRS has also been briefed on
18 during the license renewal review.

19 MEMBER SHACK: Now, what is the exact
20 acceptance criteria for that analysis? The
21 analysis assumes a uniform reduction in shell
22 thickness to the 736.

23 MS. LUND: Actually, the GE analysis,
24 actually, there was a uniform reduction, but there
25 is actually a tray model. And, actually, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bottom of the tray was .536 inches, and it
2 transitioned up to .736. And, in some ways, it
3 was a function of how the modeling was done back
4 in that era, because if you remember back in the
5 era, it was more of a pie slice instead of a 3-D,
6 so that's why this -

7 MEMBER SHACK: But, I mean, how do I -
8 - what do I measure to compare -- to get an
9 acceptance criteria? Is this the average
10 thickness over the worst bay, the 736? Is the 536
11 the thinnest minimum local UT measurement?

12 MS. LUND: Well, there's also a
13 pressure criterion, which is .490, as well. Do
14 you want to handle that, Hans, how that actually -

15
16 MR. ASHER: I can try. Otherwise,
17 I'll ask licensee to provide more information.
18 After they did all the modifications like putting
19 the coating on, and everything else, the entire
20 shell -- a very, very conservative way; that, hey,
21 my shell is not 1.15 and 154 mils thickness. It
22 is thickness of .736, 736 mils. So, that was one
23 data they put in. The second data they put in was
24 the locally thinned areas. That is where they
25 made their made their -- that is one foot by one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 square foot to three-by-three square foot on the
2 top, and the lowest thickness was .533, which was
3 not representative of any reading they had taken.

4 They wanted to make a conservative assessment at
5 that point --

6 MEMBER SHACK: But I've got a -- how
7 do they know whether they're within this licensing
8 basis or not?

9 MR. ASHER: I have a feeling. I'm
10 speculating now that they did number of gyrations
11 of calculations themselves before they came out
12 and said 736 mils. And they decided this is the
13 level where we can show the safety factor, and
14 where we can provide enough confidence that the
15 current licensing basis is good enough.

16 MS. LUND: But, they do do some --
17 what they do is -- and I see Mike Gallagher is up
18 there to talk for the licensee, as well. But when
19 they take the measurements, especially for the
20 grid, they do a statistical analysis on that,
21 because you -- this tray model is actually a 9-
22 square foot area. Okay? So, you know what they
23 have to do, is they have to say to themselves
24 afterwards that none of the individual points are
25 lower than .536, that pressure criterion .490, so

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 there's a first pass where they look at those
2 readings. And then for the averaged readings,
3 from the grids, they do a statistical analysis,
4 and get something that is for the larger area.

5 Mike, do you want to contribute to
6 that?

7 MR. GALLAGHER: Yes. This is Mike
8 Gallagher from Exelon. So, Dr. Shack, it's,
9 basically, the general acceptance criteria of 736
10 mils. So, we verify every grid is greater than
11 that. Okay? That's one step.

12 MEMBER SHACK: Okay.

13 MR. GALLAGHER: And then -- and it is.
14 And we presented all that data to you, and I have
15 it in my briefcase, if you'd like to look at it.

16 MEMBER SHACK: No, no. I just want to
17 know what the criteria is.

18 MR. GALLAGHER: So, that's one. And
19 then any point that is less than -- any individual
20 point that is less than 736 mils is compared
21 against two criteria. One is this tray that,
22 basically, was a sensitivity, you're down to 536
23 mils -- it's a three-by-three tray down to one-by-
24 one center. And we also verify that it's greater
25 than the local pressure criterion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Now, does that 536
2 point have to be within the assumed location of
3 the tray?

4 MR. GALLAGHER: The trays were -- the
5 way the trays were done was a tray could be -- one
6 tray in each bay could be done, and it was put
7 into the -- it was analyzed for the less stiffest
8 part, the value of the part between the vent
9 headers, so you can, essentially, put that tray
10 anywhere in the back. So, basically, you just
11 verify those three criteria, and then it's all
12 documented in analysis.

13 MEMBER SHACK: Thank you.

14 MR. GALLAGHER: Thanks.

15 MEMBER BROWN: Excuse me for a second.
16 Bill, I'm going to direct a question to you,
17 because I'm hoping that you'll just answer it
18 succinctly, and that's the end of it. We're
19 spending a lot of time here on measuring these
20 thicknesses and all in the area of the sand,
21 what's it called, sand?

22 MEMBER SHACK: Sandbed.

23 MEMBER BROWN: Sandbed. And, again, I
24 wasn't at the Subcommittee, so I'm a little
25 reluctant to say anything, but we've now got this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 very nice looking water seal, and it's inspected
2 regularly. But what was done about the crack that
3 was referred to as below this, what is now a
4 water seal, to verify that the thickness was what
5 it needed to be?

6 MEMBER SHACK: Okay. Just let me see
7 if I can answer it quickly. They excavated those
8 trenches, those long green lines that you saw,
9 allowed them to make direct measurements of the
10 material underneath there. Again, the argument
11 also is that that material is in intimate contact
12 with concrete.

13 MEMBER BROWN: Now, I'm familiar with
14 that. I just -

15 MEMBER SHACK: They did that -- the
16 trenches are there as a direct confirmation.

17 MEMBER BROWN: Okay. That's all.
18 Thank you.

19 MS. LUND: Okay. So, I'm going to
20 move on to -- what I wanted to point out, also, on
21 this slide was, is that all the analyses that were
22 performed demonstrated that the margins met the
23 ASME Code.

24 Okay. All three of those analyses
25 that were performed did receive independent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 reviews, so that was another thing that I wanted
2 to mention, as well.

3 The submittal that was discussed
4 today, there was a January 22nd, 2000 submittal
5 that had the base case, and the sensitivity cases.

6 And that was our review as part of the license
7 renewal inspection. And, of course, it was put
8 into the inspection report that was issued. And
9 we also received another submittal, September 9th,
10 2009, with two revised modeling approximations to
11 add different portions. And that was discussed in
12 the Subcommittee meeting, as well.

13 Both of those submittals, the
14 calculations that supported them were audited by
15 our staff. And to supplement our reviews, we
16 looked at the proprietary calculations supporting
17 the submittals. And that was to insure that the
18 analysis was conducted according to good
19 engineering and ASME Code practices, that the
20 inputs were realistic, but conservatively biased,
21 were appropriate, and that the outputs and
22 conclusions adequately supported -- was supported
23 by the data.

24 The staff reviews also whether the
25 drywell shell factors of safety from this analysis

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 met Code margins. And we recognized, as did
2 others that perform these independent reviews,
3 that there were different approaches that could be
4 taken to model the degradation and stresses that
5 would be considered appropriate by the ASME Code;
6 that with a degraded structure, such as this one
7 that was so complex, there was not one unique way
8 to model the structure, so the staff focused on
9 whether the current analysis was reasonable, and
10 consistent with good engineering and Code
11 practices.

12 Now, I'm going to go ahead and turn
13 this over to Tim O'Hara, who is going to discuss
14 his observations during the 2006 and 2008
15 inspections. And I just want to note that Tim has
16 been with the NRC for seven years. And before
17 that, he worked for Westinghouse for 20 years, and
18 was also with the Nuclear Navy. Thanks, Tim.

19 MR. O'HARA: Good afternoon. My
20 involvement with this Oyster Creek situation
21 actually started in February and March of 2006
22 during the license renewal aging management
23 inspection. At that time, I spent maybe three to
24 four weeks looking at all the data, looking at the
25 entire situation here. And then we came back in, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 guess, it was November of 2006, and watched what
2 was going on during the outage inspection of 2006.

3 The main things we were looking at,
4 that Region 1 inspection staff looked at, the
5 ultrasonic technique that was used to collect
6 data, both internally, and externally. We watched
7 the VT-1 inspection of the coating. We looked at
8 the seal inspection, and what was done there. And
9 we looked at the general condition of the drywell,
10 and how that was all recorded.

11 Secondly, the other activity that was
12 important that we were looking at is, we wanted to
13 see if there's some way to verify a process that
14 Exelon had laid out on page 19 of their slide,
15 which actually said they were -- they picked the
16 thinnest areas in the bays. And my summary of
17 what I saw, both in 2006 and 2008 is, we noted by
18 sample observations that external measurement
19 locations appeared to be chosen in areas of
20 significant relative corrosion.

21 Now, that's not certainty, but I don't
22 know how else you could have done it any
23 differently than they did. So, that's our
24 observation of what went on. And we felt
25 satisfied that Exelon had picked, to the best

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 possibility, the thinnest points.

2 And I would say in 2006 and 2008, I
3 probably entered six or seven different bays while
4 inspections were going on, while UT inspections
5 were going on, observing that they were doing them
6 correctly, and so on, and so forth. And I looked
7 at different points that were marked. They were
8 all marked, so I looked at them. And my
9 conclusion was, I couldn't have said that there
10 were other areas that were thinner. I couldn't
11 say conclusively, so my conclusion is that they
12 had done a reasonable job of picking thin spots.

13 Okay. The general observations -- by
14 the way, there are inspection reports on both the
15 2006 and 2008, and they go into much more detail.

16 I'm just talking about the sandbeds here. Okay?
17 My observations on the drywell was that the
18 exterior coating was, in general, in good
19 condition. Okay?

20 The UT inspections were conducted and
21 reported in a competent, accurate manner. And
22 what I mean there is, they had qualified
23 procedures, qualified technicians. They were
24 supervised adequately, and the results were
25 reported, and then analyzed by Level 3 UT people,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 so I think they're defensible in their Code
2 acceptable quality thickness measure, so I don't
3 have any problem with that.

4 And, finally, the sandbed general
5 conditions were good. There were some minor
6 repairs. I was more involved in the 2006
7 inspection. I spent the entire outage there. In
8 2008, I was only there a week, or so. But the
9 general conditions were good. There were some
10 minor repairs. There were some seal repairs that
11 needed to be done. And there was a coating
12 problem that had to be fixed on the drywell shell.

13 And all those conditions are reported in their
14 corrective action process, and they're all
15 adequately, or faithfully reported in their
16 inspection records. So, I have no problem with
17 what I saw. And that's, basically, my summary.
18 If anybody has any other questions, I'm -

19 MEMBER SHACK: That's the kind of
20 confirmation I was interested in.

21 MR. MANOLY: Okay. I will address the
22 next slide. This is Kamal Manoly from NRR.

23 One thing we need to focus on, that
24 even though this analysis was supposed to be
25 realistic, there are several factors that -- of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conservatism that were included in the analysis.
2 And these are fairly major conservative
3 assumptions. Using the bounding spectrum, that
4 definitely the high elevation, rather than using
5 the different location response spectrum. One of
6 the other things, the damping values used was
7 lower than the Reg Guide 161 permits up to 3
8 percent damping.

9 The weight of the flood, the water
10 from the flooding condition was all added to the
11 drywell. And, also, the sizes of the locally
12 thinned area was exaggerated to account for more
13 conservative mapping. So, these are fairly
14 sizeable areas where there are conservatisms in
15 the analysis. They're supposed to be realistic.

16 The next slide, I guess when we talk
17 about the model, and I think it's -- you all heard
18 Exelon talk about the analysis. Personally, more
19 than 35 or 40 years of experience, I haven't seen
20 a model that extensive. That is a huge model with
21 400,000 elements.

22 MEMBER SHACK: A monument to the
23 finite element art.

24 MR. MANOLY: Yes. And it's not really
25 -- it's not even used for a licensing analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This is for confirmatory analysis. The level of
2 detail is very extensive. The boundary conditions
3 which affect, usually, the analysis greatly,
4 extended at the downcomers, all the way down to
5 way beyond the zone of interest, so I think that's
6 very -- beyond what I would have expected.

7 When they committed to this analysis,
8 I didn't expect that it would be that extensive,
9 but, nevertheless, that's what they did. So,
10 we're very comfortable with the model. And we
11 think we did a very credible job on it.

12 The next slide, that's a question that
13 came up in the Subcommittee meeting. And I would
14 like to focus on a couple of things. We found
15 that the process used in arriving to the load
16 factors, and the buckling loads were consistent
17 with good engineering practice, and the ASME
18 Section 3 requirements, Code Case 284-1, which we
19 have endorsed in the regulation. And, also, the
20 Code Case in Section 8 that was later included in
21 Section 3, 754, which is similar as the Section 8
22 Code Case for modified capacity reduction factor.

23 The key point I'd like to focus on
24 here, that question came about the displacement in
25 the Tables A-2 and A-3 of the SIA model. These

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 displacements are in the bays, are not in the
2 downcomers. So, they didn't really show any
3 displacements for the downcomer, which is a large
4 pipe, essentially.

5 As they mentioned, which is, to me,
6 very reasonable, that the R over T ratio for
7 downcomers is much lower than the shell, so you
8 don't expect the downcomers to buckle before the
9 shell.

10 MEMBER SHACK: I was the one who
11 raised that, and you guys have beaten me to death.

12 (Laughter.)

13 MEMBER SHACK: As soon as I realized
14 that capacity factor was one, and all I had to do
15 was compute the buckling loads with the relative
16 capacity factors, and I know the shell is buckling
17 before the vent pipe, way before.

18 MR. MANOLY: Okay. I'm glad we agree
19 on that. The other thing that also I just -- from
20 the presentation, if you look at the weight, it's
21 taken most by the concrete and the bottom. So,
22 you are not going to -- these downcomers are not
23 going to see a whole lot of load. It's mostly
24 going to the very bottom part of the shell. So,
25 if you don't see load, you're not going to get

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 buckling. I hope that's clear.

2 VICE CHAIR ABDEL-KHALIK: Now, the
3 knock-down factors that I used in this analysis,
4 assuming that the deviation from the ideal
5 spherical or cylindrical geometry is less than the
6 maximum allowed by Code.

7 MR. MANOLY: Yes.

8 VICE CHAIR ABDEL-KHALIK: How do we
9 know that that's the case today?

10 MR. MANOLY: Well, based on the
11 geometry. You get capacity reduction factor, you
12 get modified capacity reduction factor. The
13 modified accounts for the tension in the element.

14 VICE CHAIR ABDEL-KHALIK: I understand
15 what it means. I'm asking you a specific
16 question.

17 MR. MANOLY: Yes?

18 VICE CHAIR ABDEL-KHALIK: How do we
19 know that the deviation of the geometry from the
20 ideal spherical or cylindrical geometry today is
21 consistent with the limits specified in the Codes
22 for responding to those capacity reduction
23 factors?

24 MR. MANOLY: Based on the measurement
25 that they obtained.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 VICE CHAIR ABDEL-KHALIK: When?

2 MR. MANOLY: You have certain
3 geometries for the bays. I mean, the capacity
4 reduction factor is a function of the geometry and
5 the properties of a certain zone. So, you are
6 accounting for that area.

7 MR. ASHER: If I may say, the capacity
8 reduction factor are in Code Case 284-1, are based
9 on tests, tests on the cylindrical and spherical
10 types of shells. And they are derived from them,
11 and I believe they are very conservatively put
12 together here, kind of a curve, which is a
13 parameter, M, which was explained earlier. That
14 parameter is one that dictates as to which
15 particular capacity reduction factor you can use.
16 So, it is based on tests on the imperfect kind of
17 a shell.

18 MR. MANOLY: It's empirical.

19 MR. ASHER: It's empirical in that
20 sense, yes. But, still, it is based on tests to
21 make sure that the capacity reduction factor
22 really reflects the more commonly used shapes,
23 shells, I mean, which is cylindrical shells, and
24 spherical shells.

25 MEMBER SHACK: Does that answer your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question?

2 VICE CHAIR ABDEL-KHALIK: No, it
3 doesn't answer my question.

4 MEMBER POWERS: What he's asking you
5 is, how do you know that you've got a Russian
6 spherical shell now, today?

7 VICE CHAIR ABDEL-KHALIK: Right.

8 MEMBER POWERS: As we speak.

9 MR. MANOLY: It depended on the
10 geometry of the -- if you have a cylindrical
11 shell, you're going to have a different capacity
12 reduction factor than you have a spherical shell.

13 VICE CHAIR ABDEL-KHALIK: We all
14 understand that. That is not the question.

15 MR. MANOLY: It's a derived -- it's an
16 empirical equation that -

17 MEMBER MAYNARD: We're not asking
18 about the analysis. It's just simply the Oyster
19 Creek shell, as built, as it is right now -

20 MEMBER SHACK: Matches the drawings
21 that we're using for the analysis.

22 MEMBER MAYNARD: How do we know the
23 Oyster Creek shell, itself, is cylindrical right
24 now? It has nothing to do with evaluation -

25 MR. MANOLY: How do we know it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cylindrical?

2 MEMBER SHACK: Do I think the licensee
3 is telling -

4 VICE CHAIR ABDEL-KHALIK: It's
5 sphericity is consistent with the code limitation.

6 How do we know that today?

7 MR. GALLAGHER: Yes. If I can, I
8 think you asked the same question at the
9 Subcommittee, and Dr. Miller, we can try that
10 answer. I think you're referring to the E over T.

11 VICE CHAIR ABDEL-KHALIK: I'm asking
12 what is the geometry now? How far off from a
13 sphere are we today? And is that deviation
14 consistent with the limitations imposed in the
15 Code, corresponding to these knock-down factors?

16 MR. GALLAGHER: Yes. And, basically,
17 there was criteria in the original design, and it
18 met the E over T criteria that Dr. Miller could
19 talk about. And then the Oyster Creek was -- the
20 shell was installed per their specifications and
21 drawings. So, all those design drawings, and
22 construction installations were checked during
23 construction. And that is, that is basically what
24 we had.

25 MEMBER POWERS: But he's not asking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 about the time of construction. He's asking
2 today.

3 MR. GALLAGHER: Understand, but there
4 was no changes in the fabrication, or the
5 installation, so it was all installed per design,
6 and we used the design drawings to build the
7 model. Now, there are conservatisms in safety
8 factor, and even in the capacity reduction factor
9 that would accommodate any uncertainties. But it
10 was designed and installed in accordance with the
11 requirements and specifications.

12 MEMBER POWERS: I think the answer to
13 your question is they don't know.

14 MS. LUND: Well, is the question
15 you're asking, is it -

16 MR. GALLAGHER: Because it is designed
17 and installed, and we -

18 VICE CHAIR ABDEL-KHALIK: Here is the
19 rationale for my question. The capacity reduction
20 factor -

21 MR. GALLAGHER: Not going to change
22 the structure.

23 VICE CHAIR ABDEL-KHALIK: The capacity
24 reduction factors depend on how far off from a
25 perfect sphere you are.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. LUND: Right.

2 VICE CHAIR ABDEL-KHALIK: And,
3 presumably, the values that were used were
4 consistent with the limits imposed in the Code,
5 which, presumably, were verified at the time of
6 construction.

7 MS. LUND: Right, because they had the

8 -

9 VICE CHAIR ABDEL-KHALIK: The question
10 is, what does it look like now?

11 MS. LUND: Right. Because they -

12 VICE CHAIR ABDEL-KHALIK: How far off
13 from a sphere are we?

14 MS. LUND: Basically, is the question
15 you're asking inferring that there has been some
16 plastic deformation, and it's changed from its as-
17 built dimensions? Is that what the -- what's
18 underlying?

19 VICE CHAIR ABDEL-KHALIK: For whatever
20 reason, difference in ability to accurately
21 measure deviation from perfect sphericity between
22 then and now. The issue is how sensitive is that
23 capacity reduction factor to -

24 MS. LUND: Small changes?

25 VICE CHAIR ABDEL-KHALIK: Deviations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from -

2 MS. LUND: I think that's the
3 question.

4 VICE CHAIR ABDEL-KHALIK: -- what the
5 Code limits dictate.

6 MS. LUND: Right. Right. Basically,
7 they were putting in the measurements from their
8 as-designed, and as-built shell. And what you're
9 asking is, is that if there were small changes
10 because of some deformation, how would that impact
11 really what it is today? Is that what -

12 MEMBER ARMIJO: Could I ask -- if you
13 take that sphere, it's a big sphere. There's a
14 three-inch gap between the concrete and the
15 containment vessel. If that diameter increased by
16 six inches, stretched out by six inches, would it
17 make any difference? That's a limit. That's as
18 big as that sphere could get from -

19 MR. MANOLY: If the shell was
20 perfectly round, and there's no defections, you
21 would not need the capacity reduction factors.

22 MS. LUND: Right.

23 MEMBER ARMIJO: I understand that.

24 MR. MANOLY: You're really accounting
25 for imperfections in the shell.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER ARMIJO: He's asking how
2 imperfect is it today, and does that meet the
3 criteria that you used in the analysis?

4 MS. LUND: And whether there could be
5 any changes from what they actually calculated to
6 begin with, because could there be any feasible
7 mechanism for it to deform, or in some way not
8 represent what it was when the initial
9 measurements were used.

10 MR. MANOLY: I don't think the
11 numbers in the capacity reduction factor are very
12 sensitive, if the -- when the shell was
13 constructed, it, obviously, met the construction
14 specs. Okay? So, the Code Case was developed
15 when we have certain potential variations in the -
16 - from the perfect shell.

17 MEMBER SHACK: I think the best we
18 could do is get an expert opinion by Dr. Miller.

19 VICE CHAIR ABDEL-KHALIK: Please.

20 MEMBER SHACK: If we've met the
21 original configuration -

22 MR. MILLER: I can't positively
23 answer, you're right.

24 VICE CHAIR ABDEL-KHALIK: Thank you.

25 MR. MILLER: Your question, what I can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 say, that the initial out-of-roundness allowed by
2 the ASME Code is one shell thickness measured over
3 a half-buckle wavelength, which I mentioned was
4 somewhere between 62 and 89 inches. Typically,
5 the initial construction will be well within that
6 one shell thickness, much less, maybe only half of
7 the shell thickness, or less. I can't positively
8 tell you that it's -

9 VICE CHAIR ABDEL-KHALIK: What it
10 looks like now.

11 MR. MILLER: I would say if you go out
12 and measure, I would be very surprised if you
13 found there is a point of the shell where the
14 deviation is greater than the shell thickness.

15 VICE CHAIR ABDEL-KHALIK: So the
16 question then is, if I were to plot this capacity
17 reduction factor as a function of the fractional
18 deviation from perfect sphericity, how rapidly
19 does this thing drop off, as this sort of
20 imperfection size increases?

21 MR. MILLER: Actually, in the Code
22 Case, I have an equation which relates the
23 measured deviation with the allowable -- in other
24 words, the capacity reduction factor, I have an
25 equation, regardless of what the value -- there is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 some lower bound, but in the case of this
2 particular sphere, there's two criteria. One is
3 local deviations in the unstiffened sphere. The
4 second criteria is if you put ring stiffeners, you
5 get to the point where the Alpha factor is based
6 on the ring stiffeners, and not the local
7 deviation. And it just happens that in this
8 particular drywell shell, the Alpha value that
9 we're using is based on the distance between
10 stiffeners, as opposed to the one based on R over
11 T. The one based on R over T is related to this E
12 over T of one.

13 VICE CHAIR ABDEL-KHALIK: Thank you.

14 MR. MANOLY: I think another point we
15 need to add here, that if you don't account for
16 the modified capacity reduction factor, which
17 improves the shell buckling capacity, if you take
18 that out, and just calculated the factor of
19 safety, you still meet the Code limit. So, the
20 whole notion about modified capacity reduction
21 factor -

22 VICE CHAIR ABDEL-KHALIK: But you
23 wouldn't have a 3.5 safety factor that gets -

24 MR. MANOLY: It would be less, but
25 will meet the Code limit. That's the point I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 trying to make, that even if you know the whole
2 argument about the tension of the shell and the
3 whole direction that included this buckling
4 capacity, you still will meet the Code limit at
5 the lower number from what they show here. So, I
6 think that's another thing that we need to keep in
7 mind.

8 VICE CHAIR ABDEL-KHALIK: Thank you.

9 MR. MANOLY: The next slide really
10 talks about the sensitivity analysis, and we've
11 talked about that several times. The key here is
12 that it was intended to capture uncertainty,
13 potential uncertainty in the mapping of the
14 thinned areas. And as they showed in the S-1 and
15 S-2 analysis, in one day they reduced it by 100
16 mils in Bay 1, and the entire -- the thinned area
17 was thinned by 100 mils. And Bay 19 was 50 mils
18 in the entire bay. That's, in our opinion, very
19 conservative. And, really, they can do the
20 sensitivity analysis in a thousand different ways,
21 and anybody can decide which way is right, but I
22 think this is very conservative way of considering
23 two pieces that are pretty extreme. And, also, if
24 you add that to the analysis done by Sandia,
25 analysis done by GE, they all point to the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 direction, that we still meet the Code limit. So,
2 we think that the analysis was very adequate and
3 reasonable for the focus that it was done.

4 MS. LUND: Okay. Summarizing our
5 presentation, we say to ourselves, what were we
6 actually aiming to do? Okay? Or what was the
7 licensee aiming to do? And I think their intent
8 was to do a conservatively biased realistic
9 analysis that gave them some sense of what
10 additional margin there was above the ASME Code
11 limits. And in doing that, and also to look at
12 the sensitivity of that analysis to thinning in
13 both the thinned areas, and also in the bay. And
14 as Kamal has said, I think that there can be other
15 approaches towards modeling. There's going to be
16 other approaches towards looking at realistic
17 versus conservative inputs, but -- and, also, as
18 Tim has said in his presentation, as well, we
19 looked at what they had done, and it looked
20 reasonable, and it looked like it was
21 conservatively biased. And we had confidence that
22 what they had done was what was asked in this
23 particular analysis.

24 And another thing I wanted to mention,
25 too, is, when Tim was -- and also the other

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 regional inspectors were looking at this, there's
2 a lot of background information on the work that
3 they did to characterize this, to put on the
4 coating, to the inspection reports. There's
5 piles, and piles, and piles of documentation, and
6 probably far more than I've seen for a lot of work
7 that I've seen done. It is very adequately
8 documented, a lot of the work that they've done in
9 the past. And I know that the inspections had --
10 the inspectors and the inspections had use of a
11 lot of that material to prepare for that, and
12 understand what happens. Anyway, that concludes
13 what our presentation is.

14 MEMBER SHACK: Any further questions
15 from the Committee? Again, a lively discussion.
16 This thing always does seem to raise a number of
17 issues. Thank you.

18 MEMBER POWERS: A defense-in-depth
19 physical barrier. It should receive lots of
20 attention.

21 MEMBER SHACK: Thanks very much to the
22 Staff, and to the licensee for the very good
23 presentations. Are there any questions from
24 anybody in the audience? Back to you, Mr.
25 Chairman. Sorry we're a little late.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIR BONACA: Thank you very much for
2 the presentation, and we'll take a break now until
3 ten of six, and we'll get together, and talk about
4 the letters.

5 (Whereupon, the proceedings went off
6 the record at 5:36 p.m.)

7
8
9
10
11
12
13
14
15
16
17
18
19

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

North Anna

3

North Anna Unit 3 Presentation to Advisory Committee on Reactor Safeguards




Dominion's North Anna 3 Licensing Activities

- ESP Application submitted 9/25/03
- ESP issued 11/27/07
- COLA submitted 11/27/07
- Draft EIS issued 12/17/08
- COLA Revision 1 submitted 12/20/08


Dominion North Anna 3 Presentations to ACRS Subcommittee

- June 11, 2009
 - Chapters 1, 4, 6, 7, 8, 15, 17, 18, 19
- July 21 and 22, 2009
 - Chapter 5, 9, 10, 11, 12, 13, 16
- August 21, 2009
 - Chapters 2, 3, 14


Location of North Anna Power Station



Location of North Anna Power Station



North Anna Power Station



Introduction of COLA Team's Meeting Participants

Dominion

- Joe Hegner
- Gina Borsh

GEH

- Rick Kingston
- Patricia Campbell

Bechtel

- Doug Kemp
- Geoff Quinn

Subject Matter Experts by phone

North Anna

3

ACRS COLA Presentation: Site-Specific Topics and ACRS Inquiries

Introduction

- NAPS U3 FSAR Content
 - Incorporated by reference (IBR):
 - ESBWR DCD as permitted by 10CFR52.55(c)
 - ESPA SSAR
 - Supplemental information added:
 - COL Item
 - ESP COL Action Item
 - ESP Permit Condition
 - Conceptual Design Information
 - Supplemental Information (e.g., Reg Guide 1.206)

Discussion Topics

- Chapter 2 – Site Characteristics
 - 2.4, Hydrology
 - 2.5, Geology, Seismology, and Geotechnical Engineering
- 9.2.3 Makeup Water System
- 10.4.5 Circulating Water System
- 9.2.1 Plant Service Water System

Chapter 2, Site Characteristics: Background

- Compares Unit 3 FSAR site characteristics and facility design values with corresponding DCD, ESP, or ESP Application SSAR values to determine if:
 - Unit 3 site characteristics fall within DCD's site parameters
 - Unit 3 site characteristics or facility design fall within ESP's site characteristics or design parameters [ESP used plant parameter envelope (PPE)]
 - Unit 3 site characteristics and design values fall within SSAR site characteristic and design parameter values

North Anna

3

Chapter 2: Site Characteristics

Section 2.4, Hydrology

Chapter 2, Site Characteristics:

2.4 Hydrology

- SSAR Section 2.4 is incorporated by reference and supplemented with:
 - Impact on wetlands and two intermittent streams that flow into Lake Anna [NAPS COL]
 - Design plant grade is above design basis flooding level [NAPS COL]
 - Location of safety-related SSCs is above maximum water surface elevation produced by local intense precipitation [NAPS ESP COL]

Chapter 2, Site Characteristics:

2.4 Hydrology (cont.)

- Supplemental Information (cont):
 - Water supply to the UHS is above design plant grade elevation [NAPS COL]
 - Engineered underground reservoirs or storage basins not used for UHS [NAPS ESP COL]
 - Emergency cooling water for Unit 3 is provided from UHS, which is not affected by ice conditions [NAPS COL]
 - Lake Anna is not used for safety-related water withdrawals for Unit 3 [NAPS ESP COL]

Chapter 2, Site Characteristics:

2.4 Hydrology (cont.)

- Supplemental Information (cont):
 - Embankment for water intake structure is protected by rip-rap [NAPS ESP COL]
 - Maximum PMP water level in power block area is 2.8 ft below design plant grade elevation for safety-related facilities [NAPS COL]
 - Circulating water system operating modes [NAPS ESP COL]

Chapter 2, Site Characteristics:

2.4 Hydrology (cont.)

- Supplemental Information (cont):
 - Additional borings, groundwater level measurements, hydraulic conductivity testing [NAPS COL, NAPS ESP VAR]
 - Groundwater supply wells, groundwater use, and groundwater level monitoring program [NAPS COL, NAPS ESP VAR]
 - Estimated maximum groundwater level in power block area is 7 ft below design plant grade elevation of 290 ft; therefore, permanent dewatering system is not required for safe operation of Unit 3 [NAPS COL]

Chapter 2, Site Characteristics:

2.4 Hydrology (cont.)

- Supplemental Information (cont):
 - Mitigating design features are incorporated into design of Unit 3 to preclude an accidental release of liquid effluents [NAPS COL, NAPS ESP PC]
 - Accidental release of radioactive liquid effluent to either groundwater or surface water complies with 10 CFR 20 limits for release to unrestricted areas [NAPS COL]
 - Unit 3 will shut down when water level in Lake Anna drops below Elevation 242 ft msl [NAPS ESP COL]

North Anna

3

Chapter 2: Site Characteristics

Section 2.5, Geology,
Seismology, and
Geotechnical Engineering

Chapter 2, Site Characteristics:

2.5 Geology, Seismology, and Geotechnical Engineering

- SSAR Section 2.5 is incorporated by reference and supplemented with:
 - Additional Unit 3 borings to further describe the site stratigraphy [NAPS COL]
 - Weathered or fractured rock at foundation level for safety-related structures will be excavated and replaced with lean concrete before foundation construction [NAPS ESP PC]
 - Future excavations for safety-related structures will be geologically mapped and unforeseen geologic features will be evaluated [NAPS ESP PC]

Chapter 2, Site Characteristics:

2.5 Geology, Seismology, and Geotechnical Engineering

- Supplemental Information (cont):
 - Unit 3 OBE ground motion is one-third of FIRS and is bounded by DCD OBE [NAPS COL]
 - Description of excavations, fills, and slopes, including discussion of excavation and fill methods and stability [NAPS ESP COL, NAPS ESP PC]
 - SWV profiles for soil used for liquefaction analysis and slope stability analysis; backfill for FWSC [NAPS COL, NAPS ESP COL]

Chapter 2, Site Characteristics:

2.5 Geology, Seismology, and Geotechnical Engineering (cont)

- Supplemental Information (cont):
 - Liquefaction Potential [NAPS COL, NAPS ESP PC]
 - Chances of liquefaction occurring in Zone IIA saprolite are extremely low; will not impact stability of any Seismic Category I or II structure
 - Foundation and Slope Stability
 - Allowable bearing capacity values are adequate for Seismic Category I and II structures, and Radwaste Building [NAPS COL]
 - Total and differential settlement values are within limits for Seismic Category I structures [NAPS ESP COL]
 - Static and seismic lateral earth pressures are provided [NAPS ESP COL]
 - Slope stability analysis [NAPS ESP COL]

North Anna

3

Water Systems

Make-up Water System

Circulating Water System

Plant Service Water System

Chapter 9, Auxiliary Systems:

Section 9.2.3 Makeup Water System

- Function: Supplies demineralized water to equipment listed in DCD
 - Nonsafety-related system
- During shutdown/refueling/startup mode, increases in plant water consumption may require use of temporary demineralization subsystem
 - Per DCD, design capacity is for normal power requirements
 - Increase is due to draining of non-contaminated systems that can't be refilled with condensate-quality water
 - Ensures adequate supply to supplement CST volume
 - Effective outage Makeup Water usage plan will minimize need for temporary subsystem

Chapter 10, Steam and Power Conversion System: Section 10.4.5: Circulating Water System

- PRA model for system is described in DCD PRA
- Plant-specific design of circulating water system (e.g., cooling towers) is enveloped by DCD PRA analysis
 - Condenser only credited in PRA for events with low significance – where offsite power is available
 - DCD PRA includes analysis of CIRC pump failures due to power loss and trash rack plugging
 - Cooling tower fans not specifically modeled in DCD PRA
 - Fan power supply is same as CIRC water pumps

Chapter 9, Auxiliary Systems: Section 9.2.1 Plant Service Water System (PSWS)

- Function: PSWS rejects heat from nonsafety-related Reactor Component Cooling Water System (RCCWS) and Turbine Component Cooling Water System (TCCWS)
 - No safety-related function
 - Categorized in DCD as RTNSS C

Chapter 9, Auxiliary Systems:

Section 9.2.1 Plant Service Water System (PSWS) (cont)

- DCD conceptual design provides for connection between PSWS and normal plant heat sink (CIRC)
- NAPS U3 design does not include this connection
 - Operating conditions might require design changes for other systems (RCCW, TCCW)
 - LOOP would require re-alignment
 - Increased capital cost (e.g., larger normal power heat sink, added booster pumps or larger PSWS pumps) and operating cost (e.g., added booster pump maintenance and increased auxiliary power demand) without offsetting benefits
- NAPS U3 PSWS meets the DCD's performance requirements without cross-connect

Chapter 9, Auxiliary Systems: Section 9.2.1 Plant Service Water System (PSWS) (cont)

- Piping for underground portion of system will be fiberglass reinforced polyester (FRP) pipe
- Rationale
 - Meets design requirements
 - Advantages over other options (e.g., long-term resistance to internal and external corrosion and biological attack)
- ASME code case being used as guidance to develop applicable requirements

Conclusions

- R-COLA work continues
 - Addressing remaining RAIs
 - Advanced SER with no Open Items scheduled to be issued September 2, 2010
 - ACRS review of SER with no Open Items scheduled to be completed December 21, 2010



Presentation to the ACRS Full Committee

North Anna Unit 3 COL Application

Safety Evaluation Report (SER) with Open Items (OI)

October 8, 2009

Office of New Reactors

ACRS Full Committee Presentation North Anna SER/OI

Agenda

- ❖ Opening Comments
- ❖ Overview – Applicant and Staff
- ❖ Open Items Update
- ❖ Hydrologic Engineering (SER Section 2.4)
- ❖ Geology, Seismology, & Geotechnical Engineering (SER 2.5)
- ❖ Functional Design, Qualification, and Inservice Testing Programs and Environmental Qualification of Equipment (SER 3.9.6, 3.11)
- ❖ Plant Water Systems – Circulating, Makeup, & Plant Service (SER 10.4.5, 9.2.3, & 9.2.1)
- ❖ ITAAC (SER 14.3)
- ❖ COL Application Review Schedule

ACRS Full Committee Presentation North Anna SER/OI

Staff Overview

- ❖ SER/OI complete
 - 19 chapters + appendices
 - DNRL Memorandum to ACRS [ML092150277]
- ❖ North Anna COL Application, Revision 1 (12/08)
 - Incorporates by reference
 - Early Site Permit (ESP-003) – Site Safety Analysis Report
 - ESBWR Design Control Document, Revision 5
 - Includes responses to staff RAIs (Phase 1)

ACRS Full Committee Presentation North Anna SER/OI

Staff Overview (continued)

- ❖ ACRS Subcommittee Meetings
 - Focus – North Anna COL application
 - Presentation topics
 - June 18 – Chapters 1, 4, 6, 7, 8, 15, 17, 18, & 19
 - July 21-22 – Chapters 5, 9, 10, 11, 12, 13, and 16
 - August 21 – Chapters 2, 3, and 14
 - No significant issues identified
 - Questions/comments
 - Addressed in meetings or written response
 - DCD resolution

ACRS Full Committee Presentation North Anna SER/OI

Staff Overview (continued)

- ❖ Today's Presentations
 - Open Item update
 - Site characteristics
 - relationship with ESP & DCD
 - Site-specific systems
 - interface DCD
 - Subcommittee transcript comments
- ❖ Presentation format
 - Dominion – application (FSAR) content
 - Staff – safety evaluation
- ❖ Milestone – 1st COLA SER/OI presentation to ACRS

ACRS Full Committee Presentation North Anna SER/OI

BACKUP SLIDES

ACRS Full Committee Presentation North Anna SER/OI

Staff Overview (Backup)

- ❖ Lesson Learned – ACRS subcommittee feedback (June 18th) regarding evaluation of “IBR” information
 - SER: “The staff reviewed ... FSAR and checked the referenced DCD to ensure that the combination of the DCD and the information in the COL application represent the complete scope of information relating to this review topic. The review confirmed that the information contained in the application and incorporated by reference addresses the relevant information related to”
Staff presentations to include examples

ACRS Full Committee Presentation North Anna SER/OI

Open Items

- ❖ Open Item 1-1 – ESBWR DCD not finalized (IBR)
- ❖ E-RAI Report – Open RAIs
 - Staff: All open RAIs on path toward resolution
 - RAIs in Sections 2.4, 2.5, 3.9, 3.11, & 9.2 – addressed in technical presentations
 - 5.3.2 PTLR – staff review recent submittal
 - 13.3 FEMA – multiple being addressed by offsite entities;
 - 13.6 Security – on-going review with RAIs
 - Chapter 16 – finalize plant-specific technical specifications
 - Turbine Missile Probability Analysis – review commencing – possible RAIs

Open RAIs

<u>RAI</u>	<u>Status</u>	<u>Subject</u>
01-4	Responded	source, byproduct and special nuclear material
02.04.02-4	Responded	Local intense precipitation flood calculation
02.04.02-5	Responded	Local intense precipitation flood calculation
02.04.02-6	Responded	Local intense precipitation flood calculation
02.04.02-7	Responded	Local intense precipitation flood calculation
02.04.12-2	Responded	groundwater modeling.
02.04.13-4	Responded	radionuclide transport analysis.
02.05.04-20	Issued/Open	backfill ITAAC
02.05.04-21	Issued/Open	properties of concrete fill.
03.02.01-7	Issued/Open	SSCs necessary for continued safe operation following OBE
03.09.06-1	Responded	design and qualification of safety-related valves and dynamic restraints
03.10-1	Issued/Open	seismic qualification of equipment.
03.11-1	Responded	environmental qualification operational program
03.11-2	Responded	implementation of environmental qualification approach in DCD
05.03.02-2	Issued/Open	Pressure-temperature limits (GEH Licensing Topical Report NEDC-33441P)
05.03.02-3	Issued/Open	Pressure-temperature limits
05.03.02-4	Issued/Open	Pressure-temperature limits
05.03.02-5	Issued/Open	Pressure-temperature limits.
05.03.02-6	Issued/Open	Pressure-temperature limits.
05.03.02-7	Issued/Open	Pressure-temperature limits
05.03.02-8	Issued/Open	Pressure-temperature limits
09.02.01-13	Responded	fiberglass reinforced polyester pipe in Plant Service Water System
11.04-3	Issued/Open	storage of low-level radioactive wastes.
12.03-12.04-8	Responded	minimization of radioactive contamination and waste (10 CFR 20.1406(a))
13.03-5	Issued/Open	ITAAC for Emergency Operations Facility.
13.03-6	Responded	ITAAC for emergency exercises.
13.03 FEMA	Issued/Open	offsite emergency planning issues
13.06 Security	Issued/Open	RAIs on several topics
16-1	Responded	plant-specific technical specifications.

ACRS Full Committee Presentation North Anna SER/OI

Section 2.4

Hydrologic Engineering

ACRS Full Committee Presentation North Anna SER/OI

Section 2.4 - General Remarks

- ❖ Section 2.4 includes many different water topics, from floods and tsunamis to ice and groundwater. Emphasis is on physical rather than biological issues.
- ❖ The ESP review was comprehensive.
- ❖ Six variances exist in section 2.4, but were of minor technical consequence.

ACRS Full Committee Presentation

North Anna SER/OI

Section 2.4 - General Remarks (Continued)

- ❖ ESP Permit Condition 3.E(2) – Single unit only. The permit condition for second unit cooling no longer applies.
- ❖ ESP Permit Condition 3.E(3) Features to Preclude Accidental Releases of Radionuclides into Potential Liquid Pathways
 - Below-grade tanks are in steel-lined compartments large enough to contain entire contents
 - Above-grade condensate storage tank is in a basin large enough to contain entire contents
 - *Staff concluded that these design features satisfy the permit condition*

ACRS Full Committee Presentation

North Anna SER/OI


Section 2.4.2 – Floods

There are two different flooding issues:

- ❖ Watershed-Scale Flooding
 - The design plant grade elevation is above probable maximum flood (including dam breaks and wave action)
 - No Open Items

- ❖ Locally Intense Precipitation Flooding
 - Two Open Items

Section 2.4.2 – Floods (continued)



Based on FSAR Figure 2.4-201

ACRS Full Committee Presentation North Anna SER/OI

Section 2.4.2 – Floods (continued)

- ❖ Locally Intense Precipitation Flooding
 - Water Levels near Unit 3
 - Modeling analysis demonstrates that water elevations are not high enough near Unit 3 nuclear island to be problematic.

ACRS Full Committee Presentation

North Anna SER/OI

Section 2.4.2 – Floods (continued)

- ❖ Locally Intense Precipitation Flooding (continued)
 - Open Item 2.4.2-2
 - Provide updated HEC-RAS input files for NRC review. Addresses DCD Rev. 5, which adds Ancillary Diesel Building.
 - Provide additional details on the South Ditch to ensure system will function as described.
 - Three RAIs under review (2.4.2-4, 2.4.2-5, 2.4.2-6)

ACRS Full Committee Presentation

North Anna SER/OI

Section 2.4.2 – Floods (continued)

- ❖ Locally Intense Precipitation Flooding (continued)
 - Open Item 2.4.2-3
 - Uncertainty that flood will overtop access road/safety dike that protects existing units (10 CFR 52.79(a)(31))
 - One RAI under review (2.4.2-7)

ACRS Full Committee Presentation

North Anna SER/OI

Section 2.4.12 – Groundwater

- ❖ Open Item 2.4.12-2
 - Concern: Groundwater level must be more than 2 ft below plant grade of 290 ft
 - Staff Issues:
 - Model sensitivity studies of effect of drain cell properties on groundwater elevations
 - Effectiveness of surface water drainage features as groundwater drains
 - One RAI under review (2.4.12-2)

ACRS Full Committee Presentation

North Anna SER/OI

Section 2.4.13 Accidental Releases of Radioactive Liquid Effluents

- ❖ Open Item 2.4.13-4
 - Concern: Staff wants to confirm that the Applicant's groundwater transport analysis is a bounding analysis.
 - Staff issues:
 - Certain literature K_d values used in transport analysis were greater than minimum measured onsite K_d
 - Hydraulic conductivity used in transport analysis was less than the maximum measured onsite
 - One RAI (2.4.13-4)

ACRS Full Committee Presentation North Anna SER/OI

QUESTIONS ?

Section 2.4 Hydrologic Engineering

ACRS Full Committee Presentation North Anna SER/OI

Section 2.5

Geology, Seismology, and Geotechnical Engineering

ACRS Full Committee Presentation

North Anna SER/OI

- ❖ 2.5.1 Basic Geologic & Seismic Information
- ❖ 2.5.3 Surface Faulting
- ❖ 2.5.5 Stability of Slopes
 - Provided additional site geologic and seismic information
 - Performed new slope stability analyses using updated site data
 - No outstanding issues

ACRS Full Committee Presentation

North Anna SER/OI

- ❖ 2.5.2 Vibratory Ground Motion
 - Addressed COL items and ESP permit conditions
 - Revised Ground Motion Response Spectra (GMRS) based on updated site subsurface profile
 - No outstanding issues

ACRS Full Committee Presentation

North Anna SER/OI

- ❖ 2.5.4 Stability of Subsurface Materials and Foundations
 - Addressed the COL items by providing additional boring data, site soil profiles, subsurface material properties, and stability analyses
 - Resolved RAIs/OIs related to:
 - static and dynamic properties of backfill soil
 - foundation stability analysis
 - coefficient of friction at foundation interface
 - dynamic settlement calculation of soil slope

ACRS Full Committee Presentation

North Anna SER/OI

- ❖ **2.5.4 Stability of Subsurface Materials and Foundations – Remaining Open Items**
 - Clearly describe acceptance criteria in backfill soil ITAAC and define field density test frequency (02.05.04-20)
 - Clearly define concrete fill properties in COL FSAR (02.05.04-21)


ACRS Full Committee Presentation North Anna SER/OI

QUESTIONS ?

Section 2.5 Geology, Seismology, and Geotechnical Engineering

Back up slides


ACRS Full Committee Presentation North Anna SER/OI



Comparison of Horizontal Ground Motion Response Spectra (GMRS)

ACRS Full Committee Presentation

North Anna SER/OI




Unit 3 Boring Locations – Power Block

ACRS Full Committee Presentation North Anna SER/OI

Site Investigations	ESP	COL
Borings	7	55
Corn Penetration Test	8	23
Test Pits	0	6
Observation Wells	9	7
Velocity Test	5	6

ACRS Full Committee Presentation


North Anna SER/OI



Typical Subsurface Profile Across Unit 3 Power Block Area

ACRS Full Committee Presentation North Anna SER/OI

Staff Stability of Slopes Confirmatory Analysis Results



Note: The return period for 0.3g at 2.5 Hz is about 70,000 years, which corresponds to an annual frequency of exceedance of 1.4×10^{-5} per year.

ACRS Full Committee Presentation North Anna SER/OI

Section 3.9.6

Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints

Section 3.11

Environmental Qualification of Mechanical and Electrical Equipment

ACRS Full Committee Presentation North Anna SER/OI

Section 3.9.6

- ❖ COL application relies on ESBWR DCD and FSAR to fully describe functional design, qualification, and IST programs for pumps, valves, and dynamic restraints
- ❖ In response to RAIs, Dominion and GEH revised FSAR and DCD
- ❖ NRC performed audit of GEH design and procurement specifications in July 2009 to evaluate implementation of DCD provisions

ACRS Full Committee Presentation

North Anna SER/OI

Section 3.9.6

- ❖ DCD specifies ASME Standard QME-1-2007 for functional design and qualification of new valves with key QME-1 aspects required for previously qualified valves
- ❖ DCD describes valve IST program based on 2001 Edition/2003 Addenda of ASME OM Code
- ❖ FSAR supplements DCD for IST provisions and periodic verification of design-basis capability of power-operated valves
- ❖ FSAR describes snubber IST program consistent with ASME OM Code, Section ISTD

ACRS Full Committee Presentation North Anna SER/OI

Section 3.9.6

- ❖ **Open Item 3.9.6-01 (Implementation of DCD qualification and IST provisions)**
 - NRC audit results summarized in memorandum dated September 1, 2009
 - GEH provided response to audit follow-up items in letter dated September 21, 2009
 - GEH response resolves most audit follow-up items with minor issues remaining to close open item

ACRS Full Committee Presentation

North Anna SER/OI

Section 3.11

- ❖ FSAR incorporates by reference DCD description of EQ program for mechanical and electrical equipment
- ❖ DCD description of EQ process acceptable based on NUREG-1503 (ABWR SER)
- ❖ ITAAC will confirm electrical and mechanical EQ
- ❖ NRC performed audit of GEH design and procurement specifications in July 2009 to evaluate implementation of DCD EQ provisions

ACRS Full Committee Presentation North Anna SER/OI

Section 3.11

- ❖ **Open Item 3.11-01 (Implement DCD EQ provisions)**
 - NRC audit summarized in September 1, 2009, memorandum
 - GEH response provided in September 21, 2009, letter that resolves most audit follow-up items
- ❖ **Open Item 3.11-02 (Safety-related mechanical equipment EQ)**
 - NRC staff review of GEH audit response to be used to close open item

ACRS Full Committee Presentation North Anna SER/OI

QUESTIONS ?

Section 3.9.6

**Functional Design, Qualification, and Inservice
Testing Programs for Pumps, Valves, and
Dynamic Restraints**

Section 3.11

**Environmental Qualification of
Mechanical and Electrical Equipment**

ACRS Full Committee Presentation North Anna SER/OI

Section 9.2.1

Plant Service Water System

ACRS Full Committee Presentation North Anna SER/OI

Section 9.2.1

Plant Service Water System (PSWS)

- Open Items – Subcommittee interest (July meeting)
- Open Items Resolved (Confirmatory Items)
 - OI #8 - Revised Interface Requirement (ITAAC)
 - PSWS ability to remove necessary heat load
 - OI #9 - Above ground PSWS piping materials
 - OI #10 - PSWS treatment under Maintenance Rule
 - OI #11 - Clearly identify CDI and COL items in FSAR
 - OI #12 - Design capability of the Auxiliary Heat Sink
 - Initial plant test program
 - Water hammer design features

ACRS Full Committee Presentation North Anna SER/OI

Section 9.2.1

Plant Service Water System (PSWS)

- Open Item #13 – Buried Fiberglass Piping (FRP)
- Proposed Resolution
 - NRC-approved ASME Code, Section III Code Case N-155-2, provides rules for fabrication and installation of FRP
 - Procedures in Code Case provide for FRP to be properly designed and installed and thus provide for structural integrity and safety commensurate with RTNSS status of the system
 - Applicant agreed to use Code Case to design/install FRP
 - Path to resolve OI #13:
 - Staff will audit applicant's use of Code Case
 - Applicant will document use of Code Case in FSAR

ACRS Full Committee Presentation North Anna SER/OI

QUESTIONS ?

Section 9.2.1 Plant Service Water System

ACRS Full Committee Presentation North Anna SER/OI

Section 14.3

Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC)

ACRS Full Committee Presentation North Anna SER/OI

Section 14.3 – ITAAC

North Anna ITAAC

- ❖ ESBWR Certified Design ITAAC
 - ESBWR DCD Tier 1
 - North Anna incorporates by reference
- ❖ Emergency Planning
(SER 13.3 – 2 open RAIs)
- ❖ Physical Security
(SER 13.6 – on-going review)
- ❖ Site-specific Structures, Systems, Components

ACRS Full Committee Presentation

North Anna SER/OI

Section 14.3 – ITAAC

Site-specific Structures, Systems, Components

- ❖ Selection Criteria and Methodology
 - North Anna – same as DCD
 - Applied to systems not evaluated in DCD
- ❖ Backfill under Category I Structures
(SER 2.5.4 – open RAI)
- ❖ Plant Service Water System
(SER 9.2.1 – confirmatory RAI)
- ❖ Offsite Power
(SER 8.2 – confirmatory RAI)
- ❖ Other Systems - No ITAAC

ACRS Full Committee Presentation North Anna SER/OI

Section 14.3 – ITAAC

Post COL Activities

- ❖ ITAAC – license condition to be satisfied before fuel load
- ❖ ITAAC closure process – Regulatory Guide 1.215

ACRS Full Committee Presentation North Anna SER/OI

QUESTIONS ?

Section 14.3 Inspections, Tests, Analyses, and Acceptance Criteria (ITAAC)

ACRS Full Committee Presentation North Anna SER/OI

COL Application Review Schedule

Safety Review

- ❖ Phase 1 - Requests for Additional Information – Complete
- ❖ Phase 2 - SER with Open Items – Complete
- ❖ Phase 3 - ACRS Review of SER with Open Items – 11/04/09
- ❖ Phase 4 - Advanced SER with no Open Items – 09/10
- ❖ Phase 5 - ACRS Review of SER with no Open Items – 12/10
- ❖ Phase 6 – Issue Final SER – 02/11

ACRS Full Committee Presentation North Anna SER/OI

QUESTIONS / COMMENTS

Susquehanna Steam Electric Station

License Renewal ACRS Meeting

October 8, 2009





Introductions

- ▶ Rick Pagodin, General Manager – Engineering
- ▶ John Kraiss, Manager – Special Projects
- ▶ Dale Roth, Supervisor Programs and Testing
- ▶ Dave Flyte, License Renewal Lead Engineer
- ▶ Subject Matter Experts and LR Project Team



Agenda

- ▶ Site Description
- ▶ Operating Experience Review
- ▶ Commitment Process
- ▶ Subcommittee Follow-Up Items
 - Underground Medium Voltage Cables
 - Station Blackout Recovery Scoping
 - Condition of Containment
 - Main Steam Line Flow Restrictors
- ▶ Summary



Site Description

- ▶ Location: Northeast Pennsylvania
- ▶ Plant Owners
 - PPL Susquehanna, LLC (90%)
 - Allegheny Electric Cooperative (10%)
- ▶ Licensee/Operator: PPL Susquehanna, LLC



Site Description

- ▶ Two Units - BWR/4
 - 3952 MWt
 - 1300 MWe
- ▶ General Electric (NSSS), Bechtel (AE)
- ▶ Ultimate Heat Sink - Spray Pond
- ▶ Turbine Cycle Cooling Provided By Natural Draft Towers
- ▶ Make-up Water - Susquehanna River



Site Description

- ▶ Construction Permit November 1973
- ▶ Operating License (Unit 1/Unit 2) July 1982/March 1984
- ▶ Stretch Power Uprate ~4.5%
(Unit 1/Unit 2) February 1995/April 1994
- ▶ MUR Power Uprate ~1.5% July 2001
- ▶ LRA Submitted September 2006
- ▶ Extended Power Uprate ~14% January 2008
- ▶ License Expires (Unit 1/Unit 2) July 2022/March 2024



Operating Experience Review

- ▶ Operating Experience Review Per the Guidance in NEI 95-10
- ▶ EPRI Tools Used as Starting Point to Identify Aging Effects
- ▶ Five Years of SSES and Industry Operating Experience Reviewed to Ensure Identification of Aging Effects



Commitment Process

- ▶ 60 Regulatory Commitments for License Renewal
- ▶ Entered into the SSES Commitment Tracking Process
- ▶ Commitments Assigned to Station Personnel for Implementation



Subcommittee Follow-Up Items


Underground Medium Voltage Cables

- ▶ 5 kV Safety-Related Cables – No Submerged Cables Observed
- ▶ 15 kV Non Safety-Related Cables – Submerged Cables Observed in 2 Manholes
 - License Renewal Commitment Consistent with GALL
 - Test Underground MV Cables
 - Inspect/Pump Manholes to Keep MV Cables from Exposure to Standing Water
 - Testing/Pumping Preventive Maintenance Activities In Place Today



Subcommittee Follow-Up Items

Station Blackout Recovery Scoping




License Renewal Scope —



Subcommittee Follow-Up Items

Condition of Containment



MARK 2 CONTAINMENT



Subcommittee Follow-Up Items

Condition of Containment

- ▶ Nominal 6 Foot Reinforced Concrete – Pressure Retaining Structure
- ▶ 1/4 Inch Steel Liner – Leaktight Membrane
- ▶ Visual Inspections Under ISI Program per ASME Section XI
- ▶ Pressure Tested in Accordance with 10 CFR 50 Appendix J

The logo for PPL Susquehanna, LLC is located in the top left corner. It features a stylized atomic symbol with a central yellow star and three red and white orbital paths. The text "PPL Susquehanna, LLC" is written in a circular arc above the symbol, and "One Team One Commitment" is written in a circular arc below it.

Subcommittee Follow-Up Items Condition of Containment

- ▶ Inspections Have Not Identified Any Significant Degradation Over the Past 25 Years
- ▶ Pressure Testing has Not Identified Any Indication of Degradation
- ▶ Programs are Effectively Managing Aging of Containment – No Degradation of Design Function



Subcommittee Follow-Up Items

Main Steam Line Flow Restrictors

- ▶ Potential Loss of Material Due to Corrosion and Erosion Evaluated
- ▶ Loss of Material Due to Corrosion Managed by BWR Water Chemistry Program
 - Dry Steam Environment Not Conducive to Corrosion
 - One-Time Inspection of Bounding Components to Verify Effectiveness of BWR Water Chemistry Program
- ▶ Erosion Evaluated as TLAA
 - Dispositioned Per 10 CFR 54.21(c)(1)(ii) – Projected for 60 Years
 - Dry Steam Environment and Resistant Material



Summary

- ▶ LRA Conforms to Regulatory Requirements and Follows Industry Guidance
- ▶ Thorough Review of the Application and Supporting Documentation
- ▶ No Open Items
- ▶ SSES Will Manage Aging in the Period of Extended Operation





Advisory Committee on Reactor Safeguards

Susquehanna Steam Electric Station Units

No. 1 and 2

Safety Evaluation Report

October 8, 2009

Evelyn Gettys, Project Manager
Office of Nuclear Reactor Regulation



Introduction

- Overview of SSES license renewal review
- Section 2: Scoping and Screening Review
- License Renewal Regional Inspection
- Section 3: Aging Management Program and Review Results
- Section 4: Time-Limited Aging Analyses (TLAAs)
- Conclusion



Overview

- LRA Submitted by letter dated Sept 13, 2006
- GE Boiling Water Reactor (BWR), Mark II containment
- Jan. 30, 2008 - Extended Power Uprate (EPU) was granted to SSES to operate at
3952 MWth, 1300 MWe for Units 1 & 2
- Operating license for Unit 1- NPR-14 expires July 17, 2022
- Operating license for Unit 2- NPR-22 expires March 23, 2024
- Located approximately 7 miles NE of Berwick, PA



Overview

Recap of the April 1, 2009 ACRS subcommittee meeting

- SER issued March 2009
- 278 RAI's
- 59 Commitments
- No Open or Confirmatory Items



Overview

Subsequent to subcommittee meeting

- 8 RAIs issued:
 - 5 Boral
 - 3 Metal Fatigue
- 1 Commitment



Section 2 – Conclusion for Scoping and Screening

- The applicant's scoping and screening methodology is consistent with the requirements of 10 CFR 54.4 and 10 CFR 54.21(a)(1)
- The applicant adequately identified those SSCs within the scope of license renewal in accordance with 10 CFR 54.4(a) and those SCs subject to an AMR in accordance with 10 CFR 54.21(a)(1)



Regional Inspection Conclusions

- Scoping of non-safety SSCs and aging management programs are acceptable
- Inspection results support a conclusion of reasonable assurance that aging effects will be managed and intended functions will be maintained



Section 3.0 Aging Management Review Results

- Section 3.0 – Aging Management Programs
- Section 3.1 – Reactor Vessel & Internals
- Section 3.2 – Engineered Safety Features
- Section 3.3 – Auxiliary Systems
- Section 3.4 – Steam and Power Conversion System
- Section 3.5 – Containments, Structures and Component Supports
- Section 3.6 – Electrical and Instrumentation and Controls System



Section 3.3.2.2.6 Reduction of Neutron-Absorbing Capacity and Loss of Material due to General Corrosion

- Commitment to continue spent fuel pool Boral coupon testing into the period of extended operation
- Water Chemistry Program & Boral Coupon Testing Program



Section 3 Conclusion

- Based on its review of the LRA and additional information submitted as the result of RAIs, the staff concluded that the effects of aging will be managed so that intended function(s) will be maintained during the period of extended operations, per 10 CFR 54.21(a)(3).



Section 4: Time-Limited Aging Analyses

- 4.1 Identification of Time Limited Aging Analyses (TLAAs)
- 4.2 Reactor Vessel Neutron Embrittlement
- 4.3 Metal Fatigue
- 4.4 Environmental Qualification of Electrical Equipment
- 4.5 Concrete Containment Tendon Prestress (N/A)
- 4.6 Containment Liner Plate and Penetration Fatigue
- 4.7 Other Plant-Specific TLAAs



- **Section 4.3.1 – Reactor Pressure Vessel Fatigue Analyses**

- Requested transient event design specifications and recording of transient data.
- Applicant responded and indicated that all monitored transient events are bounded by the design specifications and that cycle tracking activities covered the entire operating history of the plant.



Section 4.3.1 – Reactor Pressure Vessel Fatigue Analyses

- Requested justification for the large reductions in projected 60-year CUF values seen for some locations, with relatively minor reduction in cycle projections, even though some transients have projected cycles higher than design cycles
- Applicant provided justification: 40-year design CUF values have incorporated extra conservatism, including contribution from faulted condition loads, directly using results of bounding location, and conservative design cycles.



Section 4.3.3 Effects of Reactor Coolant Environment on Fatigue Life of Components and Piping

- Requested pre –1994 data to supplement the data previously provided and also justification that the DO data is applicable to all NUREG/CR-6260 components
- Applicant provided the DO data, described the water sampling schedule schemes, the water flowing routes, and demonstrated applicability of the sampled data to all of the NUREG/CR-6260 locations considered



Section 4 Conclusion


Based on its review of the LRA and additional information submitted as the result of RAIs, the staff concluded that the applicant provided an adequate list of TLAAs, per 10 CFR 54.3, and that the:

- TLAAs will remain valid for the period of extended operation, per 10 CFR 54.21(c)(1)(i)
- TLAAs have been projected to the end of the period of extended operation, per 10 CFR 54.21(c)(1)(ii); or
- Aging effects will be managed for the period of extended operation, per 10 CFR 54.21(c)(1)(iii)



Conclusion

- The staff has concluded there is reasonable assurance that the activities authorized by the renewed license will continue to be conducted in accordance with the CLB, and that any changes made to the SSES CLB in order to comply with 10 CFR 54.29(a) are in accordance with the Act and the Commission's regulations




STEAM GENERATOR ACTION PLAN OPENING REMARKS

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

OCTOBER 8, 2009

TIMOTHY J. MCGINTY
Director, Division of Policy and Rulemaking
NRC Office of Nuclear Reactor Regulation



STEAM GENERATOR ACTION PLAN BACKGROUND AND OVERVIEW

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS


OCTOBER 8, 2009

DAVID BEAULIEU

**Project Manager, Division of Policy and Rulemaking
NRC Office of Nuclear Reactor Regulation**

Steam Generator Action Plan History


- 1985-1990 NUREG 1150 severe accident risk studies evaluated the issue of “consequential” steam generator (SG) tube rupture.
- For severe accident induced consequential SG tube ruptures, concern was that the high temperature gases created during core damage sequences could cause SG tubes to be the first component of the reactor coolant pressure boundary to fail, resulting in a potential containment bypass and the release of large amounts of radioactive material outside containment.
- NUREG-1150 quantified frequency in the low 10^{-6} /reactor-year range on the basis of expert elicitation.



SG Action Plan History (cont'd)

Differing Professional Opinion

- In the early 1990s, the industry made several requests for relaxation of regulatory requirements for SG tube integrity.
- A Differing Professional Opinion (DPO) was filed involving concerns associated with this relaxation given that while eddy-current methods could accurately measure uniform tube wall thinning due to general corrosion, they were less reliable in detecting and sizing cracks that occur in Alloy 600 tubes due to stress corrosion cracking.
- Staff review of those relaxation requests identified that granting them might substantially increase the conditional probability of containment bypass during core damage accidents.




SG Action Plan History (cont'd)

- In the early 1990s, the NRC staff began a study of the effects of severe accident conditions on SG tube integrity as background information for a proposed new rulemaking on SG tube integrity.
- The results from this study, published as NUREG-1570, indicated that the risk is controlled by the current tube integrity requirements to a value that is low enough that no new rulemaking was needed.
- The DPO remained open.

SG Action Plan History (cont'd)


DPO Was Referred to ACRS for Resolution

- In 2000, the DPO was referred to the ACRS for resolution.
- After extensive public meetings and review of the issues raised in the DPO, the ACRS published NUREG-1740 to present its conclusions and recommendations.
- In particular, the ACRS concluded that the methodology being used to quantify the risk of containment bypass due to high-temperature challenges to SG tubes was “not technically defensible.”




SG Action Plan (Section 3) Created to Address ACRS Recommendations

- Technical staff in NRR and RES jointly reviewed the full text of NUREG-1740 to extract the list of issues that required additional work.
- Those tasks were incorporated into a new section (Section 3) of the SG Action Plan .




SG Action Plan Tasks

- Most, but not all, SG Action Plan tasks involve severe accident induced SG tube ruptures.
- SG Action Plan also includes tasks work that involved design basis events, which addressed the potential for damage progression of multiple SG tubes due to SG depressurization. (e.g., during a main steam line break (MSLB) or other type of secondary side design basis accident).




Design Basis Event Tasks Closed – ACRS Review Complete

- The staff's work to address SG action plan items involving design basis events is complete, and;
- ACRS has previously reviewed and endorsed the closure of these items.
- Basis - Dynamic loads from such design basis events are low and do not affect the structural integrity of tubes or lead to additional leakage or ruptures beyond what would be determined using differential pressure loads alone.




SG Action Plan Status

- The staff has completed its work to close all SGAP items.
- Closeout documentation has been provided to ACRS.
- The purpose of this meeting is for ACRS to review all SGAP items that ACRS has not previously reviewed and closed.




Desired Outcome of ACRS Review

- The staff requests an ACRS letter that finds acceptable the staff's closeout of each SGAP item that ACRS has not previously reviewed and closed which are:
 - SG Action Plan Items 3.1.k, 3.4, 3.5, 3.10, 3.11, and 3.12



Agenda


- Essentially all of today's items are directly related to the work to define the risk associated with severe accident induced SG tube ruptures leading to containment bypass.
- This work involved the following technical areas of research:
 - thermal-hydraulics,
 - steam generator tube material failures;
 - reactor coolant system material failures;
 - component behavior studies, and
 - probabilistic risk assessment



SG Action Plan Closeout

Future Activities Outside of Action Plan Process

- SG Action Plan work is complete and, following ACRS review, the staff would like to close the SG Action Plan.
- NRR User Need to RES is in concurrence -- Requests specific research products to facilitate the development and review of future risk assessments involving consequential SG tube rupture events. These products will build upon analysis methods, tools, and expertise developed as part of the SG Action Plan.
- The RES work to address the NRR User Need no longer requires the level of coordination and agency focus required to implement the action plan process.
- Future work activities associated with this topic will be coordinated using other agency tools such as the User Need and the Planning, Budgeting, and Performance Management processes.



Steam Generator Action Plan Item 3.11

- SGAP Item 3.11 states, "In order to resolve GSI 163, it is necessary to complete the work associated with tasks 3.1, 3.7, 3.8, and 3.9. Upon completion of this task, develop detailed milestones associated with preparing a GSI resolution document and obtaining the necessary approvals for closing the GSI, including ACRS acceptance of the resolution."
- ACRS letter dated May 20, 2009, endorsed the closure of GSI-163.
- The staff requests that ACRS document that ACRS considers the staff's closeout of SGAP Item 3.11 acceptable.

ACRS

Steam Generator Action Plan (SGAP)

October 8, 2009

Rockville, MD

SGAP Items 3.4.a-g
Thermal-Hydraulics
System Code Predictions and CFD

Christopher Boyd RES/DSA


Background

- SGAP section 3.4.a-g
 - thermal-hydraulic behavior of the system during severe accidents
- NUREG/CR-6995 (draft) summarizes the overall project and focuses on the system level predictions. This work improves our understanding of the T/H behavior of the plant during these types of scenarios and addresses criticisms of past analyses.
 - Covers 3.4.a, b, d, f
- Supporting CFD analyses improves our technical basis and helps to extend experimental results to full-scale conditions
 - Covers 3.4.c, e, g
 - NUREG-1781 and NUREG-1788
 - NUREG-1922 (draft)


A Fast Scenario


RCS failure within 4 hours

- loss of offsite power, failure of diesel generators, and failure of all auxiliary feedwater
- Reactor coolant pump seal LOCA and secondary side boil off
- secondary system dry out, safety relief valves cycling, primary inventory lost through valves and pump seal LOCA
- loop circulation stops
- Inventory falls below hot legs, natural circulation of superheated steam begins, system heats up
- Core uncovers, core oxidizes and releases significant energy, system heat up accelerates and induced failure is predicted for RCS components.
- High-Dry-Low conditions needed to challenge the SG tubes.
- Clearing the loop seals creates direct circulation flow path and presents a severe challenge to the SG tubes.



RCS Temperatures






Temperature contours from 3D CFD prediction


System Model is adjusted to be consistent with 3D Computational Fluid Dynamics and Experiments

CFD modeling used to extend experimental results to full-scale SGs




CFD Predicts Peak Temperatures

- Consistent results over 3 different models and with multiple turbulence options.
- High confidence in grid independence.



Summary

- SGAP items 3.4.a, b, d, f are addressed by NUREG/CR-6995.
- SGAP items 3.4.c, e, and g are addressed by NUREG-1781 and NUREG-1788.
 - Specific ACRS concerns are further supported by the updated modeling in NUREG-1922
- Future work will be completed in support of the agencies ongoing research into steam generator tube integrity issues as needed.



STEAM GENERATOR ACTION PLAN


ITEM 3.4h POTENTIAL RCS FAILURE LOCATIONS

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

OCTOBER 8, 2009

T. R. LUPOLD

Branch Chief, Corrosion & Metallurgy Branch
NRC Office of Nuclear Regulatory Research
Timothy.Lupold@nrc.gov




3.4h: Systematic Examination of the Alternate Vulnerable Locations in the RCS.

- h.1 Evaluate Creep failure of primary system passive components.
 - * i.e pressurizer surge line, hot leg
 - * Consider material properties, residual & applied stresses pressure stress, and presence of flaws

- h.2 Evaluate active component failure.
 - * i.e. PORVs, safety valves, and bolted seals
 - * Based on operability and “weakest link” considerations

- h.3 Determine Feasibility of extending the Rhodes model (RCP seals leakage/failure) to severe accident conditions.

- h.4 Conduct large scale tests if needed.



Three phase study:

- Phase I:
 - Reviewed methods & models (failure modes and times-to-failure)
 - Identified additional information needed,
 - Scoped RCS components that might be “weak links”
- Phase II:
 - Developed 3-D computer models of select RCS components (Westinghouse 4-Loop)
 - Utilized detailed plant drawings
 - Included analyses of component operating history
- Phase III:
 - Calculated RCS component failure sequence
 - Utilized improved codes and modeling
 - (RELAP5) Reactor Leak and Power Safety Excursion code
 - (CFD) Computational Fluid Dynamics
 - Expanded high-temperature materials database


Phase I

- November 2001 Workshop held to discuss expected behavior of non-SGT RCS components and bolted connections during severe accidents in PWRs
 - Workshop concluded it would be possible to analytically predict behavior during severe accidents of certain components
- Following Workshop, non-SGT RCS components and bolted connections were modeled to predict failure times
 - In view of closeness of predicted rupture times for SGTs, surge lines and hot-leg piping reported in NUREG-1570, NRC initiated effort to develop improved models for predicting failure of non-SGT RCS components
- Selected Components for Phase II analysis

Phase II

- Analysis based on Zion Nuclear Station
 - Hot leg and nozzles of Loop 4, which include pressurizer and surge line, were analyzed for reference station blackout (SBO) severe accident transient that involved "high-dry" sequence
 - Results from RELAP5 thermal hydraulic analysis of surface heat flux were used as input for thermal-conduction and stress-strain analyses
 - Failure times due to tensile and creep rupture were calculated with data from literature when available,
 - developed or extrapolated data were only available at lower-than-severe accident temperatures
 - Sensitivity analyses were conducted to determine variability of predicted failure times
 - due to variations of surface heat flux, thermal conductivity, creep rate, and yield strength
 - Also analyzed was stress-strain response due to repeat plug-to-seat impact of typical PORV

Phase II Results



Phase III

- Improvements were made to the thermal hydraulic modeling
 - Refinements were made to surge-line-to-hot-leg connection in RELAP5 model
 - Thermal hydraulic data calculated using RELAP5 were improved to account for entrance effects and flow reversals during PORV cycling
 - High-temperature materials database was expanded by conducting high-temperature tensile and creep tests on stainless steel and carbon steel weldments.
- Enhancements changed calculated failure sequence
 - Resulted in hot leg failing first
 - Suggested that RCP seals could possibly fail prior to SGTs
- Expert Workshop was held to evaluate new findings
 - It was agreed that seal failure could occur sooner than previously estimated and could possibly avert or mitigate containment bypass
 - Based on judgment and experience with RCP seals

Conclusions

- Research accomplished overall goal of developing improved models for evaluating non-SGT PWR RCS components under severe accident conditions
- Determined that differences in times-to-failure between non-SGT (except RCP seals) RCS components were relatively close to each other for transients evaluated
 - Failure times were only nominally affected by variations in heat transfer entrance effects and other sensitivity variations
 - Analysis results for some components (e.g., RTD welds, primary manway, instrument line welds) are sufficiently generic to be applicable to other Westinghouse plants
 - Analyses related to hot leg and surge line may also be applicable to other plants provided relevant dimensions and constraints are comparable
- Determined that RCP seals could fail prior to SGTs, which could avert or mitigate containment bypass
 - Quantifying RCP seals time-to-failure with adequate confidence would require additional experimental and analytical studies
- NRR and RES looking at follow-on research


Steam Generator Action Plan Item 3.10

- 3.10 - To address concerns in the ACRS report regarding our current level of understanding of stress corrosion cracking, the limitations of current laboratory data, the difficulties with using the current laboratory data for predicting field experience (crack initiation, crack growth rates), and the notion that crack growth should not be linear with time while voltage growth is, the following tasks will be performed:

Conduct tests to evaluate crack initiation, evolution, and growth. Tests to be conducted under prototypic field conditions with respect to stresses, temperatures and environments. Some tests will be conducted using tubular specimens.


Using the extensive experience on stress corrosion cracking in operating SGs, and results from laboratory testing under prototypic conditions, develop models for predicting the cracking behavior of SG tubing in the operating environment.

Based on the knowledge accumulated on stress corrosion cracking behavior and the properties of eddy current testing, attempt to explain the observed relationship between changes in eddy current signal voltage response and crack growth.



Staff Closure of SGAP 3.10


- Not based on a specific ACRS recommended action in NUREG-1740
- Operating experience indicates that plant practices for predicting flaw initiation and growth have been effective in ensuring tube integrity consistent with our assumptions in risk analyses
- NRC staff monitors plant operating experience through the inspection process and our review of licensee reports on the results of their steam generator tube inspections. If analysis of future operating experience or research indicates the need to revisit this area, it will be considered and prioritized consistent with our budget process.



**SGAP TASK 3.1K
SGAP TASKS 3.4J AND 3.4K
SGAP TASK 3.12**


**ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
OCTOBER 8, 2009**

ROBERT PALLA, NRR/DRA




Task 3.1k – Based on Tasks 3.1a – 3.1j, evaluate the probability of multiple tube failures in risk assessments for SG tube ARC

- Objective of Task 3.1k – develop probability distribution for total SG leakage under ΔP loads alone
- The need for this calculation was diminished for several reasons
 - Postulated phenomena associated with depressurization (addressed in Tasks 3.1a – 3.1j) did not prove to be realistic
 - Performance-based TS provides reasonable assurance that DBA leakage will be small and well within that assumed in risk studies
 - Replacement SGs result in fewer flawed tubes left in service and fewer proposals to increase allowable leakage
- The calculations planned under Task 3.1k are not needed to support closeout of GSI-163
- This task can be closed




Task 3.4j – Develop probability distribution for rate of tube leakage for ARC applied to flaws in restricted places

- Task 3.4i provided predicted flaw areas and leak rates from cracks under the TSP during MSLB and severe accidents
- As part of Task 3.5 SNL/SAIC developed a methodology to compute the probability of tube failure during an accident which uses the models developed in Task 3.4i
- The SNL/SAIC methodology can be used to assess the impact of alternate assumptions or models for flaws in restricted places
- This effort has achieved the intent of SGAP Task 3.4j
- This task can be closed



Task 3.4k – Integrate information provided by Tasks 3.4a – 3.4j & 3.5 to address ACRS criticisms on risk assessments for ARC

- Specific concern: ARC that credit “indications restricted against burst”
- Concern was specific to South Texas Project unit with stainless steel drilled-hole support plates (the only SGs of this type in US)
- To limit displacement, tubes were expanded at various elevations
- Staff estimated conservative leak rate of 5 gpm per burst tube within TSP region
- Result could be included in a risk calculation but was not pursued because South Texas Project SGs have been replaced




Task 3.4k (Continued)

- Broader concern: Other SG tube integrity and licensing issues related to flaws in the free-span of SG tubes, and the ability to perform severe accident calculations in a technically defensible manner
- SGAP Task 3.5, “Develop improved methods for assessing the risk associated with SG tubes under accident conditions” was specifically intended to address this concern
- Although additional research related to C-SGTR is planned, the work completed has achieved the intent of SGAP Task 3.4k
- This task can be closed


Task 3.12 – Review Insights from Task 3.5 and Assess Need for Completing Additional Regulatory Guidance

- Staff has assessed the need for guidance on SGTR, and concludes additional guidance and tools are still needed
- Decision rationale
 - Task 3.5 and other studies have not generically dispositioned the issue. Plant-specific PRAs should continue to address C-SGTR
 - Limitations of current work restrict its usefulness in supporting future risk assessments (flaw distributions, TH, documentation & tools)
 - Alternative methods have been developed by industry and are being used by licensees but have not been reviewed by NRC
 - Effectiveness of the peer review process in assuring technical adequacy of this PRA element is not clear
- Development of this guidance will be part of an RES User Need now in concurrence



User Need on C-SGTR

- Additional TH analysis
 - CFD and system code TH analyses for CE plants
 - Impact of incore instrument tube failure on C-SGTR
- Updated flaw distributions and RCS structural analyses
 - Distributions for remaining alloy 600 SGs and replacement 690 SGs
 - Finite element analyses of RCS components
- Guidance and tools for future risk assessments
 - Simplified tools and supporting documentation
 - Reassessment of P_{C-SGTR} based on updated TH and flaw distributions
 - RG on RI-decisionmaking related to C-SGTR
- A document compiling/summarizing key research




A RISK ASSESSMENT OF CONSEQUENTIAL STEAM GENERATOR TUBE RUPTURES

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

OCTOBER 8, 2009


Dr. Selim Sancaktar
Probabilistic Risk Assessment Branch
NRC Office of Nuclear Regulatory Research



Task 3.5 – Main Objectives

- Develop improved methods for assessing the risk of consequential SG tube rupture (C-SGTR) (3.5.d)
 - Extend method to CE plants (3.5.e)
 - Extend method to external events and low power/shutdown (3.5.f)
 - Extend method to include consideration of Main Steam Line Breaks (MSLBs) (3.5.g)

- Demonstrate the method with illustrative calculations of the frequency of containment bypass at example plants




General Approach

- Method should be straightforward and scrutable
 - Previous approaches to model C-SGTR have relied on intrusive changes to the PRA

- Reflect current understanding of factors leading to C-SGTR
 - The conditions and sequences that can lead to C-SGTR are well studied and understood
 - Consider plant specific features (SG tube flaw distributions, mitigative credit)

- Utilize Agency Standardized Plant Analysis risk (SPAR) Models
 - Represents as-built, as-operated plant and verified through benchmarking and review activities

- Information and data available at the time of performance of tasks is used – considered prudently conservative



Analysis Method

- A straightforward systematic method based on the sequence results from a PRA is used:
 - 1) Identify sequences that challenge SG tubes
 - 2) Apply mitigation credit (i.e. probability that the operators mitigate the conditions leading to C-SGTR)
 - 3) Apply conditional C-SGTR probability (i.e. probability that SG tubes do not fail given the conditions)
 - 4) Calculate containment bypass frequency.
- Scope of the method does not include LERF analysis; the measure of C-SGTR importance calculated is containment bypass frequency.
- Intended to provide a method for NRR to assess C-SGTR risk: can be incorporated into a formal guidance document


Analysis Method – Identify Sequences

- Identify sequences that can lead to a C-SGTR by performing the following steps:
 - 1) Sort core damage sequences by their contribution to CDF
 - Identify risk-significant sequences that lead to High-Dry-Low conditions
 - Typical scenarios involve failure of AFW system and RCS feed and bleed
 - 2) Identify sequences that represent a pressure challenge to SG tubes (including otherwise successful sequences)
 - ATWS
 - MSLB
 - LOCA

May require some simple modeling changes to PRA model
- Method should consider external events and shutdown initiators as appropriate


Analysis Method – Apply Mitigation Credit

- Given that a core damage event has occurred, what is the probability that recovery actions to mitigate the plant conditions leading to a C-SGTR will fail?
 - Actions generally involve restoration of secondary cooling or RCS depressurization
 - Any standard HRA method may be used – screening values are used in the report
- Recovery may not be feasible in certain situations (e.g., fast developing scenarios)
- Highly plant specific evaluation
- Certain strategies may rely on security related actions
 - Credit should conform to Regulatory Issue Summary 2008-15, “NRC Staff Position on Crediting Mitigative Strategies Implemented in Response to Security Orders in Risk-Informed Licensing Actions”



Analysis Method – Apply SG Tube Failure Probability

- A C-SGTR Tube Failure Probability Calculator Integrates thermal-hydraulic and materials information
 - Flaw distributions
 - Pressure and temperature history
 - Material properties
 - Failure times for alternate RCS locations
- C-SGTR probabilities generally fall into four bins:
 - High probability (0.4)
 - Low probability (0.02)
 - Negligible probability (0.001)
 - Unanalyzed (0.5)




Illustrative Examples

- The quantitative risk assessment method and its application to multiple plants are in a technical PRA report prepared by RES.
- Method applied to
 - 4-loop Westinghouse (Plant 1)
 - 2-loop Westinghouse (Plant 2)
 - 2-loop Combustion Engineering (Plant 3)
- Includes risk from internal and other hazard categories (“external events”)
- Includes C-SGTR caused by initiating events, as well as RCS conditions after core damage sequences
- Examples of three dominant C-SGTR sequences are given in the backup slides.

Plant-1 4-Loop Westinghouse single unit on a site - Results


Event Category	CDF	Bypass frequency due to C-SGTR	Bypass Freq. as % of Total Plant CDF
Internal Events at Power	2.0E-05	9.0E-07	1.55%
Internal Flooding Events	3.9E-06	1.9E-07	0.33%
Internal Fire Events	3.4E-05	2.0E-07	0.35%
Large Steam Line Break Events	2.5E-08	1.2E-08	0.02%
Seismic Events Bin 1 (pga 0.05 to 0.3g)	2.7E-08	1.3E-09	0.00%
Seismic Events Bin 2 (pga 0.3 to 0.5g)	7.9E-08	1.3E-08	0.02%
Seismic Events Bin 3 (pga > 0.5g)	6.9E-07	3.0E-07	0.52%
Totals	5.8E-05	1.6E-06	2.8%



Conclusions

- Key insight - the fraction of CDF from potential C-SGTR sequences is lower or at the same order of containment bypass fraction that may exist for the currently postulated containment bypass fraction of internal events (e.g. 0.1 or less)
 - C-SGTR is not a negligible part, nor a main contributor of total plant risk. It should be considered and monitored in plant risk assessments in a manner commensurate with its expected importance for each plant.

- An otherwise “successful” accident sequence turning into a core damage sequence due to C-SGTR is not a major contributor to plant risk. However, an accident sequence initially progressing as core damage turning into a containment bypass sequence due to C-SGTR may not be negligible.




Recommendations

- Plant PRAs should address C-SGTR in their evaluation of plant LERF or level 2 analyses on a plant-specific basis, referring to the existing PRA standard. However, an in-depth and intrusive modeling of C-SGTR within the current level 1 models may not be necessary.
- Results sensitive to degree of credit allowed for mitigative actions
- Care must be taken not to take excessive credit for SAMG actions, other recovery actions, and non-safety-related equipment to avoid C-SGTR, especially for external event scenarios.

Programmatic recommendation:

- Task 3.5 of the SGAP has been completed and should be closed.



BACKUP SLIDES

An Internal Event C-SGTR Sequence for Westinghouse 4-Loop Plant

- A loss of offsite power initiating event occurs and results in station blackout; Initially AFW system is operable via the turbine-driven AFW pump; rapid secondary depressurization is successful; 21 gpm per pump RCP seal LOCA occurs; recovery off offsite and onsite power in 8 hours fail; loss of AFW pump due to battery depletion is postulated (operator action for pump control is not credited in SPAR models to avoid core damage); core damage is postulated.
- Sequence proceeds as a very Small LOCA without AFW and without feed and bleed. Sequence CDF is 3.35E-06/year; due to availability of long time window, mitigation credit for secondary cooling to avoid C-SGTR is credited as 0.1. The sequence is assigned a high conditional C-SGTR probability of 0.4.
- The estimated C-SGTR frequency is
$$F = 3.35E-06 * 0.1 * 0.4 = 1.3E-07/\text{year}.$$

High-pga Seismic Event for W 2-Loop Plant

- Seismic events with high pga (> 0.5 g) causing failure of structures, where core damage is postulated.
 - The frequency of this seismic event for plant-2 is three times the frequency of the corresponding one for plant-1. There are large uncertainties in which equipment is failed and which equipment may be still available. Conservative assumptions may be present in the classification of this “sequence”.
- The initial sequence CDF is $3.8E-06$. The large structural failures considered are reactor vessel, steam generators, RCS piping, containment building, turbine building, and auxiliary building.
- 35.4% of the sequence already has either containment bypass or vessel failure. In order to estimate the additional containment bypass risk due to C-SGTR, the original sequence CDF is multiplied by 0.646 ($1.0 - 0.354$).

High-pga Seismic Event (continued)

- This is a high-pga seismic event beyond design basis:
 - no mitigative strategy is credited (no recovery). No credit is given for B5b equipment.
 - the highest conditional C-SGTR probability of unanalyzed case = 0.5 is used.
 - (For those sequences that are not studied in the Sandia report, a screening value of 0.5, which is very similar to this highest reported conditional C-SGTR frequency, is selected. Use of such a screening value in PRA acknowledges that information about this parameter is not known: however it is neither deemed to occur with certainty, nor it is deemed to be insignificant.)

- The estimated C-SGTR frequency is:
$$F = 3.8E-06 * (1 - 0.354) * 0.5 = 1.2E-06/\text{yr}.$$

A Fire Event Sequence for W 2-Loop Plant

- Internal fire event that result in evacuation of the main control room and causes LOOP.
- Control of the plant at the dedicated shutdown panel and AFW fails. Both the fire scenario frequency and the equipment that can be credited to deal with the sequence have large uncertainties and possibly conservative assumptions.
- Initial sequence CDF is 3.23E-06.
- Since AFW fails and no safety injection is credited, core damage occurs relatively rapidly. Due to the short available time for the operator actions, use of B5b equipment or AFW recovery are not credited.
- High conditional C-SGTR probability of 0.4 is used. This probability applies to transient or an RCP seal leak of up to 150 gpm per pump (RCS pressurized; no relief or small leak).
- The estimated C-SGTR frequency is:
$$F = 3.23E-06 * 0.4 = 1.3E-06/\text{yr}.$$



Oyster Creek 3D Drywell Analysis

ACRS Full Committee
October 08, 2009

- ✓ Summary of 3D Drywell Analysis
- ✓ Resolution of Questions from September 23, 2009 Subcommittee Meeting
- ✓ Presenters:
 - Mike Gallagher
 - John O'Rourke
 - Stan Tang
 - Dr. Clarence Miller

- ✓ Exelon made a commitment to perform 3D Drywell Analysis at the February 01, 2007 ACRS Meeting
- ✓ The ACRS described Exelon's commitment in its February 08, 2007 letter to Chairman Klein as follows:
 - “The applicant has committed to perform a 3D finite-element analysis of the OCGS drywell to determine the margin of the shell in the as-found condition using modern methods. This analysis will provide a more accurate quantification of the margin above the Code required minimum for buckling. The analysis should include sensitivity studies to determine the degree to which uncertainties in the size of thinned areas affect the Code margins”
- ✓ Exelon formalized this commitment in a letter dated February 15, 2007
- ✓ The analyses were submitted to the NRC on January 22, 2009.

Overall Results (Sandbed Region)

Load Combination Case	Required Safety Factor	Base Case Safety Factor (Limiting)	Case 1 Safety Factor (Limiting)	Case 2 Safety Factor (Limiting)
		Based on 2006 data confirmed by 2008 data	100 mil local reduction in Bay 1	50 mil reduction of Bay 19
Refueling	2.0	3.54 Bay 3	3.21 Bay 3	3.46 Bay 3
Post Accident Flooding	1.67 (Service Level C)	2.02 Bay 19	2.01 Bay 19	1.98 Bay 19

Drywell Description




Figure 1-1: Oyster Creek Containment Schematic

- ✓ Detailed finite element model developed using design drawings
- ✓ Shell thicknesses were developed based on UT thickness data
- ✓ Current licensing basis inputs such as code of record, loads and load combinations were used
 - The Oyster Creek drywell vessel was designed, fabricated and erected in accordance with the 1962 Edition of ASME Code, Section VIII and Code Cases 1270N-5, 1271N-5 and 1272N-5
 - For the size of the region of increased membrane stress, guidance sought from the 1989 Edition of ASME Code (including Winter 1991 Addenda), Section III, Subsection NE, Class MC Components
 - For the post-accident stress limits, Standard Review Plan Section 3.8.2 was used as guidance
- ✓ Buckling analysis performed
 - Allowable Stress Values per Section NE-3222 of the 1989 Edition (with Winter 1991 Addenda) of the ASME Code, Section III, Division 1, Subsection NE, Class MC Components
 - Modified Capacity Reduction Factor utilized in accordance with Code Case N-284-1 whose primary author was Dr. Clarence Miller
 - Code minimum safety factors satisfied
- ✓ Stress evaluation performed
 - Stresses are within Code allowables

Drywell Thickness Description

Sandbed Measurement Locations


2006 Measurement Locations in the Sandbed Region

Color Code for thickness:

- Green = UT Measurements > 736 Mils
- Yellow = UT Measurements Between 636 and 736 Mils
- Red = UT Measurements Between 536 and 636 Mils

Location / Type of UT Measurement

- △ External Point UT Measurements
- Internal Grid UT Measurements
- Internal Point UT Measurements



Bay Location (Bay Number)

- ✓ Why is it appropriate to use the UT Internal Grid averages as the modeled thickness for large areas of the sand bed bay?
- ✓ Response:
 - The internal UT grids were located based on a series of data taken to locate the thinnest general areas for ongoing monitoring. Therefore, these grids are representative of the general area average thickness, biased on the thin side.
 - The half buckling wavelength is large, on the order of 5 to 8 feet, which indicates a bay-wide effect. Therefore, the use of average thickness over a bay is acceptable.

- ✓ From 1983 to 1986, measurements were taken around the inside of the drywell at elev. 11'3"
 - Over 500 initial data points were measured
 - When thin locations were identified, UT measurements were taken horizontally and vertically to locate the thinnest locations
 - UT grid measurements were taken at the thinnest locations
 - 19 locations were selected for ongoing corrosion monitoring with at least one grid is located in each of the 10 bays
- ✓ UT measurements are obtained at these locations every other refueling outage as part of the ongoing aging management program

The UT Internal Grid locations are representative of the general area average thickness, biased on the thin side. Therefore, the UT Internal Grids measurements are appropriate to use as inputs to conservatively model general bay thicknesses.

- ✓ Trenches in Bays 5 and 17 were excavated in 1986 to characterize the extent of corrosion in sand bed at elevations below the drywell interior floor
 - Bays 5 and 17 were selected because UT measurements indicated these bays had the least and the most corrosion, respectively
 - The trenches extend to about the elevation of the bottom of the sand bed
 - UT measurements taken in the trenches confirmed that the corrosion below elev. 11' 3" was bounded by the monitoring at elev. 11' 3".


This supports our conclusion that the UT Internal Grid measurements are appropriate to use as inputs to conservatively model general bay thickness.

- ✓ Local Buckling Stresses depend on the applied stress over the half buckle wavelength L_c
 - $L_c = 3.72(Rt)^{0.5}$
 - For the Oyster Creek Drywell Shell, the half buckle wavelength varies between 62 inches and 89 inches
 - For shells with variable thickness, the thickness can be averaged over a distance of, at least, the half buckle wavelength L_c
- ✓ Tests (Miller, 1982) have been conducted on axially compressed shells with unreinforced openings which show little reduction in the buckling strength when the diameter of the hole, d , is $< 0.8(Rt)^{0.5}$. For the Oyster Creek drywell shell $d = 13$ in. to 18 in.
 - A hole less than 13 inches will have little effect on the buckling strength, therefore, thinned areas less than 13 in. will have little effect on the buckling strength

Conclusion: Use of average thicknesses for a bay as input to the 3D Analysis is acceptable.


Bay 19 Thickness

- ✓ The bay exhibits historical corrosion above and below Elevation 11'-0"
- ✓ 3 internal grids (All nominally 49 points) are used to measure shell thicknesses in Bay 19
- ✓ Average of three internal grids used as general area thickness for entire bay (826 mils)




Bay 19
(2006)

Bay 19 Locally Thinned Area




Bay 1 Thickness


- ✓ Visual observation of the external shell surface in Bay 1 indicates the presence of historical corrosion
- ✓ 1 internal grid (7 point) is used to measure shell thickness in Bay 1
- ✓ Internal near nominal grid shell readings for Bay 1 indicate that the grid location is above the former sand/water/air interface boundary
- ✓ Adjacent bay (Bay 19) is one of the most corroded bays
- ✓ Bay 1 thickness was conservatively estimated to be the same as Bay 19 thickness



Bay 1
(2006)

Bay 1 Locally Thinned Area






Notes

1. Small-diameter circles in Bays 13, 15, and 17 represent 18-inch diameter locally-thinned areas that were modeled as part of the "base case."
2. Large-diameter circles in Bays 1, 17 and 19 represent 51-inch diameter locally-thinned areas that were modeled as part of the "base case."


- ✓ Why are the External UT points considered biased thin?
- ✓ Response:
 - The External UT Points were identified visually as thin areas for further evaluation. The areas were also ground to permit UT measurement. Therefore, they are biased thin.

- ✓ After the sand and corrosion byproducts were removed from the sandbed bays, the thinnest locations in each bay were identified.
- ✓ Each bay was visually inspected and the thinnest local spots were investigated both visually and using UT measurements.
- ✓ Approximately 100 locations were identified and mapped.
- ✓ The external surface of the shell was rough, requiring most of the locations to be ground down to create small flat surfaces so the UT probe could be placed perpendicular to the shell wall.
 - This resulted in small 1 to 2 inch diameter dimples in the surface with relatively thinner local areas (biased thin) that were then measured by UT.
 - Micrometer characterization showed that the grinding process may have removed up to 100 mils.
 - Between the individual External UT points, the shell is thicker.

The External UT points are biased thin. They were used to develop the locally thinned modeled areas. It is not appropriate to use these individual measurements to determine general area thicknesses.



Approximate 51 inch circle
at 696 mils thick
modeled locally thinned area



Finite Element Model

✓ ANSYS

- Release 8.1 and ANSYS Release 11 used to generate the three dimensional model
- Industry accepted, finite element analysis software


✓ Dimensions and material properties obtained from OEM drawings

✓ Model Size

- Approximately 406,000 elements
- Approximately 400,000 nodes


✓ Mesh Sensitivity

- Up to approximately 1,000,000 elements



Elevation View of Finite Element Model

MESH SIZES	
Region	General Mesh Size (Inch)
Local Thinning Area	0.75
Sandbed Region	1.50
Mid Spherical Shell	3.00
Knuckle Region	3.00
Cylindrical Shell	3.00
Top Dome	6.00
6 inch or smaller penetrations	2.50
8 inch or larger penetrations	5.00
Vent Pipes	6.00
Vent Header	10.00
Equipment Hatch	6.00
Bottom Spherical Shell (within concrete)	12.00




0.75 inch mesh size

1.5 inch mesh size

Locally Thinned Area in Bay 19

- ✓ Describe specifically the modeling of the vent header boundary condition. Is this boundary condition appropriate as to the effect on the shell? Will the downcomer vents buckle?
- ✓ Response:
 - The vent header boundary condition modeling is appropriate and the boundary condition does not provide added benefit to the shell analysis
 - The vent pipes/header will not buckle before the shell



- ✓ Detailed modeling of the vent headers/downcomers is included for realistic representation of stiffness/interaction of components attached to the drywell shell
 - Similar to the use of stiffness matrix as boundary conditions
- ✓ Detailed modeling reduces conservatism in stress/buckling results
 - Account for realistic load transfer
 - Alternate simplified approach is to model with estimated boundary conditions at vent pipes/vent header interface location

- ✓ Loads going through the vent pipes are low

- ✓ Case: Flooding Loads
 - 93% of reaction force was at the embedded bottom head boundary conditions

 - 4% of reaction force was at the vent header boundary conditions

 - 3% went to other boundary conditions (equipment hatch and star truss)

Vent Pipes will not Buckle before the Shell

- ✓ R/t: Vent pipe ≈ 150 , Vent header ≈ 110 , Downcomers ≈ 48
 - Cylindrical shell R/t ≈ 300
 - Spherical shell R/t ≈ 400 to 600
- ✓ Length between stiffeners: Vent Pipe $\approx 85''$, Vent header $\approx 48''$, Downcomers $\approx 75''$
 - Cylindrical shell length between stiffeners = $103''$
 - Spherical shell length between stiffeners = $235''$ to $332''$
- ✓ In Code Case N-284-1, for cylinder, a smaller R/t gives a larger capacity reduction factor and higher buckling strength

Conclusion: Based on the comparison of R/t and the length between stiffeners for the vent pipes and the shell, the vent pipes would have higher buckling strength and larger safety factors than the shell.

Sensitivity Studies

- ✓ Case 1: Reduce the wall thickness of the 51 inch defined locally thin area in Bay 1 by 100 mils (from 696 mils to 596 mils), keeping the general area of the thickness in Bay 1 constant (826 mils)
- ✓ Case 2: Reduce the wall thickness of the general area in Bay 19 by 50 mils (from 826 mils to 776 mils), keeping the locally thin area constant (720 mils)

Results (Sandbed Region)

Load Combination Case	Required Safety Factor	Base Case Safety Factor (Limiting)	Case 1 Safety Factor (Limiting)	Case 2 Safety Factor (Limiting)
		Based on 2006 data confirmed by 2008 data	100 mil local reduction in Bay 1	50 mil reduction of Bay 19
Refueling	2.0	3.54 Bay 3	3.21 Bay 3	3.46 Bay 3
Post Accident Flooding	1.67 (Service Level C)	2.02 Bay 19	2.01 Bay 19	1.98 Bay 19

- ✓ How is the selection of the 100 mil local reduction and 50 mil bay-wide reduction related to UT data?
- ✓ Response:
 - **Local Area Reduction:** The measurement difference between individual external UT points was -6/+1 mils. The 100 mil local reduction is over 15 times the observed external UT measurement difference and, therefore, is expected to bound data uncertainties.
 - **General Bay-Wide Reduction:** The internal UT Grid measurement standard errors range from +/- 2 to +/- 16.6 mils. The 50 mil bay-wide reduction is at least 3 times the standard error for the data used to determine the general bay-wide thickness input and, therefore, is expected to bound data uncertainties.
 - UT measurements demonstrate that the drywell shell is not experiencing corrosion; however, a hypothetical corrosion rate of 2 mils per year would yield a postulated bounding value of 8 mils over a 4 year measurement interval. The selected reductions of 100 mil local or 50 mil bay-wide are much greater.

Overall Results/Conclusions

- ✓ For normal operating conditions, the limiting condition is the refueling condition. For this condition, the current safety factor of the limiting sandbed bay is 3.54, which results in a safety margin greater than the ASME Code specified safety factor of 2.0.
- ✓ For emergency conditions, the limiting condition is the post-accident flooding condition. For this condition, the current safety factor of the limiting sandbed bay is 2.02, which results in a safety margin greater than the ASME Code specified safety factor for Service Level C conditions of 1.67.
- ✓ Sensitivity studies demonstrate that significant thickness changes could occur in the future, or measurement uncertainties could exist, without a significant reduction in margin to ASME Code specified safety factors.

Questions?



U.S. NRC

UNITED STATES NUCLEAR REGULATORY COMMISSION

Protecting People and the Environment

NRC Staff Review of Oyster Creek Drywell Shell 3-D Finite Element Analysis

Allen Hiser, Jr.

Hans Ashar

Division of License Renewal

Kamal Manoly

Division of Engineering

Timothy O'Hara

Region I

Advisory Committee on Reactor Safeguards

October 8, 2009

- Overall Perspective
- Historical Perspective of Analyses
- NRC Inspections
- NRC Staff Review
- NRC Conclusions

OVERALL PERSPECTIVE

- Corrosion identified late 1980s
 - Narrow band of the lower spherical portion of the shell – “sandbed” region
 - Prevalent in half of bays
- Remediation
 - Removed source of corrosion (wet sand)
 - Protected with a robust coating
 - Ultrasonic test measurements indicate corrosion arrested; upper shell measurements indicate low general corrosion

OYSTER CREEK DRYWELL SHELL ANALYSES

- General Electric Analysis - 1992
 - Assumed uniform reduction in shell thickness (sandbed region) to minimum measurement (0.736 in.) and locally thinned area (0.536 in.)
 - Modified capacity reduction factor – refuel load
 - Current licensing basis analysis
- Sandia - 2007
 - Conservatively modeled degradation based on average of external UT measurements, locally thinned area set to bay lowest thickness
 - Conservative assumptions based on no access to proprietary design data
 - Unmodified capacity reduction factor – refuel load
- Structural Integrity Associates – 2009
 - Realistic analysis to compute margins in existing drywell shell above ASME Code
 - Performed base case analysis and sensitivity analyses to address measurement uncertainty
 - Access to GE proprietary design data
 - Modified capacity reduction factor – refuel load

All analyses demonstrate margins that exceed ASME Code

INDEPENDENT REVIEWS

- Brookhaven National Laboratory review of GE analysis for NRC
- ACRS review of Sandia analysis as a part of license renewal review
- Becht Nuclear Services review of SIA analysis for State of New Jersey

All three reviews point to the conclusion that the Oyster Creek drywell shell can perform its intended function without compromising the ASME Code margins

NRC STAFF REVIEWS

- January 22, 2009, submittal
 - Base case and sensitivity cases
 - Detailed rigorous review of submittal
 - Part of license renewal inspection
 - Inspection report issued (ML091380379)
 - Staff assessment issued (ML091310413)

- September 9, 2009, submittal
 - Two revised modeling approximations
 - Detailed review of submittal
 - Performed audit to supplement review
 - Audit report to be issued

ACTIVITIES

- Region I inspectors observed Exelon's drywell shell inspections in 2006 and 2008
- Noted by sample observation that external measurement locations appeared to be chosen in areas of significant relative corrosion

OBSERVATIONS

- Drywell exterior coating was, in general, in good condition
- UT inspections were conducted and reported in a competent, accurate manner
- Sandbed general conditions were good, some minor repairs to seals and coating were needed

CONSERVATIVE ASSUMPTIONS

- Bounding seismic response spectra
- In post accident flooding case, all the water in included as added mass in the drywell seismic analysis
- Conservative 2% damping under OBE
- Post accident Flooding Case evaluated against ASME Service Level C limits
- Support provided at locations of Star Truss/bioshield wall conservatively neglected from the analyses, especially in buckling evaluation
- Sizes of locally thinned areas in sandbed region conservatively mapped

FINITE ELEMENT MODEL

- Realistic estimate analysis of current condition of the drywell shell including realistic simulation of locally-thinned areas identified in 1992 and confirmed in 1994, 2006 & 2008
- Extensive model with general element size of 3", refined to 0.75" in locally-thinned areas

STRESS EVALUATION

- Refueling case limiting load combination in Levels A and B service conditions, while post-accident flooding case limiting for Level C service condition

BUCKLING EVALUATION

- Where applicable, CRF modified to account for benefit of hoop tensile stresses in the shell as a result of the weight of the water in the reactor cavity pool
- Refueling and post-accident flooding load cases are controlling for buckling evaluation
- In refueling load case, minimum FS 3.39 in the cylindrical region compared against a min FS of 2.0
- In flooding load case, minimum FS 2.0 in the sandbed region, compared against a min FS of 1.67

SENSITIVITY ANALYSIS CASES

- Two sensitivity analysis cases considered to capture potential uncertainties in location and degradation of locally thinned areas
- Stresses in regions above the sandbed area marginally affected and remain essentially the same as in the baseline analysis ... less than 8% increase in stress intensities well below allowable ASME Code limits

NRC CONCLUSIONS

- Overall, the 3-D FEA analysis performed utilizing widely accepted engineering practices consistent with ASME Code, good engineering judgment, and applied conservatively biased realistic assumptions
- All components of the drywell shell show adequate margins against instability under refueling loads and post-accident flooding loads
- In all loading cases, stresses are less than allowable ASME Code limits
- For refueling load case, margin against buckling is the lowest in the cylindrical shell region, an area that has experienced little corrosion
- Evaluations in all cases (baseline and sensitivity cases) confirm the Oyster Creek drywell shell complies with the ASME Code limits, and provide reasonable and realistic quantification of the available safety margin of the drywell shell for the postulated loading conditions