

PMSTPCOL PEmails

From: Joseph, Stacy
Sent: Wednesday, October 14, 2009 10:28 AM
To: 'rhscheide@stpegs.com'
Cc: STPCOL; Govan, Tekia; Muniz, Adrian
Subject: DRAFT RAI related to Chapters 4, 6 and 15
Attachments: RAI 3792.doc

Dick,

Please review this DRAFT RAI related to COL Information Items in Chapters 4, 6 and 15. Please let me know within 5 days if a telecon with the technical reviewer is required. If I do not hear back from you by close of business on Wednesday, October 21, I will issue the RAI.

Thank you,
Stacy Joseph

Stacy Joseph
Project Manager
U. S. Nuclear Regulatory Commission
Office of New Reactors
Division of New Reactor Licensing

(Office) 301-415-2849
(Fax): 301-415-5399
Mail Stop T7-F31
Washington DC 20555-0001

Hearing Identifier: SouthTexas34Public_EX
Email Number: 1781

Mail Envelope Properties (BBC4D3C29CD0E64E9FD6CE1AF26D84D5500E9556)

Subject: DRAFT RAI related to Chapters 4, 6 and 15
Sent Date: 10/14/2009 10:27:55 AM
Received Date: 10/14/2009 10:27:56 AM
From: Joseph, Stacy

Created By: Stacy.Joseph@nrc.gov

Recipients:

"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Govan, Tekia" <Tekia.Govan@nrc.gov>
Tracking Status: None
"Muniz, Adrian" <Adrian.Muniz@nrc.gov>
Tracking Status: None
"rhscheide@stpegs.com" <rhscheide@stpegs.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

| Files | Size | Date & Time |
|--------------|-------------|------------------------|
| MESSAGE | 533 | 10/14/2009 10:27:56 AM |
| RAI 3792.doc | 27202 | |

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 3792 Revision 2

South Texas Project Units 3 and 4
South Texas Project Nuclear Operating Co
Docket No. 52-012 and 52-013
SRP Section: 04.04 - Thermal and Hydraulic Design
Application Section: 4.4, 6.3 and 15

QUESTIONS for Reactor System, Nuclear Performance and Code Review (SRSB)

04.04-***

For the COL items listed below, the applicant has proposed to provide the required information as an amendment to the FSAR at least one year prior to fuel load. The method proposed by the applicant is not an acceptable resolution of a COL information item. For each of the following COL items, please provide a method of resolution that will allow the NRC staff to reach a safety conclusion on each issue:

FSAR Section 4.4.7.1 COL Information Item 4.2 (COM 4.4-1)
FSAR Section 4.4.7.2 COL Information Item 4.3 (COM 4.4-2)
FSAR Section 6.3.6.1 COL Information Item 6.6 (COM 6.3-1)
FSAR Section 6.3.6.3 COL Information Item 6.7a (COM 6.3-3)
FSAR Section 15.0.5.1 (COM 15.0-1)
FSAR Section 15.0-5.2 (COM 15.0-2)
FSAR Section 15.0.5.3 (COM 15.0-3)
FSAR Section 15.1.2.3.2.2 COL Information Item 15.1 (COM 15.1-1)
FSAR Section 15, 2,1.3.1 COL Information Item 15.2 (COM 15.2-1)
FSAR Section 15. 2.2.3.2.3 COL Information Item 15.2 (COM 15.2-2)
FSAR Section 15.4.11.1 COL Information Item 15.5 (COM 15.4-1)
FSAR Section 15.4.11.2 COL Information Item 15.6 (COM 15.4-2)