14.3S Inspections, Tests, Analyses and Acceptance Criteria (ITAAC)

The selection criteria and methodology provided in Section 14.3 of the reference ABWR DCD for the certified ABWR design were utilized as the site-specific selection criteria and methodology for inspections, tests, analyses, and acceptance criteria including those applicable to the emergency planning and physical security hardware. In general, the ITAAC for site-specific systems were developed to correspond to the interface criteria in Tier 1 of the reference ABWR DCD. For those site-specific systems that do not have a safety function sufficiently significant to meet the selection criteria for ITAAC, the system is identified with the designation “No entry for this system.”

The emergency planning ITAAC conform to the guidance provided in Sections C.I.14 and C.II.1 of Regulatory Guide 1.206, as modified to reflect the design and specific emergency planning program requirements.

The security ITAAC conform to the guidance in Appendix C.II.1-C of Regulatory Guide 1.206, as modified to reflect the design and site-specific security requirements.