

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261
October 30, 2009

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 09-301A
NL&OS/ETS
Docket No. 50-338
License No. NPF-4

VIRGINIA ELECTRIC AND POWER COMPANY (DOMINION)
NORTH ANNA POWER STATION UNIT 1
ONE TIME EXTENSION OF THE COMPLETION TIME FOR
1 "J" - 480 VOLT AC DISTRIBUTION SUBSYSTEM
WITHDRAWAL OF LICENSE AMENDMENT REQUEST

In a July 23, 2009 letter (Serial No. 09-301), Dominion requested an amendment to the Facility Operating License, in the form of changes to the Technical Specifications to Facility Operating License Number NPF-4 for North Anna Power Station Unit 1. Dominion had requested that the proposed change be reviewed on an expedited basis to proactively address conditions after North Anna Unit 1 experienced a small fire in a breaker for a control rod drive mechanism (CRDM) fan. The proposed change would have revised Technical Specification (TS) 3.8.9 Condition A, by adding a note to allow a one-time 72 hour Completion Time to interrogate a failed breaker and the associated Unit 1 "J" 480 Volt emergency bus switchgear to ensure the emergency power system continues operation in a reliable condition for the remainder of the operating cycle.

On October 23, 2009 North Anna Unit 1 was shut down due to leakage in the letdown system. With the unit off line, Dominion was able to remove the affected breaker and perform an inspection of the Unit 1 "J" 480 Volt emergency bus switchgear. Therefore, the one time 72 hour Completion Time is no longer necessary and Dominion is hereby withdrawing the amendment request.

If you have any further questions or require additional information, please contact Mr. Thomas Shaub at (804) 273-2763.

Very truly yours,


J. Alan Price
Vice President – Nuclear Engineering

Commitments made in this letter: None

cc: U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth Street, SW
Suite 23T85
Atlanta, Georgia 30303

Mr. J. E. Reasor, Jr.
Old Dominion Electric Cooperative
Innsbrook Corporate Center
4201 Dominion Blvd.
Suite 300
Glen Allen, Virginia 23060

State Health Commissioner
Virginia Department of Health
James Madison Building – 7th Floor
109 Governor Street
Suite 730
Richmond, VA 23218

NRC Senior Resident Inspector
North Anna Power Station

Dr. V. Sreenivas
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop O8 - G9A
Rockville, Maryland 20852-2738

Ms. K. R. Cotton
NRC Project Manager
U. S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop O8 - G9A
Rockville, Maryland 20852-2738