

Ferdas, Marc

From: Billy Rogers *NRR*
Sent: Tuesday, April 28, 2009 4:19 PM
To: Marc Ferdas
Subject: Oyster Creek Hotwell Reject Line

Hi Marc,

Louise Lund (NRR/DLR) suggested I contact you to see if you could provide some information concerning the hotwell reject line to the CST. This is the 8-inch diameter carbon steel pipe located under the condensate transfer building (which the licensee found contained a less than 1-inch hole. Do you know whether the Oyster Creek included this line within the scope of license renewal. The tech divisions at HQ are looking into this but I thought you might have the information right at hand. I appreciate your help.

Thanks,
Bill

Bill Rogers
Sr. Reactor Engineer
Division of License Renewal
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission M/S: O-11F1
Washington DC, 20555

Office: OWFN-11E8
Phone: 301-415-2945
Email: billy.rogers@nrc.gov