

Southern Nuclear
Operating Company, Inc.
150 North College Street
P.O. Box 600000
Birmingham, AL 35206-0000
Tel: 205.991.5000



Energy to Serve Your World

November 5, 2009

Docket No.: 50-348

NL-09-1773

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555-0001

Joseph M. Farley Nuclear Plant Unit 1
Withdrawal of Request to Revise
Technical Specification 3.7.8, "Service Water System (SWS)"

Ladies and Gentlemen:


In letter (NL-09-1676) dated October 21, 2009 Southern Nuclear Operating Company (SNC) submitted a proposed revision to the Technical Specifications (TS), Appendix A to Facility Operating License Number NPF-2 for the Joseph M. Farley Nuclear Plant Unit 1. The proposed revision was for limited time changes for Unit 1, to prevent an unnecessary Unit shutdown for the repair or replacement of SWS seismic support ring assemblies. Subsequent inspection of the SWS seismic support ring assemblies indicated satisfactory condition and no need for repair or replacement. Therefore, SNC hereby withdraws the subject TS revision package.

Mr. M. J. Ajluni states he is Nuclear Licensing Manager of Southern Nuclear Operating Company, is authorized to execute this oath on behalf of Southern Nuclear Operating Company and to the best of his knowledge and belief, the facts set forth in this letter are true.

This letter contains no NRC commitments. If you have any questions, please advise.

Respectfully submitted,

SOUTHERN NUCLEAR OPERATING COMPANY



M. J. Ajluni
Nuclear Licensing Manager

Sworn to and subscribed before me this 5th day of November, 2009.



Patricia H. Raymond
Notary Public

My commission expires: 7-21-2012

MJA/TDH/lac

cc: Southern Nuclear Operating Company
Mr. J. T. Gasser, Executive Vice President
Mr. J. R. Johnson, Vice President – Farley
Ms. P. M. Marino, Vice President – Engineering
RTYPE: CFA04.054

U. S. Nuclear Regulatory Commission
Mr. L. A. Reyes, Regional Administrator
Mr. R. E. Martin, NRR Project Manager – Farley
Mr. E. L. Crowe, Senior Resident Inspector – Farley

Alabama Department of Public Health
Dr. D. E. Williamson, State Health Officer