

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor
Safeguards
EPR Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, November 3, 2009

Work Order No.: NRC-3179

Pages 1-204

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 EPR SUBCOMMITTEE

8 + + + + +

9 TUESDAY

10 NOVEMBER 3, 2009

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B3, 11545 Rockville Pike, at 8:30 a.m., Dana A.
17 Powers, Chairman, presiding.

18
19
20 SUBCOMMITTEE MEMBERS PRESENT:

21 DANA A. POWERS, Chairman

22 MICHAEL T. RYAN

23 WILLIAM J. SHACK

24 JOHN W. STETKAR

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

NRC STAFF PRESENT :

- DEREK WIDMAYER
- SANDRA SLOAN
- GETACHEW TESFAYE
- RONALDO JENKINS
- JIM STECKEL
- PETER KANG
- JOE COLACCINO
- CLIFF MUNSON
- KENNETH SEE
- BRAD HARVEY
- WEIJUN WANG

ALSO PRESENT :

- SANDRA SLOAN
- GEORGE PANNELL
- BRIAN GARDES
- JIM REDDY
- VIC FREGONESE
- ZIA SALAMI
- TODD OSWALD
- TED MESSIER

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

T-A-B-L-E O-F C-O-N-T-E-N-T-S

Introduction

Dr. Dana Powers 5

Introduction of U.S. EPR DC APPLICATION Review

Getachew Tesfaye. 8

a. U.S. EPR DC APPLICATION FSAR Chapter 8, Electric

Power

Sandra Sloan. 11

George Pannell. 14

Brian Gardes. 18

Jim Reddy 30

b. U.S. EPR Electrical Distribution System (EDS),

Model Development & System Analyses

Zia Salami. 62

SER with Open Items for Chapter 8, Electric Power

Getachew Tesfaye. 84

Jim Steckel 85

Peter Kang. 86

U.S. EPR DC APPLICATION FSAR Chapter 2, Site

Characteristics

Sandra Sloan. 121

Todd Oswald 122

Ted Messier 123

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1
2
3
4
5
6
7
8

SER with Open Items for Chapter 2, Site

Characteristics

Getachew Tesfaye167
Brad Harvey170
Ken See189
Weijun Wang192

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIRMAN POWERS: Meeting will now come to order. This is the meeting of the Advisory Committee on Reactor Safeguards U.S. EPR Subcommittee.

I'm Dana Powers, the harassed and harried chairman of the Subcommittee.

ACRS members in attendance are: John Stetkar, virtually back from the exotic Swiss Alps; Michael Ryan from the Deep South; and Bill Shack from the rough and tumble world of Chicago.

Derek Widmayer of the ACRS is the designated federal official for this meeting.

The purpose of the meeting is to begin our review of the safety evaluation report, otherwise known as the SER, with open items for the design certification document, sometimes known as the DCD, sometimes known as the blankety-blank CD, submitted by AREVA NP for the U.S. EPR design.

Today we will hear presentations and discuss Chapter 2, Site Characteristics, and Chapter 8, Electric Power. The Subcommittee will gather relevant information today and report to the full committee later on this week, but we will not be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 formulating any findings on these matters at the
2 conclusion of today's meeting.

3 The Subcommittee will meet again on
4 November the 19th and hear presentations and discuss
5 the SER for Chapter 10, Steam and Power Conversion
6 Systems, and Chapter 12, Radiation Protection Model.

7 At the conclusion of the November 19th
8 meeting, the Subcommittee members will decide what
9 recommendations to take to the full Committee
10 concerning these four chapters of the SER. The full
11 Committee will meet on December 3rd through 5th,
12 2009.

13 The rules for participation today's
14 meeting have been announced as part of the notice of
15 this meeting previously published in the Federal
16 Register. We have received no written comments or
17 requests for time to make oral statements from
18 members of the public regarding today's meeting.
19 However, if members of the public do have comments
20 they would like to make, we will allow them time as
21 is appropriate.

22 A transcript of the meeting is being
23 kept and will be made available as stated in the
24 Federal Register notice. Therefore, we request that
25 participants in the meeting use the microphones

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 located throughout the meeting room when addressing
2 the Subcommittee. They should first identify
3 themselves and speak with sufficient clarity and
4 volume so they may be readily heard.

5 Copies of the meeting agenda and
6 handouts are available in the back of the room.

7 I understand we have a telephone bridge
8 and we have participants from AREVA NP on the line.
9 And there are a variety of rules for participating,
10 most of which is to keep your telephone on mute.

11 Do the members of the Subcommittee have
12 any opening comments they would care to make?

13 (No audible response.)

14 CHAIRMAN POWERS: Seeing none.

15 Well, we're about to get started on
16 this.

17 You ready, Sandra?

18 MS. SLOAN: I think we're ready.

19 MR. TESFAYE: I'm going to get started.

20 CHAIRMAN POWERS: You're going to lead
21 it off? All right.

22 MR. TESFAYE: Yes, give a short overview
23 of the project and where we're at with the project.

24 Good morning, everybody.

25 CHAIRMAN POWERS: We're going to let you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in just a second.

2 Okay. This is the first of what is it,
3 20 chapters altogether?

4 MR. TESFAYE: Nineteen.

5 CHAIRMAN POWERS: Nineteen? So, we've
6 broken it down into about eight different sections
7 to make life easy for ourselves. And then we'll get
8 started.

9 So, Mr. Tesfaye, you were going to give
10 us an overview. Please do so.

11 MR. TESFAYE: Good morning, everyone.
12 Again, my name is Getachew Tesfaye. I'm the lead
13 project manager for EPR design certification
14 application review.

15 I'd like to give you a short overview of
16 this project. This project will be almost five
17 years old next month. The pre-application
18 activities began back December 2nd, 2004, and for
19 three years AREVA engaged the staff through public
20 meetings, some meeting topical reports, technical
21 reports, and then the application was submitted on
22 December 11th, 2007. It was accepted or docketed
23 for review on February 25th, 2008 and the staff
24 issued a review schedule on March 26th, 2008.

25 We completed Phase 1 of the review,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 which is developing a preliminary safety evaluation
2 report and generating RAIs on January 29th, 2009,
3 and that was done on schedule. During that period,
4 the staff issued over 2,500 RAIs, and we continue to
5 issue RAIs through Phase 2. To date we have issued
6 over close to 3,400 RAI questions to the AREVA.

7 We have also revised the original review
8 schedule twice based on response schedules that we
9 received from AREVA and the current schedule that
10 I'm going to show in the next slide was issued on
11 June 25th of this year.

12 We have completed so far Phase 2 review
13 for Chapters 2, 8, 10 and 12. Of course, Chapters 2
14 and 8 will be the subject of today's discussion.
15 We'll start with Chapter 8 this morning and then
16 we'll do Chapter 2 this afternoon.

17 The other major milestone of course,
18 today we officially begin the ACRS review, which is
19 basically off the review plan.

20 I think I have showed you this slide
21 last month, I mean in September when we were here to
22 discuss the -- AREVA presented the containment and
23 some other accident analysis topics. Nothing has
24 changed. This is the schedule that was published in
25 June of this year. According to the current

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 schedule, we'll be done with Phase 2 review June 30,
2 2010 and complete ACRS presentation of Phase 3
3 review on September 2010.

4 CHAIRMAN POWERS: Yes, your wording is
5 correct. Those are target dates.

6 MR. TESFAYE: Target is exactly. They
7 may change between now and the next presentation.

8 This is slightly rearranged to the ACRS
9 Phase 3 review plan. As you indicated, we broke it
10 up into several groups mainly based on the Phase 2
11 completion dates. We have groups 1A and 1B. This
12 is was originally for a two-day ACRS Committee
13 meeting. Since now they are separated by days, we
14 call them 1A and 1B. And same thing with 2A and 2B.
15 We'll finish about five more chapters before the end
16 of this year. That is Phase 2 review of five more
17 chapters. And we're going to bring six chapters in
18 the next group, Group 2A and Group 2B, in February
19 and March of 2010. And the third group will be
20 presented in May. We don't have a date for it yet,
21 but we're targeting May 2010 to present four more
22 chapters. And then we'll complete our Phase 3
23 presentation in July with additional five more
24 chapters.

25 And we're hoping to have one final

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 closing Subcommittee meeting in September to have a
2 general discussion and sum up all the open items,
3 any cross-cutting issues or even revisit some of the
4 chapters that have already been presented.

5 So, that's our plan. Again, this plan
6 may change.

7 With that, I'm done with my presentation
8 unless there's any question for me.

9 CHAIRMAN POWERS: Yes, I'm not sure I
10 have any useful questions for you.

11 MEMBER RYAN: No, nothing yet.

12 CHAIRMAN POWERS: That is the plan we're
13 operating to and we will do our best.

14 MR. TESFAYE: Thank you.

15 CHAIRMAN POWERS: Sandra, I guess you're
16 up.

17 MS. SLOAN: All right. While he's
18 bringing up the slides, as Getachew said --

19 CHAIRMAN POWERS: Is there a reason for
20 doing Electric Power before Sit Characteristics? I
21 mean, is there some subtle, you know, topical
22 element here that I'm just missing, or something
23 like --

24 MS. SLOAN: No.

25 CHAIRMAN POWERS: Other than it makes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 sense. We wouldn't be here -- if this plant doesn't
2 generate electrical power, I don't care. I don't
3 care where you locate it. If it just sits there and
4 is a paperweight, you know, you can put it anywhere
5 you want to, I suppose.

6 MS. SLOAN: Okay.

7 CHAIRMAN POWERS: Okay.

8 MS. SLOAN: So as Getachew said, this is
9 first in a series of what we hoped were a
10 constructive set of interactions with the ACRS
11 Subcommittee to go through the chapter SERs with
12 open items.

13 And our objective here today with the
14 lead-off presentation is to provide summary level
15 information about how the chapters is organized and
16 the material in it. Obviously, given the
17 constraints of the agenda, it really is a summary-
18 level presentation, but we are trying to give you
19 the highlights of what's in the design certification
20 FSAR for EPR and taking to heart what you've told us
21 in the past, trying to focus on those things that
22 may be new or different for EPR. So not boring you
23 with those things that are kind of business as usual
24 for U.S. PWRs.

25 So, feel free to ask us questions as we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 go along.

2 CHAIRMAN POWERS: Oh, we almost never
3 hesitate.

4 MS. SLOAN: I know you don't miss an
5 opportunity.

6 CHAIRMAN POWERS: Almost never. There
7 are some members that I think maybe need
8 encouragement, but in general, no.

9 MS. SLOAN: Not shy. Not shy.

10 And I did want to reiterate, we do have
11 phone participants who are listening in Charlotte,
12 North Carolina. So what we've instructed our
13 presenters to do is if they feel like on a given
14 question they need support from their colleagues,
15 then they will address their colleagues by phone and
16 ask them to respond to the question.

17 CHAIRMAN POWERS: It's a lot more fun to
18 watch them squirm.

19 MS. SLOAN: So, we have our phone-a-
20 friends.

21 PARTICIPANT: A life line.

22 MS. SLOAN: A life line. Yes, that's
23 another way to look at it, I suppose.

24 CHAIRMAN POWERS: Hey, we can give them
25 multiple choices, you know?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. SLOAN: But we'll start off. Our
2 presenter today for Chapter 8 is George Pannell, who
3 is one of our senior licensing managers in AREVA.
4 He'll talk to you a little bit about his background.
5 And he's also supporting --

6 CHAIRMAN POWERS: Oh, yes, George,
7 that's right. Since you guys are all new here to
8 us, you've got to give us some reason why you're
9 qualified to speak before this august body.

10 MR. PANSELL: I'd be glad to do that.
11 Yes, sir.

12 MS. SLOAN: And then he's joined by
13 Brian Gardes and Jim Reddy, who are subject matter
14 experts from AREVA who've been the leaders in
15 developing electrical design for the U.S. EPR. And
16 then after they cover the material that's included
17 in Tier 2, Chapter 8, then Dr. Zia Salami, who's
18 sitting here on the side, will give an overview of
19 the electrical distribution system modeling and
20 analyses.

21 So with that, unless there are any
22 particular questions for me, I'll turn it over to
23 George.

24 MR. PANSELL: Good morning. A little
25 background on myself. I've been involved in nuclear

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 technology for about 41 years now. I got out of the
2 Navy in '73. Went to work for Virginia Power. So
3 I've been involved in the start up of three reactors
4 actually. I started up in North Anna 1 as an
5 operations manager, North Anna 2 as an engineering
6 manager, and Watts Bar 1 as a site licensing
7 manager. And as you know, North Anna 2 was caught
8 up in the post-TMI moratorium-kind of thing, so at
9 that point in time I was responsible for electrical
10 I&C, fire protection, EQ, and I performed the first
11 human factors modification of an existing control
12 room in the country at that time. That was 1980
13 vintage. And I had to do quite a few modifications
14 to the distribution system to get that plant to
15 perform a little bit better.

16 In the mid-'80s I ran an industry
17 program, Westinghouse Owners' Group Trip Reduction
18 and Assessment Program; you may have heard of it,
19 WOGTRAP. I chaired that starting in '85 when we
20 were having on average, if you counted all the
21 reactors vendors, one-and-a-half trips a day. So, I
22 think we turned that around a bit.

23 CHAIRMAN POWERS: Beautiful.

24 MR. PANNELL: And then in that same time
25 frame I was part of the corporate emergency response

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 team when we had to deal with the pipe rupture at
2 Sorry, December of '86, and the six-hundred-gallon-
3 a-minute tube rupture at North Anna Unit 1.

4 So the modifications I did to the
5 electrical on North Anna 1 really helped us better
6 manage that event. I mean, we had the generator
7 bottled up in about 30 minutes and cooled the unit
8 down. So, that was important.

9 And another kind of milestone, submitted
10 a tech spec change, if you recall back when we were
11 doing surveillance on emergency diesels, we were
12 kind of testing them to destruction. So, I
13 submitted kind of a precedent-setting tech spec
14 change which allowed us to, when we do surveillance
15 on like to warm the engine up, load it, instead of
16 doing so many cold fast starts. That was another
17 good thing.

18 So, that's kind of my background and
19 what I've been doing.

20 So, what I would like to do today is
21 present -- the first couple slides are kind of
22 here's the machine and then we'll relate the
23 electrical system to the machine.

24 So, we're going to talk about the four
25 sections in the SAR, and then I've put together a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 summary to kind of wrap it up.

2 So, the basic layout of the machine is
3 we have a four-week PWR and four safeguards areas.
4 If it's okay with you gentlemen, I'm going to point
5 rather than use the mouse. So if you can't hear me,
6 just yell.

7 So, what we have is four safeguards
8 areas around the reactor. And the overview layout
9 plat plan of the station, important characteristics.
10 The diesel buildings are on opposite sides of the
11 containment. There are Safeguards 1, 2, 3 and 4
12 again. Station blackout diesels back here. Power
13 transformers we're going to talk about are back
14 here. Diesel buildings 1 and 2 are in the same
15 buildings, but they're properly separated. The
16 diesel buildings are on opposite sides of the
17 containment building for additional physical
18 protection.

19 The switchyard of course is COLA-
20 specific. Our basic off-site power system consists
21 of three what we call normal auxiliary transformers
22 and two emergency auxiliary transformers, and they
23 supply the emergency buses.

24 On-site power, we have several
25 uninterruptible power systems, non-class 1E. We

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have the four divisions of class 1E. Four emergency
2 diesels. That's a little bit different than a lot
3 of plants. Then we have of course two station
4 blackout diesels.

5 On-site power, non-1E UPS. Four
6 divisions of 1E UPS and a 12-hour UPS system, which
7 we'll talk about in a little bit.

8 So, what's fundamentally the same with
9 the EPR that you've probably seen many times before.

10 CHAIRMAN POWERS: Can I ask you a
11 question about your 12-hour interruptible power
12 supply?

13 MR. PANSELL: Sure.

14 CHAIRMAN POWERS: Why 12 hours?

15 MR. PANSELL: Well, it has to do with
16 station blackout and severe accident mitigation.

17 CHAIRMAN POWERS: Why 12 hours?

18 MR. PANSELL: That is long enough to get
19 the SBO diesels back and control the plant, keep it
20 stable. That's our engineering assessment of the
21 situation.

22 CHAIRMAN POWERS: How did you do that?

23 MR. PANSELL: Brian?

24 MR. GARDES: Sure. As I said, I'm Brian
25 Gardes and I'd better give my qualifications so at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 least --

2 CHAIRMAN POWERS: Go ahead. Please.

3 MR. GARDES: -- maybe you'll --

4 CHAIRMAN POWERS: Yes, I mean, this is
5 the first time we meet you at the Subcommittee
6 meeting. It's nice to know who we're talking to.

7 MR. GARDES: I've been involved with the
8 EPR for about four years, same with AREVA. I've
9 been in electrical design the whole time. So I've
10 been involved in almost all the technical issues
11 and --

12 CHAIRMAN POWERS: Did you suddenly
13 appear out of the ether?

14 MR. GARDES: Nope. I came from Columbia
15 Generating Station for 10 years, mostly in
16 operations, including shutdown reactor --

17 CHAIRMAN POWERS: You survived the
18 cultural shock from --

19 MR. GARDES: Well, I grew up in
20 Maryland, so getting back to --

21 CHAIRMAN POWERS: Ah, so you -- I see.
22 You're tired of looking at broad vistas and things
23 like that. You wanted trees in the way to --

24 MR. GARDES: Yes, a lot of people think
25 Washington State is all trees, but obviously --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: Not true then? They
2 potted trees there.

3 MR. GARDES: And then nine years in the
4 Navy on submarines --

5 CHAIRMAN POWERS: Oh, okay. What boat?

6 MR. GARDES: U.S.S. Guitarro.

7 CHAIRMAN POWERS: Oh, okay.

8 MR. GARDES: Okay. The 12 hours, that's
9 basically a time duration that was developed from
10 the European side and it was the duration set where
11 they would expect to recover either the station
12 blackout diesel, emergency diesel generator and/or
13 the off-site power. And it was a duration of which
14 the passive part of the severe accident design on
15 the 12-hours UPS could manage the event until we had
16 to get active systems involved that require a larger
17 amount of power such as the severe accident heat
18 removal system for containment spray and the IRWST
19 cooling. So, it's both the time it takes to restore
20 power sources and also to mitigate the event during
21 the 12 hours. And that's the duration of --

22 CHAIRMAN POWERS: I'm still struggling.
23 Why 12 hours? You say this came out of the European
24 analysis. They have a very reliable grid, more
25 reliable than ours.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GARDES: That's true, but this is
2 like a least improbable event. So, you know, you've
3 already talked about loss of off-site power, the
4 failure for emergency diesels, and in this case, the
5 failure of two of the station blackout diesels, so
6 you have no AC power source. So, whatever that took
7 all those major AC sources out, you know, is fairly
8 improbable, but at least it would take some amount
9 of maintenance to restore one of the sources,
10 whether it's the grid and the grid operator can
11 bring a source back to off-site.

12 CHAIRMAN POWERS: But the median time to
13 repair a diesel, it's eight hours.

14 MR. GARDES: Then the 12 hours would be
15 a conservative duration.

16 CHAIRMAN POWERS: It's conservative on
17 the median. It may not be conservative on the mean.
18 I just don't happen to know what the mean is. But I
19 mean, at least that would be a rationale for 12
20 hours.

21 MR. GARDES: And also I think the
22 containment design is such that it's the design of
23 the containment system, etcetera, for the severe
24 accident, would the systems on the 12-hour UPS cover
25 that 12-hour duration prior to needing to restore an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 active system for severe accident mitigation such as
2 the severe accident heat removal system.

3 CHAIRMAN POWERS: I don't think it's the
4 magic number. I think it's more of, given what
5 Brian said, an engineering judgment. Got a design a
6 system here, so that would be quantified.

7 MEMBER STETKAR: Let me ask you, I
8 flipped ahead in the -- to interrupt. Are you done?

9 CHAIRMAN POWERS: Probably not, but
10 please go ahead.

11 MEMBER STETKAR: I flipped ahead and I
12 notice you aren't spending much time on the station
13 blackout or the station blackout coping analysis,
14 which is what we're really talking about.

15 You mentioned 12 hours is partially
16 based on the time to recover off-site power. The
17 switchyard design is completely outside the scope of
18 the Certified Design for this plant. Except for the
19 fact there's some mention of things like redundant
20 DC control power supplies or some things like that,
21 there's no specification on the expected life time
22 of the switchyard batteries, as far as I can tell.

23 How do you get off-site power back into
24 the site if you can't operate the circuit breakers?
25 finite element, if the switchyard batteries have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 life of, oh, 15 minutes or an hour, you're never
2 going to get off-site power back into the site
3 without some heroic efforts on the part of
4 switchyard people.

5 So, I was curious what sort of
6 assumptions you made about timing for restoration of
7 power since you know nothing about how long people
8 can actually operate circuit breakers out in that
9 switchyard after you've lost all AC power. It could
10 be days. Maybe not days. That's probably an
11 exaggeration. It could be considerably longer than
12 eight hours or twelve hours or sixteen hours or --

13 MR. PANNELL: Well, maybe I can relate
14 to my experience of managing a couple of events.
15 There's a lot of support when you have an off-normal
16 situation, as you can imagine.

17 So, unless the site was just not
18 accessible, you put a lot of things into motion when
19 you have an off-normal event and you have a lot of
20 support. So, even if you were to have some
21 switchyard battery problem, you can get T&D out
22 there to do some things fairly quickly, given
23 that --

24 MEMBER STETKAR: Fairly quickly, and
25 given the fact that off-site power often fails

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 during storm events and things like that where T&D
2 is busy doing a lot of things, that's a bit of --

3 MR. PANNELL: I agree. But again, it's
4 engineering judgment. You're looking at a scenario,
5 trying to make design decisions, looking at the
6 trade-offs, looking at the probability of the event.
7 So, yes, you could come up with some scenarios where
8 the switchyard may be a problem, but you still have
9 to account for a little bit of help from the
10 outside. Believe me, when you're in the middle of
11 an event, you call in all the help you need. So,
12 you do what you need to do. And you can pick a
13 number for the batteries; two hours, four hours, six
14 hours.

15 MEMBER STETKAR: I was just curious
16 because the life of the batteries out there do
17 affect a station blackout coping duration --

18 MR. PANNELL: Oh, sure. Sure.

19 MEMBER STETKAR: -- inside the plant,
20 even though you're not controlling the design of the
21 switchyard. I was curious why there was no
22 specification regarding possible life of the
23 batteries, because in this particular plant they are
24 distinct elements that affect the time available to
25 restore off-site power.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANSELL: True. I don't think we
2 have a better answer to that than what we gave.

3 MR. GARDES: The SBO coping duration for
4 the EPR is eight hours before we do it. And even
5 though it's COLA-specific the batteries will last,
6 you know, longer than 15 minutes an hour. They're
7 designed to last up to the coping duration of --

8 MEMBER STETKAR: I didn't see that
9 anywhere in the FSAR though, that that's a
10 requirement. It's --

11 MR. GARDES: But that's COLA- specific
12 for the switchyard.

13 MEMBER STETKAR: Yes, because I didn't
14 see a requirement that said that the COL applicant
15 needs to account for that. It just says that they
16 should have two redundant DC sources and all of that
17 kind of good stuff.

18 MR. PANSELL: That's a good point.
19 You're right. Correct.

20 MEMBER STETKAR: If you don't put it in
21 there, the applicant can do whatever he wants to, he
22 or she.

23 MR. PANSELL: Good comment. Thanks.
24 Shall we move on?

25 CHAIRMAN POWERS: Please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: So, what fundamentally is
2 different generally speaking about the EPR
3 electrical design?

4 We have four emergency diesels. That's
5 somewhat different.

6 The alternate. We have what we call the
7 alternate electrical feed configuration, and we're
8 going to talk about that in a few minutes in more
9 detail.

10 The diesel load sequencer is part of the
11 I&C protection system. In older plant designs,
12 those are kind of stand-alone timing-kinds of things
13 that are triggered by what happens on the emergency
14 (off microphone.)

15 We have two station blackout diesels.
16 This bullet I think is an important one. No fast
17 transfer of plant loads during start up, shut down
18 or plant trip. In the older designs where you have
19 start up transformers, station service transformers
20 and you transfer the hotel load to the main
21 generator and you lose the unit, you get a pretty
22 good electrical transient in the middle of whatever
23 else you're dealing with. Take the case of the tube
24 rupture. We avoided that by having redesigned the
25 distribution system. So it's just another thing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that the shift supervisor has to deal with that we
2 avoid with this design. So, it's a very stable off-
3 site power source.

4 We have separate off-site feeds to
5 safety and non-safety buses. Again, no main
6 generator carried station service transformer, so
7 you've got direct feeds from the switchyard to both
8 sets of transformers. That's an important feature
9 of the design.

10 We have what we call island mode; I'll
11 talk about that in a minute. May address your
12 question on the battery. And of course our 12-hour
13 EPS.

14 PARTICIPANT: Sir, please keep your
15 voice up when you're adjacent to the table.

16 MR. PANNELL: Oh, yes. Thank you.

17 This is the fundamental layout of the
18 emergency power system. Two emergency transformers,
19 two secondaries for load tap changers. So there's
20 the four divisions, 1, 2, 3 and 4. And you can see
21 how the power feeds are split, off-site power from
22 the switchyard with overhead lines.

23 MEMBER STETKAR: George, you mentioned
24 overhead lines. Is that required, or --

25 MR. PANNELL: No, that's just the way

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're approaching it for now.

2 These are the normal auxiliary
3 transformers, and we've split the loads on the hotel
4 system into 26 frames to balance the plant. Same
5 thing, they have their own off-site feeds. As I
6 pointed out earlier, in older designs these
7 transformers would be potentially from the main
8 generator. You'd swap hotel load. If you lost the
9 unit, that load would have to go back to the EATs
10 which presents some design challenges. So these get
11 off-site feed. They're stable, regulated.

12 MEMBER STETKAR: Before you flip down to
13 the on-site stuff, are you going to go back to the
14 off-site? No, you're not. You're digging down
15 deeper.

16 MR. PANSELL: Yes, we can go back.

17 MEMBER STETKAR: Well, let me stop you
18 here. This design does not specify a main generator
19 output breaker, is that correct?

20 MR. PANSELL: Right.

21 MEMBER STETKAR: So you can configure
22 the connection from the main generator to the
23 switchyard any way you want to?

24 MR. PANSELL: Yes.

25 MEMBER STETKAR: There's a failure modes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and effects analysis in the FSAR for the off-site
2 power supply and things that you have up on this
3 slide here.

4 MR. PANNELL: Yes.

5 MEMBER STETKAR: That failure modes and
6 effects analysis extends out to the main
7 transformers, which I guess is within your scope of
8 supply. It does not address failures of the
9 interconnections of the plant with the switchyard
10 and how those interconnections may affect off-site
11 power availability to the safety systems.

12 MR. PANNELL: Yes.

13 MEMBER STETKAR: For example, you make
14 the point that if a main transformer fails, circuit
15 breakers out in the switchyard will separate the
16 main transformer. Well, if you have a unit trip,
17 for example, and one of those switchyard breakers
18 fails to open, there would be naturally some sort of
19 backup protection relaying in the switchyard that
20 will open up feeds to isolate wherever the fault is.

21 MR. PANNELL: True.

22 MEMBER STETKAR: Those feeds that are
23 isolated could affect off-site power to one or more
24 of your emergency power transformers, emergency
25 auxiliary transformers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: Sure.

2 MEMBER STETKAR: Why doesn't the failure
3 modes and effects analysis or the design
4 requirements specify anything about those connection
5 breakers out in the switchyard?

6 MR. PANNELL: Brian?

7 MR. GARDES: I might pass that to Jim
8 and COLA as far as the switchyard failure modes and
9 effects and the departure between what's in the FSAR
10 compared to what might in the COLA.

11 MR. REDDY: Yes, my name is Jim Reddy
12 and I've been with AREVA and then on the EPR project
13 three-and-a-half years, primarily responsible for
14 the development of the Chapter 8 and the RAIs,
15 answering those. Before that, eight years out at
16 Columbia Generating Station where I was an equipment
17 operator/reactor operator/control room supervisor.
18 And then before that, 11 years in the Navy as an RO.

19 So, as far as the generator breakers or
20 generator output breakers in the switchyard, that
21 was essentially considered to be covered within the
22 COLA responsibility since the switchyard itself is
23 the under the COLA responsibility.

24 MEMBER STETKAR: Okay. I guess I'll
25 wait until the staff comes up and see if they're

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 happy with that, that way of drawing the dotted line
2 in terms of responsibility.

3 MR. PANNELL: Sure.

4 MEMBER STETKAR: Thank you.

5 MR. PANNELL: Sure. I'll try and spend
6 a little time on this diagram. This is the
7 emergency power system again. And the reason I
8 highlighted they things that I did, it shows you
9 left to right the four diesels. And I have some key
10 interfaces here I'd like to talk about a minute.
11 You have four diesels. This is 6.9 kV. And we
12 mentioned in one of the earlier bullets the
13 alternate feed arrangement that we can perform on
14 this unit. So, what I've shown for division 1, this
15 is a source that can feed a bus in division 2. So
16 this is the supply. This is load. Same thing is
17 true from division 2. This is a source that can
18 supply a division 1 bus.

19 Now, these are divisional pairs, we call
20 them. So only 1 and 2 can supply one another and
21 only 3 and 4. They can't go from 1 to 3 or 1 to 4,
22 or that sort of thing.

23 MEMBER STETKAR: You're going to talk
24 more about --

25 MR. PANNELL: Yes, I am. I'm going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 go in detail on that.

2 So, that's why I highlighted those
3 connections. That's an important aspect of the
4 design. We'll talk about it in a few minutes.

5 We have two SBO diesels. Mentioned
6 those before. I put these rectangular boxes.
7 Diesel one can supply these two buses. SBO diesel 2
8 can supply these. That's important from a battery
9 charger standpoint, get power back to those
10 batteries.

11 Like I said, this voltage level at these
12 buses is 6.9 kV.

13 MEMBER STETKAR: George?

14 MR. PANNELL: Yes, sir.

15 MEMBER STETKAR: Before drive down in,
16 we're going to get into more details of the on-site
17 thing --

18 MR. PANNELL: Sure.

19 MEMBER STETKAR: -- you mentioned island
20 mode operation --

21 MR. PANNELL: Yes.

22 MEMBER STETKAR: -- which is a term that
23 I'm familiar with, but I don't understand what it
24 means in the context of this design. So --

25 MR. PANNELL: Well, let me see if I can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do it quick. We're talking about loss of off-site
2 power and various issues. It basically is a
3 configuration where you can have the main generator
4 supplying the EATs and NATs and be divorced from the
5 grid.

6 MEMBER STETKAR: Okay. So, that's the
7 way I understand island mode. But it's typically
8 where you have a main generator breaker and a more
9 traditional --

10 MR. PANSELL: Right. Right in where
11 you --

12 MEMBER STETKAR: -- alignment where you
13 separate the plant from the switchyard.

14 MR. PANSELL: Right.

15 MEMBER STETKAR: -- have to feed the
16 switchyard --

17 MR. PANSELL: Yes.

18 MEMBER STETKAR: -- and come back in.

19 MR. PANSELL: Yes, go out to the
20 switchyard and back. But when you're in that mode,
21 you're divorced from the grid basically and carrying
22 your own hotel loads --

23 MEMBER STETKAR: Provided the loss of
24 off-site power wasn't due to failures in the
25 switchyard, which a good fraction are.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: Yes. Yes.

2 MEMBER STETKAR: Okay.

3 MR. PANNELL: You're exactly right.

4 This just gives you a feel. We talked
5 about the safeguards divisions. We've picked
6 division 2 because it has the main control room.
7 But basically, the layout of the EPR, the fluid
8 systems are below switch gear and I&C stuff. Main
9 control room support systems up above.

10 So, we talked about emergency diesels.
11 We have four to support the four division. Output
12 is 9,500 kW. And again, the load sequencing in this
13 station is performed by the I&C protection system,
14 which is a bit different than you're probably used
15 to seeing. And of course we have adequate physical
16 separations within safeguards buildings, even with
17 the EDG buildings where the diesels are beside one
18 another, 1 and 2 and 3 and 4.

19 Alternate feed. This is an important
20 aspect of the design, so we'll spend a little time
21 on this and talk about it. They're designed to
22 enhance operational capability and flexibility.
23 What we don't say in that bullet is while
24 maintaining complete Chapter 15 mitigation
25 capability with the diesel. We're going to talk

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about that some more.

2 They can only be established, as I
3 mentioned, between 1 and 2, 3 and 4. You can't go
4 from 1 to 4. When you make the connection and going
5 to alternate feed, you are supporting the systems
6 that are basically two-train systems that you need.
7 And I'll talk about Chapter 15. We'll walk through
8 that here in a second.

9 These are the basic loads on the
10 divisions. One thing that could be a little
11 misleading, primary containment isolation valves.
12 We show four Xs. It's really not four divisions.
13 It depends on the systems. In some cases division 1
14 and 2 might power the inside and outside valve and
15 division 3 and 4 on another. So that could be a
16 little -- the PCIIVs are not four-trains. They're
17 just on occasion powered by different divisions.
18 And then the bolded box are the two-train systems I
19 mentioned. And we'll show how we retain that
20 functionality when we talk about alternate --

21 MEMBER STETKAR: What's a KLC system?

22 MR. PANNELL: That's a cooling system
23 for safeguards buildings.

24 MEMBER STETKAR: Okay. Chilled-water-
25 type?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: Yes, forced cooling,
2 recirc cool.

3 So, this is the basic concept,
4 divisional pairs. I mentioned you can 1 to 2, 2 to
5 1, and of course 3 and 4. So the basic idea is I
6 can supply the opposite division with the other
7 division's diesel. In the next slide I'll talk
8 about how that works. We'll take a diesel. The
9 concept, just two pairs, divisional pairs.

10 So, let's assume we take diesel 1 out
11 for maintenance. You're going to make the
12 connection from division 2 to division 1. And I
13 might explain that that is not an automatic
14 transfer. That's a dead-bus transfer. So, basically
15 what operations is going to have to do is maneuver
16 whatever systems they had on that bus and downstream
17 of that bus to make this transfer to being a 72-hour
18 action. They'll do their transfer. Disconnect from
19 the normal source, which would be div 1, connect to
20 div 2, power the bus back on. Now you're out of the
21 action -- does that make sense?

22 So, now you've restored at that bus
23 level all the safety-related functionality you need
24 in the station. So literally, you could leave that
25 diesel as is, theoretically, and you still meet

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 15 analysis.

2 Yes, sir?

3 MEMBER STETKAR: Let me ask about this
4 one.

5 MR. PANNELL: Okay.

6 MEMBER STETKAR: Suppose we now have a
7 loss of off-site power in this configuration.

8 MR. PANNELL: Okay.

9 MEMBER STETKAR: Let me see if I can
10 phrase the question correctly here. You mentioned
11 that there are not individual load sequencers for
12 the diesel generators, that the loads are sequenced
13 the --

14 MR. PANNELL: Yes, protection --

15 MEMBER STETKAR: -- protection control
16 system.

17 MR. PANNELL: Right.

18 MEMBER STETKAR: Does the division 2
19 protection and control system sequence all loads
20 onto diesel 2?

21 MR. PANNELL: Yes.

22 MEMBER STETKAR: How does the division 2
23 protection control system interface with the circuit
24 breakers over there in your division 1 bus that you
25 now have connected to division 2? It sounds like an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 inter-divisional I&C signal configuration that is
2 not normal at all.

3 MR. PANNELL: Brian?

4 MR. GARDES: Sure. The actual
5 connection from division 2 to division 1 will be
6 done with manually operated breakers up from the
7 control room/locally. So once you've put in the tie
8 that will be from the 6.9 kV bus in division to the
9 corresponding 6.9 kV bus in division 1. And if I
10 have a loss of off-site power event, the actual main
11 distribution breakers, I'm not going to open those
12 main distribution breakers. They will stay closed.
13 So, they won't have to be sequenced back in. So,
14 when the diesel comes onto the orange, big orange
15 bus in division 2, it will then come down and power
16 up that smaller bus.

17 MEMBER STETKAR: Oh, you don't sequence
18 any loads on the yellow bus, the division 1 bus?

19 MR. GARDES: Right now, potentially the
20 only load we would sequence on would be the safety
21 chiller compressors on there. The rest of the loads
22 for the most part are smaller loads that would come
23 with the distribution system.

24 MEMBER STETKAR: So there is potentially
25 one load?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GARDES: Correct.

2 MEMBER STETKAR: So let's focus on --
3 because I don't care whether there's one or a
4 hundred. That's a division 1 circuit breaker that
5 has division 1 DC power to it. It has normal
6 division 1 protection control signals to it that is
7 now potentially being told to close via a division 2
8 instrumentation and control signal. So I'm curious
9 about how that's accomplished, because it sounds
10 like we have inter-divisional control signals going
11 on here, and I'm curious how that's done.

12 MR. GARDES: That's the requirement we
13 have. As far as the actual Chapter 7 and the
14 digital I&C and how it would be done, and protection
15 and how it would be separated out within the signal
16 spaces, I myself am not, you know, the technical
17 expert in that particular area, although I
18 understand your question.

19 MEMBER STETKAR: Do we have anybody who
20 can answer that question, because I hate dividing up
21 things up into digital I&Cs simply because that's a
22 chapter in the FSAR, because this is an electrical
23 question.

24 MR. PANSELL: Well, Mr. Fregonese --

25 MR. FREGONESE: Hi, good morning. My

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 name is Vic Fregonese.

2 I can comment that the protection system
3 sends the signal still to the division 1 breakers
4 and we're not transferring the function of
5 protection system. What you're really doing is just
6 taking the loads in the electrical system and
7 transferring them over. We're not physically moving
8 anything. So, the connections from the protection
9 system still go from division 1 to division 1.

10 MEMBER STETKAR: I understand that.

11 MR. FREGONESE: Right.

12 MEMBER STETKAR: But if there is a
13 single one or more loads on that yellow bus, on that
14 division 1 bus, that must start and load onto that
15 division 2 diesel generator after that diesel
16 generator starts and loads. That's not a protection
17 function. That's a signal to close the circuit
18 breaker for that particular division 1 load.

19 MR. FREGONESE: And a protection system
20 will still do that. The protection system doesn't
21 know that the alternate feed is in. So, when you
22 get an initiation signal, the coincident logic just
23 tells the output of the protection system to send
24 the outputs to every division complement that needs
25 to be sequenced. So, it doesn't really know that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the alternate feed is in place. So, you haven't
2 done anything with the protection system. I'll try
3 to clarify -- I'll clarify that again.

4 MEMBER STETKAR: I guess if I was a
5 protection system, I'd like to know which diesel I'm
6 loading onto, because it might affect the load.

7 MR. FREGONESE: No, Zia will talk about
8 the analysis later as to how the diesels are sized.
9 But what I will tell you is that all we need to do
10 is close the breaker that supplies the load and the
11 diesel can take that load. So in this case, we have
12 not changed the function of the protection system at
13 all.

14 MR. PANSELL: I can see your gears
15 turning. What we'll have to do is look at that
16 interface.

17 MEMBER STETKAR: I'm curious --

18 MR. PANSELL: Yes, you can design an
19 isolated signal to that breaker.

20 MEMBER STETKAR: I can think of many
21 ways of designing it. I'd like to see how it is
22 designed, please.

23 MR. PANSELL: Yes. I know where you're
24 going. But, yes.

25 MEMBER STETKAR: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: You'd have to have an
2 appropriate isolated input to that breaker to
3 control it.

4 MEMBER STETKAR: It's unusual because it
5 is a cross-divisional I&C function.

6 MR. PANNELL: Yes, it is. You're
7 absolutely right.

8 MR. FREGONESE: Yes, but once again, we
9 don't change the mode of the protection system. And
10 I guess we can clarify that later, if we need to, in
11 another --

12 MR. PANNELL: That's a good point
13 though.

14 MR. FREGONESE: -- in either Chapter 8
15 or Chapter 7.

16 MR. PANNELL: You must provide
17 appropriate isolation if we send a signal from one
18 division to the other.

19 MEMBER STETKAR: If there is a signal,
20 it goes over. And if there isn't a signal, it goes
21 over. Then I'd like to see how that really works in
22 practice so that you don't miss loading possible
23 loads onto that bus that you really need.

24 MR. PANNELL: Good comment.

25 MEMBER STETKAR: Okay. Thanks.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: Okay. So, let's go
2 through this scenario where we have the alternate
3 feed in place. And of course the most visible
4 obvious thing is, oh, what if you lose that diesel
5 or the alternate feed? Well, this is that scenario.
6 And as you can see, we had this diesel in
7 maintenance. This was carrying the alternate feed,
8 its own division. We take that as have an event.
9 Take that as a single failure. We still retain two
10 divisions, the fluid systems, one division of the
11 two-train systems we talked about earlier in the
12 load chart. And so, in that condition with an event
13 and a single failure, you can still mitigate the
14 Chapter 15 accident.

15 So, same scenario event, different
16 diesel. Same diesel out for maintenance. Actually
17 end up with more equipment. You end up with the
18 alternate-fed bus and again at least divisions of
19 fluid systems and containment isolation.

20 MEMBER STETKAR: It's probably the time
21 to ask this one, too, since we have the diagrams of
22 various diesels available and out of service.

23 The design of the plant supports on-line
24 preventive maintenance, and I'm assuming that's a
25 planned activity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANNELL: Sure.

2 MEMBER STETKAR: The tech specs allow a
3 single diesel to be out of service for up to, I
4 believe, 120 days, isn't it?

5 MR. PANNELL: Well, yes, that's what we
6 propose.

7 MEMBER STETKAR: So that's a four-month
8 maximum time. If people perform rolling preventive
9 maintenance during plant power operation, there
10 could be a measurable fraction of time when you're
11 actually operating the plant in this alternate power
12 alignment. I have no idea. There's no experience
13 in the United States. I'm a bit familiar with
14 plants in Europe where the kind of rolling
15 preventive maintenance durations last anywhere from
16 two to four weeks.

17 MR. PANNELL: Sure.

18 MEMBER STETKAR: And if that's the case,
19 if you want to get through one maintenance cycle in
20 a year or year-and-a-half, you could be operating in
21 this alignment a reasonable fraction of time.

22 I just wanted to make that point and
23 make sure that I understood --

24 MR. PANNELL: Well, I think --

25 MEMBER STETKAR: -- to the best

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 extent --

2 MR. PANSELL: Yes, the maintenance rule
3 will come, too. You're probably not going to end up
4 leaving that for an extended period. But the other
5 issue we ran into in the past is having some sort of
6 -- assuming it's not a common problem to the engine
7 and trying to do quick maintenance on a big diesel
8 engine. So, to me, that's a pretty good trade-off.
9 Just make sure you get fixed properly.

10 MEMBER STETKAR: In terms of specifying
11 that that 120-day tech spec time limit for the
12 diesels, did you look at all at using the risk
13 assessment approach to look at that time limit? The
14 other time limits you have in there are fairly
15 standard in terms of standard tech spec times. But
16 the 120-day time limit is kind of a new beast, if
17 you will --

18 MR. PANSELL: It is.

19 MEMBER STETKAR: -- in terms of our
20 licensing world.

21 MR. PANSELL: Yes.

22 MEMBER STETKAR: Have you looked at risk
23 informing that duration at all in terms of risk
24 sensitivity to what it might be?

25 MR. PANSELL: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Thank you. Continue.

2 MR. PANSELL: Thanks. Again, this is
3 the normal transformers. The purpose for this slide
4 is simply to show where the SBODs will tie into the
5 non-safety. And so you can see the same four
6 rectangular orange boxes I showed on the emergency.
7 And then it eventually ends up feeding the emergency
8 power system the way I showed earlier. It's just to
9 show where the SBOs tie in.

10 So, class 1E uninterruptible power. We
11 have four divisions, two battery chargers per, and
12 they're capable of being fed by the SBO diesel.
13 Remember those four orange boxes I showed you on the
14 safety buses.

15 And we had redundant feeds to the I&C
16 cabinets, and I'm going to talk about that in a
17 minute. It's a little bit different than you're
18 used to seeing.

19 We learned a lot from having looked at
20 the Forsmark event. If you recall, that event
21 started with a fault in the switchyard and kind of
22 went downhill from there. So some of that drove
23 some of the things you're going to see in this
24 design in terms of not losing invertors, UPS
25 systems. If you remember, two divisions of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 batteries kind of were un-powered for awhile.

2 That's not a good idea. So, we'll talk about that a
3 bit.

4 So, a basic UPS arrangement. Circles
5 around a battery. You've got a 250-volt battery
6 bus. Two battery charges that can support the DC
7 loads.

8 We have an inverter with a static
9 switch. Should be a bumpless transfer of the
10 inverter probes for some reason. That should swap
11 over to that power source.

12 MEMBER STETKAR: That's the plan.

13 CHAIRMAN POWERS: Anyway.

14 MEMBER STETKAR: They work.

15 MR. PANSELL: They usually do, yes.

16 MEMBER STETKAR: The newer ones work.

17 MR. PANSELL: Yes. Yes. And then you
18 have of course from the same MCC that supports the
19 static switch, kind of a maintenance connection. So
20 if you have to take that inverter out, you can work
21 on it.

22 This is the interface we talked about
23 earlier, kind of related to the Forsmark. In
24 typical designs you have the old battery inverter
25 supplies the I&C cabinets. Well, that's the left

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hand device. In this case, we have both an AC to DC
2 feed to the I&C cabinets and a DC to DC feed.

3 MEMBER STETKAR: George, are those feeds
4 cabinet-by-cabinet, or are they division-by-
5 division?

6 MR. PANSELL: I don't recall.

7 MEMBER STETKAR: For example, division 1
8 cabinets, is there a single power supply that feeds
9 all of the I&C cabinets in a particular room, or are
10 these isolated by cabinet-to-cabinet?

11 MR. PANSELL: I don't know we split it.

12 MEMBER STETKAR: Because again, it's the
13 interface between I&C and electric power, but --

14 MR. PANSELL: Right. Of course they're
15 optioned here together.

16 MEMBER STETKAR: Yes.

17 MR. GARDES: It's definitely division-
18 by-division. So when you look at a division, you
19 have division 1 power, both AC and DC, to division 1
20 I&C cabinets. The converter modules could be kind
21 of considered like battery cells where you have
22 several modules in a cabinet, and it could supply
23 several I&C cabinets. But you'd have more than one
24 converter module per se cabinet in a division
25 because of the number of I&C cabinets. So, this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 could represent a cabinet here and you could have
2 potentially three or four cabinets that have these
3 modules supply X-number of I&C cabinets in that
4 division. And the same with these cabinets.

5 MEMBER STETKAR: That's what I was
6 trying to get a handle on, whether if I think of
7 this as division 1, do I have two and only two of
8 those devices, you know, once each, or do I have 50
9 of them if I have 25 individual cabinets?

10 MR. PANSELL: Like one big bus versus --

11 MEMBER STETKAR: One big versus
12 distributed power supplies.

13 MR. GARDES: More than one, less than
14 50. But I think if I had to guess, as far as the
15 number without having to look at the thing, we're
16 probably up to maybe five or six cabinets, converted
17 cabinets per division supplying X-number of I&C
18 cabinets. So, probably around a half-a-dozen or so.

19 MEMBER STETKAR: And this design does
20 not have alternate feeds to I&C from the other
21 divisions, right?

22 MR. GARDES: It doesn't have alternate
23 feeds as far as it's concerned down here at the I&C
24 cabinets. But if you go up above to where the
25 battery chargers --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: They'll cross ties at a
2 higher level?

3 MR. GARDES: That's correct.

4 MEMBER STETKAR: But down at the cabinet
5 level, it's strictly divisions?

6 MR. GARDES: That is correct.

7 MEMBER STETKAR: Okay.

8 MR. FREGONESE: This goes back to your
9 previous comment. This is Vic Fregonese. This kind
10 of illustrates what we were talking about before
11 with the alternate feed and sequencing. The I&C
12 system always stays powered up. So the logic, the
13 processors in the sequencing is always powered up
14 even in the alternate-fed configuration. So the
15 output of the system still goes to the division 1
16 breaker, even though the bus is powered from
17 division 2. So, that breakers always gets the same
18 one from the I&C based on the coincident logic
19 that's developed. So, the cabinets are powered up.
20 We never take the division 1 I&C out when the
21 division 1 diesel is out.

22 MEMBER STETKAR: I'll leave it open on
23 the table, because --

24 MR. PANSELL: Oh, okay. Thank you.

25 MEMBER STETKAR: -- the I&C signals

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 often need to know what the configuration of the AC
2 electric power system is.

3 MR. PANNELL: Yes, I've had to deal with
4 some of that stuff.

5 We were talking a little bit about the
6 12 hours UPS, two trains. Part of it's for SBO
7 control. And this plant actually has designed into
8 it severe accident mitigation capability. Core
9 areas under the vessel, spray systems, etcetera.

10 We mentioned island mode. It's actually
11 pretty straightforward given you can work out the
12 switchyard breakers. You basically end up with the
13 unit being self-sustaining, if you want, powering
14 its own hotel loads, divorced from the grid.

15 COURT REPORTER: Please keep your voice
16 up, sir.

17 CHAIRMAN POWERS: Yes. Station
18 blackout. We mentioned we had two SBO diesels.
19 They can be connected to divisions 1, 2, 3 and 4, as
20 we showed earlier. Thirty-nine-hundred kW. And
21 they're different, intentionally of course, to be
22 diverse. Engines. Different areas. Even different
23 cooling. Larger engines are water cooled. Smaller
24 ones air cooled. No common systems, and they can be
25 put in service in ten minutes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Two questions before
2 you leave this one.

3 MR. PANNELL: Sure.

4 MEMBER STETKAR: I looked enough at the
5 design and basically understand the philosophy.
6 When you say there's no sharing of fuel systems,
7 does the plant design include a common large fuel
8 oil storage tank that's used to refill the
9 individual tanks for each of the emergency diesels
10 and the station blackout diesels? Some plants have
11 that large storage capacity.

12 MR. PANNELL: Right. Right. I'm used
13 to that.

14 MEMBER STETKAR: Other plants simply
15 have individual tanks for each diesel. So, I was
16 curious about that possibility of a common large on-
17 site fuel storage capability.

18 MR. GARDES: I'm not aware that there is
19 a common fuel storage tank. Each diesel, whether
20 it's emergency or SBO, has its own fuel oil storage
21 tank associated with it. And I'm familiar with what
22 you're saying about a common tank that you can --

23 MEMBER STETKAR: Make a -- right.

24 MR. GARDES: -- or a spoiler, whatever.
25 But, that's not in this design. Each one is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 storage tank stand alone.

2 MEMBER STETKAR: Is there a
3 specification to prohibit that in terms of the COL?
4 Because that indeed would be a source of commonality
5 in terms of contaminated fuel among --

6 CHAIRMAN POWERS: Sure. That's quite an
7 old issue. You're going to have the same thing just
8 on delivery. It doesn't matter --

9 MEMBER STETKAR: Except delivery is
10 often different times. So, you can argue that it
11 contaminates --

12 MR. PANSELL: Yes, I think currently
13 sampling-kind of requirements kind going to take
14 care of that.

15 MEMBER STETKAR: I'm going to ask the
16 staff about this. I'll wait and ask the staff about
17 the 10 minutes.

18 MR. PANSELL: Okay. Sure.

19 So in summary, the design meets
20 regulatory requirements, protects the health and
21 safety of the public. And this is key; again, based
22 on my experience, the goal here is to provide the
23 operating staff with a stable power supply system.
24 So, if they have to deal with some off-normal event,
25 they have the equipment they need, whether it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 safety-related or not to manage that event. That's
2 extremely important. So having a stable power
3 supply is a very important aspect of this design.
4 So, it provides stable power for normal operations
5 and for event management, which is very critical.

6 We think it's evolutionary. We
7 certainly stayed abreast of what's been going on for
8 30-35 years, tried to incorporate those lessons
9 learned.

10 Again, the off-site emergency bus
11 transformer feeds are separated from off-site non-
12 safety bus transformer feeds. There is no large
13 load transfer when you lose the unit. That's again
14 an important aspect for operational folks.

15 No shared transformers between safety
16 and non-safety and the non-safety loads are not
17 powered from the main generator, which requires
18 typically a large hotel load transfer.

19 We have more redundancy than you've
20 probably seen before in older plants. And the
21 alternate feed provides a key power supply so that
22 you can take a diesel out, do good maintenance on
23 it, but still be protected as far as Chapter 15
24 events go.

25 That's all I had.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: This is an off-the-wall
2 question, more off-the-wall than the other ones.

3 There are, as I understand it, a
4 relatively large number of underground cable ducts
5 that get power from point A to point B in this plan.
6 I think the FSAR mentions ducts for essential
7 service water, the station blackout diesels, the
8 power to the safeguards buildings and so forth.

9 We've had substantial operating
10 experience here in the United States with water
11 intrusion into underground cable raceways and cable
12 ducts. And I noticed that the FSAR acknowledges
13 that, and it says manholes for duct bank access had
14 recesses for temporary sump pumps for water
15 draining. Manholes located below the groundwater
16 line had a permanent sump pump design.

17 I was curious, given the experience with
18 water intrusion from a variety of known and unknown
19 sources here in the U.S., many of which are very,
20 very plant-specific and some of which are not
21 entirely understood, I think, why you don't just put
22 permanent sump pumps in all of the low points in all
23 of the cable ducts just to keep them dry, regardless
24 of whether they're above or below nominal
25 groundwater level?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. PANSELL: I think that's a great
2 question. Again, I'm relating back to my
3 experience. Even if you, in my view, put permanent
4 pumps in, I wouldn't totally rely on those.

5 MEMBER STETKAR: Oh, yes, you still have
6 to look in there, because --

7 MR. PANSELL: You likely think they're
8 always going to work, but --

9 MEMBER STETKAR: But having a sump pump
10 versus no sump pump is --

11 MR. PANSELL: Yes. Absolutely. That's
12 right.

13 MEMBER STETKAR: -- better than just
14 relying on some periodic --

15 MR. PANSELL: Well, I wouldn't totally
16 rely on it without some periodic look in the hole
17 and see what's going on.

18 MEMBER STETKAR: There was apparently
19 and active decision made not to put pumps in all of
20 those ducts for some reason.

21 MR. PANSELL: I can't address that one,
22 no.

23 MR. GARDES: I'll pass that to Jim,
24 because we took an RAI question on that as well, as
25 far as the cabling and underground issues.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REDDY: Right. And with the RAI,
2 essentially what we determined there was the -- and
3 then you mentioned the experience there with, for
4 example, Generic Letter 2007-01. Essentially we're
5 to create a COLA item for at least the periodic
6 inspection of those. And then at the same time, you
7 know, if there were to be a permanent sump pump
8 design in there, that that would be, you know,
9 within the COLA to do that. But at least to
10 recognize what you're saying that it's, you know,
11 certainly a problem to be considered and addressed,
12 and at the same time to acknowledge it, do the
13 appropriate inspection. And if you needed to do or
14 if you elected to have a permanent sump pump design,
15 then you would do that at the site-specific, or you
16 would know what your water tables are and so forth.

17 MEMBER STETKAR: Well, what we've seen
18 in many cases, it isn't so much a function of the
19 water table. It certainly depends on the water
20 table, but there's also water intrusion from surface
21 water runoff, from rainfall, from you name it, snow
22 melt.

23 MEMBER RYAN: Could I ask you a
24 question, John, somewhere along in here?

25 The groundwater question is a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 particularly interesting one, and it's very site-
2 specific. But, you know, you could end up with a
3 circumstance where pumping isn't going to do much
4 good. The minute you shut them off, you're back to
5 where you started. So, what's plan B?

6 MR. PANSELL: Well, I don't know of any
7 other way to address it other than know what the
8 site conditions are at the time. And if you suspect
9 that potential, there's a foot of water running on
10 the ground, you're probably going to have to look at
11 those and see what's happening.

12 MEMBER RYAN: Well, in a large part of
13 the Southeast, groundwater is pretty close to the
14 surface, if not at the surface.

15 MR. PANSELL: Yes. Oh, yes.

16 MEMBER RYAN: So, you can end up with a
17 saturated water condition no matter how hard you
18 pump.

19 MR. PANSELL: Oh, yes.

20 MEMBER RYAN: So is the alternative some
21 kind of waterproof cabling?

22 MR. GARDES: Jim can correct me if I'm
23 wrong, but I believe the actual mitigation used for
24 the underground duct banks again would be COLA-
25 specific, site-specific, because you know, there

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 would be existing plants, you know, most likely at
2 these locations that already have designed in
3 certain features. And when they look at that,
4 they'll have to evaluate for the site location.
5 Some from a generic aspect, it's hard to come up
6 with the solution. And that's a COL item where the
7 COLA applicant will have to come up with the
8 solution that best solves that particular issue.

9 MEMBER RYAN: But the guarantee is not
10 there that you can get the water out.

11 MR. PANSELL: That's right.

12 MEMBER RYAN: That's my only caution.
13 You could end up with a situation where you will be
14 saturated whether you like it or not. And there's
15 been a lot of blame assessed for rainwater running
16 in, and I'm not convinced it's all rainwater running
17 in.

18 MR. PANSELL: Well, the other issue is
19 not just wetting. Our experience has been wetting
20 and drying.

21 MEMBER RYAN: Wetting and drying.

22 MR. PANSELL: Pretty soon the thing
23 breaks down and you got to --

24 MEMBER RYAN: Well, it could be in a
25 circumstance where pumping against the hydraulic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 head of the dry water is bad.

2 MEMBER STETKAR: Mike made a good point.
3 You haven't specified submersible qualified cables
4 for these underground duct banks, have you? They're
5 all just standard cables, is that correct?

6 MR. REDDY: That's correct.

7 MEMBER STETKAR: Okay.

8 MEMBER RYAN: And I do appreciate the
9 COLA comment, that it is very site-specific, but
10 there may be a wider range of options needed to
11 address --

12 MR. PANSELL: Yes, it's a somewhat
13 tricky issue, even the access. Can I actually
14 inspect well enough if I put these --

15 MEMBER RYAN: Right.

16 MR. PANSELL: Can I see what I need to
17 see?

18 MEMBER RYAN: Absolutely.

19 MR. PANSELL: It's an interesting --

20 MEMBER RYAN: And how many inspection
21 ports are you going to have?

22 MR. PANSELL: Yes.

23 MEMBER RYAN: Are they ever hundred feet
24 or every thousand feet?

25 MR. PANSELL: Yes, exactly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: Or how do you line that
2 up?

3 MR. PANNELL: It's an interesting
4 problem.

5 MEMBER RYAN: Yes.

6 MEMBER STETKAR: But the duct bank
7 writing and duck back design is all part of the
8 Certified Design?

9 MR. PANNELL: Correct.

10 MEMBER STETKAR: The COL applicant has
11 no control over the actual physical configuration of
12 the duct banks, unless they want to take an
13 exception to the Certified Design. Is that right?

14 MR. PANNELL: Right. I think that's the
15 case.

16 Anything else, gentlemen?

17 MEMBER RYAN: Thanks, John. Thank you.

18 CHAIRMAN POWERS: You're getting
19 altogether too friendly. There's supposed to be a
20 tension. Lots of happy smiling tension.

21 Sandra?

22 MS. SLOAN: All right. We'll turn to
23 Dr. Zia Salami.

24 If you could just give a little bit of
25 your background?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. SALAMI: Sure. Good morning. My
2 name is Zia Salami. I graduated in 1992, '99 for
3 B.S., M.S., University of Alabama. 1998 --

4 CHAIRMAN POWERS: Actually, you didn't
5 really pick up the accent at all.

6 DR. SALAMI: Everybody telling me that.

7 CHAIRMAN POWERS: I guess that's not
8 required, right?

9 DR. SALAMI: Well, pretty much. But, I
10 had a lot of friends; we were so close. They forget
11 out my accent. They didn't care.

12 But, then moved to North Carolina.
13 Graduated in 1998 University of North Carolina.
14 Since 2000, I've been working with AREVA than 11
15 years. My main responsibility was regarding
16 responsible for electrical calculation and analysis.
17 2004, I got responsibility going to -- '03 for
18 responsible for electrical design, model development
19 and calculation. I was leading their electrical
20 distribution system model development and all the
21 calculation. Came back 2006, two years experience.
22 And since then joined U.S. EPR supporting EPR and
23 leading again in electrical calculation analysis and
24 model development for U.S. EPR and also all the
25 COLAs and later on.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I have a brief presentation regarding
2 model development and electrical calculation and
3 analysis and the approach. Then we're going to look
4 at the system evaluation and the result, and finally
5 the conclusion.

6 The main objective of our task, our
7 team, was to make sure that what George mention
8 regarding the electrical distribution system can be
9 designed, is adequate and it can perform its
10 function during the worst case scenario, worst case
11 loading scenario, worst case configuration, either
12 the power is fed from on-site or off-site, with
13 worst case condition of the voltage and the grid
14 condition. In order to achieve these objective, we
15 have several design criteria, or I'll call it index.
16 To me, if you could able to achieve those objective,
17 therefore you could claim that electrical
18 distribution system is adequate and can perform its
19 function either safety or non-safety.

20 I have a few items listed here. That's
21 the major item that to me that needs to be achieved
22 for electrical distribution system. Make sure the
23 continuous and short-time loading, make sure occur,
24 make sure circuit capability are met. To make sure
25 that we have voltage acceptance criteria, acceptance

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 voltage current and power flow throughout the system
2 and to make sure that we're able to provide this
3 equipment base on the standard and availability. I
4 have a few example on this item later on during my
5 presentation.

6 CHAIRMAN POWERS: Help me understand.
7 When you say "model," you're setting up a
8 mathematical model of this system?

9 DR. SALAMI: That is correct.
10 Simulation model which have all the components in
11 the electrical distribution system.

12 DR. SALAMI: Molded in a steady-state-
13 kind of fashion?

14 DR. SALAMI: Yes, sir, that is correct,
15 sir. In a steady state condition --

16 CHAIRMAN POWERS: You're really not
17 solving differential equations here?

18 DR. SALAMI: Correct, sir. Static
19 analysis, or as you mention, a steady state, because
20 during the early phase of the project, providing the
21 dynamic model would be not wise because the
22 parameters are so sensitive and the result would not
23 be any good. Therefore --

24 CHAIRMAN POWERS: Yes, I was just trying
25 to understand.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DR. SALAMI: Sure.

2 CHAIRMAN POWERS: In no way a criticism,
3 because I'm --

4 DR. SALAMI: Sure. Sure. I will get --

5 CHAIRMAN POWERS: -- going to come down
6 to the heart my question here in a second.

7 DR. SALAMI: I will get to -- I have a
8 few slides on the electrical distribution system
9 model development and I'll show you later on.

10 CHAIRMAN POWERS: Now, you're going to
11 introduce into this steady state model a disruption?

12 DR. SALAMI: That is correct, sir.

13 CHAIRMAN POWERS: How do you do that?

14 DR. SALAMI: In order to create the
15 model, therefore, if you go to the next slide, that
16 is the steps that we're going through to provide and
17 to achieve model development. I'm going through one
18 step at a time and I hope I can answer your question
19 during my next few slides.

20 The next step that we had to do is
21 selecting a software that can be using a simulation
22 and can be done for electrical analysis. AREVA
23 adapted ETAP as a major software to do perform its
24 study during the -- not only for U.S. EPR, also for
25 operating unit for at this point. ETAP is V&V

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 software base on the QA requirement and standard.
2 And at this point, base on their Web site, 90
3 percent of nuclear power utilities are utilizing
4 this software to perform their analysis and
5 calculations.

6 The next step was to define and assume
7 conservative and bounding assumption and
8 methodology. I have one sample example later on in
9 my slide.

10 Then create the model and imprint the
11 data, because again, data is also the major part of
12 the model development and the data for the models
13 for the cables, transformers, buses, switchyard
14 circuit breakers.

15 Next step would be after creating the
16 model, creating the configuration, because the power
17 may be fed, as George mentioned, from the outside
18 switchyard. The power may be fed from the emergency
19 diesel generator, or maybe SBO. You have to analyze
20 each alignment or configuration to make sure during
21 that alignment and configuration the system and
22 component can do their function. I'll show you a
23 few configuration in next slide on my presentation.
24 Also, power can be from the DC battery source.

25 CHAIRMAN POWERS: Let's go back to your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 data.

2 DR. SALAMI: Yes, sir.

3 CHAIRMAN POWERS: You made a truism.
4 You've got to put in and describe the components in
5 ETAP.

6 DR. SALAMI: That is correct, sir. You
7 have to put the data in component of ETAP?

8 CHAIRMAN POWERS: How do you do that?
9 You haven't built the plant yet.

10 DR. SALAMI: In order to do that, for
11 example, as I mention in found conservative and
12 bounding modeling approach and philosophy, you have
13 to assume in case you don't have a typical data,
14 first you have to use a typical data. If is not
15 available, is it plant data? And if it not
16 available, you have to assume some conservative
17 parameters. For example, or in some case we used
18 ETAP library, because the library is a conservative
19 number and is check base on the manufactured data.
20 Therefore, we have a document; we call it ETAP Rule
21 Development. In that document, we define each
22 component, where the data coming from. For example,
23 where the data from the model is coming from. What
24 is the, for example, local current would be the
25 conservative local current to use for medium-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 voltage? What is the power fact efficiency, the
2 conservative number would be used for the model and
3 so on? Static load. What would be the conservative
4 power factor that you have to use for the static
5 load? For the cable, what would be the length or
6 the impedance or the size that you have to?

7 Therefore, we define all the equipment
8 parameters that later on that you will see in the
9 model. In ETAP Model Development and Rule Book, we
10 call it, and define where the data coming from.
11 Typically, if we have base on the -- sometimes the
12 data coming from the industrial data, or from
13 experience or, I mean, from other plant data.
14 Therefore, we collected all the data with
15 corresponding references documented in our rule
16 book. When we get --

17 CHAIRMAN POWERS: Well, I guess I'm a
18 little puzzled. Suppose I go through this and I
19 take conservative on everything. Do I end up with a
20 conservative model?

21 DR. SALAMI: Exactly, sir. For example,
22 I have one example in the following slide and show
23 you one of the way of modeling methodology and
24 assumption that we made and why that causes the
25 model to be conservative. Again, I can go through

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all the element and component and describe what we
2 use for to complete model to be a conservative
3 model.

4 For example, let me just give you a few
5 now. On the grid voltage variation, we assuming
6 plus/minus 10 percent on the grid voltage variation.
7 Typical grid voltage variation in U.S., I cannot see
8 more than -- well, I cannot say 100 percent, but
9 pretty much plus/minus five percent. Therefore, we
10 assuming that range of variation to make sure that
11 we are cover the entire electrical distribution
12 system within that. On the transformer impedance,
13 for example, we using the conservative percent
14 tolerance for each component. For the cable length,
15 we assuming plus/minus some percentage for the error
16 and the conservatism. For a motor, for example, we
17 using the worst case local current to make sure when
18 we start the component, when we start the motor we
19 have a largest local current that cause that worst
20 case voltage to get throughout the system.

21 Therefore, and one sample example in
22 this one that I'm going to through that, why the
23 model is conservative. This is just a small test, a
24 few buses system and trying to show you how we model
25 the electrical distribution system in medium-voltage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and the low-voltage. Throughout the model
2 development, we model entire medium-voltage load
3 regardless it's a safety or non-safety, including
4 again, the worst case parameters for which that
5 component. For the LV system, as we know that the
6 worst case and the weakest link in each plant is a
7 component down connected to MCC, or a small load
8 connected to low-voltage system MCC or load center.
9 One of the approach that we selected here to make
10 sure that low-voltage system is conservative and
11 bounded I'm going to discuss.

12 In addition to this description, I need
13 to mention that we have a load list contain 5,000
14 elements of the load, probably 85 percent low-
15 voltage, 15 percent medium-voltage. Therefore, 15
16 percent medium-voltage was model for entire -- this
17 is a cycle I got 6.9 kV system, 480-volt load
18 center, 480-volt MCC, just a portion of this, our
19 electrical distribution system. We have 5,000
20 component in the load list. If the load list -- for
21 example, in this MCC1 and MCC2, we took approach, we
22 call it equivalent modeling. We assume all the load
23 connected through this MCC and add 10 percent
24 addition to that, and we model it as equivalent load
25 for the other MCC. The same for the load center.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Then we went through process of
2 selecting the transformer. We add additional 10
3 percent to total connect the load and select a
4 transformer base on this standard. When you select
5 the transformer base on this standard, typically you
6 get more than 10 percent margin. Because, for
7 example, if you have 1,000 kVA load, the next
8 available transformer size is 1,500. Therefore, we
9 had to force selecting that 1,500 kVA transformer.

10 Now, what we have done, we add
11 additional load beside what we have in the load,
12 least on the top of 10 percent, to make the total
13 connected load from LV system to be equal of the
14 transformer kVA. What we have done, we force 400
15 kVA load in addition to what we had to make sure the
16 low-voltage system here equal to transformer kVA.

17 Now, what this gives you: More power,
18 more loading the system, of course more voltage
19 drop. Since we model all the load as I mention as a
20 motor load, that motor contribution short circuit
21 throughout the system and also the power flow and
22 the current going through steady state current and
23 power flow going through the system for selecting of
24 the circuit breaker, bus rating, so on, with all the
25 maximize, as I mention.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 This is one of the assumption and
2 conservatism that we took to model the LV system.
3 Just show you one example. Again, we have document
4 all this assumption and conservatism and bounding
5 condition in our ETAP rule.

6 Here is ETAP model development for
7 electrical distribution system for U.S. EPR. As I
8 mention, we model all the load on the LV system and
9 the low-voltage we went using the equivalent
10 modeling. The red one is the safety system, EAT.
11 There are two transformer connected there. The
12 yellow is NATS supplying power to TI. The color
13 one, the yellow one. Again, as George mention, we
14 try to separate the safety and non-safety system.
15 Because, as you know that the largest load are
16 connected to non-safety system. For example,
17 reactor coolant, RCP, main feed water pump, those
18 are huge. Starting those component wide separate of
19 the way we have will not impact on the safety-
20 related component which are located on division 1,
21 2, 3 and 4.

22 Just a big picture description of what
23 we have here. Thirteen-point-eight from non-safety
24 coming from three NATs supply power to reactor
25 cooler pump in the blue. They are located in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 nuclear island. Here are located on turbine island.
2 Two EDS supplying power to four divisions. One of
3 that also design that we did, that one transformer
4 can handle all, in case of the failure of one
5 transformer can handle all the loads. For example,
6 if you lose one of the transformer due to some
7 internal problem or malfunctioning of the
8 transformer, all the load can be transferred to one
9 transformer.

10 The same here. If you lose on NAT, we
11 designed the system that all the load which supply
12 come from that NAT will transfer to the other two
13 NATs. Therefore, the advantage would be that we
14 would not be down time in case of the transformer
15 failure. Transformer failure, especially the ops
16 transformer failure will happen. Actually, I was
17 reading a few months ago some plant lost one of the
18 aux transformer and it was down for several weeks.

19 Now, in addition we have a cooling tower
20 area that is about 2,000 feet from the turbine
21 island in green, and aux and rad building. As you
22 see here, this is a configuration that the system is
23 power-fed from the switchyard.

24 Next configuration, the first one I just
25 mention, we analyze it for the voltage dip, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 short circuit characteristic and also power flow.
2 The other configuration, as you see here, the system
3 on the safety is fed from the EDG, EDG train one.
4 And this is an example. Supply to its own division
5 and also supply power, as George mention, and Brian,
6 to alternate-fed loads that are located in the
7 division 2. The way we design the system that we
8 connect all the load that needs to be power for the
9 alternate loads in one switch gear. Therefore, the
10 power from here going to the other 6.9 kV and all
11 the loads are here designed to be used for alternate
12 load and to do the function.

13 The next one here, we just have the SBO
14 configuration. Again, we have analyzed the SBO
15 configuration. SBO located here in train one,
16 supply power to division 1 and 2. There are two
17 line here. One goes to division 1. One lines go
18 division 2. Again, we analyze the system to make
19 sure if the power is fed from the SBO. The system
20 can handle and the equipment can perform their
21 function.

22 After creating the configuration, now we
23 have to perform the study and simulation. We have
24 done such as load flow analysis, short circuit,
25 motor is starting and also the equipment sizing.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 After going through the simulation and
2 the study, you have to compare, make sure -- if you
3 remember the objective we establish on the first
4 page, we achieve that. We can say that equipment or
5 within the steady state and short time rating are
6 met. Equipment are within the short circuit
7 capability. The voltage current power flow
8 throughout the system, each configuration are met,
9 meaning within acceptance criteria. Just give you
10 an example what I mean with that. If the medium-
11 voltage is supposed to start at 75 percent at the
12 terminal, therefore we had to make sure in worst
13 case scenario be able to supply the voltage at that
14 terminal 75 percent and of course plus other margin
15 that we have established.

16 Make sure the equipment are available
17 base on the standard and the electrical distribution
18 system can be -- just example for this one, typical
19 15.8 kV switch gear breaker is maximum is 63 kA with
20 170 kA interrupting capability, asymmetrical. If
21 you had designed that, we had more than 63 kA,
22 therefore you cannot find the circuit breaker that
23 achieve your objective. That's why that I mention
24 that we need to make base on the standard and
25 availability, I was referring to that.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We can say base on the result that I
2 provided here and is documented that U.S. EPR are
3 verified to be adequate and acceptable.

4 And the conclusion again that electrical
5 distribution system adequately supports the supply
6 equipment to perform its function. Again, can be
7 safety or non-safety function. And it does.

8 That had just a short presentation or
9 combining just a few year's work on this area for
10 U.S. EPR. We'd be happy to answer any question.
11 And if I could, if I answer your question when you
12 ask me, please?

13 CHAIRMAN POWERS: Well, I guess my
14 principle question may turn to the staff. Is this
15 model actually used in the safety analysis? I mean,
16 most of the things you spoke of, if I were a
17 customer and buying one of these, I'd want to --
18 you'd be here for days.

19 DR. SALAMI: Sure.

20 CHAIRMAN POWERS: But it's not clear to
21 me that this really figures in the safety analysis.

22 MR. TESFAYE: I guess we'll address that
23 when we make our presentation.

24 CHAIRMAN POWERS: Okay.

25 MR. TESFAYE: In the next session. I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 mean, after the break.

2 CHAIRMAN POWERS: Yes.

3 MR. TESFAYE: Would you like a response
4 now?

5 CHAIRMAN POWERS: Well, what I'd like to
6 know is how much torture am I going to put Dr.
7 Salami through here.

8 MR. TESFAYE: Could I --

9 CHAIRMAN POWERS: Because I mean, if
10 you're not using this in any part of the safety
11 analysis, then I'm not going to torture him.

12 DR. SALAMI: Maybe I just can add
13 something which maybe not directly answer your
14 question. Maybe you're thinking about safety
15 evaluation. For example, when we have a alignment
16 from EDG, as you see here, we establish that we able
17 to start the component if the power fed from the
18 EDG. The motor can start under the condition that
19 it's power from the EDG. To me, EDG is a safety
20 function and --

21 CHAIRMAN POWERS: It makes you
22 enormously confident and it makes Sandra enormously
23 confident. The question is, did it make these guys
24 enormously confident?

25 MR. JENKINS: This is Ronaldo Jenkins,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 electrical engineering branch chief. Typically,
2 these kinds of analysis are used to support the
3 design assumptions that are in any kind of
4 electrical equipment because they are intricately
5 tied together. So, if you're doing a very involved
6 analysis to set the set points, that equipment would
7 in fact start and support safety loads. It has to
8 be backed up in most cases by analysis, and that's
9 presumably what they would be using this for. You
10 would also have verification by checking that model
11 with actual voltage measurements.

12 Does that answer your question?

13 CHAIRMAN POWERS: I don't know whether
14 that answers my question, but pretty close I would
15 say.

16 MR. JENKINS: Okay. I think, you know,
17 it depends on how you're using the computer, any
18 computer model for a safety-related application. Do
19 use it just to simply establish what the design --
20 you know, whether the design in fact is adequate, or
21 are you using it on an ongoing basis? And so, the
22 requirements, in terms of the regulatory
23 requirements, are a little bit different. There
24 would have to be some tests to verify that the model
25 in fact that you're using is correct.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: Well, ETAP is a
2 relatively well-known model.

3 MR. JENKINS: Yes, ETAP is widely used
4 throughout the industry. But you still have to look
5 at the assumptions that in fact goes in the model.

6 CHAIRMAN POWERS: Yes, I mean, I think
7 you guys looked at the safety systems outside of the
8 model and they can do anything they what with
9 they're model.

10 MR. JENKINS: Right.

11 CHAIRMAN POWERS: But you still got to
12 have a safety system that works.

13 MR. JENKINS: That's right.

14 MEMBER STETKAR: I would ask you a
15 couple of questions. Have you used the model to
16 look at breaker setpoint coordination, low voltage
17 up to high voltage, throw a bolted fault to ground
18 for example, on a low-voltage motor control center
19 and make sure that the feeder breaker to that motor
20 control center opens before the feeder breaker to
21 the 6.9 kV bus and so forth?

22 DR. SALAMI: As a quick answer to your
23 question, no, sir.

24 MEMBER STETKAR: You have not?

25 DR. SALAMI: No. And the main reason is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that we have done the fault analysis and to make
2 sure selecting the circuit breaker and circuit
3 breaker sizing, for example. What size we need
4 interrupting, the asymmetrical or symmetrical
5 interrupting. In order to do the prediction and
6 coordination which I exactly know what you're
7 referring to, we need to procure the equipment. We
8 need to get the time current characteristic curve.
9 And then we need to have a component that we know
10 how that component operates and where is the
11 setpoint, how we can set it to. Therefore, that
12 would be a next step during the detail design phase
13 that after we procure the equipment and providing
14 and the manufacture provide us with equipment,
15 including the time current characteristic. We going
16 through that process that to make sure the feeder
17 breaker will trip before the incoming break here.
18 Or if need any setpoint to be adjusted in case of,
19 for example, power circuit breaker, you need to make
20 some adjustment. If you need to make -- what type
21 of power circuit breaker you need to set it. Or on
22 the medium-voltage relay, what to be set.
23 Therefore, that is the process.

24 MEMBER STETKAR: Is that then COL scope
25 of work?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. REDDY: Yes, the analyses that Dr.
2 Salami are talking about, those would be used to
3 support and help close out the ITAAC that's
4 associated with the protection of coordination
5 aspect of the ITAAC.

6 MEMBER STETKAR: Understand.

7 CHAIRMAN POWERS: It sounds like this
8 all moves to ITAAC.

9 MEMBER STETKAR: Yes, it is. I was just
10 curious how much they've done, you know, in terms of
11 -- you can specify certain things, you know, from
12 the design side.

13 In the FSAR it mentions that you've also
14 used ETAP to evaluate the DC system. Is that
15 correct? You focused totally on the AC system
16 here --

17 DR. SALAMI: Right.

18 MEMBER STETKAR: -- which is interesting
19 to a lot of people.

20 DR. SALAMI: Sure. Is more colorful
21 picture.

22 MEMBER STETKAR: It is.

23 DR. SALAMI: And the DC, you only have
24 one bus supply, a few buses. Yes, we have done that
25 on the safety two hours UPS system. We model the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 battery coming from the invert -- to inverter, then
2 the loads. And we have done the short circuit and
3 the load flow. That is correct.

4 MEMBER STETKAR: Do you have a model for
5 the 12-hour --

6 DR. SALAMI: For two hours.

7 MEMBER STETKAR: But not the 12-hour
8 station blackout coping batteries?

9 DR. SALAMI: For the 12-hours, during
10 the detail, no, we don't have that.

11 MEMBER STETKAR: Okay. Now that you
12 have the models built, can they be used to also
13 evaluate DC breaker coordination?

14 DR. SALAMI: Correct. When we create
15 the DC model, that would be again, the next would be
16 populating the circuit breaker or adding the relay
17 to the -- at this point, we don't have any relay
18 connected to our system, because as I mention why we
19 don't have it. The next would be adding the relay.
20 You're adding the protective device setpoint, the
21 type, the manufacturer and into your model,
22 including the DC. And then --

23 MEMBER STETKAR: And DC, it's in many
24 cases fuses and rather simple circuit breakers. So
25 there is less manufacturer-specific deviations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You've not specified those ratings or anything yet?

2 DR. SALAMI: Well, we have specified the
3 breaker sizing. But as far as the type of
4 variation, for example, as you mention, at this
5 point, no.

6 MEMBER STETKAR: No? Okay. Thank you.

7 DR. SALAMI: Sure.

8 CHAIRMAN POWERS: Any other questions?

9 MEMBER STETKAR: No.

10 CHAIRMAN POWERS: Anything else you want
11 to tell us?

12 MS. SLOAN: No, we're done.

13 DR. SALAMI: Thank you so much.

14 CHAIRMAN POWERS: Okay. We are going to
15 recess until 10:45.

16 (Whereupon, at 10:08 a.m. off the record
17 until 10:45 a.m.)

18 CHAIRMAN POWERS: Let's go back into
19 session. What do you think about all this stuff?

20 MR. TESFAYE: I like it.

21 CHAIRMAN POWERS: Now, before you say
22 that, remember the Subcommittee chairman is color
23 blind, so all those color plats they have put up
24 there have made no sense to him whatsoever.

25 MR. TESFAYE: I'll try something else

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 next time.

2 CHAIRMAN POWERS: Okay.

3 MR. TESFAYE: Thank you. I guess in
4 this portion of this morning's presentation the
5 staff will discuss its finding.

6 One thing I'd like to point out, the
7 title here on the first slide is correct. There are
8 no open items in this chapter. So the agenda is
9 kind of misleading. It says SER with open items.
10 We don't have any open items.

11 CHAIRMAN POWERS: It was written a long
12 time ago. It is to give you an out. If you came in
13 here and it said Chapter with no open items and you
14 had one, you'd get castigated. This way you had the
15 option.

16 MR. TESFAYE: All right. Thank you.

17 CHAIRMAN POWERS: Besides, we need to
18 create a little excitement in Sandra's life every
19 once in awhile.

20 MS. SLOAN: They make plenty of
21 excitement in my life.

22 MR. TESFAYE: I'll ask Jim Steckel who's
23 the chapter PO for Chapter 8, and Peter Kang, the
24 technical reviewer to make this portion of the
25 presentation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Jim, please?

2 MR. STECKEL: All right. Thank you very
3 much.

4 Yes, I'm Jim Steckel. This is my first
5 time here, so I'll give you some background.

6 CHAIRMAN POWERS: Oh, please do, Jim.

7 MR. STECKEL: Not long after college I
8 started out being hired by a consulting firm to do
9 site characterization work. And I had done that for
10 several years, particularly a couple of years pre-
11 construction to the Savannah River site. But I've
12 worked on many of the sites around the Eastern
13 United States and the Midwest Quad Cities, Toledo
14 Edison at Perry and several others. I've been
15 project manager on several projects now and three-
16 and-a-half years with the NRC.

17 I have a graduate degree in management.
18 And I started out at NRC in the planning and
19 scheduling branch, but about a year ago was able to
20 get into this licensing branch.

21 CHAIRMAN POWERS: How do you like it?

22 MR. STECKEL: It's been quite
23 interesting and --

24 CHAIRMAN POWERS: It's fun, isn't it?

25 MR. STECKEL: It's maddeningly

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 enjoyable.

2 CHAIRMAN POWERS: I didn't say it was
3 easy; I said it was fun.

4 MR. STECKEL: I'll introduce Peter in
5 just a moment, our technical reviewer. But here is
6 a breakdown of our RAIs, the number of questions, I
7 should say, of the RAIs and the number of open
8 questions. We were able to satisfactorily close all
9 of our questions as we've gone through.

10 And we do have some technical topics of
11 interest we'd like to go through to everyone. And
12 to do that would be our technical reviewer, Mr.
13 Peter Kang.

14 MR. KANG: My name is Peter Kang. Good
15 morning. And I have been with the Agency since
16 1982. Mostly spend the time at the electric
17 engineering branch and the license renewal branch,
18 and as well as Office of Research. And also I spend
19 some time in the Federal Energy Regulatory
20 Commission Office of Power Regulation and the
21 Department of Energy working on Strategic Petroleum
22 Reserve or bringing in a power line to middle of
23 nowhere and the buying of equipment for pumping the
24 oil underground facilities. And also I worked in
25 the REA. Nobody remembers what is REA anymore, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Rural Electrification Administration, which
2 supply power to rural areas. And I start my career
3 with a local utility company as a PGM representative
4 and I work with the interconnection related work.

5 The first technical topics of interest
6 is on inaccessible power cable installed in a duct
7 bank and underground, the ones we discussed this
8 morning. And basically in RAI we asked -- first of
9 all, this should be a COL item. It wasn't listed as
10 a COL item at the beginning, so we said that it has
11 to be a COL item and also it should ask the
12 developing site-specific testing programs for per
13 Generic Letter 2007-01 for inaccessible power cables
14 installed in a duct bank and underground. This
15 Generic Letter was resulted from cable failure data
16 from many years compilation of operation reactor
17 experience.

18 And in response, the applicants agreed
19 that this is a COL item and they added in a COL item
20 list. And also, the applicants is to address the
21 inspection and the testing and the monitoring
22 programs for detection of degraded inaccessible
23 underground power cables. And also revised the FSAR
24 a little bit and it included a potentially
25 acceptable testing method. It listed the partial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 discharge testing and the TDR, and also TDR is the
2 time domain reflectrometry. And also power factor
3 or anticipation factor testing and the very low
4 frequency AC testing.

5 CHAIRMAN POWERS: Those are all pretty
6 classic techniques.

7 MR. KANG: Yes.

8 CHAIRMAN POWERS: How well do they work?

9 MR. KANG: Excuse me?

10 CHAIRMAN POWERS: How well do they work?
11 Do they really get after what you're worried about?

12 MR. KANG: The stuff is -- I don't know,
13 we are worried about it and a COL, it is a site very
14 specific area. And I know some places that they
15 recently start -- they install the solar-powered
16 sump pumps to pretty regularly pump the water out.

17 CHAIRMAN POWERS: Okay.

18 MR. KANG: So it is, in a certain
19 extent, it's a problem area.

20 MEMBER RYAN: One of the things that
21 troubles me is that I haven't heard anybody discuss
22 the length between sumps and whether or not the
23 middle stage is wet or dry. You know, in just a
24 real practical way, groundwater is hard to control
25 east of the Mississippi. And what we might be

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 talking about is groundwater that's relatively close
2 to the surface of run-in and snow melt and all these
3 other things that have been talked about may be
4 secondary groundwater. So, how does that work?

5 MR. KANG: Pretty regularly they have,
6 you know, duct banks which collect water.

7 MEMBER RYAN: Yes.

8 MR. KANG: So, and also gravity designs
9 certain portions when the -- where they're going to
10 install duct bank, they sort of given slope so water
11 can go in the lowest spot.

12 MEMBER RYAN: But those things are
13 design features you never really test or prove once
14 they're installed, do you?

15 MR. KANG: Well, that's correct, yes.

16 MEMBER RYAN: Okay. So the point is, we
17 really don't have any proof what's staying wet and
18 what's not. You know, a sump doesn't necessarily
19 mean the rest of the run of wire is dry. If you
20 pump it out continuously, where are you drying the
21 water from? You know, unless you can demonstrate
22 that, groundwater does funny things.

23 MR. JENKINS: This is Ronaldo Jenkins
24 again. Currently now in the operating reactor arena
25 the staff is looking at improving the inspection

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 program.

2 MEMBER RYAN: Sure.

3 MR. JENKINS: So to have inspectors go
4 and look at the accessible parts of the duct work to
5 check for water, and we currently have a generic
6 issue with industry, NEI, to come to some resolution
7 on this issue, you know, between the NRC and the
8 industry. So, we had a workshop earlier this year
9 looking at different testing methods. And there's
10 really no one method. You can combine methods, but
11 there's not one method that will allow you to
12 assess. And what we're talking about is the long-
13 term degradation of the cables. Historically cables
14 have been very reliable. For us, for the NRC, it's
15 a question of whether or not the cable's qualified
16 for its environment. And that's where the points
17 you raised about how much water are you seeing,
18 whether or not it's submerged versus wetted.

19 MEMBER RYAN: Wetted and then dried,
20 wetted and then dried.

21 MR. JENKINS: Right.

22 MEMBER RYAN: That's probably --

23 MR. JENKINS: Probably one of the worst
24 cases.

25 MEMBER RYAN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. JENKINS: Yes. And so, you know,
2 the staff is pursuing that and probably more
3 vigorously in the operating reactor area. And we're
4 following along with them to, you know, just make
5 sure we're aware of it.

6 MEMBER RYAN: I think the point made
7 earlier, this is really a COLA issue.

8 MR. JENKINS: Yes,, it is.

9 MEMBER RYAN: And that's, you know, down
10 the line some, so the pressure of time is not on
11 this activity here today.

12 MR. JENKINS: Right.

13 MEMBER RYAN: But it sure is an issue.
14 And, I mean, you could make an argument I'm sure on
15 some geohydrologic environments that not pumping at
16 all is the best answer and keeping it wet. I'm
17 going to guess that's probably true at least once.

18 MR. JENKINS: Yes. Well, we've also
19 seen evidence where, you know, there's a lot of
20 damage that has been caused by --

21 MEMBER RYAN: Yes, and then of course
22 you get into, you know, which cable, when was it
23 installed, what's the vintage and all those kind of
24 things. It's a tough problem, I appreciate that.

25 MR. JENKINS: Right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER RYAN: And I do appreciate the
2 fact the operating folks and the staff in those
3 areas are working vigorously on it as well.

4 MR. JENKINS: Yes.

5 MEMBER RYAN: And hopefully all that
6 will be cleared up and readily available for you to
7 make decisions at the COLA stage.

8 MR. JENKINS: Right. And for this
9 particular application what we want to make sure is
10 that the issue is going to be addressed by the COLA
11 applicant, and that's the main thing.

12 MEMBER RYAN: My only caution is that I
13 don't think it's fair at this stage to say that just
14 having sumps in a design is going to solve the
15 problem. That may or may not solve the problem
16 based on where you are, what the geohydrologic
17 horizon looks like. Out West, no problem at all;
18 Everything's fine. But east of the Mississippi it
19 can get tough.

20 CHAIRMAN POWERS: True of so many
21 things.

22 MEMBER RYAN: Said from a guy from
23 Albuquerque.

24 CHAIRMAN POWERS: Please go ahead,
25 Peter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KANG: Next technical topics of
2 interest is on the on-site power system. And this
3 is a alternate feed configurations. And AREVA's
4 presentation has it covered pretty much, why and the
5 how it is designed to supporting on-line
6 maintenance, and they also discussed its associated
7 tech specs. And in our -- the ultimate
8 configuration installed, the staff asked in RAI, how
9 do you meet divisional independence and satisfy
10 single failures and the risk insights? And also
11 pointed out the tech spec provisions that allows the
12 plants to operate for 120 days.

13 The response was staff received the same
14 presentations what we seeing today. And also, we
15 did have a meeting and sort of a meeting and that
16 they had came in and presented how divisional
17 independence and the single failures. They
18 explained it and also demonstrated no single failure
19 vulnerability existed on the various alternate-feed
20 scenarios. And basically, in conclusion, the
21 alternate feed configuration represents no
22 significant change in risk. And also, the line up
23 does not introduce any new safety concerns.

24 MEMBER STETKAR: Peter?

25 MR. KANG: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: A couple of questions.

2 MR. KANG: Yes.

3 MEMBER STETKAR: And I'll ask you the
4 same question that I don't think I got an answer
5 from AREVA. You mentioned several times in your
6 discussion that you're satisfied that the design
7 maintains divisional independence. I don't
8 necessarily understand how that divisional
9 independence is maintained if during the alternate
10 feed configuration one division is talking to
11 another division in terms of control signals to
12 operate circuit breakers. And I guess I'll ask you
13 how do you resolve that apparent inter-divisional
14 communications? Or is that your job because that's
15 an I&C issue and therefore it's not electrical?

16 MR. KANG: Okay. First of all, on the
17 what-do-call, the divisional concept -- in other
18 words, even though this is a four-division system,
19 actually if you look at the really close, it is two-
20 divisional. One and two is considered as one
21 division and the three and four is one division, but
22 all practical purpose for they were using as a
23 fourth divisional concept. Like what you said, if
24 you use alternate feed connections, it immediately
25 return to two-divisional concept.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: So your determination
2 is based on the concept that it's fundamentally a
3 two-division plant rather than a four-division
4 plant?

5 MR. KANG: Well, a two-divisional plant
6 with a lot of excess capacity.

7 MEMBER STETKAR: Okay.

8 MR. KANG: It's 400 percent capacity.

9 MEMBER STETKAR: Okay.

10 MR. KANG: That gives -- in a way give
11 them some comfort. In the past, we have some
12 concerns about the emergency generator capacities.

13 MEMBER STETKAR: Yes.

14 MR. KANG: And over the years that the
15 load has been grown to beyond -- close to the engine
16 capacity. And so in a way it gives some comfort
17 with that point.

18 MEMBER STETKAR: At some margin, if you
19 will.

20 MR. KANG: Yes.

21 MEMBER STETKAR: But your final
22 determination, if I understand it correctly, is that
23 if you treat the plant as a two-division plant --

24 MR. KANG: Two-divisional system, yes.

25 MEMBER STETKAR: -- it still satisfies

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the single failure criterion for a failure in one of
2 those two divisions?

3 MR. KANG: Yes.

4 MEMBER STETKAR: Good. Thanks. That
5 helps a bit.

6 The second question is, the second
7 bullet under the response that says, "Stated there's
8 no significant change in risk." When I asked AREVA
9 whether they'd used the risk assessment, for
10 example, to evaluate the 120-day LCO time limit for
11 the diesel generator, I think said no they hadn't
12 used the risk assessment.

13 MR. KANG: Okay.

14 MEMBER STETKAR: It's I guess
15 interesting. Did they provide differences in the
16 actual risk assessment results or design that had
17 the alternate feed configuration and a design that
18 did not have the alternate feed configuration to
19 show what the actual difference in risk is? This,
20 as I understand it, that bullet says there is no
21 significant change in risk, I'm assuming, from the
22 alternate feed configuration --

23 MR. KANG: Yes, sir.

24 MEMBER STETKAR: -- compared to a --

25 MR. KANG: Four-division.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: -- four-division?

2 MR. KANG: Yes, four-division. And the
3 staff asked these questions in one of RAIs, and what
4 is the risk increase to these configurations. But
5 they were saying it is negligible, less than a
6 percent. Okay? So, the way I understand is if the
7 risk is less than a percent, you don't have to
8 perform the evaluations.

9 MEMBER STETKAR: I guess --

10 MR. KANG: That's --

11 MEMBER STETKAR: -- that's. I don't
12 want to quibble over numbers. I was curious what
13 assumptions were built into that differential
14 calculation in risk, because it could be very
15 strongly influenced by the assumed fraction of time
16 that you remain in that alternate line up
17 configuration. If in the fact the plant does a
18 rolling preventative maintenance outage schedule and
19 you have one diesel out for two to four weeks a year
20 per diesel, you could be as much as two to four
21 months out of the year that you're actually in that
22 particular configuration, which is a fairly large
23 fraction of the time. I have no idea whether those
24 are reasonable numbers.

25 MR. KANG: Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: But it would be
2 interesting to look at the basis for their assertion
3 that the change in risk is very small.

4 MR. KANG: Two response. And the first
5 one was just what I ask was under these
6 configurations what kind of a risk was represented.
7 But that's probably what they came in with a
8 negligible, because one less than a percent. But in
9 the long-term, risk, what you refer to, is the staff
10 has not articulated. But on the other hand, we do
11 ask that staff would express the concern. This is
12 120 days too long and ask for the justifications.
13 And they did provide that this is came from the reg
14 guide. And also, if you have a better
15 configurations then two-divisional concept that you
16 could have a linear or more LCO time. But, it was
17 not really -- this number what I have here is
18 probably just a snapshot of the configuration risk.

19 MR. TESFAYE: This is Getachew Tesfaye
20 again. Would it be appropriate to discuss this when
21 we do PRA in Chapter 19?

22 MEMBER STETKAR: Well, I'll certainly
23 make a note to do that.

24 MR. TESFAYE: Okay.

25 MEMBER STETKAR: But again, in the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 vein as asking questions about the I&C, I don't like
2 to get trapped into a box where we're examining
3 small square bits and pieces of the design out of
4 the context of the entire story about --

5 CHAIRMAN POWERS: I don't see how the
6 question is going to change.

7 MEMBER STETKAR: The question won't
8 change.

9 CHAIRMAN POWERS: I mean, if we move to
10 Chapter 19 discussion, how is the question going to
11 be any different?

12 MR. JENKINS: This is Ronaldo Jenkins.
13 We asked the question primarily because we wanted to
14 ascertain from a deterministic point of view would
15 this alternate configuration result in a loss of its
16 ability to withstand a single failure. Okay? And,
17 I mean, AREVA, I think, in the phone conversation
18 was very clear that they were not doing a risk-
19 informed-type of analysis to make that determination
20 of, you know, no significant risk.

21 So, when you're looking at this 120
22 days, it actually really bothers me, because when
23 you're comparing what the staff does in risk-
24 informed space with technical specifications and
25 what we do from a deterministic point of view, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 main difference is there's a configuration control
2 aspect to risk-informed, you know, approvals. And
3 which we allow the maintenance, on-line maintenance
4 because you have configuration control, you have
5 maintaining defense in depth, meet the regulations
6 and you have a low risk.

7 So, in comparing those two, we said,
8 okay, what they have in their design is equivalent
9 to a spare, you know, and they're using the
10 alternate configuration in fact to accomplish that.
11 Now, some plants do have, like for battery systems,
12 a totally separate spare, you know, component that
13 they can bring in and out, do the maintenance on the
14 equipment that's on line. And they chose not to do
15 that. So, that's neither here nor there.

16 MEMBER STETKAR: I think, you know, from
17 my perspective, what Peter said earlier helped an
18 awful lot. In the deterministic sense of the
19 conclusions, that if you think of the plant in a
20 deterministic sense --

21 MR. JENKINS: And that's what we were --

22 MEMBER STETKAR: -- as basically a two-
23 train plant --

24 MR. JENKINS: Right.

25 MEMBER STETKAR: -- and evaluate whether

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it can accept the single failure criterion, I can
2 see how that determination is made. Because the
3 bullet is now up on the slide here about significant
4 change in risk, I'm trying to probe whether the
5 conclusion was at all influenced by that. And if
6 the answer is yes it was influenced, I'm really
7 curious about how that evaluation was performed to
8 confirm that there's no significant change in risk.

9 If your evaluation wasn't based at all
10 on any risk information or --

11 MR. JENKINS: It wasn't based on any
12 risk information.

13 MEMBER STETKAR: -- then I don't care;
14 they're just numbers.

15 MR. JENKINS: Right.

16 MEMBER STETKAR: Okay.

17 MR. JENKINS: The other aspect is that
18 this would be something that would fall into
19 technical specifications, you know, and that's an
20 area that we're going to pursue, this 120 days in
21 tech spec.

22 MEMBER STETKAR: In tech specs?

23 MR. JENKINS: Yes.

24 MEMBER STETKAR: Okay. Thanks.

25 MS. SLOAN: If I can add just one

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 clarification. I think we're very careful in how we
2 use the terms "risk-informed" versus "use of risk
3 insights." And I think I want to go back to the
4 question you asked earlier during our presentation,
5 because I think that's where some of this confusion
6 is coming up. Because the way the question was
7 phrased earlier was, is this risk-informed? And I
8 think we're very careful to say our design basis is
9 deterministic. But, I also want to point out that
10 we do and have used PRA for insights. And I think
11 that's part of the distinction we're all trying to
12 make here.

13 MEMBER STETKAR: I understand that from
14 your perspective. I'm asking the staff how much
15 those PRA insight arguments affected their overall
16 conclusion regarding the design, their findings in
17 the SER.

18 MR. JENKINS: Not at all.

19 MEMBER STETKAR: Because there's kind of
20 a gray area there.

21 MR. JENKINS: Right.

22 CHAIRMAN POWERS: I mean, I'm taking
23 Peter at his word, that they are looking at a system
24 that they see as a -- what did you call it -- two-
25 train system with a lot of additional capacity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Yes, I like that. I mean, I think that's an
2 excellent insight.

3 MEMBER STETKAR: Yes, that's fine.
4 That's fine. That's fine.

5 CHAIRMAN POWERS: Please go ahead.

6 MR. KANG: Okay. Next technical topics
7 of interest involves Branch Technical Position 8-6.
8 This is something to do with the adequacy of a
9 stationed electric distribution system voltage
10 analysis. And Dr. Salami came up here and provided,
11 went in great detail how they performed the analysis
12 and how the on-site power system is supported by
13 electrical calculations.

14 And so, in this regard, in the RAI staff
15 asked how to protect the safety-related equipment
16 from degraded grid voltage conditions. And it
17 basically requiring all the applicants requiring
18 performing voltage analysis to determine the
19 degraded grid setpoints. And also, in Branch
20 Technical Position 8-6 it requires the voltage
21 analysis you have done is validated by actual bus
22 voltage measurements so to clarify the analysis you
23 performed is in fact valid.

24 Also, finally, in addition staff asked
25 whether the alternate feed configurations. When

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you're in a different alternate feed configurations,
2 do you need the different degraded grid setpoints
3 rather than the ones you already done it. So,
4 basically response said applicants is responsible
5 for -- will preform the site-specific analysis to
6 determine the site-specific degraded grid setpoints
7 based on off-site power system, whether hanging in
8 there, are connected. And also, those setpoints
9 value is in the tech spec. So, and also applicants
10 indicated, stated that they will conduct the
11 verification test during planned initial testing,
12 under initial plan testing program. This is Chapter
13 14.2 sections. And staff has verified that this
14 test No. 161 does verify the measures, the voltages
15 of -- so verifies it.

16 And also, the last question, whether you
17 have a different configurations, whether do you
18 really need the different setup of degraded
19 setpoints. The answer was no. And their evaluation
20 has shown you don't need the change every time you
21 go to different configurations.

22 CHAIRMAN POWERS: I get the impression
23 that the applicant here has created this modeling
24 capability to say yes this electrical system can in
25 fact be constructed, get some idea of what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 components in the system will look like.

2 MR. KANG: Yes.

3 CHAIRMAN POWERS: And they come up with
4 a system for analysis that it says that indeed the
5 COL applicant can in fact do what he will be asked
6 to do.

7 MR. KANG: That's right. Each COL
8 applicant has to have calculation, what we used to
9 call the case base. In other words, the system
10 representations which they have, or they are going
11 to have. And based on that, they performed the load
12 for analysis, show circuit calculations and all that
13 calculations to verify their base is a real value of
14 the case. So, in a fact, that would be used to
15 setting for the degraded grid setpoints, as well as
16 they could use this program to make plan
17 modifications. If you want to add another MCC --

18 CHAIRMAN POWERS: Configure sump pumps
19 for --

20 MR. KANG: Sump pump.

21 CHAIRMAN POWERS: -- Brian happy.
22 You're very hard to please. Did you know that?

23 MR. GARDES: All depends on the --

24 MR. KANG: In the stuff asked, our reg
25 guide requires to perform this various calculation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 So in staff RAI, we asked provide some summary
2 assumptions with what you done, assumptions and a
3 summary of each calculations. And they did provided
4 in the written form, as well as we had a staff met
5 -- what do you call this, audit, performed audit on
6 that, spend a day. And they're looking through
7 those --

8 CHAIRMAN POWERS: Your staff does not
9 have an independent calculational capability for
10 these things?

11 MR. KANG: No. No, we haven't gone that
12 far yet.

13 CHAIRMAN POWERS: I don't know that you
14 need to. I mean, most of this stuff is licensee
15 land. But I was just curious.

16 MR. KANG: But, you know, the
17 verification says, you know, well we measured this
18 analysis versus these measurements. And they came
19 out within --

20 CHAIRMAN POWERS: The proof is the
21 pudding here, yes.

22 MR. KANG: It came in from a long way
23 since 1980s. We used to use a pencil calculations
24 and we are happy with that.

25 CHAIRMAN POWERS: I guess the proof is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the VOM, or something like that, right?

2 MR. KANG: Anymore questions on this?

3 (No audible response.)

4 MR. KANG: Okay. Next technical topics
5 of interest is on sizing of the station blackout
6 diesel generators. And in RAI, staff asked -- we
7 brought -- the SECY-91-078 recommends that the new
8 reactor meets EPRI utility requirement document
9 recommendations. And that recommend had the large
10 combustion turbine is used as a AAC power source and
11 it should be capable of powering at least one
12 complete set of load to cause shutdown. Okay. So,
13 I said, hey, this is what SECY says. And we asked
14 this question and in response applicants stated
15 they're installing two 3,900 kW station blackout
16 diesels who would be used AAC power source for U.S.
17 EPR design. And they clarified a cold shutdown is
18 not required under --

19 CHAIRMAN POWERS: That's the one I don't
20 understand. I don't understand --

21 MR. KANG: A cold shutdown is not
22 required on the current NCFE of 56 degree. And so
23 the U.S. EPR plan is only designed for to go hot
24 shutdown and the standby during the coping period.

25 CHAIRMAN POWERS: Well, if I go to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 appendix R, and I think cold shutdown is required
2 there, isn't it?

3 MR. KANG: Well, we did look at the
4 appendix R review as well as the reason they ask for
5 large AAC power source at the combustion turbine.
6 This is U.S. ABWR. They were putting 20 megawatt.
7 In other words, essentially what they doing is they
8 are replacing all non-class 1 be able to power non-
9 class 1E system. But in this case is considering
10 for emergency diesel generators, as well as a off-
11 site power system. And the current regulation is on
12 the 10 C.F.R. 53. That's what they want to stick
13 to. So, that's where we resolved the issues and the
14 staff had no further questions.

15 MR. JENKINS: And to answer your
16 question, that's correct. Appendix R requires that
17 the equipment be -- bring the plant to cold
18 shutdown. That's my understanding.

19 CHAIRMAN POWERS: One of the ways to get
20 into a station blackout is to have a fire.

21 MR. JENKINS: Yes, there's a couple ways
22 to get there.

23 CHAIRMAN POWERS: Yes. So I don't quite
24 understand that one.

25 Sandra, can you explain to us a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 bit?

2 MS. SLOAN: I can explain that the
3 design basis of the plant is consistent with all
4 operating plants, which is consistent with the
5 station blackout rule, which explicitly talks about
6 powering the plant down to hot shutdown loads. And
7 I'm going to look at our technical staff and see if
8 they want to add more.

9 MR. GARDES: I'm going to try do the
10 limits of my knowledge, but I believe appendix R,
11 you know, post-fire safe shutdown you can still
12 credit the emergency diesel generators and that you
13 will have, you know, a divisional train protected.
14 But in station blackout beyond design basis, you
15 can't credit the EDG. So for sure in appendix R
16 with the EDG capacity capability, you can go to cold
17 shutdown --

18 CHAIRMAN POWERS: You are right.

19 MR. GARDES: Okay.

20 CHAIRMAN POWERS: You are 100 percent
21 right. There's a protected train in appendix R, and
22 here there is not. That's the difference.

23 MR. GARDES: Right.

24 CHAIRMAN POWERS: Now, the fact that we
25 can get into a station blackout -- a fire. Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Good enough. I understand now. Thank you.

2 MR. GARDES: You're welcome.

3 MEMBER STETKAR: Peter?

4 MR. KANG: Yes?

5 MEMBER STETKAR: The last couple of
6 slides are sort of close-out slides, right? Let me
7 bring you back to the station blackout diesels. The
8 station blackout diesels are started automatically,
9 but all loads are placed on those diesels manually,
10 is that correct?

11 MR. KANG: Manually, yes, within 10
12 minutes. Yes.

13 MEMBER STETKAR: Now, that's the
14 question that I had. Within 10 minutes --

15 MR. KANG: Right.

16 MEMBER STETKAR: -- what type of
17 evaluation was done to show that indeed those
18 diesels can be connected to all of the required
19 buses and the loads can be started and connected
20 within 10 minutes?

21 MR. KANG: Okay. That is the ITAAC.
22 When during ITAAC time they were supposed to verify
23 this stuff, within 10 minutes that they can start
24 and be able to connect the load.

25 MEMBER STETKAR: I guess my curiosity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is, we have a lot of discussions in the digital
2 instrumentation and control system area with
3 determining whether the design for diverse actuation
4 systems need to be automatic or can they be manual.
5 In other words, can an operator manually start
6 equipment from the diverse actuation panel or must
7 those start signals be automatic considering, you
8 know, a common-cause failure of software or
9 something over in the digital I&C platforms?

10 I view this as kind of an analogous
11 situation where we have a station blackout. We've
12 had a loss of off-site power, some failure of the
13 EDGs, and now the station blackout diesels must
14 provide power within some required time frame.
15 There are -- I don't want to use the term
16 "requirements," because they're not requirements.
17 There is Interim Staff Guidance and a NUREG, 1852,
18 that lays out a methodology for evaluating whether
19 or not manual actions are acceptable. And that
20 methodology looks at the available time window and
21 the amount of time that's actually required to
22 perform the actions with some margin.

23 MR. KANG: Okay.

24 MEMBER STETKAR: And those guidelines
25 are used fairly extensively in evaluating diverse

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 actuation systems. I didn't any discussion of that
2 type of analysis for this design. And if you say,
3 well, it's up to the COL applicant to perform that
4 evaluation, suppose he fails? That's a design
5 issue.

6 MR. KANG: I did check with the reactor
7 systems branch folks who are reviewing these issues.
8 And I think very recently they did have an audit on
9 this how long the EPR plant can last without the
10 electrical powers. Is that what time margins do
11 they have? I think they were looking almost over an
12 hour.

13 MEMBER STETKAR: Okay. I'm not arguing
14 with the -- I have to be careful in my words here.
15 I'm not arguing with technical. I'm arguing with
16 the justification that says no analysis is required
17 because it is asserted that the equipment can be
18 repowered within 10 minutes. Ten minutes is not a
19 long time frame if you're talking about closing a
20 couple of sets of series circuit breakers and re-
21 energizing equipment under conditions that you've
22 never seen before.

23 MR. KANG: Yes. And one of SBO rule
24 requires a training and develop of procedures. And
25 they were supposed to -- each COL applicants are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 supposed to go practice or procedures to
2 periodically perform this exercise.

3 MEMBER STETKAR: I guess I feel
4 uncomfortable with someone just stating, well, it
5 shall be done within 10 minutes because we're going
6 to train the operators to do it within 10 minutes
7 without performing any type of reasonable analysis
8 to at least try to demonstrate that, especially when
9 we as an agency in other areas; in particular the
10 digital I&C diverse actuation system area, are
11 spending a lot of effort requiring applicants to
12 demonstrate that capability, to justify whether
13 something needs to be automatically initiated or can
14 it be manually initiated. And here we seem to be
15 just taking an assertion that it can be done in 10
16 minutes and we're going to train the operators to do
17 that and accepting it.

18 MR. KANG: Well, in FSAR they did not
19 provide the scenarios and how the sequence was to be
20 done. So, we have reviewed it and I ran by the
21 active systems and seems like it is a doable. And
22 also in the ITAAC, they are demonstrating it can be
23 done.

24 MEMBER STETKAR: Okay. I guess I can't
25 say anything more. I just feel uncomfortable. A) I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 feel uncomfortable with a 10-minute time frame for
2 all of those actions, given a station blackout and
3 the confusion factors that are going to be inside
4 the main control room when you have something that
5 you never expected would ever occur, simultaneous
6 failure of all of your emergency diesel generators
7 after a loss of off-site power that never happens.
8 So the absolute value is one concern.

9 MR. KANG: But and also --

10 MEMBER STETKAR: But the larger concern
11 is that we apparently are accepting that value prima
12 facie without any supporting analyses on the part of
13 the applicant to confirm that indeed they looked at
14 human-factors-type things and actual realistic time
15 frames with the types of margins that we're
16 requiring for other features of the design approval
17 process. You know, that's just a statement.

18 MR. KANG: Yes.

19 MEMBER STETKAR: I don't think we need
20 to discuss it anymore. I understand what you've
21 said.

22 MR. KANG: Yes, staff findings. And
23 this is --

24 CHAIRMAN POWERS: Please go ahead,
25 Peter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. KANG: And the staff findings and
2 the U.S. EPR FSAR provides, first of all, sufficient
3 informations about off-site power system inter-
4 relationship among nuclear utility, nuclear unit and
5 the utility switchyard, and the interconnection grid
6 -- COL applicants.

7 And next bullet is sufficient
8 information about the on-site power system to
9 mitigate the design basis events and given a loss of
10 off-site power and a single failure in on-site power
11 system.

12 And the last one is necessary analysis
13 has been performed to determine capability to
14 withstand and recover from SBO event of specified
15 eight-hour durations.

16 CHAIRMAN POWERS: Do we have any other
17 questions for Mr. Kang?

18 (No audible response.)

19 CHAIRMAN POWERS: I see no more
20 questions.

21 MR. TESFAYE: That's all we have for
22 Chapter 8.

23 CHAIRMAN POWERS: Do you have a
24 question?

25 MEMBER STETKAR: I do. Does it surprise

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 you? You're shocked.

2 CHAIRMAN POWERS: Well, my question is
3 whether it's pertinent to the discussion.

4 MEMBER STETKAR: Yes.

5 CHAIRMAN POWERS: Oh, okay.

6 MEMBER STETKAR: In my feeble mind it
7 is.

8 For other plant designs that come up
9 before us, there is this concept of RTNSS,
10 regulatory treatment of non-safety systems, for
11 systems that are nominally not safety-related, but
12 important to risk, I guess. We haven't really
13 understood quite what the definition of a RTNSS
14 requirement is.

15 And I guess my question is, does that
16 category of require apply in the EPR design? In
17 other words, are you looking at tech spec-related
18 issues for safety equipment and RTNSS requirements,
19 additional regulatory scrutiny for non-safety
20 equipment, but equipment that's still relatively
21 important to overall plant risk?

22 MR. TESFAYE: No, RTNSS is not
23 considered. The EPR is not a passive system.

24 Joe, maybe you want to add something to
25 this?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. COLACCINO: Yes, hi. My name is
2 Joe --

3 MEMBER STETKAR: That's only for passive
4 plants?

5 MR. COLACCINO: Yes. My name is Joe
6 Colaccino. I'm the chief of the EPR Projects
7 Branch. The RTNSS system, that was first documented
8 in the review of the AP600. And you also see that
9 in the AP1000. It's carried over into the ESBWR.
10 It is strictly for passive safety system plants that
11 are under review with design certification by the
12 NRC. What you have before you in the EPR is an
13 active safety system plant. And so there isn't a
14 question of -- a lot of the systems that are in --
15 that are active safety systems plants are not
16 safety-related in those other designs. And so, the
17 discussions; and there are other people in this room
18 who could probably expand on it, but I'll just keep
19 it really succinct, it's that like, okay, so these
20 systems are not active safety systems, but what are
21 other considerations that could look at to have some
22 treatment of these systems in regulatory space? And
23 so regulatory treatment of non-safety-related
24 systems.

25 There's a really good write-up in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 20, I believe it is, of NUREG-1793. I think
2 that's the AP1000. That's the Rev 15 version. I
3 believe it's Chapter 20. I'm pulling that out of
4 memory right now. But the first several pages of
5 that gives you a discussion of the background
6 associated with RTNSS.

7 CHAIRMAN POWERS: I have to admit I did
8 not know that RTNSS was strictly for passive.

9 MR. COLACCINO: Either did I.

10 CHAIRMAN POWERS: We've been struggling
11 with this --

12 MR. COLACCINO: Dr. Powers, I'm going to
13 take you at your word, sir.

14 CHAIRMAN POWERS: What's that reference?
15 There's a really good write-up?

16 MR. COLACCINO: It's the --

17 CHAIRMAN POWERS: Seventeen-ninety-
18 three.

19 MR. COLACCINO: Yes, it's the AP1000
20 FSAR. And maybe Hanh Phan here from the PRA group
21 maybe give you a little more, if you want it. But
22 that's basically what I've done is the Reader's
23 Digest abridged version for project managers.

24 CHAIRMAN POWERS: They keep giving us --

25 MEMBER STETKAR: If indeed in terms of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the Agency RTNSS applies strictly to passive design;
2 I don't understand why that's the case, but if
3 that's the case, then I understand why it doesn't
4 apply here. I was going to ask, you know, in
5 particular with respect to the station blackout
6 diesels, because in the passive designs the station
7 blackout diesels would be considered a RTNSS piece
8 of equipment. But their analogous equivalent are.

9 MR. COLACCINO: I took the reference
10 from memory. I'm sure Derek can -- I believe it's
11 NUREG-1792 or 1793. We'll get you covered. We'll
12 get you that reference.

13 CHAIRMAN POWERS: That would be useful.
14 That may be helpful in a lot of --

15 MR. COLACCINO: Yes. And I know because
16 I was the project manager that took that and put
17 that in there, and I thought that this was a good
18 place. And it comes from the AP600, and it's
19 something that we needed to preserve as background.
20 And so it goes through the regulatory history of how
21 we got to that point.

22 CHAIRMAN POWERS: Very nice. That would
23 be good. Thank you.

24 MEMBER STETKAR: Now I don't have any
25 more questions. Was it relevant?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: It was extremely
2 useful. Maybe not relevant to EPR, but there are
3 other contexts that this will help.

4 MEMBER STETKAR: So you're happy?

5 CHAIRMAN POWERS: I didn't say that.

6 MEMBER STETKAR: Okay.

7 CHAIRMAN POWERS: We're done?

8 MR. TESFAYE: Yes, sir.

9 CHAIRMAN POWERS: So we'll move onto
10 site characteristics after a midday repast. And
11 after means at 1:30.

12 (Whereupon, the hearing was recessed at
13 11:34 a.m. to reconvene at 1:30 p.m. this same day.)

14

15

16

17

18

19

20

21

22

23

24

25

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 A-F-T-E-R-N-O-O-N S-E-S-S-I-O-N

2 1:30 p.m.

3 CHAIRMAN POWERS: Let's come back into
4 session. We're going to try to avoid the heated
5 controversies that we had earlier today, Sandra, and
6 begin to discuss site characteristics.

7 Do you have any introductory comments to
8 make on this?

9 MR. TESFAYE: No, I don't.

10 CHAIRMAN POWERS: You're going to let
11 this fight out on hit's own, huh?

12 MR. TESFAYE: Yes.

13 CHAIRMAN POWERS: Okay. Sandra, let's
14 talk about sites.

15 MS. SLOAN: Okay. Well, as with the
16 morning --

17 CHAIRMAN POWERS: In Finland.

18 MS. SLOAN: What's that? Oh, no.

19 CHAIRMAN POWERS: The coast of France?

20 MS. SLOAN: Not that it's not a nice
21 site. It's a perfect site. Cold water and hard
22 rock -- site to build a nuclear power plant.

23 CHAIRMAN POWERS: Persistent sea
24 breezes, things like that, and not far from fairly
25 good Italian food, right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. SLOAN: Sure. Okay. So just like
2 in the morning, what we thought we'd do for tier 2,
3 Chapter 2 is in the AREVA presentation give you a
4 summary level overview of the organization of
5 Chapter 2 and the material in Chapter 2. And I also
6 wanted to mention, as with the morning session, we
7 have participants on the phone line right now from a
8 couple of remote AREVA locations. So there may be
9 times when the presenters will call on the
10 supporting staff at the other locations.

11 And so, with that, I asked this time for
12 Todd and Ted to at the very beginning give you a
13 brief introduction of who they are. And then Todd
14 will start the actual presentation.

15 CHAIRMAN POWERS: Good. Good. Welcome
16 to the Committee.

17 MR. OSWALD: All right. Ready to go?

18 CHAIRMAN POWERS: Yes.

19 MR. OSWALD: Okay. My name is Todd
20 Oswald. I'm currently a technical consultant in the
21 civil structural group within AREVA and I have been
22 responsible over the last five years for all of the
23 civil structural activities that we've had going on
24 on the U.S. EPR license application.

25 I've been around the nuclear around 29

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 years. Started off in the nuclear Navy out of
2 college. Came out, worked at Maguire Nuclear
3 Station with Duke Energy and doing modifications and
4 doing performance testing.

5 CHAIRMAN POWERS: So you're a relative
6 newcomer here?

7 MR. OSWALD: Yes, a relative newcomer,
8 like most of us. Yes, probably the youngest.

9 I did my undergraduate work and master's
10 degree from the University of South Carolina, again
11 in structural engineering. And after I came out of
12 the Navy, I mentioned I went to Maguire Nuclear
13 Station. And then after I left Maguire Nuclear
14 Station, which was stayed there about seven years,
15 worked for the last 17 years in a design engineering
16 organization. Started off with the ABB System 80+
17 certification. Lot of familiar faces around here
18 from that work. And then like I said, for the last
19 five years I've been the structural lead on the U.S.
20 EPR.

21 I'll be presented Chapter 2 with the
22 exception of Section 2.3, which my colleague here,
23 Mr. Ted Messier -- he'll present Section 2.3. And
24 I'll let Ted introduce himself.

25 MR. MESSIER: Good afternoon. I'm Ted

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Messier. My title is principal scientist. In the
2 Radiation and Nuclear Radiation Engineering Group in
3 Marlboro, Massachusetts. I've worked of bits and
4 pieces of the design certification application for
5 COL applications and two applications for the
6 uranium enrichment plants. And I also do work
7 supporting the existing operating fleet here in the
8 U.S. I've been in the industry 20 years this year.

9 Educational background, I have a
10 bachelor or science degree in meteorology from the
11 University of Lowell in Massachusetts and a master's
12 degree in meteorology from The Pennsylvania State
13 University.

14 CHAIRMAN POWERS: The Pennsylvania State
15 University. Okay.

16 MR. MESSIER: Otherwise known as Penn
17 State.

18 Mr. Oswald, you have the floor, sir.

19 MR. OSWALD: Okay. If you'll go to the
20 next slide here, let's get started.

21 Chapter 2. Chapter 2 introduces the
22 description of the all the design parameters used in
23 the U.S. EPR of the FSAR. And the requirements
24 placed on the COL applicants to characterize their
25 site and reconcile with those parameters that are in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Chapter 2 in the FSAR.

2 The following areas, as you can see on
3 the screen, are included in Chapter 2: Geography
4 and demography; nearby industrial transportation and
5 military facilities; meteorology, which Mr. Messier
6 here will address; hydrologic engineering; and
7 geology, seismology and geotechnical engineering.

8 Okay. Chapter 2 in general. The U.S.
9 EPR design is based on a set of what we feel are
10 conservatively established parameters which
11 represent more demanding site conditions than you
12 would probably see at any give site. Again, this is
13 Certified Design. Table 2.1-1 is the best summary
14 of all these requirements that are put on the COL
15 applicant. And it's got all of the site parameters
16 used in the U.S. EPR standard design.

17 Any COL applicant that references the
18 design, will make a comparison of the site-specific
19 characteristics with the parameters that are listed
20 in table 2.1. Of course, if they fall within the
21 parameters of 2.1-1, it's considered bounding. If
22 they don't, the data has to be collated and
23 confirmed that the U.S. EPR design parameters or the
24 design itself will envelope the site-specific
25 characteristics.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Okay. Section 2.1, geography and
2 demography. And this section requires the COL
3 applicant to define and describe the site, describe
4 the exclusion area authority in control and describe
5 the population distribution.

6 And in Section 2.1.1., the site location
7 and description, there's a requirement to specify
8 the locations in terms of the latitude, the
9 longitude, using universal transfer mercator
10 coordinates and the political subdivisions. Also, a
11 map is required of the area with relevant features
12 such as plant property lines, site and exclusion
13 area boundaries, the EAB, location and orientation
14 of --

15 CHAIRMAN POWERS: Does the applicant
16 have to own the exclusion area?

17 MR. OSWALD: Does the applicant have to
18 own the exclusion area?

19 CHAIRMAN POWERS: Yes.

20 MR. OSWALD: That is not explicitly
21 addressed in the U.S. EPR FSAR. There is no
22 specific requirement currently in there.

23 Want to take a note on that one and we
24 can pull the string on that. Does the applicant
25 have to own the exclusion area?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. SLOAN: Sure.

2 MR. OSWALD: Then in Section 2.1.2 the
3 exclusion area authority control requires the
4 applicant to define the authority and activities of
5 the exclusion area. So, they've got to identify who
6 owns it, who's in control there and all the
7 activities that are going on there.

8 Section 2.1.3, population distribution.
9 That requires the applicant to describe the
10 population within the site vicinity.

11 Before we go to 2.2, are there any
12 questions on what's required in 2.1?

13 CHAIRMAN POWERS: You do not
14 specifically call out special needs facilities and
15 things like that?

16 MR. OSWALD: No, we do not in the FSAR.
17 Are you talking about local fire department support
18 or --

19 CHAIRMAN POWERS: Hospitals, old age
20 homes, invalid.

21 MR. OSWALD: Oh, you're referring to
22 evacuation zones and requirements?

23 CHAIRMAN POWERS: If there are any
24 complications in the evacuation plan for the site.

25 MR. OSWALD: No. Again, this is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Certified Design FSAR. That's all pretty much the
2 burden of the COL application to identify all of
3 that.

4 CHAIRMAN POWERS: Surprising that you
5 don't alert them to the fact. I'm sure he knows.

6 MR. OSWALD: Yes, right. We point them
7 to the reg points, point them appropriate
8 requirements.

9 CHAIRMAN POWERS: Continue, please.

10 MR. OSWALD: But we leave it up to the
11 COL applicant.

12 CHAIRMAN POWERS: COL applicants have to
13 know what they're doing?

14 MR. OSWALD: Yes. Yes. We try and make
15 sure they're going down the right path, but we don't
16 tie their hands or anything.

17 Okay. Section 2.2, nearby industrial
18 transportation and military facilities. Again, the
19 U.S. EPR, I'm sure you are somewhat familiar with
20 the design of this structure. It is a very robust
21 design when considering any potential external
22 hazards. And again, this robust design, the reason
23 we make that statement is because we have -- it's
24 primarily attributed to an external shield wall
25 which we have around a significant portion of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plant, 1.8 meters of six-foot thick reinforced
2 concrete. And also, we have four divisions and they
3 are all separated a distance around the plant. So
4 therefore, we feel like this is a very robust design
5 when you're considering external hazards.

6 Section 2.2, again, the burden is on the
7 applicant to identify all of these items.

8 CHAIRMAN POWERS: Do you alert him to
9 consider not just what's there, but what's going to
10 be there?

11 MR. OSWALD: Again, we don't talk about
12 future items or future development activities around
13 there in the standard design.

14 CHAIRMAN POWERS: Yes, when we do the
15 early site permits and whatnot we of course are
16 required to interrogate local officials about what
17 changes are anticipated in the future as far as
18 transportation, military facilities, flight paths,
19 things like that. And oftentimes we find that those
20 officials are aware of changes anticipated in the
21 future.

22 MR. OSWALD: Planning commissions know
23 what's coming. We can take a look. I don't think
24 there's any explicit reference to future development
25 in the Certified Design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: Well, the plant's
2 going to last for at least 40 and maybe 60 to 80
3 years.

4 MS. SLOAN: I think if anything it would
5 be in their environmental report or in their COLA
6 application.

7 CHAIRMAN POWERS: It's required in their
8 application. I mean, right now you're just quoting
9 the standard content and the design. Within this
10 particular subsection I'm just wondering how far you
11 go. I mean, clearly you're just alerting the
12 applicant to these things and setting the ground
13 work for what your design basis is. And I'm just
14 wondering how far you go. That's all I'm trying to
15 find out.

16 MR. OSWALD: I don't recall any wording
17 in 2.2 requiring them to look at future projected
18 development around the site.

19 MS. SLOAN: (Off microphone.)

20 MR. OSWALD: Okay. That will be in 2.2.

21 Okay. Let's see where we are. Section
22 2.2.1, location and routes. The applicant is
23 required to describe the location and the routes
24 associated with the facilities, the industrial
25 transportation and military facilities.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2.2.2, descriptions. The COL applicant
2 is required to describe the facilities' primary
3 function and the nature of the hazard imposed by
4 these facilities close to the plant.

5 Section 2.2.3, evaluation of potential
6 accidents. The applicant will provide an evaluation
7 of the potential for an accident associated with the
8 facilities and the consequences. And we do
9 recognize that the applicant may use a probabilistic
10 approach on those hazards.

11 Any questions thus far through 2.2? Any
12 more?

13 (No audible response.)

14 MS. SLOAN: And I just doubled checked,
15 Todd. There's nothing in 2.2 that specifically
16 directs the COL applicant to consider future plans.
17 It just says simply the COL applicant will address
18 nearby industrial, blah, blah, blah facilities.
19 It's pretty general.

20 CHAIRMAN POWERS: You're not obligated
21 to do anything. I just wondered how far you went.

22 MR. OSWALD: Okay. If there are no more
23 questions on 2.2, I'll reintroduce you to Mr. Ted
24 Messier here. He's going to talk about Section 2.3
25 with the meteorology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MESSIER: Now we get to see just how
2 good my new bifocals are.

3 CHAIRMAN POWERS: If you're new to them,
4 Ted, you're in trouble.

5 MR. MESSIER: So Section 2.3,
6 meteorology. As I'm sure you've heard, the EPR
7 design is based on meteorological parameters such as
8 extreme air temperatures, precipitation rates and so
9 on, which are provided in table 2.1-1, which is the
10 site design envelope parameter list.

11 CHAIRMAN POWERS: Yes, let's get right
12 to the question that is going to emerge sooner or
13 later here.

14 MR. MESSIER: Okay.

15 CHAIRMAN POWERS: You're going to build
16 a plant that's going to last for 60 years. It's
17 going to take you five to seven years to build this
18 plant. So we're talking about a significant portion
19 of a century here.

20 MR. MESSIER: Yes.

21 CHAIRMAN POWERS: You're going to
22 specify the meteorological extremes based on
23 historical evidence. What basis does one have for
24 arguing that historical meteorological data is
25 applicable for the next century?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MESSIER: That's a very good
2 question. I'm not so sure I have a good answer for
3 it.

4 If you look at global circulation models
5 that are being used now to predict climate change,
6 the results are fairly general in nature, you know,
7 on a fairly large scale. And as you try to reduce
8 them to a smaller and smaller scale, say regional,
9 the error associated with doing that increases. And
10 I think that's fairly well spelled out in IPCC
11 reports and I think the U.S. Government report on
12 climate change.

13 So, you can make some estimates of how
14 you think climate is going to change here over time.
15 But what it boils down to is what we have for hard
16 data is the historical record. So that's more or
17 less got to be our starting point. It's the data we
18 have that's been observed. We know it to be true.
19 It's a ground truth, if you will, for future
20 analysis.

21 CHAIRMAN POWERS: Suppose I say global
22 climate change, don't care? I just look at the
23 historical data.

24 MR. MESSIER: Yes.

25 CHAIRMAN POWERS: And I look at the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 historical data. Suppose I was going to build a
2 plant maybe on the Atlantic Coast of the United
3 States, maybe in Maryland some place. Maybe. And I
4 looked at that data and I would find that there are
5 cycles in hurricane frequency, Atlantic storms and
6 whatnot.

7 MR. MESSIER: Yes.

8 CHAIRMAN POWERS: And I'd find maybe
9 that there are two cycles and that we've been in a
10 period of relative tranquility and moving into a
11 period of heightened activity, or certainly over the
12 course of 75 years I'm going to enter into a period
13 of heightened activity. Shouldn't I take that into
14 account when I set my parameters?

15 MR. MESSIER: Well, first of all, there
16 have been heightened periods of hurricane activity I
17 think as recent as the '40s and '50s, if I'm not
18 mistaken. And that information has been captured
19 and put into things such as the ASCE-7 standard on
20 design. And we use that information from that
21 standard for non-tornado wind speed information for
22 designing safety-related structures and non-safety-
23 related structures.

24 So with regard to hurricane winds and
25 impact on plants, that has been taken into account.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 You know, it is part of the standard review plan,
2 NUREG-0800.

3 CHAIRMAN POWERS: That I'm not aware of.
4 There are hurricane cycles in the standard review
5 plan?

6 MR. MESSIER: Not cycles, but the impact
7 of hurricanes is addressed.

8 MEMBER RYAN: And one maybe related
9 question is, have you done any kind of recurrence
10 interval estimates on the parameter values you have
11 selected?

12 MR. MESSIER: In terms of?

13 MEMBER RYAN: How likely they are in a
14 hundred years, or some kind of recurrence-sort of
15 parameter that would tell us what's the probability
16 that that value will be met or exceeded.

17 MR. MESSIER: Most of the site
18 parameters for meteorology for design, except for
19 tornadoes and snow load which came from NRC
20 Guidance, Interim Staff Guidance 7 for the snow load
21 and Reg Guide 1.76 for tornadoes, most of it has
22 come from the EPRI Advanced Light Water Reactor
23 Utility Requirements.

24 CHAIRMAN POWERS: I'm operating from
25 memory, I'll have to assure, but I do not recall

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 them going into any detail about talking about what
2 I know about our hurricane frequencies on the East
3 Coast.

4 MR. MESSIER: Nor do I. I'm just
5 stating the provenance of the information.

6 We have not been required to look at say
7 100-year return period values of precipitation,
8 extreme precipitation rates or extreme temperatures.
9 We're using the so-called zero percent exceedance
10 maximum temperature values for our design, which is
11 115 degrees dry fall and 80 degrees coincident wet
12 fall, which seems to bound most of the United States
13 potential site locations.

14 MEMBER RYAN: And I appreciate and
15 accept that, but I'm trying to get a different way
16 to get at Powers' question, which is if you had some
17 idea of a recurrence interval of some value, you
18 know, you could sort of address the question, well,
19 you know, given what we know, and the history you
20 mentioned, the likelihood of exceeding this value in
21 100 years or 300 years is X.

22 MR. MESSIER: Okay.

23 MEMBER RYAN: There a way, at least for
24 me, to think about his question in a slightly
25 different way.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MESSIER: For the snow load and for
2 the non-tornado wind speed, both of those do take
3 into account 100-year return period values of
4 snowfall, snow depth, and wind speed.

5 MEMBER RYAN: Okay.

6 MR. MESSIER: So in that regard, in
7 terms of structural strength, that has been
8 included.

9 MEMBER RYAN: How so? How has it been
10 addressed?

11 MR. MESSIER: ASCE-7, the value we use I
12 believe is for a 50-year recurrence value period.
13 But then there's an importance factor you can use to
14 bump that up to a 100-year value. And that's what
15 we've provided.

16 MEMBER RYAN: Okay.

17 MR. MESSIER: Interim Staff Guidance
18 goes into detail on 100-year return period snow
19 depth and snowfall.

20 MEMBER RYAN: Thank you.

21 MR. MESSIER: You're welcome, sir.

22 MEMBER STETKAR: Ted, and you're careful
23 about excluding tornadoes. I didn't look very far
24 ahead in your slides. Were you going to talk
25 separately about tornadoes or not? Is this the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 appropriate time to ask about --

2 MR. MESSIER: If you'd like to ask a
3 question, you might as well.

4 MEMBER STETKAR: Well, then I will. In
5 the same vein as Mike mentioned about recurrence
6 intervals, if I look at the design tornado wind
7 speed loadings, they're in the 180 to 200-plus mile
8 per hour range, which is somewhere in the F3, F4
9 Fugita intensity range. And I understand the basis
10 for that. I guess my curiosity is if you look at
11 return intervals, which obviously vary quite
12 dramatically depending on where you are in the
13 United States; I just pulled up some data for a
14 place that actually isn't all that infrequent for
15 tornadoes, recurrence intervals for F3, F4 tornadoes
16 striking something roughly the size of a nuclear
17 power plant profile are on the order of somewhere
18 around 10 to the minus five or a little higher per
19 year. So once in roughly 100,000 years. It can be
20 a little bit higher. This happens to kind of a
21 moderate activity site. It was just one I could
22 pull up for reference here quickly.

23 I guess my question is not so much in
24 terms of the design, because I understand the
25 criteria you're using for the design. My curiosity

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 is that the risk assessment claims to have accounted
2 for all internal and all external events. And they
3 published total core damage frequencies on the order
4 of three times ten to the minus eight per year, or
5 roughly a factor of 1,000 times lower frequency than
6 the site being hit by a tornado that exceeds the sit
7 design characteristics.

8 Do you have any idea how the risk
9 assessment folks factored the design criteria or
10 recurrence intervals for these very extreme events
11 into their analyses?

12 MR. MESSIER: No, sir, I'm sorry I
13 don't.

14 MEMBER STETKAR: I mean, I understand
15 what you've designed the buildings to. The question
16 is, you know, how does that actually affect the
17 overall risk of the site?

18 MS. SLOAN: I think we're going to have
19 to take the question, because I think it's really
20 one for our PRA folks.

21 MEMBER STETKAR: I just wanted to make
22 sure I understood the basis for the actual wind
23 loading design and things like that. And since the
24 question about recurrence intervals came up, I
25 thought I'd raise that frequency argument also.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MESSIER: Sure.

2 MEMBER STETKAR: And you're right,
3 Sandra, it's more a question for the risk assessment
4 folks than the design. I understand the criteria
5 that you're using.

6 CHAIRMAN POWERS: That's the strategy
7 we'll use. We'll put everything on the risk --

8 MEMBER STETKAR: Well, it is. As I
9 mentioned this morning, you kind of like to raise
10 some of these issues in the context --

11 CHAIRMAN POWERS: That they arise.

12 MEMBER STETKAR: -- that they arise,
13 rather than waiting for the risk assessment.
14 Because many times when you look at the risk
15 assessment, you get bogged down into a lot of other
16 things,

17 CHAIRMAN POWERS: Stuff that Stetkar
18 brings up.

19 MEMBER STETKAR: Not me. Okay. Thanks.

20 MR. MESSIER: I'll just continue with
21 this slide. Once again, if the COL applicant that
22 references the design comes up with values that are
23 outside of the range, they will have to demonstrate
24 the acceptability of the site-specific open sections
25 of their application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 2.3 is broken up into five
2 subsections. The first is regional climatology.
3 And this will include such things as air quality,
4 severe weather information, meteorological data used
5 in the evaluation of the ultimate heat sink. This
6 is all provide by the COL applicant, as these are
7 site-specific characteristics.

8 .2 subsection is local meteorology. And
9 this would be the bread and butter of all
10 meteorologists, the statistics of temperature,
11 precipitation, snowfall and so on, again all site-
12 specific characteristics.

13 .3 subsection, the meteorological
14 measurement program. Again, site-specific. You
15 will talk about the system accuracies and so on that
16 are required, data reduction, data recovery goals
17 and so on and so forth.

18 A little more interesting, .4, which is
19 the short-term atmospheric dispersion estimate for
20 accidental releases. We have looked at these. We
21 have come up with values that we consider to be
22 representative of potential future sites in the U.S.
23 and to calculate the postulated accidental releases,
24 the consequences thereof.

25 CHAIRMAN POWERS: One of the problems we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 always encounter in looking at dispersion around a
2 plant is local building wake effects. Do you
3 provide a description of those wake effects?

4 MR. MESSIER: For the accidental
5 releases we did not take credit for building wake
6 effects. So we know that that it's there. The
7 models do have a component that you can turn on or
8 off. But for the accident analysis we did not take
9 credit for building wake effects that may prove --

10 CHAIRMAN POWERS: You haven't ever put
11 this plant design into a wind tunnel and looked at
12 things?

13 MR. MESSIER: Not to my knowledge, no.

14 CHAIRMAN POWERS: Actually, I know it
15 has been.

16 MR. MESSIER: I know for a control room
17 habitability analysis, we used the ARCON96 code,
18 which was developed by Van Ramsdell. And that does
19 include a lot of work I believe he has done in the
20 past with building structures in wind tunnels and so
21 forth.

22 CHAIRMAN POWERS: Yes, it just has a
23 model of wake effects, and that model is probably
24 the best approximation running around right now.
25 It's certainly better than the Campe model.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. MESSIER: Yes.

2 CHAIRMAN POWERS: But, you know, it
3 would be neat to actually put the building into a
4 wind tunnel and see what things look like around it,
5 I mean, in the modeling and things like that. But
6 you don't provide that?

7 MR. MESSIER: Unfortunately, no.

8 CHAIRMAN POWERS: Okay.

9 MR. MESSIER: Okay. Once again, the COL
10 applicant would come up with their site-specific
11 accident chi over Q values to see whether they are
12 bounded by those provided in the EPR design. If
13 not, they would have to demonstrate that the
14 radiological consequences still meet the applicable
15 dose limits.

16 And in subsection 5, which is the long-
17 term annual average atmospheric dispersion estimates
18 for routine releases from the plant, we have
19 developed a value we feel to be representative of
20 many potential future locations. COL applicant must
21 come up with their own site-specific values once
22 again, see whether they have bounded or not. If
23 not, they must do an evaluation to show that they
24 still meet the applicable dose limits.

25 Are there any other questions on Section

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2.3?

2 (No audible response.)

3 MR. MESSIER: Hearing none, I will turn
4 you back over to Mr. Oswald.

5 CHAIRMAN POWERS: One of the questions,
6 do you ask that the licensee maintain a
7 meteorological station on the site after the
8 building is constructed?

9 MR. MESSIER: Yes, sir.

10 CHAIRMAN POWERS: That's fine.

11 MR. OSWALD: Okay.

12 CHAIRMAN POWERS: Hydrologic.

13 MR. OSWALD: Hydrologic, Section 2.4.
14 And Section 2.4 describes the hydrologic parameters
15 considered for the U.S. EPR, and again, back up to
16 the COL applicant again, to reconcile with these
17 parameters.

18 CHAIRMAN POWERS: Poor COL.

19 MR. OSWALD: Yes.

20 CHAIRMAN POWERS: Never have I seen a
21 customer abused so badly here.

22 MR. OSWALD: Okay. In our parameters on
23 the U.S. EPR, of course we consider all the
24 groundwater, winter precipitations, snow, sleet,
25 ice, rainfall, surface flooding. And again, these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 values are provided in table 2.1-1 for a quick
2 summary. Take a quick look at what our parameters
3 are considered in the design.

4 Section 2.4.1, hydrologic
5 characteristics. In this section the applicant is
6 required to describe the site-specific
7 characteristics related to the hydrologic conditions
8 at the site.

9 Section 2.4.2, the floods. The
10 applicant is required to investigate and describe
11 the site-specific flood history, the flood design
12 features and the effects of local precipitation on
13 the design.

14 MEMBER STETKAR: Todd, on hydrologic, I
15 notice the specification is that the maximum
16 groundwater elevation is 3.3 feet below grade,
17 roughly a meter below.

18 MR. OSWALD: A meter below.

19 MEMBER STETKAR: With some relevance to
20 the discussion this morning regarding underground
21 cable ducts, do you have any information what the
22 bottom elevation of any of the building structures
23 are below grade, or the elevations of those cable
24 ducts below grade? I didn't have a chance to go
25 look at it and I don't even know whether the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 information is available, so I'm kind of asking --

2 MR. OSWALD: Right. Most of the duct
3 work, the cable ducts of course would be up near the
4 top.

5 MEMBER STETKAR: But that's only a meter
6 below grade.

7 MR. OSWALD: Yes, that's right.

8 MEMBER STETKAR: They're typically much
9 deeper than a meter below grade.

10 MR. OSWALD: That's correct.

11 MEMBER STETKAR: They're two to three,
12 at least.

13 MR. OSWALD: One of the obvious ones on
14 this design is the emergency power generation
15 building, the diesel buildings. That foundation is
16 about six-feet deep. And then duct work will come
17 out the bottom of that building, because it's deep
18 enough for external hazards, missiles, tornado
19 missiles, etcetera, to keep from damaging them and
20 run over. So, I would say they're going to be six
21 to ten feet below grade. So that groundwater
22 table --

23 MEMBER STETKAR: Will be impacted.

24 MR. OSWALD: -- will be impacted.

25 MEMBER RYAN: And one of the things it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a fairly large construction. And I guess with the
2 near field of that large construction I'm going to
3 pretty much bet any money I've got that it's not
4 going to be the same after it is before.

5 MR. OSWALD: Right.

6 MEMBER RYAN: So, how do you deal with
7 that at this stage? I know the COL has the
8 responsibility to address that question ultimately,
9 but --

10 CHAIRMAN POWERS: They need a
11 substantial amount of information from the designer
12 to do it.

13 MEMBER RYAN: Yes.

14 MR. OSWALD: Right. And those ducts, we
15 have criteria in the Certified Design for designing
16 the ducts. Well, the design code, ACI, etcetera,
17 and the requirements --

18 CHAIRMAN POWERS: But Mike's asking a
19 little different question, I think. He's saying,
20 okay, we have a site; it sits here. We have a
21 hydrologic model for that site. As soon as you put
22 that plant on that site, that hydrologic model is no
23 good anymore.

24 MEMBER RYAN: It's no good certainly
25 within the proximity of the buildings and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 structures. And you could probably make an argument
2 that it's okay at some distance. What distance it
3 is is depending upon all the key features at the
4 site. You could even seen reversals of flow.

5 MR. OSWALD: Right.

6 MEMBER RYAN: So, I'm struggling a
7 little bit with how the preexisting geohydrology, at
8 least for the near field to the building is valid
9 and how you address that.

10 MR. OSWALD: Well, of course the COL
11 applicant --

12 MEMBER RYAN: Yes.

13 MR. OSWALD: -- would have to address
14 that. And the applicants that I have seen to this
15 point have considered the excavation and the
16 resulting groundwater table after the excavation.

17 MEMBER RYAN: Just modeling, or with
18 some measurements, or --

19 MR. OSWALD: I don't know the specifics
20 of how they did all of the geotech work on that.

21 CHAIRMAN POWERS: I mean, say new things
22 like how much does this thing weigh?

23 MEMBER RYAN: And I'm thinking ahead to
24 things like, you know, the Tritium Task Force
25 results and, you know, monitoring results in a place

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 where you didn't expect them and flows that weren't
2 exactly what you might have thought they were going
3 to be and so forth. So, I guess there's work to do
4 for the COL in that area.

5 MR. OSWALD: Yes. Can you put that
6 down, the COL?

7 Okay. 2.4.1, hydrologic
8 characteristics. Again, the applicant is required
9 to describe the site-specific characteristics
10 related to the hydrologic conditions.

11 2.4.2, floods.

12 CHAIRMAN POWERS: I think if we look at
13 the guidance the staff gives in this area, that the
14 applicant is required to characterize the hydrology
15 of the site, and then he is required to consider
16 alternatives. Do you give him any guidance on how
17 to consider alternatives?

18 MR. OSWALD: We do not in the Certified
19 Design.

20 CHAIRMAN POWERS: Please continue.

21 MR. OSWALD: We do not have in the
22 Certified Design.

23 Floods, 2.4.2. Again, the applicant is
24 required to investigate and describe the site-
25 specific flood history, flood design features and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the effects of local precipitation.

2 2.4.3, PMF, probable maximum flood of
3 streams and rivers. Again, the applicant is
4 required to determine the probable maximum flood
5 from the streams and rivers and describe the effects
6 of the flooding on that design for that site.

7 CHAIRMAN POWERS: And he takes into
8 account the maximum 50-year flooding for this?

9 MR. OSWALD: I'll look. It's 50 or 100.

10 2.4.4, potential dam failures. The
11 applicant is required to determine the potential for
12 any upstream or downstream failures or any water
13 control devices that may be upstream or downstream.
14 Any natural water control devices or manmade devices
15 we call out for the applicant to investigate.

16 All right. Next. 2.4 continues.

17 2.4.5, probable maximum surge and seiche flooding.
18 The applicant is required to provide site-specific
19 information on the probable maximum surge and seiche
20 and the extent which safety-related structures will
21 require protection. And again, they have to
22 consider the wind effects on the surge and the
23 seiche.

24 CHAIRMAN POWERS: Seiche is strictly a
25 wind effect.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. OSWALD: No, it's not. It would be
2 wind or seismic effects.

3 CHAIRMAN POWERS: It's a standing wave.
4 A seiche is a standing wave.

5 MR. OSWALD: Yes, it would be the wind
6 effects on the seiche.

7 CHAIRMAN POWERS: There's only been one
8 in our nuclear power plants, so I guess we don't
9 have to worry too much about them.

10 MR. OSWALD: Okay. 2.4.6, probable
11 maximum tsunami flooding. Again, the applicant is
12 required to provide the site-specific information on
13 maximum flooding from a tsunami. Again
14 determining --

15 CHAIRMAN POWERS: What do you require in
16 your design basis for tsunami? I mean, what do you
17 do with that?

18 MR. OSWALD: Well, we've looked at
19 ground flooding -- really again, the maximum flood,
20 we've got one foot below finish grade on flooding.
21 And again, we've got our ground floor one foot above
22 finish grade. So, you read that as the applicant
23 would have to show that you've got the tsunami --

24 CHAIRMAN POWERS: Yes, but tsunami --

25 MR. OSWALD: -- one foot below the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 finished grade elevation.

2 CHAIRMAN POWERS: But, I mean --

3 MR. OSWALD: Or protect for it.

4 CHAIRMAN POWERS: -- a tsunami is a
5 probabilistic thing. So there must be some
6 probability associated with that tsunami that
7 exceeds your criterion.

8 MR. OSWALD: Right. And I don't know
9 what that probabilistic requirement -- are you
10 familiar, Ted, with the tsunami --

11 MR. MESSIER: I'm guessing that would be
12 another PRA issue.

13 MEMBER SHACK: No, I mean, it's a design
14 basis. Like your tornadoes is based on a
15 probability of exceeding that kind of a wind speed.
16 And you presumably would have sort of similar kind
17 of criterion for the tsunami.

18 CHAIRMAN POWERS: Yes. And what I want
19 to know is what the probability is.

20 MR. OSWALD: Right. Oh, the probability
21 of --

22 MEMBER SHACK: Of exceeding your design
23 basis tsunami.

24 MS. SLOAN: And again, I think that gets
25 into COL space where it's beyond what we can speak

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 for for design certification.

2 MR. OSWALD: We don't have that
3 probability spelled out in the Certified Design.
4 But they're required. We would point them to the
5 NUREGs. And I do not know what that probabilistic
6 number is.

7 MS. SLOAN: I think that's why it's a
8 COL --

9 CHAIRMAN POWERS: Okay. So you would
10 handle a tsunami just like it was flood?

11 MR. OSWALD: Right. Yes, from the
12 structural perspective.

13 MEMBER STETKAR: I mean, theoretically
14 also, to come back to the thing I'm accused of all
15 of the time, is that theoretically the risk
16 assessment should have a frequency for a range of
17 tsunami impacts, if they've really done an
18 assessment of the risk from external events, the
19 same way as there would be a frequency, or people
20 like to call it probability, for a range of
21 different tornado loads. And since the risk
22 assessment is part of the design certification
23 package, that information should be in there, at
24 least was assumed from that perspective.

25 MS. SLOAN: I think we're just going to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have to take a follow-up to get that information.

2 MR. OSWALD: Again, as was stated, we
3 considered the maximum height, whatever that risk,
4 whatever that frequency is, one foot below finish
5 grade. If it's beyond that, if it's an exception,
6 you're just going to have to describe how you're
7 going to protect for it. Build a bern around, or
8 whatever your options you want to select.

9 Ice effects, Section 2.4.7. The
10 applicant is required to evaluate the site-specific
11 ice effects, determine the forces on the structure
12 and describe the protection required for the ice
13 effects. Again, the COL applicant has to consider
14 ice blockage and build up on any moving components
15 such as fans, cooling fans.

16 2.4.8, cooling water canals and
17 reservoirs. The applicant is required to provide
18 the site-specific design basis for cooling water
19 canals and reservoirs used for make up to the
20 ultimate heat sink cooling water structures. Again,
21 the U.S. EPR ultimate heat sink is provided by
22 mechanical draft cooling towers in a safety-related,
23 what we call a central service water structure.
24 The make up intake structure is and the conduit is
25 site-specific to the central service water building.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Section 2.4.9, channel diversions. The
2 COL applicant is required to provide site-specific
3 information on panels and -- in the event of
4 diversion or rerouting of the source of the cooling
5 water and that alternate water supplies are
6 available for safety-related equipment.

7 Any questions on this slide?

8 CHAIRMAN POWERS: I see none.

9 MR. OSWALD: Okay. We'll move on.

10 Hydrology continues.

11 CHAIRMAN POWERS: It just won't give up,
12 huh?

13 MR. OSWALD: 2.4.10, flooding protection
14 requirements. Again, the applicant is required to
15 provide a description of all the static and dynamic
16 effects of flood conditions and how the safety-
17 related equipment is protected.

18 2.4.11, low water considerations. The
19 applicant is required to identify any natural events
20 that may reduce or limit cooling water supplies.

21 2.4.12, groundwater. The applicant is
22 required to identify local and regional groundwater
23 reservoirs, subsurface pathways, on-site groundwater
24 usage, and any necessary monitoring measures and any
25 effects on the structures.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 2.4.13, pathways of liquid effluents in
2 the ground and surface waters. Again, the applicant
3 has describe the ability of the surface and
4 groundwater to delay, disperse, dilute or
5 concentrate radioactive effluent releases and the
6 effects on future use of water resources around the
7 site.

8 2.4.14, tech spec and emergency
9 operation requirements. The applicant has to
10 describe any emergency measures to implement flood
11 protection and verify adequate water supply for
12 shutdown.

13 MEMBER STETKAR: Todd, just remind me; I
14 have to admit ignorance here, the U.S. EPWR design
15 does have a separate ultimate heat sink cooling
16 water basin, right? I think you mentioned --

17 MR. OSWALD: In the essential service
18 water building, yes.

19 MEMBER STETKAR: in the essential
20 service water area?

21 MR. OSWALD: Yes.

22 MEMBER STETKAR: So you don't rely on an
23 open-loop system?

24 MR. OSWALD: That's correct.

25 MEMBER STETKAR: Yes, I keep picturing

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the plant in France, which is an open-loop design.

2 MR. OSWALD: Open. Right. Right.

3 MEMBER STETKAR: But this is --

4 MR. OSWALD: Closed-loop. Again, the
5 only external is the make up --

6 MEMBER STETKAR: It's just make -- yes,
7 I mean, you need make up to it, but it --

8 MR. OSWALD: Right.

9 MEMBER STETKAR: Okay. Thanks.

10 MR. OSWALD: Yes.

11 MEMBER STETKAR: Thank you.

12 MR. OSWALD: Okay. Now the fun stuff.

13 2.5, geology, seismology and geotechnical
14 engineering. In Section 2.5, the applicant has to
15 investigate and characterize the site, describe the
16 site and do a probabilistic seismic hazard
17 assessment to determine the site-specific SSE.

18 Again, the EPR FSAR considers a range of generic
19 soil profiles and applies an appropriate Certified
20 Design response spectra. We have three spectra;
21 soft, medium and hard that would be associated with
22 the right soil condition, the soil column.

23 And Section 2.5.1, the basic geologic
24 and site information. The COL applicant has to
25 define the regional and site geology.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Section 2.5.2, the vibratory ground
2 motion. The applicant has to define the site-
3 specific SSE motion from the probabilistic seismic
4 hazard assessment and compare the site-specific SSE
5 with the certified seismic design response spectra
6 parameters in the EPR, in the FSAR. Again, our
7 three different control motions with the associated
8 soil profiles.

9 MEMBER SHACK: You have ten profile
10 grouped into three. Now, is that really three
11 profiles that you use?

12 MR. OSWALD: It's actually ten different
13 soil columns. We have layered conditions and we
14 have uniform half-space soil columns. So some of
15 these are low-shear wave velocities or soft sites.
16 Some of them are high-shear wave velocities or hard
17 sites. So, we have our ten soil columns and then we
18 put either a soft or a medium or a hard applied to
19 the appropriate soil column. So there's really ten
20 different ground motions, ten different seismic/soil
21 conditions. Now, two of those overlap. You know,
22 we'll put -- one of them has a hard and medium
23 applied to it and one of them has a medium and a
24 soft applied to it. It kind of falls in between.
25 So we actually run a total of 12 different profiles.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: Okay. So, I mean, you
2 really do have 12 different --

3 MR. OSWALD: Yes, at this point right
4 now that's what's in our Certified Design is our 12
5 profiles. We were trying to get a broad range of
6 conditions to make sure that we try to envelope as
7 much as we can.

8 CHAIRMAN POWERS: I guess I'm a little
9 confused about this. If you ask me what is the
10 acceptance spectrum for the EPR, why don't I just
11 take the soft site spectrum?

12 MR. OSWALD: Well, what we've actually
13 found was the medium spectrum ended up driving a
14 little more, depending on the soil profile that you
15 use. We had a hard profile and a medium profile
16 that were really the predominant drivers in the --

17 CHAIRMAN POWERS: So why not pick one of
18 those and then say that's what the EPR will do?

19 MR. OSWALD: We're working on that. As
20 we have figured out what are the controlling
21 motions, we recognize that we have --

22 CHAIRMAN POWERS: Has this design or
23 components of this design ever been put on a shaking
24 table?

25 MR. OSWALD: I cannot speak for what has

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 been done in the European design as far as the -- of
2 course the structure obviously hasn't been placed on
3 shake table, but at this point in the U.S. we have
4 not procured any testing or components.

5 CHAIRMAN POWERS: Okay. It's a matter
6 of fact.

7 MEMBER SHACK: Can I ask my PRA question
8 just to get it --

9 CHAIRMAN POWERS: Yes.

10 MEMBER SHACK: Okay. I'll ask my PRA
11 question now. And I don't expect an answer. I just
12 haven't looked at the PRA.

13 Do you happen to know whether the risk
14 assessment has quantified a frequency of seismic-
15 induced core damage, or have they just simply done a
16 seismic margins analysis?

17 MR. OSWALD: They've done a seismic
18 margins analysis.

19 MEMBER SHACK: Okay. So we don't know
20 what the seismic risk is?

21 MR. OSWALD: (Off microphone.)

22 MEMBER SHACK: Right. Okay. Thanks.
23 That helps.

24 MR. OSWALD: Our Certified Design
25 response spectra, the three, hard, medium and soft,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 all anchor to a .3g peak ground accelerations.
2 Again, that's defined as the hypothetical free field
3 outcrop motion at the basemat elevation for the
4 nuclear island common basemat. This design has one
5 large basemat for most everything, and then we have
6 the diesel and the ultimate heat sinks off the
7 common basemat.

8 CHAIRMAN POWERS: I guess I didn't
9 realize that. The diesels are on separate basemats?

10 MR. OSWALD: Yes, the diesels are in
11 separate buildings. Part of the separation criteria
12 we'd use for extreme hazards. That's part of the
13 design.

14 CHAIRMAN POWERS: And we find that that
15 was the cause of difficulties at the Japan
16 earthquake. They have two things that moved
17 differently and the connections are the problem.

18 MR. OSWALD: Yes.

19 CHAIRMAN POWERS: Okay. Interesting.

20 MR. OSWALD: Okay. In 2.5.2.6 is where
21 we describe the reconciliation process, how you take
22 what's in the Certified Design response spectrum
23 versus your site-specific ground motion, or SSE.
24 And again, in 2.5.6, we recognize a site-specific
25 soil structure interaction evaluation may be used to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do that reconciliation. If it's not obvious that
2 you have your soil column enveloped and your ground
3 motion enveloped, the two together, then you do the
4 site-specific SSI analysis, which is pretty much
5 where we end up with most of the time.

6 Section 2.5.3, surface faulting. The
7 applicant must investigate the region for surface
8 faults. The U.S. EPR does not allow surface faults
9 under safety-related structures.

10 CHAIRMAN POWERS: Let me ask a question.
11 In principle I doubt that there's any place in the
12 world that has not had a fault at one time or
13 another, if I go back to the age of the universe or
14 age of the planet. So surely, inactive faults
15 underneath the structure are not proscribed, are
16 they?

17 MR. OSWALD: Inactive faults are not
18 proscribed.

19 CHAIRMAN POWERS: Surely, they must not
20 be proscribed. Yes, of having an active fault. I
21 mean --

22 MR. OSWALD: Oh, an -- I thought you
23 said inactive. I was not -- okay.

24 CHAIRMAN POWERS: If I have an inactive
25 fault in under my basemat, hadn't moved in the last

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 billion years, then why do you care?

2 MR. OSWALD: I don't recall the --

3 MR. MUNSON: If I could maybe jump in.

4 This is Cliff Munson. I'm the branch chief in the
5 geosciences and geotechnical engineering.

6 We do look at surface faulting, but in a
7 sense we're looking for rupture of a fault that
8 could potentially happen underneath a nuclear
9 structure. So it's not so much an inactive fault
10 that's been dormant for several million years. We
11 wouldn't consider that as capable and obviously the
12 COL applicant would have to do investigations to
13 make sure that it was not capable.

14 MR. OSWALD: That is the key word,
15 capable faults.

16 MR. MUNSON: But what we're worried
17 about is a fault that would potentially rupture
18 underneath a nuclear structure.

19 MR. OSWALD: Okay. 2.5.4, stability of
20 subsurface materials and foundations. The applicant
21 is required to submit information about the
22 properties and stabilities of soils that may affect
23 the plant facilities under static and dynamic
24 conditions including the certified design response
25 spectra or the site SSE of the site-specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 structures.

2 Section 2.5.5, stability of slopes. The
3 applicant must evaluate all slopes, natural and
4 manmade of the site-specific SSE. Again, no slope
5 failures are considered in the Certified Design.

6 Are there any questions on 2.5?

7 (No audible response.)

8 MR. OSWALD: Okay. That concludes what
9 AREVA has to present.

10 CHAIRMAN POWERS: In looking ahead, I
11 happened to notice that in the next presentation
12 we're going to talk about what, 13 SE open items?
13 You have any comments about those?

14 MR. OSWALD: The open items, there's one
15 on the bearing capacity, how we calculated the
16 bearing capacity, the dynamic bearing capacity. The
17 comment on that was we have a value currently in the
18 FSAR of approximately 26 ksf. The initial FSAR
19 submittal had about 34.5 ksf. Initially in our
20 sliding and overturning evaluation, we took a toe
21 pressure value from that evaluation to come up with
22 our dynamic bearing capacity. That was the 34.5 ksf
23 number. Now we have 26.1 ksf dynamic bearing
24 capacity. And that's done in our SASSI analysis.
25 Again, in our sliding and overturning evaluations

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we've taken the maximum value that we determine
2 under the basemat in our SASSI analysis in the SASSI
3 Code as we were doing the sliding and overturning
4 evaluation. And the staff is looking for more
5 information on that. We had only provided the value
6 and didn't provide the full explanation.

7 The other open items are consistency
8 between use of the words "site characteristics" and
9 "site parameters." I think I actually messed that
10 up in one of the slides here, I noticed this
11 morning. Recognize that. We'll clean all of that
12 up.

13 What are some of the other open items
14 now? Some of them are -- they're mostly in your
15 area.

16 MR. MESSIER: Mostly they're mine.

17 MR. OSWALD: Yes. So good.

18 MR. MESSIER: I'll just let you keep
19 talking.

20 MR. OSWALD: No. No, no. I'm done with
21 all I can say here.

22 MR. MESSIER: I'm sure the staff is
23 going to present them. Quite a few of them are, you
24 know, clarifications that have been requested that
25 will be only too glad to provide.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: I was really looking
2 for are there any that we're not going to resolved
3 easily?

4 MR. MESSIER: I don't think so. No,
5 none of that odor.

6 CHAIRMAN POWERS: Okay. That was the
7 question I really had. But, we're on a pathway to
8 get these -- that sooner or later all will get
9 chaptered too with no open items.

10 MS. SLOAN: Hopefully sooner rather than
11 later.

12 CHAIRMAN POWERS: You've stood up
13 enough.

14 MS. SLOAN: Okay.

15 MR. OSWALD: Thank you, gentlemen for
16 the staff.

17 CHAIRMAN POWERS: We're going to have to
18 really put a string on you, Sandra. You're just too
19 disruptive.

20 MS. SLOAN: Oh, there are plenty more
21 chapters left.

22 CHAIRMAN POWERS: Oh, I'm sure.

23 MS. SLOAN: We'll have plenty of fun.

24 CHAIRMAN POWERS: When we get to Chapter
25 15, I'm sure that we will call out for pizza.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 We're scheduled for a break.

2 PARTICIPANT: We are.

3 CHAIRMAN POWERS: Thank you. We will
4 take that said break a bit early, but deserved
5 nevertheless. And so we will resume at 20 of the
6 hour.

7 (Whereupon, at 2:36 p.m. off the record
8 until 2:40 p.m.)

9 CHAIRMAN POWERS: Let's come back to our
10 discussions of site characteristics.

11 MS. TESFAYE: Thank you. Yes, this is
12 the staff's portion of this afternoon's
13 presentation. I'd like to go over the staff that
14 will be dealing with the open items. Seshagiri
15 Tammara is the one at the computer. He's sitting at
16 the back in support. He doesn't have a
17 presentation. Mr. Brad Harvey will be presenting
18 2.3, meteorology. Mr. Ken See will be presenting
19 2.4, hydrology engineering section. And Dr. Weijun
20 Wang will be presenting 2.5, geology, seismology and
21 geotechnical engineering.

22 Project manager support, myself and Jay
23 Patel. Jay Patel unfortunately is not here to --

24 CHAIRMAN POWERS: He didn't come and
25 visit with us, huh? Tell him that we missed him.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. TESFAYE: Okay. I'll do that.

2 So that's the staff that is responsible
3 for Chapter 2.

4 Next slide is the --

5 CHAIRMAN POWERS: I may just comment
6 that Mr. Harvey and Mr. Wang of course have been
7 before this Committee several times with all the
8 questions we asked before. I saw Brad roll his
9 eyes. Mr. See, however, I think you're relatively
10 new before us.

11 MR. SEE: This is my third appearance.

12 CHAIRMAN POWERS: Third appearance?
13 Okay.

14 MEMBER SHACK: He only rolls his -- or
15 lifts his eyebrows.

16 CHAIRMAN POWERS: He lifts his eyebrows.
17 Please continue.

18 MS. TESFAYE: Okay. One thing I'd like
19 to say about this slide, you asked the question
20 during the earlier presentation about the nature of
21 the open items.

22 CHAIRMAN POWERS: Yes.

23 MS. TESFAYE: Here, in the projects and
24 technical staff, we don't see a path forward in
25 Phase 4. We will not allow anything to be just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 open. So usually the open items have some (off
2 microphone.)

3 COURT REPORTER: Mr. Chair, could you
4 remove that wrapper away from the mike?

5 CHAIRMAN POWERS: I can.

6 MS. TESFAYE: So that's the nature of
7 these open items. Again, we have issue 45, request
8 for additional information for this chapter.
9 Thirteen of them are left open to be resolved in the
10 fourth part of the application review.

11 Now the next couple of slides we've
12 listed all the open items, but the ones that we're
13 going to be discussing here this afternoon are the
14 ones with red star in front of them. But after them
15 are minor in nature and we'll now be discussing
16 them. And again, I'm not going to go through this
17 open item list. This is here just for completeness.

18 Slide 6, as you heard during our
19 previous presentation, Section 2.1, geography and
20 demography and Section 2.2, nearby industrial,
21 transportation and military facilities. Here are
22 our information items. And we don't have any
23 specific presentation from the staff on those two
24 sections.

25 But we are satisfied why is there an RAI

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 from the original FSAR, but the applicant has
2 included the correct COL information item in the
3 FSAR.

4 With that, if you don't have any
5 question for me, and I like to introduce Mr. Harvey
6 to discuss meteorology, 2.3.

7 MR. HARVEY: Hello, my name is Brad
8 Harvey. I'm a meteorologist for the Sizing and
9 Accident Consequence Branch within the division of
10 Site Environmental Reviews within the Office of New
11 Reactors. I've been supporting the nuclear power
12 industry for a little over 30 years in a
13 meteorological role. I have a bachelor's from
14 Rensselaer Polytechnic Institute in physics. I have
15 a master's from the University of Michigan in
16 atmospheric science. I've been with the NRC for a
17 little over six years, during which time I've been
18 involved as the primary meteorological reviewer for
19 the first three Early Site Permits and I also
20 provided a supporting role for the role of the Early
21 Site Permit. I've been the leading meteorological
22 reviewer for the three Design Certifications
23 currently under review. I'm also reviewing several
24 of the COLA applications that are before the ACRS,
25 or will be shortly.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Before working with the NRC, I worked
2 for Yankee Atomic Electric Company, an NRC licensee,
3 for almost 20 years, and several consulting firms.
4 And full disclosure, my last job before I joined the
5 Agency was actually with AREVA. I was with AREVA
6 for 15 months before I turned over to the dark side
7 and started working for the regulator here.

8 CHAIRMAN POWERS: You left Sandra? Why?
9 You're with the good guys now though. Oh, she
10 looked at me.

11 MR. HARVEY: I'll be discussing SER
12 Section 2.3 on meteorology.

13 Section 2.3, meteorology. Typically
14 while site-specific information such as regional
15 climatology, local meteorology, on-site meteorologic
16 and measurements program, short-term atmospheric
17 dispersion estimates for design basis accident
18 releases and long term atmospheric dispersion
19 estimates are routine releases, the EPR FSAR states
20 that the COL applicant is to provide this
21 information as part of the COL application. The
22 staff finds this acceptable.

23 Meteorological site parameters. Tier 1,
24 Table 5.0-1 and Tier 2, Table 2.0-1, of the EPR FSAR
25 identify climatic and atmospheric dispersions site

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 parameters. These site parameters are the
2 postulated meteorological features assumed for the
3 site which the applicant used to design its
4 facility. The climatic site parameters were
5 selected to ensure the facility is being designed
6 such as potential threats from the physical
7 characteristics of a potential site such as regional
8 climatic extremes and severe weather will not pose
9 an undue risk to the facility in accordance with GDC
10 2.

11 The accident atmospheric dispersion site
12 parameters were selected to help demonstrate that
13 the radiological consequences of design basis
14 accidents, both off-site and in the control room,
15 meet radiation dose criteria specified in 10 C.F.R.
16 5245 and GDC 19.

17 The routine release atmospheric
18 dispersion site parameters were selected to help
19 demonstrate that calculated off-site concentrations
20 and dose consequences of routine airborne
21 radioactive releases meet criteria specified in 10
22 C.F.R., Part 20 and Appendix I, 10 C.F.R., Part 50.

23 The COL applicant needs to demonstrate
24 that his meteorological site characteristics fall
25 within the EPR meteorological site parameters

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 pursuant to 10 C.F.R. 52.79. Should the
2 meteorological site characteristics not fall within
3 the EPR meteorological site parameters, the COL
4 applicant must provide supporting justification that
5 the proposed facility is acceptable at the proposed
6 site. The staff evaluated the EPR meteorological
7 site parameters in accordance with the Standard
8 Review Plan to ensure they are representative of a
9 reasonable number of sites that may be considered
10 within a COL application. Details regarding this
11 evaluation will be presented during the next several
12 slides.

13 Climatic site parameters. The EPR FSAR
14 presents climatic site parameters related to winter
15 precipitation for roof load design, maximum wind
16 speed other than tornado, tornado, air temperature
17 and the ultimate heat sink meteorological
18 conditions, the winter precipitation site parameter
19 values for roof load design. The applicant's winter
20 precipitation site parameters are used to determine
21 the winter precipitation live loads on the roof of
22 seismic category 1 structures as discussed in FSAR
23 Chapter 3.

24 The staff compared the applicant's
25 winter precipitation site parameters barriers

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 against snowfall data recorded at weather stations
2 located throughout the contiguous United States and
3 found that the applicant's site parameter values
4 bounded most sites. The staff therefore concluded
5 that there is reasonable assurance that the
6 applicant's winter precipitation site parameter
7 values can be expected to be representative of a
8 reasonable number of potential COL sites. The staff
9 finds this acceptable.

10 The maximum wind speed other than
11 tornado site parameter values. The staff reviewed
12 the applicant's maximum wind speed site parameter
13 value by comparing it to wind loading design
14 criteria presented in ASCE-705, which is the
15 American Society of Civil Engineers' standard for
16 minimum design loads for buildings and other
17 structures.

18 The staff found that the EPR maximum
19 wind speed site parameter value meets the ASCE-705
20 wind loading design criteria except for a small
21 portion of the Coastal South and Southeast United
22 States. Consequently, the staff included that the
23 applicant's maximum wind speed site parameter value
24 is representative of a reasonable number of sites
25 that may be considered within a COL application.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The finds this acceptable.

2 CHAIRMAN POWERS: I'm struggling with --
3 suppose that you've gone in and found out only half
4 the Continental United States had values within?
5 That's okay?

6 MR. HARVEY: No.

7 CHAIRMAN POWERS: No?

8 MR. HARVEY: No, as a matter of fact,
9 one of the open items regarding wet bulb temperature
10 design basis, which is met by less than half of the
11 sites in the United States. So we would ask that
12 the applicant go back and reconsider beefing up the
13 design using a higher design basis temperature or --

14 CHAIRMAN POWERS: Suppose it was 75
15 percent?

16 MR. HARVEY: The applicants have been
17 telling us that their designs are able to be sited
18 at between 70 and 80 percent of the sites throughout
19 the United States. So, I would look for a number
20 that at least met that --

21 CHAIRMAN POWERS: Oh, okay. So, you're
22 looking for something more than 70 percent?

23 MR. HARVEY: Yes, generally that's
24 correct.

25 CHAIRMAN POWERS: Just a question of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 curiosity on my part.

2 MR. HARVEY: The tornado site parameter
3 values. The staff reviewed the applicant's tornado
4 site parameter values by comparing them to design
5 basis tornado characteristics specified in Revision
6 1 to Reg Guide 1.76. The staff found that the
7 tornado site parameter values chosen by the
8 applicant are the same as tornado intensity Region 1
9 design basis tornado characteristics specified in
10 Reg Guide 1.76 where Region 1 represents the central
11 portion of the United States where the most severe
12 tornadoes typically occur. The staff finds this
13 acceptable.

14 There was a discussion earlier about the
15 criteria for selection of these. It is basically a
16 return period of ten to the minus seven per year is
17 the frequency of tornado occurrence.

18 MEMBER STETKAR: It can't be a return
19 period for the frequency of that intensity. It has
20 to be something to do with also the probability that
21 the tornado hits a certain target area. Because it
22 can't be a ten to the minus seven return period.

23 MR. HARVEY: Target area is an area of
24 200-300 meters across.

25 MEMBER STETKAR: Two to three-hundred

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 square meters?

2 MR. HARVEY: I think if you look at the
3 target as a linear. Because if the tornado is going
4 this way, the path would be 200-300 meters across.

5 MEMBER STETKAR: Those frequencies are
6 not supported by actual data. If you just look at
7 tornado touchdown frequencies.

8 MR. HARVEY: Well again, most of the
9 touchdowns are the lower strength tornadoes. The
10 higher --

11 MEMBER STETKAR: Oh, that's absolutely
12 true, but we're talking about touchdown frequencies.

13 MR. HARVEY: -- wind speeds that we're
14 talking about. There is NUREG --

15 MEMBER STETKAR: I'm looking at that
16 right now. I haven't read it yet. I'm looking
17 at --

18 MR. HARVEY: Forty-four-sixty-one.

19 MEMBER STETKAR: -- actual tornado data
20 that have been compiled to look at touchdown
21 frequencies as a function of tornado intensity.
22 And, you know, I'm not sure where in the United
23 States you'd ever see a ten to the minus seven.
24 Western North Central perhaps, but ten to the minus
25 seven per year is just not supported in terms of a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 touchdown frequency. Now, an impact frequency, if
2 the target is small enough, I could understand that.
3 If it's a very, very small target. If you're
4 looking at a point estimate target trying to hit.

5 MR. HARVEY: It's a little larger than a
6 point estimate.

7 MEMBER STETKAR: But I haven't --

8 MR. HARVEY: Yes, the NUREG-4461 --

9 MEMBER STETKAR: I'm going to study that
10 tonight. Thanks.

11 MR. HARVEY: Okay. The air temperature
12 site parameter values. The applicant provided zero
13 percent exceedance and one percent exceedance air
14 temperature site parameter values for use in the
15 design and sizing of plant cooling equipment. The
16 zero percent exceedance values are stark high and
17 low values, whereas the one percent exceedance
18 values, assuming they are annual exceedance values,
19 are values that are expected to be exceeded on
20 average 88 hours per year since there are 8,760
21 hours in a typical year.

22 In reviewing the applicant's one percent
23 exceedance air temperature site parameter values,
24 the staff could not ascertain whether the one
25 percent exceedance values were intended to represent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 annual or seasonal exceedances. In the SER, this is
2 identified as open item 02.03.01-13.

3 The staff could not evaluate the
4 reasonableness of the applicant's one percent
5 exceedance air temperature site parameter values
6 until the applicant indicates whether these site
7 parameter values represent annual or seasonal
8 exceedances.

9 The staff reviewed the applicant's zero
10 percent exceedance air temperature site parameter
11 values by comparing them against temperature data
12 compiled by the American Society of Heating,
13 Refrigeration and Air Conditions Engineers, or
14 ASHRACE. There are over 600 weather stations
15 scattered throughout the Continental United States.
16 The staff found that except for the non-coincidence
17 wet bulb site parameter value, the applicant's zero
18 percentage exceedance air temperature site parameter
19 value, found most of the weather stations listed in
20 the ASHRACE database.

21 In response to a staff request for
22 additional information, the applicant stated the
23 non-coincident wet bulb site parameter is used
24 solely as the design point in sizing the ultimate
25 heat sink cooling towers and that the cooling tower

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 design was validated using bounding time-dependent
2 wet bulb temperature profiles from four COL
3 application sites. Consequently, the staff has
4 asked the applicant to consider deleting the non-
5 coincident wet bulb as a site parameter because
6 there is no benefit specifying a site parameter
7 value that is known to be exceeded at a number of
8 locations. In the SER, this is identified as open
9 item 02.03.01-14.

10 The ultimate heat sink meteorological
11 condition site parameter values. The EPR standard
12 plant design includes four mechanical draft cooling
13 towers which serve as the plant's ultimate heat
14 sink. The applicant presented a 72-hour set of wet
15 bulb and concurrent dry bulb temperature values as a
16 site parameter. The applicant used these data as
17 design values to evaluate the maximum evaporation
18 and drift loss of water for the ultimate heat sink.
19 It is not clear to the staff how a COL applicant can
20 demonstrate that a 72-hour set of site-specific
21 temperature values are bounded by the EPR's 72-hour
22 set of site parameter values.

23 The applicant also presented another 24-
24 hour set of wet bulb and concurrent dry bulb
25 temperatures as a site parameter. The applicant can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 use these data as the design basis to evaluate
2 minimum water cooling in the ultimate heat sink.

3 Again, it is not clear to the staff how
4 a COL applicant can demonstrate that a 24-hour set
5 of site-specific temperature values are bounded by
6 the EPR 24-hour set of site parameter values.
7 Consequently, the staff has asked the applicant to
8 consider deleting these two tables as ultimate heat
9 sink site parameter values and moving them into FSAR
10 Chapter 9 to represent the ultimate heat sink design
11 basis. The staff has also asked the applicant to
12 consider adding a COL information item stating that
13 the COL applicant should demonstrate that the
14 ultimate heat sink cooling tower design is validated
15 for their site using site-specific time-dependent
16 temperature profiles. In the SER, this is also
17 identified as part of open item 02.03.01-14.

18 Short-term dispersion site parameters
19 for design basis accident releases. The exclusion
20 area boundary, or EAB, and out of boundary at a low
21 population zone, or LPZ, atmospheric dispersion, or
22 chi over Q site parameters, are used in FSAR Tier 2,
23 Chapter 15 to help demonstrate that the off-site
24 radiological consequences of accidents meets
25 specified radiation dose guidelines as specified at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 10 C.F.R. 52.47.

2 The staff reviewed the applicant's EAB
3 and LPZ chi of Q site parameter values by comparing
4 them to the corresponding site characteristic values
5 identified in the Clinton, Grand Gulf, North Anna
6 and Vogtle Early Site Permits. The staff found that
7 the applicant's EAB and LPZ chi of Q site parameter
8 values bound the corresponding site characteristics
9 for the four ESP sites. Consequently, the staff
10 finds that the applicant's EAB and LPZ chi over Q
11 site parameter values should bound a reasonable
12 number of sites that may be considered within a COL
13 application. The staff finds this acceptable.

14 CHAIRMAN POWERS: So you looked at North
15 Anna, Clinton and Grand Gulf?

16 MR. HARVEY: And Vogtle.

17 CHAIRMAN POWERS: And Vogtle?

18 MR. HARVEY: Yes.

19 CHAIRMAN POWERS: So kind of a square in
20 the middle of the country here. We've run into
21 problems with chi over Q values for some other
22 sites. Why didn't you look at those?

23 MR. HARVEY: Primarily I looked at these
24 four, because these four were fully vetted in chi
25 over Q values --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: That's true.

2 MR. HARVEY: -- by the staff.

3 CHAIRMAN POWERS: Yes. I mean, they had
4 the imprimatur of a lot of people looking at them.

5 MR. HARVEY: And the other ones are
6 still under review.

7 CHAIRMAN POWERS: Yes. Yes, that's
8 true. And there's fair range there.

9 MR. HARVEY: Control room chi over Q
10 site parameters are used in FSAR Tier 2, Chapter 15
11 to help demonstrate that the radiological doses of
12 design basis accidents in the control room meet
13 radiation dose guidelines specified in GDC 19. The
14 staff identified two open items in the SER when it
15 reviewed the applicant's control room chi over Q
16 site parameters.

17 First, the applicant should clarify the
18 source receptor plant configuration information
19 required by COL applicants to model control room air
20 intake chi over Q values. In the SER, this is
21 identified as open item 02.03.04-7.

22 Second, the applicant should provide the
23 source receptor plant configuration information
24 required by COL applicants to model control room
25 unfiltered and leakage chi over Q values. In the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 SER, this is identified as open item 02.03.04-8.

2 CHAIRMAN POWERS: When I asked the
3 applicant about did you ever put a model of this in
4 a wind tunnel or anything, they indicated they had
5 not. And so it's unclear to me, how do you model
6 chi over Q for a plant?

7 MR. HARVEY: For the control room chi of
8 Q?

9 CHAIRMAN POWERS: Yes, for the control
10 room.

11 MR. HARVEY: That is using the ARCON96
12 model.

13 CHAIRMAN POWERS: Oh, okay.

14 MR. HARVEY: Which is under the guidance
15 of Reg Guide 1.94.

16 CHAIRMAN POWERS: So you guys just
17 believe?

18 MR. HARVEY: Well, that was developed 15
19 years ago by PNNL, Van Ramsdell, as was previously
20 mentioned. Based on empirical data that existed at
21 the time of dispersion results in the wake of nearby
22 receptors and building wakes.

23 CHAIRMAN POWERS: -- of that empirical
24 data had anything that looked like this plant?

25 MR. HARVEY: I think it probably

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 represented several different plant designs,
2 existing plants at the time.

3 CHAIRMAN POWERS: It did. I mean, we
4 know where. I mean, he says where we got his data.

5 MR. HARVEY: I'm sorry?

6 CHAIRMAN POWERS: He says where he got
7 his data.

8 MR. HARVEY: Okay.

9 CHAIRMAN POWERS: Didn't look like
10 Sandra's plant. I mean, she's got weird things
11 sticking off of -- I'm picking on you, Sandra, if
12 that's okay. I know you'll get even, right? So you
13 just believe, right?

14 MR. HARVEY: Yes, because, you know, it
15 was a result of a number of different
16 configurations. I mean, I'm not sure that any one
17 given plant is that different in terms of having
18 continued building, reactor building, turbine
19 building, so forth and so on.

20 CHAIRMAN POWERS: Okay.

21 MR. HARVEY: The staff cannot evaluate
22 the reasonableness of the applicant's controlling
23 chi over Q site parameter values until the applicant
24 provides source receptor plant configuration
25 information so that the staff can perform its own

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 independent atmospheric dispersion modeling.

2 Once the applicant provides this
3 information, the staff intends to generate a set of
4 EPR-specific controlling chi over Q values using
5 hourly meteorological data from the four approved
6 Early Site Permit sites to see if the EPR
7 controlling chi over Q site parameter values bound a
8 reasonable number of sites that may be considered
9 within a COL application. This is a staff
10 confirmatory action.

11 Long-term dispersion site parameters for
12 routine releases. The EPR FSAR utilizes routine
13 release or annual average atmospheric dispersion chi
14 over Q and deposition, or D/Q factors in FSAR Tier
15 2, Chapter 11 to calculate off-site concentrations
16 and dose consequences from normal operations to
17 demonstrate compliance of the off-site radionuclide
18 concentration criteria in 10 C.F.R., Part 20 and the
19 dose criteria in Appendix I to 10 C.F.R., Part 50.

20 The staff identified two open items in
21 the FSAR when it reviewed the applicant's routine
22 release chi over Q and D/Q values.

23 First, the routine release chi over Q
24 value, but not the routine release D/Q value is
25 identified as a site parameter. The staff has asked

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the applicant to also list the routine release D/Q
2 value as a site parameter, because the routine
3 release D/Q value is used in FSAR Tier 2, Chapter 11
4 to calculate doses to the maximally-exposed
5 individual. In the SER, this is identified as open
6 item 02.03.01-6.

7 And secondly, the applicant should
8 clarify the release plant information required by
9 COL applicants to model site-specific routine
10 release chi over Q and D/Q values. In the SER, this
11 is identified as open item 02.03.05-7.

12 The staff reviewed the applicant's
13 routine release chi over Q and D/Q values by
14 comparing them to the corresponding site
15 characteristic values identified in the Clinton,
16 Grand Gulf, North Anna and Vogtle Early Site
17 Permits. The staff found that the applicant's
18 routine release chi over Q and D/Q values bound the
19 corresponding site characteristics for the four ESP
20 sites. Consequently, the staff finds that the
21 applicant's routine release chi over Q and D/Q
22 values should bound a reasonable number of sites
23 that may be considered within a COL application.
24 The staff finds this acceptable.

25 Meteorological COL information items.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 The EPR FSAR contains several meteorological-related
2 COL information items which can be summarized as
3 follows:

4 The COL applicant is to provide
5 information on climatic and atmospheric dispersion
6 site characteristics, and, if a COL applicant
7 identified site-specific meteorological values
8 outside the range of the EPR site parameter values,
9 then the COL applicant will demonstrate the
10 acceptability of the design giving the site-specific
11 values and the appropriate sections of the COL
12 application. The staff finds the scope of the
13 applicant's COL information items to be appropriate.

14 In conclusion, pending resolution of the
15 meteorological-related open items, the staff hopes
16 to be able to eventually conclude that: 1) the
17 applicant has identified an appropriate list of site
18 parameters; and 2) the values assigned to each of
19 the site parameters are expected to be
20 representative of a reasonable number of sites that
21 may be considered for a COL application.

22 Are there any questions?

23 CHAIRMAN POWERS: Any questions on this
24 subject?

25 MEMBER STETKAR: No.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN POWERS: I think when we get to
2 the control room, we're going to go through that a
3 little more carefully just as a point, because I
4 need to understand better how you calculate one of
5 these things, just to say head's up, because we will
6 probably discuss that a little more carefully in
7 connection with that. I don't think we'd make any
8 progress discussing it here in connection with the
9 site characteristics. Okay? Let's move on.

10 MS. TESFAYE: Okay. Thank you, Brad.

11 Our next presenter is Ken See and he'll
12 present Section 2.4, hydrologic engineering.

13 Ken?

14 MR. SEE: Thank you. My name is Ken
15 See. I'm a hydrologist in the Division of Site and
16 Environmental Reviews, Hydrologic Engineering Branch
17 and I'm going to discuss briefly Section 2.4,
18 hydrologic engineering.

19 You've seen these sections before
20 presented by AREVA, and I'm not going to go into
21 each one of them in detail like they did. Needless
22 to say that the COL applicant will have to provide
23 information covering each one of these sections in
24 their application.

25 CHAIRMAN POWERS: Well, I guess, I mean,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 one of the things that we discussed in the
2 hydrologic modeling of the site is you got to model
3 the site now to put this plant, which weighs a lot,
4 on it. The hydrologic model all changes.

5 MR. SEE: Yes.

6 CHAIRMAN POWERS: And do they provide in
7 their application sufficient information in order
8 for the COL applicant to in fact calculate how a
9 hydrologic model on the site should be changed?

10 MR. SEE: Most COL applicants will have
11 their now specific design, you know, for parking
12 lots, impervious surfaces, things of this nature.
13 There are drainage systems for extreme storm events.
14 It's laid out in detail in their COL applications.
15 And we haven't had any issues, interface issues
16 between the DCD and the COL applicant. They're
17 using pretty much standard plant layouts with some
18 minor variations that are taken into consideration
19 during the COL stage.

20 CHAIRMAN POWERS: But the COL applicant
21 is responsible for -- well, I'm just asking; do they
22 provide enough information to him, I mean,
23 presumably you'll ask. I bet after he's bought
24 something he probably has a little clout to get
25 information.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. SEE: Yes. The answer is yes.

2 CHAIRMAN POWERS: Okay. See, I'm so
3 easy to place.

4 MR. SEE: Unlike the meteorology
5 sections, we only have three parameters to deal
6 with.

7 CHAIRMAN POWERS: Does that reflect that
8 you're more sophisticated or less sophisticated than
9 the meteorologists?

10 MR. SEE: We're just better. Better.
11 Just kidding.

12 The first two, they're variable weather
13 level, which is roughly a meter and they're flood
14 level, which is a foot below grade. Those values
15 identified in other applications, like AP1000 or
16 ESBWR, they are very close to the values that were
17 presented in the Utility Requirements Document and
18 evaluated in NUREG-1242. So we believe those values
19 are reasonable.

20 Earlier there was some discussion about
21 how are we going to ensure that they meet these
22 requirements, and our branch is looking at the
23 possibility of getting the COL applicants to commit
24 in their safety analysis reporting commitment to
25 monitor their data if we believe there's, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 a probability of them exceeding these values. So,
2 as part of any NEI 08, they're doing monitoring
3 anyway for radioactive. So we're not talking about
4 a large (off microphone). So we are thinking about
5 these issues.

6 The maximum rainfall rate they're using
7 here comes straight out of the hydrometeorological
8 reports 51 and 52, so we have no issues with that.

9 CHAIRMAN POWERS: So you're really
10 happy?

11 MR. SEE: Yes, we have no items. You
12 know, they've done their job.

13 CHAIRMAN POWERS: You are good, aren't
14 you?

15 MR. SEE: We had a few clarifying
16 questions, but they're all resolved. Yes.

17 Any other questions?

18 (No audible response.)

19 CHAIRMAN POWERS: Let's charge ahead.

20 MS. TESFAYE: Thank you, Ken.

21 Next presenter is Dr. Wang. He'll be
22 doing 2.5, geology, seismology and geotechnical
23 engineering.

24 Dr. Wang, please?

25 DR. WANG: Good afternoon. My name is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Weijun Wang. I'm a geotechnical engineer at the
2 NRC. I get some talking about myself.

3 I'm going to present the summary of
4 staff review on the U.S. EPR, Section 2.5. There
5 are five subsections in Section 2.5 and AREVA
6 already present all the requirement for the COL
7 applicant. So I won't repeat that.

8 The Section 2.5 is related to geology,
9 seismology and geotechnical engineering. Before I
10 go on for the presentation, I would like to point
11 out there is a mis-concept about the Section 2.5,
12 because some people the geology, seismology, the so
13 forth, as all site-specific. So therefore, it's
14 nothing in here in the standard design. The
15 alternate is not the case. Because for any reactor,
16 you have to build on a site and put that structure
17 on some type of foundation and support by some
18 material. In structure analysis you have to assume
19 some soil profile there. You have to consider all
20 the loading come from static load or the dead load,
21 dynamic load and the seismic load. So because that,
22 the designer has to assume some site parameters
23 here.

24 And also the focus on two aspect for
25 these sections. One is we review the assumed site

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 parameters to see those parameters are reasonable
2 and to see those site parameters consider that most
3 potential U.S. site for new reactors. The other
4 aspect is we look that to see the all the
5 requirements for the COL applicant are following the
6 guideline of our regulatory.

7 So, based on that, we found out that the
8 standard design for the U.S. EPR establish the
9 subsurface acceptance criteria and the site
10 parameters for a site. For example, it provides the
11 site parameter for minimum bearing capacity, the
12 minimum shear wave velocity, subsurface uniformity
13 and the maximum settlement amount other site
14 parameters.

15 We still have one open item which is and
16 AREVA already point out, because the Mr. Chairman
17 asked a question what's the open item, which is
18 regarding the dynamic bearing capacity. The FSAR of
19 the U.S. EPR provided the values for dynamic bearing
20 capacity, but it did not provide the details how
21 this value was determined. And the staff think
22 that's important because the dynamic bearing
23 capacity is affect by many factors, if not the
24 structure itself. It's affected by the soil profile
25 used in the analysis and affected by all the loading

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 conditions and the combinations. So therefore, we
2 need to get the detail, the information about the
3 analysis the applicant performed and they model they
4 use, and how they got those value.

5 Another point I would like to present is
6 something unique for this U.S. EPR design, which is
7 this design provided three, not single one, is three
8 certified seismic design response spectra. So
9 because of that, we issue RAIs regarding this
10 feature. And we are clear. I believe it's clear to
11 us that all three the CSDRS are standard design,
12 which were based on the curve generated in soil
13 profile in the design structural analysis. And then
14 they divided the other ten soil profiles into three
15 groups, namely soft, medium and hard site. And all
16 the three response spectrum are anchored on .3 g
17 peak ground acceleration. Next slide it will show
18 the figure of that three seismic designs response
19 spectra.

20 So, if you look at this slide, there are
21 three curves that represent the response spectra for
22 the soft, medium and the hard site. And this then
23 design and also the response to our staff RAI made
24 it clear for any site you have to perform your site-
25 specific site response spectra. And then you need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 computer. You have the force, the site-specific
2 force with those other design response spectrum.
3 And as I consider U.S. site-specific soil profile
4 with other ten generic soil profile used in the
5 design and then to see if the site-specific, the
6 force is enveloped by one of the three, the standard
7 design response spectrum. So if for any reason, for
8 example, your soil profile, your site-specific soil
9 profile is outside of the group or your site-
10 specific not enveloped by one of the standard
11 design, you have to perform a site-specific SSI
12 analysis. So this is a very unique feature here.
13 So that's why I would like to present here.

14 MEMBER SHACK: But do they actually end
15 up covering then a wider range of conditions, or
16 have the other people been more conservative in
17 choosing the profiles?

18 DR. WANG: Well, to answer your
19 question, first of all, the people can't design
20 anything. They can assume that any the seismic
21 input for their design. But the point here is,
22 those assume, right? It's not something real for
23 one particular site. But those assumed response
24 spectra have to cover most of the potential site in
25 the U.S.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And another point here, if you assume a
2 very wide or broad the site-specific response
3 spectrum as your input, that will require you to
4 design a structure that can withstand less kind of
5 the seismic input. That will make the structure
6 design more difficult.

7 On the other hand, if you use a very the
8 low seismic response spectra as your input, you
9 certainly then will be much easier, but you will
10 have hard time to find a site that fit your design.
11 So it's hard to say which design is more
12 conservative and which one is less conservative.

13 MR. MUNSON: But I think it's fair to
14 say; this is Cliff Munson, that the EPR design is
15 looking to be able to be sited at a number of sites.
16 This is the reason why they use the three different
17 spectra. And we're hearing that perhaps there's
18 going to be a fourth to cover even more of the
19 harder rock sites in the future. So that's --

20 MEMBER SHACK: Their intent certainly is
21 to cover a very broad range of sites.

22 MR. MUNSON: Right. So that just means
23 they have to do more homework in showing that their
24 structures and components can withstand this ground
25 motion.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: And there's going to be a
2 lot of analysis here.

3 MR. MUNSON: Right.

4 DR. WANG: Now, I come down to the
5 conclusion. Except for the open items and first we
6 feel the postulated parameters, the site parameters
7 used as a design basis reasonable and I already gave
8 some examples there. And all the site parameters
9 are list in the Tier 1, the table 5.1-1 and also in
10 Tier 2, table 2.1-1. I will not list any of those.

11 And also, we feel the requirement for
12 the COL applicant to establish a site-specific
13 characteristics in determining whether they meet the
14 standard design parameters followed the NRC
15 regulatory guidelines. That's the end of my
16 presentation.

17 CHAIRMAN POWERS: You're happy.

18 DR. WANG: Yes, I will say because base
19 on our review we looked at the site parameters.
20 Like I mention it before, the seismic certified the
21 seismic design response spectra. The other site
22 parameters such as the like the bearing capacity,
23 like the settlement requirement and the minimum
24 shear wave velocity requirement, and also other
25 parameters such as like the soil yield weight and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 like internal fraction angles. Those parameters are
2 really in both that we see in the range of the
3 engineering practice. Like I gave you example, if I
4 see like a site parameter saying the soil yield
5 weight like 80 pound per cubic feet, I will say no,
6 it's not a reasonable design because in engineering
7 practice you will probably -- as very few places
8 will find a soil yield weight like 80 pound per the
9 cubic feet. The problem is just the math, you know?
10 Like a mistake in math, something like that.

11 So, as long as I see all the parameters
12 within the normal range of engineering practice,
13 yes, I'm happy with that.

14 CHAIRMAN POWERS: One of the questions
15 that comes up is, we have recently had in Japan a
16 very significant earthquake and both of the plants
17 affected by that earthquake did fine by and large,
18 but by and large means a lot of things. The
19 question comes up, how do we know that the set of
20 parameters we use to characterize a seismic event
21 are indeed adequate? Because things happened at
22 that plant.

23 DR. WANG: Well, to answer your
24 question, yes, in Japan they experienced a much
25 higher seismic event than the original designs. All

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 I can tell to you now is that issue NRC is in
2 consideration. But for this particular design, it's
3 one because in the U.S. and we have not had that
4 magnitude of the earthquake for any the either
5 existing nuclear power plant site or any potential
6 site. As the standards design I would say that like
7 for the all the seismic response spectrum anchor, a
8 .3 g max peak ground motion of the region is
9 reasonable assumption here. And also because our
10 regulatory guide requires at least .1 g peak ground
11 motion of the region. So based on that, at least
12 for their standard design it meet our regulatory
13 guidance. And I think my branch chief Cliff may
14 want to add something regarding the seismic.

15 MR. MUNSON: If you'll recall Dana, we
16 have our performance-based approach now for seismic
17 for establishing the site-specific GMRS. And that's
18 set at ten to the minus five for the onset of
19 inelastic deformation, which is well short of
20 seismic core damage, or the kind of frequencies
21 you'd expect for core damage. So, I think the
22 requirements we have in terms of what we require the
23 siting the COL applicants and the ESP applicants to
24 use to determine their ground motion in conjunction
25 with what Weijun was talking about in terms of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 certified design. And then the requirements for
2 them, if they exceed the Certified Design to do
3 site-specific SSI to show. I think those
4 requirements would ensure that -- you know, we never
5 know that there's -- you know, there could be a
6 fault, you know, that we don't know about, but you'd
7 think that there would be seismicity and some sort
8 of, you know, the geologic characteristics and
9 evidence that we look at to determine the seismic
10 characterization. I think we're pretty demanding in
11 terms of that criteria.

12 CHAIRMAN POWERS: Yes, I agree with
13 everything you've said and this really isn't an
14 issue for the COL applicant or the staff, either
15 one. It's a question more of your research program,
16 whether we have an adequate characterization of
17 seismic events or not. So maybe I'm just thinking
18 aloud here.

19 Okay.

20 MEMBER SHACK: I do have a question,
21 though. You know, we always base this on this onset
22 of inelastic deformation, which is fine for
23 structures. But it's never clear to me that that's
24 the right criterion that we're making sure that all
25 our components meet. And, you know, we've changed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the seismic hazard and I'm sure the building will
2 still be standing --

3 CHAIRMAN POWERS: And everything works
4 inside.

5 MEMBER SHACK: You know, I'm not quite
6 as confident that everything will be working.

7 MR. MUNSON: Yes, this kind of gets into
8 our engineering Chapter 3 kind of --

9 MEMBER SHACK: Right. It's a different
10 topic.

11 MR. MUNSON: It's a different topic, so
12 I'm probably not the best person to discuss this.
13 But I do know that they have specific shake table
14 requirements for electrical components and, you
15 know, mechanical components also.

16 MEMBER SHACK: Yes, but when you've done
17 that and you've changed the seismic hazard, you
18 know, we always sort of base this on the probability
19 that we've seen in seismic PRAs up to now, and you
20 kind of then went back and based those as though the
21 structural thing was the limit. And it's not clear
22 to me that that's always been the case.

23 MR. MUNSON: Yes, and I know we look at
24 much more than just structures in --

25 MEMBER SHACK: Okay. It's a topic for a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 different discussion.

2 CHAIRMAN POWERS: We got to keep track
3 of all this.

4 Okay. Any other questions?

5 You're done, right?

6 MS. TESFAYE: Pretty much. I forgot to
7 mention that we had the list of acronyms at the
8 back.

9 CHAIRMAN POWERS: We probably couldn't
10 have survived with out them, right? Now I know what
11 EAB means, yes.

12 MS. TESFAYE: I'll make sure to mention
13 this --

14 CHAIRMAN POWERS: I don't think you need
15 to. I think you've done --

16 MS. TESFAYE: That concludes our
17 presentation of Chapter 2.

18 CHAIRMAN POWERS: Any other questions to
19 present?

20 (No audible response.)

21 CHAIRMAN POWERS: Okay. Then, Mr.
22 Stetkar, you owe me something. Mr. Ryan, I'd
23 appreciate something from you, sir.

24 MEMBER RYAN: Thank you, sir.

25 CHAIRMAN POWERS: And as I outlined at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the beginning of this meeting, we are not going to
2 bring this topic up at this coming ACRS meeting,
3 that we will wait until some time after our meeting
4 on the 19th. I assume you'll all be there. And we
5 will collect those things together and then we'll
6 make a decision on what to take to the full
7 Committee. So, I will probably inform the full
8 Committee that we've had this meeting. I will
9 probably not say anything beyond though what the
10 topics were.

11 So with that, unless there are any other
12 comments from the members --

13 PARTICIPANT: Move to adjourn.

14 CHAIRMAN POWERS: -- then I will adjourn
15 us.

16 (Whereupon, the meeting was adjourned at
17 3:36 p.m.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701



Presentation to the ACRS Subcommittee

AREVA EPR Design Certification Application Overview

**Getachew Tesfaye
Project Manager**

November 3, 2009

Major Milestones Chronology



| | |
|------------|-------------------------------------------------------|
| 12/02/2004 | Pre-application activities began |
| 12/11/2007 | Design Certification Application submitted |
| 02/25/2008 | Application accepted for review (docketed) |
| 03/26/2008 | Review scheduled published |
| 01/29/2009 | Phase 1 review completed |
| 03/19/2009 | Revised schedule published |
| 05/29/2009 | U.S. EPR FSAR, Revision 1 submitted |
| 06/25/2009 | Revised schedule published |
| Aug-Oct,09 | Phase 2 review completed for Chapters 2,8,10, and 12. |
| 11/03/2009 | ACRS begins Phase 3 review |

Review Schedule




| Task | Target Date |
|----------------------------------------------------------------------------------------------------------|--------------------|
| Phase 1 - Preliminary Safety Evaluation Report (SER) and Request for Additional Information (RAI) | Completed |
| Phase 2 - SER with Open Items | June 30, 2010 |
| Phase 3 – Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Open Items | September 28, 2010 |
| Phase 4 - Advanced SER with No Open Items | April 2011 |
| Phase 5 - ACRS Review of Advanced SER with No Open Items | July 2011 |
| Phase 6 – Final SER with No Open Items | September 2011 |
| Rulemaking | February 2012 |

ACRS Phase 3 Review Plan



| FSAR Chapters Grouped by Phase 2 Completion Date | | | | | | | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------|------------------|--------------------------------------------|----------|----------|------------------|-----------------------------------|
| Group | Chapters | Chapter Issuance | ACRS Meeting | Group | Chapters | Chapter Issuance | ACRS Meeting |
| 1A | 2 | 08/31/2009 | 11/03/2009 | 3 | 3 | 04/02/2010 | May 2010 (2 days TBD) |
| | 8 | 08/20/2009 | | | 7 | 04/02/2010 | |
| 1B | 10 | 10/19/2009 | 11/19/2009 | | 9 | 04/07/2010 | |
| | 12 | 10/07/2009 | | | 18 | 03/30/2010 | |
| 2A | 4 | 11/17/2009 | 02/02/2009 & 02/03/2009 | 4 | 1 | 05/28/2010 | July 2010 (3 days TBD) |
| | 5 | 12/22/2009 | | | 6 | 05/11/2010 | |
| | 16 | 12/30/2009 | | | 13 | 04/08/2010 | |
| | 17 | 12/03/2009 | | | 14 | 05/28/2010 | |
| 2B | 11 | 01/25/2009 | 03/03/2009 | | 15 | 05/11/2010 | |
| | 19 | 12/22/2009 | | | | | |
| Closing: <ul style="list-style-type: none"> ▪General Plant Description (final) and summation of open items ▪Cross-cutting issues and re-visit earlier chapters as needed | | | | | | | Sept 2010 (1 day TBD) |



AREVA NP Inc.

Presentation to ACRS

U.S. EPR Subcommittee

Design Certification Application

FSAR Tier 2 Chapter 8



EPR is a trademark of the AREVA Group.



Chapter 8, Electric Power: Chapter Topics




- ▶ 8.1 Introduction
- ▶ 8.2 Offsite power system
- ▶ 8.3 Onsite power system
- ▶ 8.4 Station blackout
- ▶ Summary

Chapter 8, Electric Power

8.1 Introduction


U.S. EPR Safeguards Divisions



Chapter 8, Electric Power

8.1 Introduction

Arrangement of Electrical Systems



Chapter 8, Electric Power

8.1 Introduction

U.S. EPR Electrical Systems



- ▶ **Switchyard – COLA Specific**
- ▶ **Offsite Power**
 - ◆ 3 Normal Auxiliary Transformers (NATs) – offsite power to non-Class 1E buses
 - ◆ 2 Emergency Auxiliary Transformers (EATs) – offsite power to Class 1E buses
- ▶ **Onsite Power AC**
 - ◆ Normal Power Supply System (NPSS) – non-Class 1E buses (6 trains)
 - ◆ Emergency Power Supply System (EPSS) – Class 1E buses (4 divisions)
 - ◆ Emergency Diesel Generators (EDGs) – 4 EDGs
 - ◆ Station Blackout Diesel Generators (SBODGs) – 2 SBODGs
- ▶ **Onsite Power DC**
 - ◆ Non-Class 1E Uninterruptible Power Supply (NUPS) – non-Class 1E (2 trains)
 - ◆ Class 1E Uninterruptible Power Supply (EUPS) – Class 1E (4 divisions)
 - ◆ 12 Hour Uninterruptible Power Supply (12UPS) – non-Class 1E (2 trains)

Chapter 8, Electric Power

8.1 Introduction

U.S. EPR Design Overview



▶ **U.S. EPR™ Design features that are fundamentally the same as previous designs**

- ◆ Two Independent Offsite Feeds
- ◆ Degraded Voltage System for Emergency Buses
- ◆ Emergency Diesel Generator Load Sequencing
- ◆ Containment Electrical Penetration Protection
- ◆ 2 Hr Emergency Battery Capacity (X4)
- ◆ Station Blackout Diesel Generator added or Coping Capability Verified

Chapter 8, Electric Power

8.1 Introduction

U.S. EPR Design Overview




► What is Different?

- ◆ Four Emergency Diesel Generators (EDGs) Per Unit
- ◆ Alternate Electrical Feed Configuration
- ◆ Diesel Load Sequencer is part of the I&C Protection System
- ◆ Two Station Blackout Diesel Generators
- ◆ No Fast Transfer of Plant Loads During Startup, Shutdown, or Plant Trip
- ◆ Separate Offsite Feeds (from SWYD) to Safety and Non-Safety Buses
- ◆ Island Mode
- ◆ 12 Hr Uninterruptible Power Supply (12UPS) System

Chapter 8, Electric Power

8.2 Offsite Power System


U.S. EPR Design (EATs)



Chapter 8, Electric Power



8.2 Offsite Power System

U.S. EPR Design (NATs)



Chapter 8, Electric Power

8.3 Onsite Power System (EPSS)




- NOTES:**
1. NORMALLY OPEN AND MANUALLY OPERATED DEVICES. CIRCUIT BREAKER IS NORMALLY IN SERVICE AC SHOWN. BREAKER IS DISCONNECTED DURING ALTERNATE FEED IMPLEMENTATION.
 2. ALTERNATE FEED IMPLEMENTED IN THIS CIRCUIT. AN INTERLOCK DESIGN IS USED TO PREVENT PARALLEL FEEDS TO A BUS.

Chapter 8, Electric Power

8.3 Onsite Power System (EPSS)

Equipment Location



Chapter 8, Electric Power

8.3 Onsite Power System

Emergency Diesel Generators



- ▶ **Emergency Onsite Power Sources – Four emergency diesel generators (EDGs)**
- ▶ **Minimum EDG output - 9500 kW**
- ▶ **EDG load sequencing performed by the I&C protection system vice a dedicated load sequencer**
- ▶ **Physical separation**
 - ◆ **Electrical separation within Safeguards Buildings**
 - ◆ **Two EDG Buildings located on opposite sides of Reactor Building**
 - ◆ **Each diesel generator is separated within EDG building**

Chapter 8, Electric Power


8.3 Onsite Power System

Alternate Feed, Maintenance Flexibility



- ▶ Alternate feeds are designed to enhance operational capability and flexibility
- ▶ Alternate feeds can only be established between Division 1 and 2 (one divisional pair) or Division 3 and 4 (another divisional pair)
- ▶ Two train components completing redundant safety functions are aligned to different divisional pairs.

8.3 Onsite Power System Alternate Feed Divisional Loads




| Alternate Fed Loads | DIV 1 | DIV 2 | DIV 3 | DIV 4 |
|--------------------------------------|-------|-------|-------|-------|
| EFW Valves | X | X | X | X |
| MSIV's / MSRT's | X | X | X | X |
| MFW Isolation Valves | X | X | X | X |
| S/G Isolation Valves | X | X | X | X |
| PCIV's | X | X | X | X |
| Anti Dilution Valves | X | | | X |
| Extra Boration System | X | | | X |
| Fuel Pool Cooling System | X | | | X |
| Annulus Ventilation | X | | | X |
| KLC System | X | | | X |
| CR Iodine Filtration | X | | | X |
| 2hr Battery Chargers | X | X | X | X |
| HVAC Support / Emergency lighting | X | X | X | X |

Chapter 8, Electric Power

8.3 Onsite Power System

Divisional Pairs




Chapter 8, Electric Power

8.3 Onsite Power System Divisional Pairs

Alignment for EDG No.1 in Maintenance




In Maintenance



Chapter 8, Electric Power

8.3 Onsite Power System Divisional Pairs

Event - EDG No.1 in Maintenance Single Failure of Division 2 EDG



Chapter 8, Electric Power


8.3 Onsite Power System Divisional Pairs

Event - EDG No.1 in Maintenance Single Failure of Division 4 EDG



In Maintenance



Single Failure



Chapter 8, Electric Power

8.3 Onsite Power System

Non-safety power



Chapter 8, Electric Power

8.3 Onsite Power System

Class 1E Uninterruptible Power Supply



▶ EUPS System

- ◆ 4 Divisions of Class 1E batteries and chargers
- ◆ Two battery chargers per division
- ◆ Battery chargers are capable of being fed from the SBODG
- ◆ Redundant feeds to I&C cabinets

▶ Lessons Learned from Forsmark


- ◆ Ensure selectivity between battery charger and inverter protection and coordination settings
- ◆ A power feed from the Class 1E 250 VDC bus through a 250 VDC/24 VDC converter to the I&C cabinets

Chapter 8, Electric Power

8.3 Onsite Power System

Class 1E Uninterruptible Power Supply

DIVISION 3




Chapter 8, Electric Power

8.3 Onsite Power System

Class 1E Uninterruptible Power Supply


DIVISION 3



Chapter 8, Electric Power

8.3 Onsite Power System

Class 1E Uninterruptible Power Supply




Chapter 8, Electric Power

8.3 Onsite Power System

Class 1E Uninterruptible Power Supply

DIVISION 3



Chapter 8, Electric Power

8.3 Onsite Power System

12UPS



- ▶ **12UPS Design Criteria** – A two train system used to provide a source of uninterruptible power to loads for beyond design basis events. Example of loads powered from the 12UPS:
 - ◆ SBO controls
 - ◆ Severe Accident I&C
 - ◆ Severe Accident Depressurization Valves
 - ◆ Control Room Lighting
 - ◆ Outside Containment Isolation Valves
- ▶ **Island Mode** – the plant is designed for a loss of the grid with the main generator providing power to the house loads without a plant trip. Therefore, only the plant's main generator is powering the EATs and NATs.


Chapter 8, Electric Power

8.4 Station Blackout



- ▶ **Alternate AC (AAC) source - two diesel generators**
- ▶ **Connected in Divisions 1&2 and 3&4 at 6.9 kV Buses**
- ▶ **Minimum SBODG output - 3900 kW**
- ▶ **Meets SBO Rule (10 CFR 50.63)**
 - ◆ **Diverse from EDGs**
 - Diverse engine models
 - Located in separate areas of the plant
 - SBODG air cooled vice EDG water cooled
 - No sharing of auxiliaries- engine cooling (radiator), control power, fuel systems
 - Available to the EPSS buses within 10 minutes of the onset of SBO

Chapter 8, Electric Power Summary



► The U.S. EPR™ Electrical System Design:

- ◆ Meets Regulatory Requirements
- ◆ Protects the Health and Safety of the Public
- ◆ Provides a Stable Electrical Supply for Normal Operations
- ◆ Provides a Stable Electrical Supply for Effective Event Management
- ◆ Is Evolutionary:
 - The U.S. EPR™ Electrical Design Incorporates >30 Years of Industry Lessons Learned
 - Offsite Emergency Bus Transformer Feeds are Separated From Offsite Non-Safety Bus Transformer Feeds
 - No shared transformers between safety and non-safety loads
 - Non-safety loads not powered directly from the main generator, therefore no fast transfer scheme required if the reactor trips
 - Electrical Safety System Redundancy Increased
 - Alternate Feed Provides Required Power Supply Redundancy During EDG Maintenance



Backup Slides



EPR is a trademark of the AREVA Group.



Section 8.1

FSAR Revision 1 - Text



U.S. EPR FINAL SAFETY ANALYSIS REPORT

8.0 Electric Power

8.1 Introduction

8.1.1 Offsite Power Description

Offsite power to the U.S. EPR is provided by at least two utility transmission lines connected to the station switchyard. The power plant interfaces with the switchyard at the output of the main generator via the main step-up transformers and at the station auxiliary transformers.

The utility transmission system, location of rights-of-way, transmission lines and towers, and switchyard design and interconnections are site-specific. A COL applicant that references the U.S. EPR design certification will provide site-specific information describing the interface between the offsite transmission system and the nuclear unit, including switchyard interconnections.

During normal operation, the main generator connects to the switchyard via three single-phase step-up transformers to supply power to the transmission system. The plant electrical distribution system receives offsite power during normal plant operating modes, anticipated operational occurrences, and postulated accidents via five auxiliary transformers connected to the switchyard. The U.S. EPR design does not include the traditional unit auxiliary transformer that connects the plant electrical distribution system directly to the main generator output as the normal source during power operation. The preferred power supply (PPS) is the power supply from the transmission system to the Class 1E emergency power supply system (EPSS) which is preferred to provide power under accident and post-accident conditions. Two emergency auxiliary transformers (EAT) provide the PPS from the switchyard to the EPSS with no intervening non-Class 1E switchgear. Three normal auxiliary transformers (NAT) provide power from the switchyard to the non-Class 1E normal power supply system (NPSS).

Offsite power is described in depth in Section 8.2.

8.1.2 Onsite Power System Description

The EPSS distributes 6.9 kV and 480 Vac power to safety-related and select non-safety-related plant loads. There are four divisions of switchgear, load centers, motor control centers (MCC), standby power sources, and distribution system transformers that make up the EPSS as shown in Figure 8.3-2—Emergency Power Supply System Single Line Drawing. Each division includes a Class 1E emergency diesel generator (EDG), which is the standby power source to its particular division in the event of a power loss. Each division has the ability to connect to one of two non-safety-related station blackout diesel generators (SBODG) used as the alternate AC (AAC) source during station blackout (SBO) conditions. An alternate feed is provided from EPSS

Tier 2

Revision 1

Page 8.1-1

RAI Response - Text

Section 8.1 RAIs

For Information Only

| RAI Number | Submittal |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|
| 08.01-01 | 009 |
| RAI Text | |
| Page 8.1-3 (8.1.3) of the FSAR states that "a COL applicant will identify site-specific loading differences that raise EDG or Class 1E battery loading, and demonstrate the electrical distribution system is adequately sized for the additional load." Regulatory Issue Summary (RIS)-2008-06 encourages the agency's design-centered review approach (DCRA) regarding DC and COL applications and describes the level of standardization of a particular design needed in order to make the DCRA effective. The RIS promotes the standardization of COL applications to facilitate the establishment of a predictable and consistent method for reviewing applications. The staff notes that only approximate sizing information for the main generator, EDG, and SBODG is given. It appears that the exact size for the above equipment is left for the Combined Operating License (COL) applicants to decide based on site specific information. COL applicants proposing different sizes for electrical equipment will require additional time which will impact their review schedules. The staff believes that all sizing information for the US-EPR certified design (CD) should be standardized. The staff has reviewed other standardized FSARs and found all adhering to the DCRA concept. All electrical equipment (main generator, EDG, battery and SBODG) sizes should be specified in EPR DC documentation (FSAR) and the decision should not be left to the COL applicants. In addition, all statements including the phrase "a COL applicant will identify site-specific loading differences..." should be amended to reflect this approach. Please fully delineate Areva's position on the standardized equipment sizing issue. | |
| Response Text | |
| The electrical equipment sizes (main generator, emergency diesel generators (EDG), and station blackout diesel generators (SBODG)) were sized and analyzed using the electrical transient analyzer program (ETAP) to provide the safety-related standby power source function (for EDG) plus margin, alternate AC source function (for SBODG) plus margin, and plant output capacity (for main generator). The actual rated size of the main generator, EDG, and SBODG is dependent on which manufacturer is selected to provide the equipment and the nominal values of the associated equipment. The equipment sizes are indicated (e.g., "SBODG size of 3600 kW (or greater)" and "verify an EDG output of 6500 kW or greater"), to provide a minimum equipment size to satisfy the function of the equipment, plus margin, but allows for slight differences in the size of as-procured equipment. The COLA information item verifies that any additional site-specific EDG loads do not exceed the minimum required size for the EDG of 6500 kW plus the 10 percent margin stated in Regulatory Guide 1.9. The required size for the SBODG is 3600 kW and the EDG is 6500 kW. The final ratings of the equipment may be slightly higher as stated above. The main generator output is approximately 2000 MVA but actual nameplate values depend on which turbine-generator manufacturer is selected. The ETAP analysis used 2015 MVA for assumed main generator output and the main step up transformers are sized for 2130 MVA as described in FSAR Table 8.3-1—Onsite AC Power System Component Data Nominal Values. The Class 1E battery size is listed in FSAR Table 8.3-11—Onsite DC Power System Component Data Nominal Values. The COLA item verifies that any additional site-specific Class 1E battery loads do not exceed the required size for the Class 1E batteries plus margin as defined in FSAR Table 8.3-11. | |
| FSAR Impact | |
| The FSAR will not be changed as a result of this question. | |

Wednesday, October 28, 2009

Page 1 of 5

Section 8.2



FSAR Revision 1 - Text

RAI Response - Text



8.2 Offsite Power System

8.2.1 Description

8.2.1.1 Offsite Power

The offsite power system provides power from the transmission system, via the station switchyard, to the plant Class 1E and non-Class 1E electrical distribution system. The offsite power system includes all transmission lines connected to the switchyard, the switchyard equipment (overhead buses, circuit breakers, disconnect air switches), auxiliary transformers, and ends at the input terminals of the switchgear circuit breakers. The preferred power supply (PPS) is the offsite power from the transmission system to the Class 1E emergency power supply system (EPSS) that is preferred to provide power under accident and post-accident conditions. The offsite transmission system and connections to the station switchyard are site-specific. A COL applicant that references the U.S. EPR design certification will provide site-specific information regarding the offsite transmission system and connections to the station switchyard.

The switchyard has connections to at least two transmission lines. The normally energized transmission lines are physically independent circuits that minimize the likelihood of their simultaneous failure under operating and environmental conditions and postulated events, including transmission tower or transmission line failure. These lines do not cross, and no other transmission lines cross above these two lines. Each offsite power circuit is sized to supply the station safety-related and non-safety-related loads during normal and abnormal operation.

The PPS supplies the station Class 1E EPSS buses from two independent overhead lines between the switchyard and the station transformer area via two emergency auxiliary transformers (EAT). The station remains connected to the offsite power sources during normal plant operation regardless of main generator status, without transferring buses or power sources during startup, full power operation, or shutdown. Each PPS circuit is normally in service through its respective EAT.

Three additional overhead lines provide power to three normal auxiliary transformers (NAT) for the station non-Class 1E normal power supply system (NPSS) buses.

Each auxiliary transformer is provided with two on-load tap changers to maintain the supplied bus voltage at the nominal value during transmission system voltage fluctuations, or voltage changes as a result of changes in bus loading. The reference voltage for the on-load tap changer operation is provided by voltage transformers at the respective bus to which the secondary winding is connected. Momentary bus voltage transients (e.g., motor starting) do not result in tap changers affecting bus voltage due to the short nature of the voltage transient. The voltage regulating range is based on the results of the load flow/voltage regulation studies described in Section 8.3.1.3.1.

Section 8.2 RAIs

For Information Only

| RAI Number | Submittal |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----------|
| 08.02-01 | 009 |
| RAI Text | |
| Page 8.2-2 (8.2.1.1) of the FSAR states that "The U.S. EPR does not use an automatic load dispatch system, which eliminates any interference with safety-related actions that may be required of the protection system described in Section 7.1.1.3.1." Explain whether the above sentence is relevant in this section or consider revising if necessary. | |
| Response Text | |
| SRP Section 8.2.III.9 indicates "the review of any automatic TSO action should ascertain that TSO actions (including normal and postulated failure modes of operation) will not interfere with safety actions that may be required of the reactor protection system. This system should also be reviewed to ensure that no failure mode of the TSO system will cause an incident at the generating station which would require protective action." Tier 2 Section 8.2.1.1 provides the description of the offsite power system and the plant interface with offsite power. This sentence indicates there is not an automatic TSO action that will interact with the reactor protection system. | |
| FSAR Impact | |
| The FSAR will not be changed as a result of this question. | |

Section 8.3

FSAR Revision 1 - Text



U.S. EPR FINAL SAFETY ANALYSIS REPORT

- 8.3 Onsite Power System
- 8.3.1 Alternating Current Power Systems
- 8.3.1.1 Description

The main generator provides power through the station switchyard to the transmission system via an isolated phase bus (IPB) system and three single-phase main step-up transformers (MSU). Incoming power to the onsite AC power system is from the station switchyard during all modes of plant operation, through the emergency and normal auxiliary transformers to the Class 1E and non-Class 1E distribution systems respectively.

The main generator is connected to the switchyard via two circuit breakers in the switchyard. Either breaker enables the generator to provide power to the transmission system. During main generator startup and synchronization with the grid, a generator automatic synchronizer is used in combination with an independent synchrocheck permissive relay, which provides a closing signal to the main generator breaker.

Prior to main generator synchronization with the transmission system, the plant loads are fed by the transmission system through the switchyard. The main generator circuit breakers in the switchyard are open at this time. The switchyard and offsite power supply arrangement allows station loads to remain powered from the same source during all plant operating modes and eliminates the need for bus transfers during plant startup or shutdown.

Main generator protection is provided by a primary and backup protection scheme. Protective device actuation trips the main generator output breakers in the switchyard, trips the generator excitation and initiates a turbine trip. Main generator protection includes stator overcurrent, ground fault and reverse power.

The MSU protection detects faults and initiates protection actions to minimize any potential damage to an MSU, while minimizing impact to the electrical distribution system. Protective devices installed for the protection of the MSU include transformer bank differential current, ground fault overcurrent, phase overcurrent and sudden pressure relays. Activation of an MSU protection device results in a turbine generator trip and a separation of the main generator from the grid by tripping the main generator breakers in the switchyard. The onsite electrical distribution continues to be powered from offsite through the switchyard with no power interruption to the onsite power distribution system. No offsite power source transfer is required during this transient.

If the offsite transmission system has a fault that results in a loss of power from the transmission system, the main generator continues to provide power to the plant loads from the switchyard via the normal and emergency auxiliary transformers. The main



RAI Response - Text

Section 8.3 RAIs For Information Only

| RAI Number | Submital |
|-------------|---------------|
| 08.03.01-01 | 011, Suppl. 2 |

RAI Text
Page 8.3-3 (8.3.1.1.1) of the FSAR states that "a loss of voltage at one of 6.6 kV (BDA) buses initiates an automatic fast transfer of the offsite power source, maintaining offsite power to all four divisions by switching the affected bus power supply to the unaffected EAT. The fast transfer minimizes voltage decay and frequency difference to limit motor torque during the transfer, thus minimizing equipment degradation." Explain how the automatic fast transfer scheme works and how the scheme prevents transfer into a faulted bus. Elaborate on whether any single failure vulnerability exists with the transfer scheme between the motive (AC) and control power (DC) within the affected divisions. Is the same transfer scheme used for NPSS?

Response Text
The emergency power supply system (EPSS) fast transfer is a non-safety-related bus transfer that improves the reliability of offsite power by initiating a transfer in specific fault conditions that would otherwise result in the loss of offsite power (LOOP) to EPSS switchgear. A failure in the fast transfer scheme does not affect the capability of the Class 1E emergency diesel generators (EDG) to perform their safety function of supplying electrical power to the EPSS buses in a loss of voltage condition. The offsite power system is designed to remain on the preferred source, offsite power, whenever possible. Otherwise, depending on the postulated failures, the buses will ultimately revert to their safety-related power source, the EDGs. The single point vulnerabilities that can affect the fast transfer are limited to those that will affect a single division. These potential failures beyond the initiating event (emergency auxiliary transformer (EAT) failure) are no different for the fast transfer logic than for a residual voltage bus transfer. For example, the failure of a circuit breaker in the transfer scheme (either normal or alternate) to a BDA bus will limit the impact to that specific division. Additionally, the DC control power that supports the transfer (control power for circuit breaker tripping coils and transfer supervision) is supplied by the Class 1E uninterruptible power supply system of the respective division; therefore, a failure in the control power function is limited to the affected division. In the case of a divisional DC system failure, that division EDG may also be affected. In the case of an offsite power supply breaker failure to close unrelated to a divisional DC system failure, that division EDG will start and re-energize the bus. In each of these conditions where an additional failure beyond the initiating event results in the loss of power to an EPSS division, the remaining three divisions are capable of maintaining plant safe operations (as limited by applicable technical specification required actions) and mitigating design basis events. A fast transfer of the EPSS buses to an alternate emergency auxiliary transformer (EAT) is initiated by a fault related to the normal EAT supply to the bus. The transformer protection (e.g., transformer differential current) that will isolate the faulted transformer also initiates the fast transfer. The dead bus time, or the time from contact parting to contact touching of the opening and closing circuit breakers, is typically limited to three to five cycles. Synchronization of the two sources prior to the fast transfer is verified by a synch check relay, which verifies that the phase angle between the motor bus (e.g., BDA) voltage and the alternate source voltage is within acceptable limits prior to closing the alternate source breaker. This synch check function is accomplished with a two-out-of-three logic scheme that prevents a single failure in the synch check function from permitting a bus transfer to an out-of-phase source. A bus transfer example illustrates how the fast bus transfer scheme prevents either transfer of a faulted bus to an unaffected bus or transfer of an unaffected bus onto a faulted bus. The example will also demonstrate the limit of plant impact if component failure allows the transfer with unacceptable conditions. U.S. EPR FSAR Tier 2, Figure 8.3-2—Emergency Power Supply System Single Line Drawing, Sheet 1 of 3 illustrates the following description. A fault on EAT supply 30BDT01, EPSS buses 31BDA and 33BDA normal supply will initiate the transfer of those buses to the alternate EAT supply, 30BDT02. The transfer involves opening the normal supply circuit breaker and closing the alternate supply circuit breaker using the previously described fast transfer scheme. Because the transfer is initiated by a transformer fault, a faulted bus will not be transferred. The bus is transferred onto the alternate EAT secondary winding, which verifies that the bus is not transferred onto a bus that has the potential to be faulted. If there is a bus (e.g., BDA) fault, the bus protection will trip open and lockout any source breaker associated with affected bus. This protection will prevent transfer of a faulted bus onto a transformer secondary winding that is shared with another bus. For example, a 32BDA bus fault will trip and lockout the source breakers associated with 32BDA (normal and alternate offsite power source and EDG output circuit breakers). A transfer of 31BDA (shares 30BDT02 X winding) would be unaffected by the fault on 32BDA since 32BDA source breakers are locked out. Because the auxiliary transformer protection is provided by diverse actuations, a single failure in a transformer protection device will not prevent the protection of the transformer. For example, a transformer internal fault will likely actuate several protection relays (e.g., sudden pressure, overcurrent, differential current). Single failure of one of the detection and actuation devices will not prevent the isolation of the transformer by the remaining



Section 8.4

FSAR Revision 1 - Text

RAI Response - Text



U.S. EPR FINAL SAFETY ANALYSIS REPORT

8.4 Station Blackout

The term station blackout (SBO) refers to a complete loss of alternating current (AC) electric power to the non-safety-related and safety-related switchgear buses. An SBO involves a loss of the offsite electric power system (preferred power system) occurring at the same time the emergency diesel generators (EDG) are unavailable. An SBO does not include loss of available AC power to buses fed by station batteries through inverters or by alternate alternating current (AAC) sources specifically provided for SBO mitigation.

8.4.1 Description

The U.S. EPR includes an AAC source that has been designed in accordance with 10 CFR 50.63 and RG 1.155. NUMARC 87-00 (Reference 1) was used for clarification, as permitted by RG 1.155. Two separate and independent non-safety-related station blackout diesel generators (SBODG) are provided to mitigate a postulated SBO. The SBODGs have the capacity and capability to bring the plant to, and maintain the power plant in, a non-design basis accident (non-DBA) safe shutdown condition without any support systems powered from the preferred power supply (offsite grid) or emergency power supply system (EPSS). Safe shutdown (non-DBA) means bringing the plant to those shutdown conditions specified in the U.S. EPR Technical Specifications as "hot standby."

8.4.1.1 Station Blackout Diesel Generators

The SBODGs are located in separate areas of the Switchgear Building. An electrical system failure modes and effects analysis is illustrated in Table 8.3-9—Onsite AC Power System Failure Modes and Effects Analysis. The SBODGs do not share control power, heating, ventilation and air conditioning (HVAC), engine cooling, or fuel systems with the EDGs. Considering the support system interdependence and the failure modes listed in Table 8.3-9, there are no weather-related events or single active failures that can disable the SBODGs and EDGs simultaneously. For the purposes of the failure modes and effects analysis, failure of an SBODG is equivalent to a failure of switchgear bus 31BBH or 32BBH. Failure of 31BBH or 32BBH is addressed in Table 8.3-9.

The major system loads the SBODGs provide power to during SBO conditions are:

- The division 1 and division 4 emergency feedwater (EFW) pumps.
- HVAC systems to maintain main control room (MCR) habitability and SBO equipment environments.
- Selected instrumentation and controls (I&C) systems.
- MCR lighting.

Tier 2

Revision 1

Page 8.4-1

Section 8.4 RAIs

For Information Only

| RAI Number | Submittal |
|------------|-----------|
| 08.04-01 | 011 |

RAI Text


Page 8.4-1 (8.4.1) of the FSAR states that the "SBODGs have the capacity and capability to bring the plant to and maintain the power plant in a non-design basis accident (non-DBA) safe shutdown condition without any support systems powered from the preferred power supply (offsite grid) or EPSS. Safe shutdown (non-DBA) means bringing the plant to those shutdown conditions specified in the U.S. EPR technical specifications as hot standby." However, page 21 of SECY 94-1094 recommends the preferred method of demonstrating compliance with 10 CFR 50.63 for evolutionary design to be a spare full-capacity alternate ac (AAC) power source of a diverse design and that the AAC power source powers a larger complement of shutdown equipment to bring the plant to a cold shutdown (not hot standby). Based on the above guidance, the AAC power source should bring the plant to a cold shutdown and the size of AAC should be the same size as an EDG (6000 kW) of US-EPR. The proposed SBODG for US-EPR CD provides 3000 kW which would bring the plant only to hot standby. Explain how EPR plans to satisfy the SECY guidance with regard sizing of the SBODG.

Response Text

Station Blackout End State
It is neither required nor desirable to bring the plant to cold shutdown during a station blackout event. SECY-94-004, "Policy and Technical Issues Associated with the Regulatory Treatment of Non-Safety Systems in Passive Plant Designs," March 28, 1994, is for passive plant designs and therefore does not appear to be directly applicable to the U.S. EPR. However, at page 6 of SECY-90-016, "Evolutionary Light Water Reactor (LWR) Certification Issues and Their Relationship to Current Regulatory Requirements," June 26, 1990, it is stated, "The staff believes that the preferred method of demonstrating compliance with 10 CFR 50.63 is through the installation of a spare (full capacity) alternate ac power source of diverse design that is consistent with the guidance in Regulatory Guide 1.155, and is capable of powering at least one complete set of normal safe shutdown loads." This statement is in support of a staff request that the Commission approve imposition of an alternate alternating current (AC) source for evolutionary advanced light-water reactors (ALWR). By letter dated June 26, 1990, the Commission approved in part and disapproved in part the staff's recommendations in SECY-90-16. With respect to station blackout, item II.C (page 3) states, "The Commission (with all Commissioners agreeing) has approved the staff's position that the evolutionary ALWRs have an alternate ac power source of diverse design capable of powering at least one complete set of normal shutdown loads." This statement does not identify the required end state operating mode.
The definition, "alternate ac source" contained in 10 CFR 50.2 states that an alternate AC source "has sufficient capacity and reliability for operation of all systems required for coping with station blackout and for the time required to bring and maintain the plant in safe shutdown," and provides that "Safe shutdown (non-design basis accident (non-DBA)) for station blackout means bringing the plant to those shutdown conditions addressed in plant technical specifications as Hot Standby or Hot Shutdown, as appropriate (plants have the option of maintaining the RCS at normal operating temperatures or at reduced temperatures)."
Regulatory Guide 1.155, "Station Blackout," provides a method for determining the required coping duration. For the U.S. EPR, this duration is no more than 8 hours, and may be less depending on the result of certain site-specific "factors" defined in Regulatory Guide 1.155. Regulatory Guide 1.155 and the NRC correspondence included in Appendix K to NUMARC 87-00, Revision 1, provide NRC endorsement of NUMARC 87-00, Revision 1, "Guidelines and Technical Bases for NUMARC Initiatives Addressing Station Blackout at Light Water Reactors." NUMARC 87-00, Revision 1, Appendix I Question I.8.119 also defines safe shutdown as "hot shutdown or hot standby as appropriate."
As stated in U.S. EPR FSAR Tier 2 Section 8.4.2.8.1, the U.S. EPR design envelopes an eight hour coping duration for the worst case site conditions. This duration was determined in accordance with Regulatory Guide 1.155, Table 2, "Acceptable Station Blackout Duration Capability," and NUMARC 87-00, Revision 1, Section 3, "Required Coping Duration Category." As defined by 10 CFR 50.2, "Station Blackout" means a complete loss of alternating current power to the essential and non-essential switchgear buses. Therefore, the Reactor Coolant Pumps are unavailable during a station blackout. The cooldown rate during the resulting natural circulation cooldown is greatly reduced as compared to a normal cooldown, so that cold shutdown is not achievable during an eight-hour station blackout event. Even if a cooldown to cold shutdown was possible, this would be undesirable, because it would cause shrinkage of the reactor coolant system inventory.
Alternate AC Source (Station Blackout Diesel Generator) Size
The alternate AC source and emergency diesel generators (EDG) have different design bases, and therefore the nominal sizes are different.
Referring again to 10 CFR 50.2, the alternate AC source is defined to have sufficient capacity for operation of all systems required for coping with station blackout and for the time required to bring and maintain the plant in safe shutdown (non-design basis accident). Conversely, the EDGs are specifically designed to power design basis

Wednesday, October 28, 2009

Page 1 of 13



U.S. EPR Electrical Distribution System (EDS), Model Development & System Analyses

Dr. Zia Salami, Ph.D.

Advisory Electrical Engineer


November 03, 2009



EPR is a trademark of the AREVA Group.




EDS Model Development and System Analyses



- ▶ **Objective**
- ▶ **Approach and methodology**
- ▶ **System evaluation and summary of results**
- ▶ **Conclusion**

EDS Model Development and System Analyses




► Objective:

◆ To analyze U.S. EPR, EDS design:

- To verify the distribution system is adequate and can perform its required function during the various loading scenarios, configurations and design basis accidents considering worst case offsite and/or onsite power source configuration, based on the following major criteria:
 - Equipment (e.g., EDG/SBODG, transformers, buses, circuit breakers, cables):
 - Continuous and short-time (momentary) loadings
 - Short-circuit capabilities and ratings
 - Acceptable continuous and momentary voltages, current, and power flow capabilities
 - Availability (standard)

EDS Model Development and System Analyses



► Approach and Methodology



◆ Software Platform

- Electrical Transient Analyzer Program (ETAP), by Operation Technology, Inc (OTI), selected as main electrical analyzer tool within AREVA NP

◆ Model Development

- Define conservative and bounding modeling methodology and assumptions
- Develop EDS ETAP single line diagram
- Develop plant configurations and mode of operations, such as:
 - Power from grid (offsite power)
 - Power from emergency diesel generator (EDG) (onsite emergency power)
 - Power from station blackout diesel generators (SBODG) (onsite alternate AC source)
 - Power from DC (battery) source

EDS Model Development and System Analyses




► Example of modeling approach for low voltage system:

◆ Medium Voltage (MV) System

- Modeling the entire MV loads for both safety and non-safety system

◆ Low Voltage (LV) System:


- Equivalent load for both safety and non-safety system
- Adjust total LV loads equals to supply transformer rating
- Largest allowable motor load is connected to load center (LC) and motor control center (MCC)



EDS Model Development and System Analyses

U.S. EPR ETAP SLD, From Grid

US EPR - ETAP SLD




EDS Model Development and System Analyses



U.S. EPR ETAP SLD, From EDG


US EPR - ETAP SLD




EDS Model Development and System Analyses

U.S. EPR ETAP SLD, From SBODG

US EPR - ETAP SLD



EDS Model Development and System Analyses




► Approach and Methodology (Cont.):

◆ Perform System Study and Simulation Such As:

- Load Flow Study
- Short-Circuit (Fault) Study
- Motor Starting Study
- Equipment Sizing Study

EDS Model Development and System Analyses




▶ System Evaluation and Summary of Results

◆ Study Results Against Acceptance Criteria (Iterative Process)

- Equipment (e.g., EDG/SBODG, transformers, buses, circuit breakers, and cables) are within their loading requirements
- Equipment are within their short-circuit capabilities
- Equipment are within acceptable continuous and momentary, voltage, current, and power ratings
- Distribution system equipment sizes are available based on standard equipment availability

◆ U.S. EPR EDS design verified to be adequate

EDS Model Development and System Analyses



▶ Conclusion:

◆ The U.S. EPR™ Electrical Distribution System:

- Adequately supports the supplied equipment during performance of the design functions (safety or non-safety)

▶ QUESTIONS?



Presentation to the ACRS Subcommittee

AREVA U.S. EPR Design Certification Application Review

Safety Evaluation Report

CHAPTER 8: ELECTRIC POWER

November 3, 2009

Staff Review Team



- **Technical Staff**
 - ◆ **Peter Kang**
Electrical Engineering Branch

- **Project Managers**
 - ◆ **Getachew Tesfaye**
 - ◆ **James Steckel**

Overview of Staff's Review



| SRP Section/Application Section | | Number of RAI Questions | Number of SE Open Questions |
|----------------------------------------|-------------------------------------------------|--------------------------------|------------------------------------|
| 8.1 | Introduction | 4 | 0 |
| 8.2 | Offsite Power System | 7 | 0 |
| 8.3.1 | Alternating Current (AC) Power Systems (Onsite) | 24 | 0 |
| 8.3.2 | Direct Current (DC) Power Systems (Onsite) | 5 | 0 |
| 8.4 | Station Blackout | 9 | 0 |
| Totals | | 49 | 0 |

Technical Topics of Interest

Section 8.2 - Offsite Power System



Inaccessible Power Cables Installed in Duct Bank, or Underground

- RAI
 - ♦ COL applicants should be responsible for developing site-specific testing programs per Generic Letter 2007-01 for inaccessible power cables installed in duct bank, or under underground
- Response
 - ♦ Agreed to add a COL item describing need for inspection, testing, and monitoring programs for the detection of the degraded inaccessible underground power cables
 - ♦ Cited use of the following potential testing methods: partial discharge testing, time domain reflectometry, dissipation factor testing, or very low frequency ac testing
- Result
 - ♦ Staff has no further questions regarding cable testing program

Technical Topics of Interest

Section 8.3 - Onsite Power System



Alternate feed Configurations and EDG Technical Specification (TS)

- RAI
 - ♦ Divisional independence
 - ♦ Single failure requirement and risk insights
 - ♦ TS provision allows the plant to operate for 120 days
- Response
 - ♦ Provided technical details of divisional independence, and demonstrated no single failure vulnerability exists under various alternate feed scenarios
 - ♦ Stated no significant change in risk
 - ♦ Stated that the lineup does not introduce any new safety concerns
- Result
 - ♦ Staff has no further questions regarding alternate feed configurations

Technical Topics of Interest

Section 8.3 - Onsite Power System



BTP 8-6 Adequacy of Station Electric Distribution System Voltages

- RAI
 - ♦ Protect the safety-related equipment from degraded grid voltage conditions
 - ♦ Verify the voltage analysis by actual bus voltage measurements
 - ♦ Evaluate whether different degraded grid setpoints are needed for any alternate feed configurations
- Response
 - ♦ COL applicant will perform this analysis to:
 - Determine the site-specific degraded grid setpoints based on the offsite power system grid (TS item)
 - Conduct verification during the plant initial testing program
 - Demonstrate no changes to degraded grid settings for any alternate feed configurations
- Result
 - ♦ Staff has no further questions on degraded voltage protection

Technical Topics of Interest

Section 8.4 Station Blackout (SBO)



Sizing of SBO diesel generators (SBODGs)

- RAI
 - ♦ SECY 91-078 recommended that new reactors meet Electric Power Research Institute (EPRI) Utility Requirements Document recommendation that a large combustion turbine as an AAC power source be capable of powering at least one complete set of loads to cold shutdown
- Response
 - ♦ Two SBODGs will be used as an AAC power source for U.S. EPR design
 - ♦ Cold shutdown not required as the desired end state operating mode
- Result
 - ♦ Staff has no further questions regarding the sizing of SBODGs

Staff Findings




The U.S. EPR FSAR Provides:

- Sufficient information about offsite power system interrelationships among the nuclear unit, utility switchyard, and interconnection grids to assist the COL applicant
- Sufficient information about the onsite power system to mitigate design-basis events, given a loss of offsite power system and a single failure in the onsite power system
- Necessary analyses to determine capability to withstand and recover from an SBO event of specified 8 hour duration

Acronyms



- ac – alternating current
- AAC – alternate ac source
- COL – combined license
- EDG – emergency diesel generators
- EPRI – Electric Power Research Institute
- RAI – request for additional information
- SBO – station blackout
- SBODGs – station blackout diesel generators
- SECY – Secretary of the Commission
- TS – technical specification



AREVA NP Inc.

Presentation to ACRS

U.S. EPR Subcommittee

Design Certification Application


FSAR Tier 2 Chapter 2



EPR is a trademark of the AREVA Group.



Chapter 2, Site Characteristics: Chapter Topics



- ▶ **Geography and Demography**
- ▶ **Nearby industrial, transportation, and military facilities**
- ▶ **Meteorology**
- ▶ **Hydrologic engineering**
- ▶ **Geology, seismology and geotechnical engineering**

Chapter 2, Site Characteristics: Supplemental Information




2.0 Site Characteristics

▶ U.S. EPR Design

- ◆ Based on a set of conservatively established site characteristics, which represent more demanding site conditions than normally expected for most U.S. nuclear power plant sites
- ◆ A COL applicant that references the U.S. EPR design certification will compare site-specific data to the design parameter data in Tier 2 [Table 2.1-1](#)
 - If the data for the site is within the assumed design data and characteristics in Table 2.1-1, then the U.S. EPR standard design is bounding
 - If the data for the site is outside the bounds of the assumed design data and characteristics in Table 2.1-1, the COL applicant will confirm that the U.S. EPR design meets any additional requirements that may be imposed by the more limiting site-specific design parameter data or characteristics

Chapter 2, Site Characteristics: Supplemental Information



2.1 Geography and demography

2.1.1 Site location and Description - COL Applicant

- Specific location by longitude and latitude, Universal Transverse Mercator (UTM) coordinates, and political subdivisions; the site's relative location with respect to natural and man-made features of the area such as highways, railways, and waterways; and local population distribution
- A map of the site area of suitable scale showing relevant features such as the plant property lines, site and exclusion area boundaries (EAB), location and orientation of principal plant structures within the site area, and highways, railways and waterways that traverse or are adjacent to the site.


2.1.2 Exclusion Area Authority and Control - COL Applicant

- Define the authority and activities within the exclusion area

2.1.3 Population Distribution - COL Applicant

- Describe the population in the site vicinity

Chapter 2, Site Characteristics: Supplemental Information



2.2 Nearby industrial, transportation, and military facilities

- Robust design that can withstand a range of potential external hazards
- COL applicant will provide related site-specific information

2.2.1 Location and routes – COL Applicant

- COL applicant will provide related site-specific information on the location and routes associated with these facilities


2.2.2 Descriptions – COL Applicant

- COL applicant will provide related site-specific information which describes the primary function of each external facility and the nature of the hazard it presents

2.2.3 Evaluation of potential accidents – COL Applicant

- COL applicant will provide information concerning site specific evaluations pertaining to nearby industrial, transportation, and military facilities
- COL applicant will reconcile the site-specific hazards with the design

Chapter 2, Site Characteristics: Supplemental Information




2.3 Meteorology

“The U.S. EPR design is based on meteorological parameters (e.g., air temperature extremes, humidity, precipitation such as rainfall, snow and ice, maximum wind speeds, tornado wind speeds, and atmospheric stability characteristics) provided in Section 2.1, [Table 2.1-1—U.S. EPR Site Design Envelope](#).”

“If a COL applicant that references the U.S. EPR design certification identifies site-specific meteorology values outside the range of the design parameters in Table 2.1-1, then the COL applicant will demonstrate the acceptability of the site-specific values in the appropriate sections of the Combined License application.”

Chapter 2, Site Characteristics: Supplemental Information



2.3 Meteorology (Cont'd)

2.3.1 Regional climatology – COL Applicant

- COL applicant will provide related site-specific characteristics for regional climatology


2.3.2 Local meteorology – COL Applicant

- COL applicant will provide related site-specific characteristics for local meteorology

2.3.3 Onsite meteorological measurement program – COL Applicant

- COL applicant will provide the site-specific, onsite meteorological measurement program

Chapter 2, Site Characteristics: Supplemental Information



2.3 Meteorology (Cont'd)


2.3.4 Short-term atmospheric dispersion estimates for accident releases – COL Applicant

- Atmospheric dispersion factors (χ/Q values) considered to be representative of potential future nuclear plant sites in the U.S. were used to calculate the consequences from postulated accidental releases
- COL applicant will confirm that site-specific χ/Q values are bounded by those specified by the U.S. EPR
- For site-specific χ/Q values that exceed the U.S. EPR values, the COL applicant will demonstrate that the radiological consequences meet applicable dose limits

2.3.5 Long-term atmospheric dispersion estimates for routine releases – COL Applicant

- An atmospheric dispersion factor considered to be representative of potential future nuclear plant sites in the U.S. was used to calculate the consequences from postulated normal effluent releases
- COL applicant will confirm that the site-specific annual average χ/Q values are bounded by the U.S. EPR value
- For site-specific χ/Q values that exceed the U.S. EPR value, the COL applicant will demonstrate that the radiological consequences meet applicable dose limits

Chapter 2, Site Characteristics: Supplemental Information



2.4 Hydrologic engineering

The U.S. EPR standard design considers groundwater, winter precipitation (snow, sleet, ice), rainfall, and surface flooding. The COL applicant is required to reconcile the site specific parameters with the standard design.

2.4.1 Hydrologic description – COL Applicant

- Site specific hydrologic characteristics

2.4.2 Floods – COL Applicant

- Site specific information on flood history, flood design, and effects of local precipitation

2.4.3 Probable maximum flood (PMF) on streams and rivers – COL Applicant

- Site specific information on the PMF of streams and rivers

2.4.4 Potential dam failures – COL Applicant

- Site specific information on failure of upstream or downstream water control structures

Chapter 2, Site Characteristics: Supplemental Information



2.4 Hydrologic engineering (Cont'd)

2.4.5 Probable maximum surge and seiche flooding – COL Applicant

- Site specific information on surge and seiche flooding and protection requirements

2.4.6 Probable maximum tsunami flooding – COL Applicant

- Site specific information on tsunami flooding and protection required

2.4.7 Ice effects – COL Applicant

- Site specific ice effects, induced ice forces and protection required


2.4.8 Cooling water canals and reservoirs – COL Applicant

- Site specific information is required on the design basis for cooling water canals and reservoirs used for makeup to the UHS cooling water structures

2.4.9 Channel diversions – COL Applicant

- Site specific channel information and demonstrate alternate water supplies will be available

Chapter 2, Site Characteristics: Supplemental Information



2.4 Hydrologic engineering (Cont'd)

2.4.10 Flooding protection requirements – COL Applicant

- Static and dynamic effects of flood conditions and protection of safety related equipment

2.4.11 Low water considerations – COL Applicant

- Identify natural events that may reduce or limit cooling water supply

2.4.12 Groundwater – COL Applicant

- Identify local and regional groundwater reservoirs, subsurface pathways, onsite use, monitoring measures, effect on structures


2.4.13 Pathways of liquid effluents in ground and surface waters – COL Applicant

- Ability of surface and groundwater to delay, disperse, dilute, or concentrate radioactive effluent releases and effects on future use of water resources

2.4.14 Technical specification and emergency operation requirements– COL Applicant

- Emergency measures to implement flood protection and verify adequate water supply for shutdown

Chapter 2, Site Characteristics: Supplemental Information



2.5 Geology, seismology, and geotechnical engineering

“Geology, seismology, and geotechnical engineering information are specific to the site and region and will be addressed by applicants on a site-specific basis.”

“ A range of generic site conditions has been selected for evaluating US EPR”

2.5.1 Basic geologic and seismic information – COL Applicant

- Data concerning geological, seismic, geophysical, and geotechnical information

2.5.2 Vibratory ground motion – COL Applicant

- Define the site specific SSE and compare to the Certified Seismic Design Response Spectra (CSDRS)

2.5.3 Surface faulting – COL Applicant

- No surface faults are allowed under safety related structures

2.5.4 Stability of subsurface materials and foundations – COL Applicant

- Site specific information about stability of subsurface materials under static and dynamic conditions

2.5.5 Stability of slopes – COL Applicant

- Evaluate the stability of earth and rock slopes both natural and manmade



Backup Slides



EPR is a trademark of the AREVA Group.



Table 2.1-1 - includes RAI Responses submitted since Revision 1



Table 2.1-1—U.S. EPR Site Design Envelope
Sheet 1 of 7

| U.S. EPR Site Design Envelope | |
|-----------------------------------------------------|----------------------------------------------------------------------------------------------|
| Precipitation (Refer to Section 2.4) | |
| Rainfall rate | ≤19.4 in/hr |
| Normal ground precipitation load | ≤100 psf (100-year MRI) |
| Normal roof precipitation load | ≤70 psf (100-year MRI) |
| 48-hour PMWP liquid roof load | 0 psf ⁽¹⁾ |
| 48-hour PMWP frozen ground load | ≤43 psf (based on 55 inches) |
| 48-hour PMWP frozen roof load | ≤30 psf |
| Extreme winter precipitation roof load | ≤100 psf (100-year MRI) |
| Seismology (Refer to Sections 2.5 & 3.7) | |
| Horizontal SSE Acceleration | 0.3g Peak (CSDRS shapes – See Section 3.7) |
| Vertical SSE Acceleration | 0.3g Peak (CSDRS shapes – See Section 3.7) |
| Fault Displacement Potential | No fault displacement is considered for safety-related SSC in U.S. EPR design certification. |



Section 2.1



2.0 Site Characteristics

The U.S. EPR standard design is based on a set of conservatively established site characteristics. These characteristics represent more demanding site conditions than normally expected for most U.S. nuclear power plant sites. These site-related design basis parameters are provided in Table 2.1-1—U.S. EPR Site Design Envelope.

A COL applicant that references the U.S. EPR design certification will compare site-specific data to the design parameter data in Table 2.1-1. If the specific data for the site falls within the assumed design parameter data and characteristics in Table 2.1-1, then the U.S. EPR standard design is bounding for the site. For site-specific design parameter data or characteristics that are outside the bounds of the assumptions presented in Table 2.1-1, the COL applicant will confirm that the U.S. EPR design acceptably meets any additional requirements that may be imposed by the more limiting site-specific design parameter data or characteristic, and that the design maintains conformance to the design commitments and acceptance criteria described in this FSAR.

2.1 Geography and Demography

A COL applicant that references the U.S. EPR design certification will provide site-specific information related to site location and description, exclusion area authority and control, and population distribution.

2.1.1 Site Location and Description

The site location and description is site-specific and will be addressed by the COL applicant, including:

- Specific location by longitude and latitude, Universal Transverse Mercator (UTM) coordinates, and political subdivisions; the site's relative location with respect to natural and man-made features of the area such as highways, railways, and waterways; and local population distribution.
- A map of the site area of suitable scale (with explanatory text as necessary) showing relevant features such as the plant property lines, site and exclusion area boundaries (EAB), location and orientation of principal plant structures within the site area, and highways, railways and waterways that traverse or are adjacent to the site.

2.1.2 Exclusion Area Authority and Control


The authority for control of activities in the site exclusion area is site-specific and will be addressed by the COL applicant. This information will describe activities unrelated to plant operation that are permitted within the exclusion area.



Including RAI Responses submitted since Revision 1



Section 2.2



2.2 Nearby Industrial, Transportation, and Military Facilities

The U.S. EPR is designed to withstand the effects of external events resulting from such occurrences as earthquakes, storms, or other natural phenomena. This provides a robust design that can withstand a range of potential external hazards. A COL applicant that references the U.S. EPR design certification will provide site-specific information related to the identification of potential hazards stemming from nearby industrial, transportation, and military facilities within the site vicinity, including an evaluation of potential accidents (such as explosions, toxic chemicals, and fires).

2.2.1 Location and Routes

The location and routes for nearby industrial, transportation, and military facilities is site-specific and will be addressed by the COL applicant.

2.2.2 Descriptions

Nearby industrial, transportation, and military facilities are site-specific information and will be addressed by the COL applicant. This information will describe the primary function of each facility and the nature of the hazard it presents.

2.2.3 Evaluation of Potential Accidents

The U.S. EPR design is acceptable for any site when reasonable qualitative arguments can demonstrate that the realistic probability of severe consequences from any external accident is less than 10^{-6} occurrences per year. A COL applicant that references the U.S. EPR design certification will provide information concerning site-specific evaluations to determine the consequences that potential accidents at nearby industrial, transportation, and military facilities could have on the site. The information provided by the COL applicant will include specific changes made to the U.S. EPR design to qualify the design of the site against potential external accidents with an unacceptable probability of severe consequences (Reference 1).

2.2.4 References

1. NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants," U.S. Nuclear Regulatory Commission, March 2007.

[Next File](#)



Section 2.3



2.3 Meteorology

The U.S. EPR design is based on meteorological parameters (e.g., air temperature extremes, humidity, precipitation such as rainfall, snow and ice, maximum wind speeds, tornado wind speeds, and atmospheric stability characteristics) provided in Section 2.1, Table 2.1-1—U.S. EPR Site Design Envelope. If a COL applicant that references the U.S. EPR design certification identifies site-specific meteorology values outside the range of the design parameters in Table 2.1-1, then the COL applicant will demonstrate the acceptability of the site-specific values in the appropriate sections of the Combined License application.

2.3.1 Regional Climatology

The following information is provided in Section 2.1, Table 2.1-1:

- Weight of the normal winter precipitation event and the weight of the extreme winter precipitation event.
- 100-year, 3-second gust wind speed.
- Tornado parameters.
- Dry bulb and wet bulb temperatures.

2.3.1.1 Basis for Meteorological Parameters

The design parameters for the dry-bulb and wet-bulb temperatures are based on the EPRI ALWR Utility Requirements Document (Reference 1) and available Early Site Permit applications. The two percent annual exceedance dry and wet bulb temperature values, as recommended by RG 1.206 and SRP 2.3.1, are not provided in Table 2.1-1. However, the two percent annual exceedance dry and wet bulb temperature values are bounded by the provided zero percent annual exceedance and one percent annual exceedance dry and wet bulb temperature values.

SRP 2.3.1 and RG 1.206 also recommend that the 100-year maximum dry bulb and coincident wet bulb temperature values, the 100-year maximum non-coincident wet bulb temperature value, and the 100-year minimum dry bulb temperature values be provided. Instead, the zero percent exceedance values for these parameters have been provided. Zero percent exceedance values are based on conservative estimates of historical high and low values for potential sites.

The prescribed loads included in the combination of normal live loads are based on the weight of the normal winter precipitation event recorded at ground level. Winter precipitation loads to be included in the combination of extreme live loads is based on the addition of the weight of the extreme frozen or liquid precipitation event.

Section 2.4



2.4 Hydrologic Engineering

The U.S. EPR is designed for a groundwater elevation up to 3.3 feet below the finished grade elevation and an exterior flood level of one foot below the finished grade elevation. For factored load combinations, the lateral soil load is based on saturated soil associated with flooding and groundwater. The finished yard grade is nominally one foot below ground floor top of concrete, with slopes provided for drainage to preclude water from entering the buildings. No safety-related dewatering systems are provided in the U.S. EPR. Flood protection features are described in Section 3.4.

The U.S. EPR is designed for a maximum rainfall rate of 19.4 inches per hour. A rain, snow, and ice load of 100 pounds per square foot has been used, which includes the weight of the normal winter precipitation event and the weight of the extreme winter precipitation event.

The hydrologic information in Section 2.4 is site specific and will be provided by the Combined License (COL) applicant that references the U.S. EPR design certification.

Sites are acceptable that are within the envelope of the groundwater and flood water maximum elevations described for the U.S. EPR standard plant design.

2.4.1 Hydrologic Description

A COL applicant that references the U.S. EPR design certification will provide a site-specific description of the hydrologic characteristics of the plant site.

2.4.2 Floods

A COL applicant that references the U.S. EPR design certification will identify site-specific information related to flood history, flood design considerations, and effects of local intense precipitation.

2.4.3 Probable Maximum Flood (PMF) on Streams and Rivers

A COL applicant that references the U.S. EPR design certification will provide site-specific information to describe the probable maximum flood of streams and rivers and the effect of flooding on the design.

2.4.4 Potential Dam Failures

A COL applicant that references the U.S. EPR design certification will verify that the site-specific potential hazards to safety-related facilities due to the failure of upstream and downstream water control structures are within the hydro-geologic design basis.



Section 2.5



| | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2.5 | Geology, Seismology, and Geotechnical Engineering |
| | Geology, seismology, and geotechnical engineering information are specific to the site and region and will be addressed by applicants on a site-specific basis. A range of generic site conditions which encompasses a number of potential reactor sites throughout the United States has been selected for evaluating the U.S. EPR. |
| 2.5.1 | Basic Geologic and Seismic Information |
| | A combined license (COL) applicant that references the U.S. EPR design certification will use site-specific information to investigate and provide data concerning geological, seismic, geophysical, and geotechnical information. |
| 2.5.1.1 | Regional Geology |
| | Regional geology is site specific and will be addressed by the COL applicant. |
| 2.5.1.2 | Site Geology |
| | Site-specific geology information will be addressed by the COL applicant. |
| 2.5.2 | Vibratory Ground Motion |
| | A COL applicant that references the U.S. EPR design certification will review and investigate site-specific details of seismic, geophysical, geological, and geotechnical information to determine the safe shutdown earthquake (SSE) ground motion for the site and compare site-specific ground motion to the Certified Seismic Design Response Spectra (CSDRS) for the U.S. EPR. |
| | The seismic design basis for the U.S. EPR is presented in Section 3.7.1.1.1. As noted therein, the U.S. EPR is designed for 0.3g peak ground acceleration (PGA) design ground motion which is defined as a hypothetical free-field outcrop motion at approximately 41.33 ft below grade at the bottom elevation of the foundation basemat for the Nuclear Island (NI) Common Basemat Structures (GDC 2). The certified seismic design response spectra (CSDRS) for the U.S. EPR are shown in Figure 3.7.1-1. The CSDRS are the same in both horizontal directions and in the vertical direction. |
| | Section 3.7.1.3 describes a range of 10 generic soil profiles and associated dynamic soil properties selected for the design of the U.S. EPR. Table 3.7.1-6 shows the soil layering, the assumed strain-dependent properties, and the CSDRS design control motion associated with the profile. The variation in shear wave velocity in each of the assumed profiles is illustrated in Figure 3.7.1-31 and Figure 3.7.1-32. The soil properties associated with the various shear wave velocities assumed in the 10 generic soil profiles are discussed further in Section 3.7.2.4.1 and summarized in Table 3.7.2-9. Section 3.7.1.3 and Section 3.7.2.4.1 discuss that, for soil-structure interaction (SSI) analysis for the U.S. EPR design certification, the assumed generic shear wave |

| | |
|---------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 2.5 | Geology, Seismology, and Geotechnical Engineering |
| | Geology, seismology, and geotechnical engineering information are specific to the site and region and will be addressed by applicants on a site-specific basis. A range of generic site conditions which encompasses a number of potential reactor sites throughout the United States has been selected for evaluating the U.S. EPR. |
| 2.5.1 | Basic Geologic and Seismic Information |
| | A combined license (COL) applicant that references the U.S. EPR design certification will use site-specific information to investigate and provide data concerning geological, seismic, geophysical, and geotechnical information. |
| 2.5.1.1 | Regional Geology |
| | Regional geology is site specific and will be addressed by the COL applicant. |
| 2.5.1.2 | Site Geology |
| | Site-specific geology information will be addressed by the COL applicant. |
| 2.5.2 | Vibratory Ground Motion |
| | A COL applicant that references the U.S. EPR design certification will review and investigate site-specific details of seismic, geophysical, geological, and geotechnical information to determine the safe shutdown earthquake (SSE) ground motion for the site and compare site-specific ground motion to the Certified Seismic Design Response Spectra (CSDRS) for the U.S. EPR. |
| | The seismic design basis for the U.S. EPR is presented in Section 3.7.1.1.1. As noted therein, the U.S. EPR is designed for 0.3g peak ground acceleration (PGA) design ground motion which is defined as a hypothetical free-field outcrop motion at approximately 41.33 ft below grade at the bottom elevation of the foundation basemat for the Nuclear Island (NI) Common Basemat Structures (GDC 2). The certified seismic design response spectra (CSDRS) for the U.S. EPR are shown in Figure 3.7.1-1. The CSDRS are the same in both horizontal directions and in the vertical direction. |
| | Section 3.7.1.3 describes a range of 10 generic soil profiles and associated dynamic soil properties selected for the design of the U.S. EPR. Table 3.7.1-6 shows the soil layering, the assumed strain-dependent properties, and the CSDRS design control motion associated with the profile. The variation in shear wave velocity in each of the assumed profiles is illustrated in Figure 3.7.1-31 and Figure 3.7.1-32. The soil properties associated with the various shear wave velocities assumed in the 10 generic soil profiles are discussed further in Section 3.7.2.4.1 and summarized in Table 3.7.2-9. Section 3.7.1.3 and Section 3.7.2.4.1 discuss that, for soil-structure interaction (SSI) analysis for the U.S. EPR design certification, the assumed generic shear wave |

Including RAI Responses submitted since Revision 1





Presentation to the ACRS Subcommittee

AREVA U.S. EPR Design Certification Application Review

Safety Evaluation Report with Open Items

Chapter 2: SITE CHARACTERISTICS

November 3, 2009

Staff Review Team

- **Technical Staff**
 - ♦ **Seshagiri Tammara**
Siting & Accident Consequences Branch
 - ♦ **Brad Harvey**
Siting & Accident Consequences Branch
 - ♦ **Kenneth See**
Hydrologic Engineering Branch
 - ♦ **Weijun Wang**
Geoscience and Geotechnical Engineering Branch 2
- **Project Managers**
 - ♦ **Getachew Tesfaye**
 - ♦ **Jay Patel**

Overview of Design Certification Application



| SRP Section/Application Section | | Number of RAI Questions | Number of SE Open Items |
|----------------------------------------|------------------------------------------------------------|--------------------------------|--------------------------------|
| 2.0 | Site Characteristics | 2 | 2 |
| 2.1 | Geography and Demography | 0 | 0 |
| 2.2 | Nearby Industrial, Transportation, and Military Facilities | 0 | 0 |
| 2.3 | Meteorology | 31 | 10 |
| 2.4 | Hydrologic Engineering | 4 | 0 |
| 2.5 | Geology, Seismology, and Geotechnical Engineering | 8 | 1 |
| 2.6 | COL Information Items | 0 | 0 |
| Totals | | 45 | 13 |

Description of SE Open Items



- **RAI 274, Question 02-1:** Use the terms "site characteristics" and "site parameters" in COL Information Item 2.0-1 and FSAR Tier 2, Section 2.0, in accordance with the definitions provided in 10 CFR 52.1(a).
- **RAI 288, Question 02-2:** Use the terms "site characteristics" and "site parameters" in COL Information Item 2.0-1 and FSAR Tier 2, Section 2.0, in accordance with the definitions provided in 10 CFR 52.1(a).
- **RAI 256, Question 02.03.01-13*:** Clarify whether 1% exceedance air temperature site parameter values are annual or seasonal exceedance values
- **RAI 256, Question 02.03.01-14*:** Delete noncoincident wet bulb temperature as a site parameter and add a COL Information Item requiring COL applicants to validate the standard plant UHS cooling tower design using site-specific temperature profiles
- **RAI 256, Question 02.03.01-15:** Use titles for the winter precipitation site parameters that are consistent with terminology provided in ISG-7
- **RAI 288, Question 02.03.01-16:** Revise COL Information Item 2.3-1 to distinguish between site parameters and site characteristics as defined in 10 CFR 52.1(a) and describe how the actual site characteristics will be compared to the postulated design parameters set forth in the U.S. EPR FSAR.

Description of SE Open Items



- **RAI 256, Question 02.03.04-7***: Clarify the source/receptor information required to model control room *air intake* atmospheric dispersion factors
 - **RAI 256, Question 02.03.04-8***: Provide the source/receptor information required to model control room *unfiltered inleakage* atmospheric dispersion factors
 - **RAI 288, Question 02.03.04-9**: Remove distances from the titles of the EAB and LPZ atmospheric dispersion site parameters
 - **RAI 256, Question 02.03.05-6***: Add the routine release atmospheric deposition (D/Q) value as a site parameter
 - **RAI 256, Question 02.03.05-7***: Clarify the routine release pathway characteristics
 - **RAI 288, Question 02.03.05-8**: Remove distance from the title of the routine release atmospheric dispersion factor (χ/Q) site parameter
 - **RAI 261, Question 02.05.04-4***: Did not provide details on how the minimum required dynamic bearing capacity was determined
 - ♦ Minimum value of 34,560 lb/ft² was provided without details on supporting analysis
- * Questions will be discussed in Technical Topics of Interest**

Technical Topics of Interest

Section 2.1 - Geography and Demography

Section 2.2 - Nearby Industrial,
Transportation, and Military Facilities



Section 2.1 - Geography and Demography

- Site Location and Description
- Exclusion Area Authority and Control
- Population Distribution

Section 2.2 - Nearby Industrial, Transportation, and Military Facilities

- Identification of Potential Hazards in Site Vicinity
- Evaluation of Potential Accidents

The COL applicant is to provide this information as part of the COL application.

Technical Topics of Interest

Section 2.3 - Meteorology



SER 2.3: Meteorology

- Involves site specific information such as:
 - ♦ 2.3.1 – Regional Climatology
 - ♦ 2.3.2 – Local Meteorology
 - ♦ 2.3.3 – Onsite Meteorological Measurements Program
 - ♦ 2.3.4 – Short-term Atmospheric Dispersion Estimates for Design-Basis Accidental Releases
 - ♦ 2.3.5 – Long-term Atmospheric Dispersion Estimates for Routine Releases
- The COL applicant is to provide this information as part of the COL application

Technical Topics of Interest

Section 2.3 - Meteorology



Meteorological Site Parameters

- The applicant identified meteorological site parameters related to:
 - ♦ Climate Extremes and Severe Weather
 - ♦ Atmospheric Dispersion (Accident & Routine Releases)
- A COL applicant needs to demonstrate that its site characteristics fall within the U.S. EPR site parameters
- The staff evaluated the U.S. EPR meteorological site parameter values to ensure they are representative of a reasonable number of sites that have been or may be considered for a COL application

Technical Topics of Interest

Section 2.3 - Meteorology



Climatic Site Parameters

- Winter Precipitation (for Roof Load Design)
- Maximum Wind Speed (other than Tornado)
- Tornado
- Air Temperature
 - **RAI 256, Question 02.03.01-13:** Clarify whether 1% exceedance values are annual or seasonal exceedances
 - **RAI 256, Question 02.03.01-14:** Delete noncoincident wet bulb temperature as a site parameter
- UHS Meteorological Conditions
 - **RAI 256, Question 02.03.01-14:** Add a COL Information Item requiring COL applicants to validate the standard plant UHS cooling tower design using site-specific temperature profiles

Technical Topics of Interest

Section 2.3 - Meteorology



Short-Term Dispersion Site Parameters for Design-Basis Accident

Releases

- EAB and LPZ χ/Q Site Parameter Values
- CR χ/Q Site Parameter Values
 - **RAI 256, Question 02.03.04-7:** Clarify the source/receptor information required to model CR air intake atmospheric dispersion factors
 - **RAI 256, Question 02.03.04-8:** Provide the source/receptor information required to model CR unfiltered inleakage atmospheric dispersion factors
 - **Confirmatory Action NRC (RAI 10, Question 02.03.04-2):** Evaluate the reasonableness of the applicant's CR χ/Q site parameter values

Technical Topics of Interest

Section 2.3 - Meteorology



Long-Term Dispersion Site Parameters for Routine Releases

- Site Boundary χ/Q Values
 - **RAI 256, Question 02.03.05-6:** Add the routine release atmospheric deposition (D/Q) value as a site parameter
 - **RAI 256, Question 02.03.05-7:** Clarify the routine release pathway characteristics

Technical Topics of Interest

Section 2.3 - Meteorology



COL Information Items

- The COL applicant is to provide information on climate and atmospheric dispersion site characteristics
- If a COL applicant identifies site-specific meteorological values outside the range of the U.S. EPR site parameter values, then the COL applicant will demonstrate the acceptability of the design

CONCLUSION

Section 2.3 - Meteorology



- Except for the SE Open Items:
 - ♦ Applicant has identified an appropriate list of site parameters
 - ♦ The values assigned to each of the site parameters are expected to be representative of a reasonable number of sites that may be considered for a COL application

Technical Topics of Interest

Section 2.4 -Hydrologic Engineering



Involves site specific information such as

- 2.4.1 Hydrological description
- 2.4.2 Floods
- 2.4.3 Probable Maximum Flood on Streams and Rivers
- 2.4.4 Potential Dam Failures
- 2.4.5 Probable Maximum Surge and Seiche Flooding
- 2.4.6 Probable Maximum Tsunami Flooding
- 2.4.7 Ice Effects
- 2.4.8 Cooling Water Channels and Reservoirs
- 2.4.9 Channel diversion
- 2.4.10 Flood Protection Requirements
- 2.4.11 Low Water Considerations
- 2.4.12 Groundwater
- 2.4.13 Accidental Release of Liquid Effluents in Ground and Surface Water
- 2.4.14 Technical Specifications and Emergency Operations Requirements

Information in all sections to be provided as part of the COL application.

Technical Topics of Interest

Section 2.4 -Hydrologic Engineering



- Hydrologic Parameters
 - ♦ The applicant identified three hydrologic parameters
 - Maximum groundwater level (3.3 ft below finished grade)
 - Maximum flood level (1 ft below finished grade)
 - Maximum rainfall rate (19.4 in/hr.)
- A COL applicant needs to demonstrate that its site characteristics fall within the U.S. EPR FSAR site parameters
- The staff evaluated these three parameters for reasonableness.

Conclusion

Section 2.4 – Hydrologic Engineering



- Applicant has properly identified information to be provided as part of the COL application.

Technical Topics of Interest


Section 2.5 – Geology, Seismology, and Geotechnical Engineering



- Establishes subsurface acceptance criteria for a site
 - ♦ Minimum bearing capacity
 - ♦ Minimum shear wave velocity
 - ♦ Subsurface uniformity
 - ♦ Maximum settlement, etc.
- **RAI 261, Question 02.05.04-4:** Did not provide details on determination of dynamic bearing capacity
- Establishes three certified seismic design response spectra (CSDRS) to be met for a site
 - ♦ Based on 10 generic soil profiles
 - ♦ Divided into 3 site groups: soft, medium and hard
 - ♦ Anchored at 0.3g peak ground acceleration

Technical Topics of Interest
Section 2.5 – Geology, Seismology, and Geotechnical
Engineering

FSAR Tier 1, Figure 5.0-1 – Design Response Spectra for EUR Control Motions (Hard, Medium and Soft Sites)



CONCLUSION

Section 2.5 – Geology, Seismology, and Geotechnical Engineering

- Except for the SE Open Items:
 - ♦ Postulated parameters used in design are reasonable
 - ♦ Requirements for COL applicant to establish site-specific characteristics in determining whether they meet the standard design parameters followed NRC regulatory guidelines

ACRONYMS

- SE – safety evaluation
- RAI – request for additional information
- COL – combined license
- D/Q - deposition factor ($1/m^2$)
- EAB - exclusion area boundary
- LPZ - outer boundary of the low population zone
- UHS - ultimate heat sink
- χ/Q - atmospheric dispersion factor (sec/m^3)

THE END