

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
)
Indian Point 3 Nuclear Power Plant)

APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to Section 3.7.B and Tables 3.5-1, 3.5-3 and 4.1-1 of Appendix A of the Operating License (Technical Specifications). The proposed changes to the Technical Specifications which include the addition of relay setpoints, tolerances, testing intervals and calibration intervals for the 480v Emergency Buses, would provide protection for the degraded grid voltage condition. In addition, the proposed amendment would add a requirement that a bus automatic fast transfer be prevented by the operator by placing the 6.9KV bus tie breakers' control switches in the "pullout" position whenever the 138KV power source is lost and the 13.8KV power source is being used to feed Buses 5 and 6. Minor administrative changes are also included in this submittal.

The proposed change to the Technical Specifications is presented in Attachment I to the Application. The Safety Evaluation is included in Attachment II.

POWER AUTHORITY OF THE STATE
OF NEW YORK

By J. P. Bayne
J. P. Bayne
Senior Vice President
Nuclear Generation

8204190077 820413
PDR ADDCK 05000286
PDR

State of New York
County of New York

Subscribed and sworn to before
me this 13th day of APRIL, 1982

Edgar K. Byham
Notary Public

EDGAR K. BYHAM
Notary Public, State of New York
No. 31-4600492
Qualified in New York County
Commission Expires March 30, 1984