

POWER AUTHORITY OF THE STATE OF NEW YORK

10 COLUMBUS CIRCLE NEW YORK, N. Y. 10019

(212) 397-6200

TRUSTEES

JOHN S. DYSON
CHAIRMAN

GEORGE L. INGALLS
VICE CHAIRMAN

RICHARD M. FLYNN

ROBERT I. MILLONZI

FREDERICK R. CLARK



October 18, 1982

IPN-82-69

LEROY W. SINCLAIR
PRESIDENT & CHIEF
OPERATING OFFICER

WALTER T. KICINSKI
FIRST EXECUTIVE
VICE PRESIDENT &
CHIEF ADMINISTRATIVE
OFFICER

JOSEPH R. SCHMIEDER
EXECUTIVE VICE
PRESIDENT & CHIEF
ENGINEER

JOHN W. BOSTON
EXECUTIVE VICE
PRESIDENT PROCEDURES
& PERFORMANCE

THOMAS R. FREY
SENIOR VICE PRESIDENT
& GENERAL COUNSEL

Director of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Mr. Steven A. Varga, Chief
Operating Reactors Branch No. 1
Division of Licensing

Subject: Indian Point 3 Nuclear Power Plant
Docket No. 50-286
Proposed Changes to the Operating License
and Technical Specifications Related to
Steam Generator Surveillance Requirements

Dear Sir:

Enclosed for filing are three (3) signed originals and nineteen (19) copies of a document entitled, "Application for Amendment to Operating License", together with forty (40) copies of Attachments I and II thereto, comprising a statement of the proposed changes to the Technical Specifications and the associated Safety Evaluation.

This application seeks to amend Appendix A, Section 4.9 of the Operating License. The proposed changes result from the steam generator inspection performed during the cycle 3/4 refueling outage and consist of the following:

- 1) A revised definition of "tube inspection," section 4.9.A.1.h,
- 2) A revised steam generator "tube plugging limit," section 4.9.A.1.f,
- 3) A revised requirement for "corrective measures," section 4.9.B, and
- 4) A new steam generator tube "sleeve plugging limit," section 4.9.A.1.g.

8210210459 821018
PDR ADOCK 05000286
PDR

A001
w/check
\$4000.00

The Authority has classified this application for amendment to the Operating License as Class III since it involves the single safety issue of steam generator tube surveillance. Enclosed is a check in the amount of \$4,000 as the filing fee per 10 CFR 170.22, which the Authority pays under protest pending a final determination of the legality of the fee schedule.

Very truly yours,



J. P. Bayne
Executive Vice President
Nuclear Generation

Yr

Enc.

cc: Resident Inspectors Office
Indian Point Unit 3
USNRC
P. O. BOX 38
Buchanan, N. Y. 10511