

BEFORE THE UNITED STATES
NUCLEAR REGULATORY COMMISSION

In the Matter of)
)
POWER AUTHORITY OF THE STATE OF NEW YORK) Docket No. 50-286
)
Indian Point 3 Nuclear Power Plant)


APPLICATION FOR AMENDMENT TO
OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission (NRC), the Power Authority of the State of New York, as holder of Facility Operating License No. DPR-64, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application seeks to amend Sections 2.1, 2.3, 3.1 and 3.10 of the Technical Specifications. These proposed changes result from the Emergency Core Cooling System reanalysis for up to 24% steam generator equivalent tube plugging. These changes also delete references to three loop operation since IP-3 is restricted to 10% power or less for less than four loop operation.

The proposed change to the Technical Specifications is presented in Attachment I to this Application. The Safety Evaluation corresponding to this change is included in Attachment II.

POWER AUTHORITY OF THE STATE
OF NEW YORK

By 
J. P. Bayne
Executive Vice President
Nuclear Generation

8301180113 830113
PDR ADOCK 05000286
P PDR

State of New York
County of New York

Subscribed and sworn to before
me this day of 1982.

Notary Public